

## PUBLIC UTILITIES COMMISSION

505 VAN NESS AVENUE

SAN FRANCISCO, CA 94102-3298



September 2, 2008

Janine Watkins-Ivie, Director  
Regulatory Policy and Affairs  
Southern California Edison (SCE)  
P.O. Box 800  
Rosemead, CA 91770

**CPUC File No.: EA2008-07**

**SUBJECT:** Electric Audit of SCE's Redlands District

On behalf of the Utilities Safety and Reliability Branch of the California Public Utilities Commission (CPUC), I conducted an electric audit of SCE's Redlands District on April 21-24, 2008. The audit included a review of your records for the period of 2005 – 2008 and field inspection of your facilities.

I found that SCE did not document all General Orders (GOs) 95 and 128 violations found during its inspections. In addition, some GO 95 and GO 128 violations that your staff discovered during detailed inspections were not corrected by SCE's due dates.

Please advise me within 30 days of corrective measure taken by SCE regarding the above violations. If you have any questions, please contact me at (213) 576-7099.

Sincerely,

A handwritten signature in black ink, appearing to read "Ryan T. Yamamoto".

Ryan T. Yamamoto  
Utilities Engineer  
Utilities Safety and Reliability Branch  
Consumer Protection and Safety Division

c: Melvin Stark, Maintenance and Inspection Organization – SCE  
1444 E. McFadden Avenue, Santa Ana, CA 92705