

June 30, 1999

Wesley Franklin - Executive Director
California Public Utilities Commission
505 Van Ness Avenue, Room 5222
San Francisco, California 94102-3298

RE: PacifiCorp's (U901-E) Plan for Inspections, Record Keeping, and Reporting
D.97-03-070
I.95-02-015/R.96-11-004

As required by California D.97-03-070, Appendix A, dated March 31, 1997, PacifiCorp provides an original and five copies of the attached Plan for Inspections, Record Keeping, and Reporting. In addition an electronic version has been sent via e-mail to Wade McCartney @ WSM@cpuc.ca.gov.

Should you have any questions regarding this report, please contact Steve Henderson at (503) 813-6157 or Carole Rockney at (503) 813-6091.

Respectfully submitted on behalf of PacifiCorp

By: Anne E. Eakin, Vice President
Regulation, PacifiCorp
825 N.E. Multnomah, Suite 800
Portland, Oregon 97232
Telephone: (503) 813-6065
Facsimile: (503) 813-6060

Enclosure

c: President Richard A. Bilas, Commissioner Henry M. Duque,
Commissioner Joel Z. Hyatt, Commissioner Josiah L. Neeper,
Commissioner Carl W. Wood
Wade McCartney, Energy Division w/diskette
Brian Schumacher, Energy Division

PacificCorp

BEFORE THE PUBLIC UTILITIES COMMISSION
OF THE STATE OF CALIFORNIA

Commission Order Instituting Investigation) into the rates, charges, services, and) practices of Pacific Gas and Electric) Company. (U 39 M))	I.95-02-015 (Filed February 22, 1995)
<hr/> Order Instituting Rulemaking for electric) distribution facility standard setting.)	R.96-11-004 (Filed November 8, 1996)

PACIFICORP'S IMPLEMENTATION PLAN FOR INSPECTIONS

USING INDICES SET FORTH IN APPENDIX A OF D.97-03-070

FOR CALENDAR YEAR 1998

June 30, 1999

PacifiCorp
Inspection and Maintenance Programs
California 1998

The attached sheets demonstrate the status of 1998 Inspections and Corrections in the state of California for PacifiCorp owned facilities. PacifiCorp has four districts in California: Tulelake, Alturas, Crescent City and Yreka/Mt. Shasta.

Inspections

All inspections were completed in 1998 for Urban & Rural Patrol, Detail and Intrusive inspection types. All Districts, except Crescent City, have chosen to upgrade to the Urban plan for their Rural areas, this is reflected by a NA in the attached sheets. The attached Inspection sheets break down the inspections into three categories: Poles, Street Lights and Equipment. The information includes the type of equipment, the plan for each inspection category and the actuals of the inspection plan.

Conditions

Conditions found by the inspections were rated as either an A or B priority, A priority being more severe. All A priority conditions found by the inspections have been corrected except for 16. These conditions are in a very inaccessible location. Each structure requires hand digging, rock holes, and placement by helicopter. Because of the location, these facilities do not create a public, or employee hazard. These structures will be replaced before July 30, 1999. The remaining B priority conditions will be corrected by year-end 2000. The attached Condition sheets breakdown the conditions into four categories: number of conditions found in 1998, 1998 conditions corrected as of 6/28/99, 1998 conditions currently outstanding, and the final date outstanding conditions will be corrected by.

Dated in Portland, Oregon this 30th day of June, 1999.

Respectfully Submitted,

Anne E. Eakin, Vice President
Regulation
PacifiCorp
825 N.E. Multnomah, Suite 800
Portland, Oregon 97232
Telephone: (503) 813-6065
Facsimile: (503) 813-6060

PACIFICORP
CERTIFICATE OF SERVICE

I hereby certify that on this 30th day of June, 1999, I served true copies of PacifiCorp's Plan for Inspections, Record Keeping, and Reporting - California I.95-02-015 and R.96-11-004 on the following service lists by first -class postage paid mail.

Dated: June 30, 1999

Kathleen M. Sauer
Tariff Policy
PacifiCorp

1998 Inspections - Poles

DISTRICT	# of Poles	Patrol Urban		Patrol Rural *		Intrusive	
		Plan	Actual	Plan	Actual	Plan	Actual
Tulelake	12975	100%	100%	NA*	NA*	10%	7%
Alturas	3650	100%	100%	NA*	NA*	10%	10%
Crescent City	8188	100%	100%	50%	50%	10%	13%
Yreka/Mt. Shasta	30687	100%	100%	NA*	NA*	10%	10%
California Total	55500	100%	100%	50%	50%	10%	10%

1998 Inspections - Street Lights

DISTRICT	# of St. Lgts.	Patrol Urban		Patrol Rural	
		Plan	Actual	Plan	Actual
Tulelake	9	100%	100%	NA*	NA*
Alturas	8	100%	100%	NA*	NA*
Crescent City	14	100%	100%	50%	50%
Yreka/Mt. Shasta	95	100%	100%	NA*	NA*
California Total	126	100%	100%	50%	50%

* All Districts except Crescent City have chosen to Inspect all facilities as Urban

1998 Inspections - Equipment

DISTRICT	Type	Patrol Urban		Patrol Rural *		Detail U&R	
		Plan %	Actual %	Plan %	Actual %	Plan %	Actual **
Tulelake							
Transformers	Overhead	100%	100%	NA*	NA*	20%	532
	Padmounted	100%	100%	NA*	NA*	20%	0
Switch/Protect Device	Overhead	100%	100%	NA*	NA*	20%	0
	Padmounted	100%	100%	NA*	NA*	20%	0
Regs/Caps	Overhead	100%	100%	NA*	NA*	20%	0
Alturas							
Transformers	Overhead	100%	100%	NA*	NA*	20%	73
	Padmounted	100%	100%	NA*	NA*	20%	6
Switch/Protect Device	Overhead	100%	100%	NA*	NA*	20%	0
	Padmounted	100%	100%	NA*	NA*	20%	0
Regs/Caps	Overhead	100%	100%	NA*	NA*	20%	0
Crescent City							
Transformers	Overhead	100%	100%	50%	50%	20%	224
	Padmounted	100%	100%	50%	50%	20%	31
Switch/Protect Device	Overhead	100%	100%	50%	50%	20%	9
	Padmounted	100%	100%	50%	50%	20%	0
Regs/Caps	Overhead	100%	100%	50%	50%	20%	0
Yreka/Mt. Shasta							
Transformers	Overhead	100%	100%	NA*	NA*	20%	1323
	Padmounted	100%	100%	NA*	NA*	20%	169
Switch/Protect Device	Overhead	100%	100%	NA*	NA*	20%	0
	Padmounted	100%	100%	NA*	NA*	20%	0
Regs/Caps	Overhead	100%	100%	NA*	NA*	20%	6

* All Districts except Crescent City have chosen to Inspect all facilities as Urban

** After 5 year cycle is complete, total Equip. count will be known

1998 Conditions - Poles

DISTRICT	Conditions Found In 1998		98 Conditions Corrected As of 06/28/99		Conditions Outstanding As of 06/28/99			Total Conditions Outstanding Date to be Corrected		
	A	B	A	B	A	Pre 98 B	1998 B	A	Pre 98 B	1998 B
Tulelake	19	80	19	2	0	187	78	Complete	#####	#####
Alturas	0	14	0	0	0	6	14	Complete	#####	#####
Crescent City	19	85	19	4	0	0	81	Complete	Complete	#####
Yreka/Mt Shasta	107	365	91	35	16	104	330	7/30/1999	#####	#####
California Total	145	544	129	41	16	297	503			

1998 Conditions - Street Lights

DISTRICT	Conditions Found In 1998		98 Conditions Corrected As of 06/28/99		98 Conditions Outstanding As of 06/28/99			Total Conditions Outstanding Date to be Corrected		
	A	B	A	B	A	Pre 98 B	1998 B	A	Pre 98 B	1998 B
Tulelake	0	13	0	0	0	0	13	Complete	Complete	#####
Alturas	0	1	0	0	0	0	1	Complete	Complete	#####
Crescent City	0	6	0	0	0	0	6	Complete	Complete	#####
Yreka/Mt Shasta	0	11	0	0	0	3	11	Complete	#####	#####
California Total	0	31	0	0	0	3	31			

1998 Conditions - Equipment

DISTRICT	Type	Conditions Found In 1998		Conditions Corrected As of 06/28/99		Conditions Outstanding As of 06/28/99			Conditions Outstanding Date to be Corrected		
		A	B	A	B	A	Pre 98 B	1998 B	A	Pre 98 B	
Tulelake											
Transformers	Overhead	0	23	0	0	0	0	23	Complete	Complete	
	Padmounted	0	0	0	0	0	0	0	Complete	Complete	
Switch/Protect Device	Overhead	0	6	0	1	0	3	5	Complete	12/31/1999	
	Padmounted	0	0	0	0	0	0	0	Complete	Complete	
Regs/Caps	Overhead	0	1	0	0	0	0	1	Complete	Complete	
Alturas											
Transformers	Overhead	0	1	0	0	0	0	1	Complete	Complete	
	Padmounted	0	0	0	0	0	0	0	Complete	Complete	
Switch/Protect Device	Overhead	0	0	0	0	0	0	0	Complete	Complete	
	Padmounted	0	0	0	0	0	0	0	Complete	Complete	
Regs/Caps	Overhead	0	0	0	0	0	0	0	Complete	Complete	
Crescent City											
Transformers	Overhead	0	12	0	0	0	4	12	Complete	12/31/1999	
	Padmounted	0	0	0	0	0	2	0	Complete	12/31/1999	
Switch/Protect Device	Overhead	2	3	2	0	0	0	3	Complete	Complete	
	Padmounted	0	11	0	0	0	3	11	Complete	12/31/1999	
Regs/Caps	Overhead	0	0	0	0	0	0	0	Complete	Complete	
Yreka/Mt. Shasta											
Transformers	Overhead	0	9	0	0	0	0	9	Complete	Complete	
	Padmounted	0	0	0	0	0	0	0	Complete	Complete	
Switch/Protect Device	Overhead	4	5	4	0	0	2	5	Complete	12/31/1999	
	Padmounted	0	1	0	0	0	6	1	Complete	12/31/1999	
Regs/Caps	Overhead	0	0	0	0	0	0	0	Complete	Complete	
CA Total											
Transformers	Overhead	0	45	0	0	0	4	45			
	Padmounted	0	0	0	0	0	2	0			
Switch/Protect Device	Overhead	6	14	6	1	0	5	13			
	Padmounted	0	12	0	0	0	9	12			
Regs/Caps	Overhead	0	1	0	0	0	0	1			
Totals		6	72	6	1	0	20	71			