

June 15, 2001

Wesley Franklin - Executive Director
California Public Utilities Commission
505 Van Ness Avenue, Room 5222
San Francisco, California 94102-3298

RE: PacifiCorp's (U901-E) Plan for Inspections, Record Keeping, and Reporting
D.97-03-070
I.95-02-015/R.96-11-004

As required by California D.97-03-070, Appendix A, dated March 31, 1997, PacifiCorp provides an original and five copies of the attached Plan for Inspections, Record Keeping, and Reporting. This report is also being served on the attached service list of I.95-02-015. In addition an electronic version has been sent via e-mail to Wade McCartney @ WSM@cpuc.ca.gov.

Should you have any questions regarding this report, please contact Paul Capell at (503) 813-5334.

Respectfully submitted on behalf of PacifiCorp.

By: Carole Rockney, Director
Customer and Regulatory Liaison
1900 SW 4th Avenue, Plaza Level
Portland, Oregon 97232
Telephone: (503) 813-7408
Facsimile: (503) 813- 7313

Enclosure

c: Wade McCartney, Energy Division w/diskette
Brian Schumacher, Energy Division

BEFORE THE PUBLIC UTILITIES COMMISSION
OF THE STATE OF CALIFORNIA

Commission Order Instituting Investigation) into the rates, charges, services, and) practices of Pacific Gas and Electric) Company. (U 39 M))	I.95-02-015 (Filed February 22, 1995)
<hr/> Order Instituting Rulemaking for electric) distribution facility standard setting.)	R.96-11-004 (Filed November 8, 1996)

PACIFICORP'S (U901-E) IMPLEMENTATION PLAN FOR INSPECTIONS

USING INDICES SET FORTH IN APPENDIX A OF D.97-03-070

FOR CALENDAR YEAR 2000

June 15, 2000

PacifiCorp
Inspection and Maintenance Programs
California 2000

The attached sheets demonstrate the status of 2000 Inspections, Conditions found and Corrections in the state of California for PacifiCorp owned facilities. PacifiCorp has four districts in California: Tulelake, Alturas, Crescent City and Yreka/Mt. Shasta.

Inspections

All inspections were completed in 2000 for Urban & Rural Patrol, Detail and Intrusive inspection types. The attached Inspection sheets break down the inspections into three categories: Poles, Street Lights and Equipment. The information includes the type of equipment, the plan for each inspection category and the actuals of the inspection plan.

Conditions

Conditions found by the inspections were rated as either A or B priority, A priority requiring more immediate action. All A priority conditions have been corrected. The B priority conditions that have not been corrected as of June 5, 2001, will be corrected by the end of 2001 or 2002 depending on the date found.

The attached conditions work papers break down the conditions into four categories:

- number of conditions found in 2000;
- 1999 conditions corrected as of June 5, 2001;
- conditions currently outstanding;
- the final date outstanding conditions will be corrected by.

Dated in Portland, Oregon this 15th day of June 2001.

Respectfully Submitted,

Carole Rockney, Director
Customer and Regulatory Liaison
1900 SW 4th Avenue, Plaza Level
Portland, Oregon 97232
Telephone: (503) 813-7408
Facsimile: (503) 813- 7313

PACIFICORP
CERTIFICATE OF SERVICE

I hereby certify that on this 15th day of June, 2001, I served true copies of PacifiCorp's (U901-E) Plan for Inspections, Record Keeping, and Reporting - California I.95-02-015 on the following service list by first -class postage paid mail.

Dated: June 15 2001

Kathleen M. Sauer
Regulatory Liaison
PacifiCorp

2000 Inspections - Poles

District	Total # of Poles	Patrol Urban		Patrol Rural		Intrusive	
		Plan%	Actual%	Plan%	Actual%	Plan	Actual
Tulelake	12919	100%	100%	50%	50%	1228	1690
Alturas	3634	100%	100%	50%	50%	360	305
Crescent City	8146	100%	100%	50%	50%	624	854
Yreka/Mt. Shasta	30671	100%	100%	50%	50%	2520	388
California Total	55370	100%	100%	50%	50%	4732	3237

2000 Inspections - Street Lights

District	# of St. Lgts.	Patrol Urban		Patrol Rural	
		Plan%	Actual%	Plan%	Actual%
TuleLake	111	100%	100%	50%	50%
Alturas	101	100%	100%	50%	50%
Crescent City	3	100%	100%	50%	50%
Yreka/Mt. Shasta	22	100%	100%	50%	50%
California Total	237	100%	100%	50%	50%

2000 Inspections - Equipment

District/Equipment	Type	Patrol Urban		Patrol Rural		Detail U&R	
		Plan %	Actual %	Plan %	Actual %	Plan %	Actual*
Tulelake							
Transformers	Overhead	100%	100%	50%	50%	20%	93
Switch/Protect Device	Overhead	100%	100%	50%	50%	20%	4
Regs/Caps	Overhead	100%	100%	50%	50%	20%	14
All	Underground	100%	100%	50%	50%	20%	0
Alturas							
Transformers	Overhead	100%	100%	50%	50%	20%	9
Switch/Protect Device	Overhead	100%	100%	50%	50%	20%	2
Regs/Caps	Overhead	100%	100%	50%	50%	20%	0
All	Underground	100%	100%	50%	50%	20%	0
Crescent City							
Transformers	Overhead	100%	100%	50%	50%	20%	26
Switch/Protect Device	Overhead	100%	100%	50%	50%	20%	0
Regs/Caps	Overhead	100%	100%	50%	50%	20%	0
All	Underground	100%	100%	50%	50%	20%	0
Yreka/Mt. Shasta							
Transformers	Overhead	100%	100%	50%	50%	20%	1611
Switch/Protect Device	Overhead	100%	100%	50%	50%	20%	119
Regs/Caps	Overhead	100%	100%	50%	50%	20%	42
All	Underground	100%	100%	50%	50%	20%	5

* After 5 year cycle is complete, total equipment count will be known.

2000 Conditions - Equipment

DISTRICT	Type	Conditions Found In 2000		1999 Conditions Corrected As of 06/08/01		Total Conditions Outstanding As of 06/08/01				Total Conditions Outstanding Date to be Corrected		
		A	B	A	B	Pre 00 A	2000 A	Pre 00 B	2000 B	Pre00 A	2000 A	Pre 00 B
Tulelake												
Transformers	Overhead	0	1	0	0	0	0	23	1	Complete	Complete	12/31/01
	Padmounted	0	0	0	0	0	0	0	0	Complete	Complete	Complete
Switch/Protect Device	Overhead	0	0	0	0	0	0	5	0	Complete	Complete	12/31/01
	Padmounted	0	0	0	0	0	0	0	0	Complete	Complete	Complete
Regs/Caps	Overhead	0	0	0	0	0	0	1	0	Complete	Complete	12/31/01
Alturas												
Transformers	Overhead	0	0	0	0	0	0	1	0	Complete	Complete	12/31/01
	Padmounted	0	0	0	0	0	0	0	0	Complete	Complete	Complete
Switch/Protect Device	Overhead	0	0	0	0	0	0	0	0	Complete	Complete	Complete
	Padmounted	0	0	0	0	0	0	0	0	Complete	Complete	Complete
Regs/Caps	Overhead	0	0	0	0	0	0	0	0	Complete	Complete	Complete
Crescent City												
Transformers	Overhead	0	0	0	0	0	0	3	0	Complete	Complete	12/31/01
	Padmounted	0	0	0	0	0	0	0	0	Complete	Complete	Complete
Switch/Protect Device	Overhead	0	0	0	0	0	0	1	0	Complete	Complete	12/31/01
	Padmounted	0	0	0	0	0	0	1	0	Complete	Complete	12/31/01
Regs/Caps	Overhead	0	0	0	0	0	0	0	0	Complete	Complete	Complete
Yreka/Mt. Shasta												
Transformers	Overhead	2	3	2	2	0	0	5	1	Complete	Complete	12/31/01
	Padmounted	1	0	1	0	0	0	0	0	Complete	Complete	Complete
Switch/Protect Device	Overhead	0	0	0	0	0	0	11	0	Complete	Complete	12/31/01
	Padmounted	0	0	0	0	0	0	0	0	Complete	Complete	Complete
Regs/Caps	Overhead	0	0	0	0	0	0	0	0	Complete	Complete	Complete
CA Total												
Transformers	Overhead	2	4	2	2	0	0	32	2			
	Padmounted	1	0	1	0	0	0	0	0			
Switch/Protect Device	Overhead	0	0	0	0	0	0	17	0			
	Padmounted	0	0	0	0	0	0	1	0			
Regs/Caps	Overhead	0	0	0	0	0	0	1	0			
Totals		3	4	3	2	0	0	51	2			

2000 Conditions - Poles

DISTRICT	Conditions Found In 2000		1999 Conditions Corrected As of 06/05/01		Total Conditions Outstanding As of 06/05/01				Total Conditions Outstanding Date to be Corrected			
	A	B	A	B	Pre 00 A	2000 A	Pre 00 B	2000 B	Pre 00 A	2000 A	Pre 00 B	2000 B
Tulelake	30	54	30	9	0	0	76	45	Complete	Complete	12/31/01	12/31/02
Alturas	3	16	3	16	0	0	25	0	Complete	Complete	12/31/01	12/31/02
Crescent City	22	29	20	18	0	2	18	11	Complete	12/31/2001	12/31/01	12/31/02
Yreka/Mt Shasta	71	171	64	84	0	7	216	87	Complete	12/31/01	12/31/01	12/31/02
California Total	126	270	117	127	0	9	335	143				

2000 Conditions - Street Lights

DISTRICT	Conditions Found In 2000		1999 Conditions Corrected As of 06/05/01		Total Conditions Outstanding As of 06/05/01				Total Conditions Outstanding Date to be Corrected			
	A	B	A	B	Pre 00 A	2000 A	Pre 00 B	2000 B	Pre 00 A	2000 A	Pre 00 B	2000 B
Tulelake	0	11	0	0	0	0	0	11	Complete	Complete	Complete	12/31/02
Alturas	0	9	0	0	0	0	0	9	Complete	Complete	Complete	12/31/02
Crescent City	0	1	0	1	0	0	0	0	Complete	Complete	Complete	Complete
Yreka/Mt Shasta	0	15	0	3	0	0	0	12	Complete	Complete	Complete	12/31/02
California Total	0	36	0	4	0	0	0	32				

2000 Conditions - Poles

DISTRICT	Conditions Found In 2000		1999 Conditions Corrected As of 06/05/01		Total Conditions Outstanding As of 06/05/01				Total Conditions Outstanding Date to be Corrected			
	A	B	A	B	Pre 00 A	2000 A	Pre 00 B	2000 B	Pre 00 A	2000 A	Pre 00 B	2000 B
Tulelake	30	54	30	9	0	0	76	45	Complete	Complete	12/31/01	12/31/02
Alturas	3	16	3	16	0	0	25	0	Complete	Complete	12/31/01	12/31/02
Crescent City	22	29	20	18	0	2	18	11	Complete	12/31/2001	12/31/01	12/31/02
Yreka/Mt Shasta	71	171	64	84	0	7	216	87	Complete	12/31/01	12/31/01	12/31/02
California Total	126	270	117	127	0	9	335	143				

2000 Conditions - Street Lights

DISTRICT	Conditions Found In 2000		1999 Conditions Corrected As of 06/05/01		Total Conditions Outstanding As of 06/05/01				Total Conditions Outstanding Date to be Corrected			
	A	B	A	B	Pre 00 A	2000 A	Pre 00 B	2000 B	Pre 00 A	2000 A	Pre 00 B	2000 B
Tulelake	0	11	0	0	0	0	0	11	Complete	Complete	Complete	12/31/02
Alturas	0	9	0	0	0	0	0	9	Complete	Complete	Complete	12/31/02
Crescent City	0	1	0	1	0	0	0	0	Complete	Complete	Complete	Complete
Yreka/Mt Shasta	0	15	0	3	0	0	0	12	Complete	Complete	Complete	12/31/02
California Total	0	36	0	4	0	0	0	32				

2000 Conditions - Equipment

DISTRICT	Type	Conditions Found In 2000		1999 Conditions Corrected As of 06/08/01		Total Conditions Outstanding As of 06/08/01				Total Conditions Outstanding Date to be Corrected		
		A	B	A	B	Pre 00 A	2000 A	Pre 00 B	2000 B	Pre00 A	2000 A	Pre 00 B
Tulelake												
Transformers	Overhead	0	1	0	0	0	0	23	1	Complete	Complete	12/31/01
	Padmounted	0	0	0	0	0	0	0	0	Complete	Complete	Complete
Switch/Protect Device	Overhead	0	0	0	0	0	0	5	0	Complete	Complete	12/31/01
	Padmounted	0	0	0	0	0	0	0	0	Complete	Complete	Complete
Regs/Caps	Overhead	0	0	0	0	0	0	1	0	Complete	Complete	12/31/01
Alturas												
Transformers	Overhead	0	0	0	0	0	0	1	0	Complete	Complete	12/31/01
	Padmounted	0	0	0	0	0	0	0	0	Complete	Complete	Complete
Switch/Protect Device	Overhead	0	0	0	0	0	0	0	0	Complete	Complete	Complete
	Padmounted	0	0	0	0	0	0	0	0	Complete	Complete	Complete
Regs/Caps	Overhead	0	0	0	0	0	0	0	0	Complete	Complete	Complete
Crescent City												
Transformers	Overhead	0	0	0	0	0	0	3	0	Complete	Complete	12/31/01
	Padmounted	0	0	0	0	0	0	0	0	Complete	Complete	Complete
Switch/Protect Device	Overhead	0	0	0	0	0	0	1	0	Complete	Complete	12/31/01
	Padmounted	0	0	0	0	0	0	1	0	Complete	Complete	12/31/01
Regs/Caps	Overhead	0	0	0	0	0	0	0	0	Complete	Complete	Complete
Yreka/Mt. Shasta												
Transformers	Overhead	2	3	2	2	0	0	5	1	Complete	Complete	12/31/01
	Padmounted	1	0	1	0	0	0	0	0	Complete	Complete	Complete
Switch/Protect Device	Overhead	0	0	0	0	0	0	11	0	Complete	Complete	12/31/01
	Padmounted	0	0	0	0	0	0	0	0	Complete	Complete	Complete
Regs/Caps	Overhead	0	0	0	0	0	0	0	0	Complete	Complete	Complete
CA Total												
Transformers	Overhead	2	4	2	2	0	0	32	2			
	Padmounted	1	0	1	0	0	0	0	0			
Switch/Protect Device	Overhead	0	0	0	0	0	0	17	0			
	Padmounted	0	0	0	0	0	0	1	0			
Regs/Caps	Overhead	0	0	0	0	0	0	1	0			
Totals		3	4	3	2	0	0	51	2			

2000 Conditions - Equipment

DISTRICT	Type	Conditions Found In 2000		1999 Conditions Corrected As of 06/08/01		Total Conditions Outstanding As of 06/08/01				Total Conditions Outstanding Date to be Corrected		
		A	B	A	B	Pre 00 A	2000 A	Pre 00 B	2000 B	Pre00 A	2000 A	Pre 00 B
Tulelake												
Transformers	Overhead	0	1	0	0	0	0	23	1	Complete	Complete	12/31/01
	Padmounted	0	0	0	0	0	0	0	0	Complete	Complete	Complete
Switch/Protect Device	Overhead	0	0	0	0	0	0	5	0	Complete	Complete	12/31/01
	Padmounted	0	0	0	0	0	0	0	0	Complete	Complete	Complete
Regs/Caps	Overhead	0	0	0	0	0	0	1	0	Complete	Complete	12/31/01
Alturas												
Transformers	Overhead	0	0	0	0	0	0	1	0	Complete	Complete	12/31/01
	Padmounted	0	0	0	0	0	0	0	0	Complete	Complete	Complete
Switch/Protect Device	Overhead	0	0	0	0	0	0	0	0	Complete	Complete	Complete
	Padmounted	0	0	0	0	0	0	0	0	Complete	Complete	Complete
Regs/Caps	Overhead	0	0	0	0	0	0	0	0	Complete	Complete	Complete
Crescent City												
Transformers	Overhead	0	0	0	0	0	0	3	0	Complete	Complete	12/31/01
	Padmounted	0	0	0	0	0	0	0	0	Complete	Complete	Complete
Switch/Protect Device	Overhead	0	0	0	0	0	0	1	0	Complete	Complete	12/31/01
	Padmounted	0	0	0	0	0	0	1	0	Complete	Complete	12/31/01
Regs/Caps	Overhead	0	0	0	0	0	0	0	0	Complete	Complete	Complete
Yreka/Mt. Shasta												
Transformers	Overhead	2	3	2	2	0	0	5	1	Complete	Complete	12/31/01
	Padmounted	1	0	1	0	0	0	0	0	Complete	Complete	Complete
Switch/Protect Device	Overhead	0	0	0	0	0	0	11	0	Complete	Complete	12/31/01
	Padmounted	0	0	0	0	0	0	0	0	Complete	Complete	Complete
Regs/Caps	Overhead	0	0	0	0	0	0	0	0	Complete	Complete	Complete
CA Total												
Transformers	Overhead	2	4	2	2	0	0	32	2			
	Padmounted	1	0	1	0	0	0	0	0			
Switch/Protect Device	Overhead	0	0	0	0	0	0	17	0			
	Padmounted	0	0	0	0	0	0	1	0			
Regs/Caps	Overhead	0	0	0	0	0	0	1	0			
Totals		3	4	3	2	0	0	51	2			

2000 Inspections - Poles

District	Total # of Poles	Patrol Urban		Patrol Rural		Intrusive	
		Plan%	Actual%	Plan%	Actual%	Plan	Actual
Tulelake	12919	100%	100%	50%	50%	1228	1690
Alturas	3634	100%	100%	50%	50%	360	305
Crescent City	8146	100%	100%	50%	50%	624	854
Yreka/Mt. Shasta	30671	100%	100%	50%	50%	2520	388
California Total	55370	100%	100%	50%	50%	4732	3237

2000 Inspections - Street Lights

District	# of St. Lgts.	Patrol Urban		Patrol Rural	
		Plan%	Actual%	Plan%	Actual%
TuleLake	111	100%	100%	50%	50%
Alturas	101	100%	100%	50%	50%
Crescent City	3	100%	100%	50%	50%
Yreka/Mt. Shasta	22	100%	100%	50%	50%
California Total	237	100%	100%	50%	50%

2000 Inspections - Equipment

District/Equipment	Type	Patrol Urban		Patrol Rural		Detail U&R	
		Plan %	Actual %	Plan %	Actual %	Plan %	Actual*
Tulelake							
Transformers	Overhead	100%	100%	50%	50%	20%	93
Switch/Protect Device	Overhead	100%	100%	50%	50%	20%	4
Regs/Caps	Overhead	100%	100%	50%	50%	20%	14
All	Underground	100%	100%	50%	50%	20%	0
Alturas							
Transformers	Overhead	100%	100%	50%	50%	20%	9
Switch/Protect Device	Overhead	100%	100%	50%	50%	20%	2
Regs/Caps	Overhead	100%	100%	50%	50%	20%	0
All	Underground	100%	100%	50%	50%	20%	0
Crescent City							
Transformers	Overhead	100%	100%	50%	50%	20%	26
Switch/Protect Device	Overhead	100%	100%	50%	50%	20%	0
Regs/Caps	Overhead	100%	100%	50%	50%	20%	0
All	Underground	100%	100%	50%	50%	20%	0
Yreka/Mt. Shasta							
Transformers	Overhead	100%	100%	50%	50%	20%	1611
Switch/Protect Device	Overhead	100%	100%	50%	50%	20%	119
Regs/Caps	Overhead	100%	100%	50%	50%	20%	42
All	Underground	100%	100%	50%	50%	20%	5

* After 5 year cycle is complete, total equipment count will be known.