

July 19, 2002

Wesley Franklin - Executive Director
California Public Utilities Commission
505 Van Ness Avenue, Room 5222
San Francisco, California 94102-3298

RE: PacifiCorp's (U901-E) Plan for Inspections, Record Keeping, and Reporting
D.97-03-070
I.95-02-015/R.96-11-004

As required by California D.97-03-070, Appendix A, dated March 31, 1997, PacifiCorp provides an original and five copies of the attached Plan for Inspections, Record Keeping, and Reporting. Under authorization granted by Wesley Franklin in a letter dated July 3, 2002, the Company was granted additional time to submit this report, with the revised due date of July 22, 2002.

This report is also being served on the attached service list of I.95-02-015. In addition an electronic version has been sent via e-mail to Wade McCartney @ WSM@cpuc.ca.gov.

Should you have any questions regarding this report, please contact Paul Capell at (503) 813-5334.

Respectfully submitted on behalf of PacifiCorp.

By: Carole Rockney, Director
Customer and Regulatory Liaison
1900 SW 4th Avenue, Plaza Level
Portland, Oregon 97232
Telephone: (503) 813-7408
Facsimile: (503) 813- 7313

Enclosure

c: Wade McCartney, Energy Division w/diskette
Brian Schumacher, Energy Division

BEFORE THE PUBLIC UTILITIES COMMISSION
OF THE STATE OF CALIFORNIA

Commission Order Instituting Investigation) into the rates, charges, services, and) practices of Pacific Gas and Electric) Company. (U 39 M))	I.95-02-015 (Filed February 22, 1995)
<hr/> Order Instituting Rulemaking for electric) distribution facility standard setting.)	R.96-11-004 (Filed November 8, 1996)

PACIFICORP'S (U901-E) IMPLEMENTATION PLAN FOR INSPECTIONS

USING INDICES SET FORTH IN APPENDIX A OF D.97-03-070

FOR CALENDAR YEAR 2001

PacifiCorp Inspection and Maintenance Programs California 2001

The attached sheets demonstrate the status of 2001 Inspections, Conditions found and Corrections in the state of California for PacifiCorp owned facilities. PacifiCorp has four districts in California: Tulelake, Alturas, Crescent City and Yreka/Mt. Shasta.

Inspections

All inspections were completed in 2001 for Urban & Rural Patrol, Detail and Intrusive inspection types. The attached Inspection sheets break down the inspections into three categories: Poles, Street Lights and Equipment. The information includes the type of equipment, the plan for each inspection category and the actuals of the inspection plan.

Conditions

Conditions found by the inspections were rated as either A or B priority, A priority requiring more immediate action. All A priority conditions will be completed by 12/31/2002. The B priority conditions found in 2001 will be corrected by the end of 2003, and all conditions found pre-2001 will be corrected by 12/31/2002.

The attached conditions work papers break down the conditions into four categories:

- number of conditions found in 2001;
- pre-2001 conditions corrected as of July 10, 2002;
- conditions currently outstanding;
- the final date outstanding conditions will be corrected by.

Dated in Portland, Oregon this 19th day of July 2002.

Respectfully Submitted,

Carole Rockney, Director
Customer and Regulatory Liaison
1900 SW 4th Avenue, Plaza Level
Portland, Oregon 97232
Telephone: (503) 813-7408
Facsimile: (503) 813- 7313

PACIFICORP
CERTIFICATE OF SERVICE

I hereby certify that on this 19th day of July, 2002, I served true copies of PacifiCorp's (U901-E) Plan for Inspections, Record Keeping, and Reporting - California I.95-02-015 on the following service list by first -class postage paid mail.

Dated: July 19, 2002

Kathleen M. Sauer
Regulatory Liaison
PacifiCorp

PacifiCorp

2001 Inspections - Poles

District	Total # of Poles	Patrol Urban		Patrol Rural		Intrusive	
		Plan %	Actual %	Plan %	Actual %	Plan	Actual
Tulelake	15,191	100%	100%	50%	50%	1,519	1,124
Alturas	4,924	100%	100%	50%	50%	492	229
Crescent City	3,150	100%	100%	50%	50%	315	896
Yreka/Mt. Shasta	35,135	100%	100%	50%	50%	3,514	2,803
California Total	58,400	100%	100%	50%	50%	5,840	5,052

2001 Inspections - Street Lights

District	# of St. Lgts.	Patrol Urban		Patrol Rural	
		Plan %	Actual %	Plan %	Actual %
TuleLake	112	100%	100%	50%	50%
Alturas	114	100%	100%	50%	50%
Crescent City	145	100%	100%	50%	50%
Yreka/Mt. Shasta	589	100%	100%	50%	50%
California Total	960	100%	100%	50%	50%

2001 Inspections - Equipment

District/Equipment	Type	Patrol Urban		Patrol Rural		Detail Urban & Rural	
		Plan %	Actual %	Plan %	Actual %	Plan %	Actual*
Tulelake							
Transformers	Overhead	100%	100%	50%	50%	20%	22
Switch/Protect Device	Overhead	100%	100%	50%	50%	20%	1
Regs/Caps	Overhead	100%	100%	50%	50%	20%	0
All	Underground	100%	100%	50%	50%	20%	0
Alturas							
Transformers	Overhead	100%	100%	50%	50%	20%	2
Switch/Protect Device	Overhead	100%	100%	50%	50%	20%	0
Regs/Caps	Overhead	100%	100%	50%	50%	20%	0
All	Underground	100%	100%	50%	50%	20%	0
Crescent City							
Transformers	Overhead	100%	100%	50%	50%	20%	43
Switch/Protect Device	Overhead	100%	100%	50%	50%	20%	0
Regs/Caps	Overhead	100%	100%	50%	50%	20%	0
All	Underground	100%	100%	50%	50%	20%	0
Yreka/Mt. Shasta							
Transformers	Overhead	100%	100%	50%	50%	20%	1,279
Switch/Protect Device	Overhead	100%	100%	50%	50%	20%	164
Regs/Caps	Overhead	100%	100%	50%	50%	20%	5
All	Underground	100%	100%	50%	50%	20%	0

* After 5 year cycle is complete, total equipment count will be known.

PacifiCorp

2001 Conditions - Poles

DISTRICT	Conditions Found In 2001		2000 Conditions Corrected As of 07/10/02		Total Conditions Outstanding As of 07/10/02				Total Conditions Outstanding Date to be Corrected			
	A	B	A	B	Pre-2001 A	2001 A	Pre-2001 B	2001 B	Pre-2001 A	2001 A	Pre-2001 B	2001 B
Tulelake	13	85	13	52	0	0	3	85	Complete	Complete	12/31/02	12/31/03
Alturas	31	17	0	15	0	0	2	12	Complete	Complete	12/31/02	12/31/03
Crescent City	9	12	2	7	0	1	20	12	Complete	12/31/02	12/31/02	12/31/03
Yreka/Mt Shasta	63	259	34	66	0	8	139	199	Complete	12/31/02	12/31/02	12/31/03
California Total	116	373	49	140	0	9	164	308				

2001 Conditions - Street Lights

DISTRICT	Conditions Found In 2001		2000 Conditions Corrected As of 07/10/02		Total Conditions Outstanding As of 07/10/02				Total Conditions Outstanding Date to be Corrected			
	A	B	A	B	Pre-2001 A	2001 A	Pre-2001 B	2001 B	Pre-2001 A	2001 A	Pre-2001 B	2001 B
Tulelake	0	0	0	0	0	0	23	0	Complete	Complete	12/31/02	Complete
Alturas	0	0	0	0	0	0	10	0	Complete	Complete	12/31/02	Complete
Crescent City	0	0	0	1	0	0	0	0	Complete	Complete	Complete	Complete
Yreka/Mt Shasta	0	0	0	15	0	0	0	0	Complete	Complete	Complete	Complete
California Total	0	0	0	16	0	0	33	0				

PacifiCorp

2001 Conditions - Equipment

DISTRICT	Type	Conditions Found In 2001		2000 Conditions Corrected As of 07/10/02		Total Conditions Outstanding As of 07/10/02				Total Conditions Outstanding Date to be Corrected			
		A	B	A	B	Pre-2001 A	2001 A	Pre-2001 B	2001 B	Pre-2001 A	2001 A	Pre-2001 B	2001 B
		Tulelake											
Transformers	Overhead	0	0	0	0	0	0	21	0	Complete	Complete	12/31/02	Complete
	Padmounted	0	0	0	0	0	0	0	0	Complete	Complete	Complete	Complete
Switch/Protect Device	Overhead	0	0	0	0	0	0	4	0	Complete	Complete	12/31/02	Complete
	Padmounted	0	0	0	0	0	0	0	0	Complete	Complete	Complete	Complete
Regs/Caps	Overhead	0	0	0	0	0	0	1	0	Complete	Complete	12/31/02	Complete
Alturas													
Transformers	Overhead	0	0	0	0	0	0	1	0	Complete	Complete	12/31/02	Complete
	Padmounted	0	0	0	0	0	0	0	0	Complete	Complete	Complete	Complete
Switch/Protect Device	Overhead	1	1	0	0	0	0	0	1	Complete	Complete	Complete	12/31/03
	Padmounted	0	0	0	0	0	0	0	0	Complete	Complete	Complete	Complete
Regs/Caps	Overhead	0	0	0	0	0	0	0	0	Complete	Complete	Complete	Complete
Crescent City													
Transformers	Overhead	0	0	0	4	0	0	0	0	Complete	Complete	Complete	Complete
	Padmounted	0	4	0	0	0	0	0	3	Complete	Complete	Complete	12/31/03
Switch/Protect Device	Overhead	0	0	0	1	0	0	0	0	Complete	Complete	Complete	Complete
	Padmounted	0	0	0	0	0	0	0	0	Complete	Complete	Complete	Complete
Regs/Caps	Overhead	0	0	0	0	0	0	0	0	Complete	Complete	Complete	Complete
Yreka/Mt. Shasta													
Transformers	Overhead	1	7	1	7	0	0	0	0	Complete	Complete	Complete	Complete
	Padmounted	0	0	0	0	0	0	0	0	Complete	Complete	Complete	Complete
Switch/Protect Device	Overhead	0	14	0	2	0	0	6	4	Complete	Complete	12/31/02	12/31/03
	Padmounted	0	0	0	0	0	0	0	0	Complete	Complete	Complete	Complete
Regs/Caps	Overhead	0	0	0	0	0	0	0	0	Complete	Complete	Complete	Complete
CA Total													
Transformers	Overhead	1	7	1	11	0	0	22	0				
	Padmounted	0	4	0	0	0	0	0	3				
Switch/Protect Device	Overhead	1	15	0	3	0	0	10	5				
	Padmounted	0	0	0	0	0	0	0	0				
Regs/Caps	Overhead	0	0	0	0	0	0	1	0				
Totals		2	26	1	14	0	0	33	8				