

TABLE A-1
2003 GENERAL ORDER 165 ANNUAL REPORT

Reporting Period: 01/01/03 - 12/31/03

PacifiCorp Wood Pole Inspections

DISTRICT	NO. OF FACILITIES		INSPECTION TYPE					
	Distribution Poles	Transmission Poles	O/H Safety (Patrol)	% Comp.	O/H Detail	% Comp.	O/H Test & Treat (Intrusive)	% Comp.
Inspection Cycle			2 Yrs	50%	5 Yrs	20%	10 Yrs	10%
Tulelake	13,486	1,718	13,405	88%	5,446	36%	1,440	9%
Alturas	4,556	1,126	3,588	63%	752	13%	0	0%
Crescent City	9,563	696	4,176	41%	1,878	18%	614	6%
Yreka/Mt. Shasta	34,482	2,008	23,660	65%	9,264	25%	6,206	17%
Main Grid	0	3,742	5,195	139%	60	2%	0	0%
California Totals	62,087	9,290	50,024	70%	17,400	24%	8,260	12%

TABLE A-2
2003 GENERAL ORDER 165 ANNUAL REPORT

Reporting Period: 01/01/03- 12/31/03

PacifiCorp Line Equipment Inspections

District/Equipment	Type	QTY	Safety (Patrol) Rural ⁽¹⁾			Detailed Rural ⁽¹⁾		
			Plan ⁽²⁾	Actual	% Complete	Plan ⁽²⁾	Actual	% Complete
			2 Yrs		50%	4 or 5 Yrs		20-25%
Tulelake								
Transformers	Overhead	2576	1,288	1,492	47%	515	1,137	36%
Switch/Protect Device	Overhead	555	278			111		
Regs/Caps	Overhead	43	22			9		
All	Pad Mounted	213				53	23	11%
Total			1,587	1,492		688	1,160	34%
Alturas								
Transformers	Overhead	1031	516	685	58%	206	156	13%
Switch/Protect Device	Overhead	144	72			29		
Regs/Caps	Overhead	1	1			0		
All	Pad Mounted	45				11	11	24%
Total			588	685		246	167	14%
Crescent City								
Transformers	Overhead	3469	1,735	1,614	38%	694	783	18%
Switch/Protect Device	Overhead	807	404			161		
Regs/Caps	Overhead	3	2			1		
All	Pad Mounted	2118				530	234	11%
Total			2,140	1,614		1,385	1,017	16%
Yreka/Mt. Shasta								
Transformers	Overhead	9176	4,588	7,987	69%	1,835	2,925	25%
Switch/Protect Device	Overhead	2304	1,152			461		
Regs/Caps	Overhead	40	20			8		
All	Pad Mounted	7088				1,772	0	0%
Total			5,760	7,987		4,076	2,925	16%
California Totals								
Transformers	Overhead	16252	8,126	11,778	58%	3,250	5,001	25%
Switch/Protect Device	Overhead	3810	1,905			762		
Regs/Caps	Overhead	87	44			17		
All	Pad Mounted	9464				2,366	268	3%

NOTES:

1. PacifiCorp has no Urban area in its California service territory. Urban is defined as those areas with a population of more than 1,000 persons per square mile and Rural as those with a population less than 1,000 persons per square mile as determined by the U.S. Bureau of the Census.

U. S. Bureau of the Census reports the population densities below (using 2000 Census data)

Each of these counties is reported to have a reducing population

7.0 persons/sq.mi.	Siskiyou County (Tulelake, Yreka, Mt. Shasta)
27.3 persons/sq.mi.	Del Norte County (Crescent City)
2.4 persons/sq.mi.	Modoc County (Alturas)

2. Planned inspection cycles:

Overhead	<u>Patrol</u>	<u>Detailed</u>
Pad Mounted	2 years	5 years
		4 years

3. Due to calendar year reporting vs. fiscal year operations, some variances to plan are artifacts of timing differences.

TABLE B-1
2003 GENERAL ORDER 165 ANNUAL REPORT

Reporting Period: 01/01/03 - 12/31/03

PacifiCorp Wood Pole Conditions

DISTRICT	CONDITIONS FOUND		CONDITIONS CORRECTED		REMOVED FROM SYSTEM		CONDITIONS OUTSTANDING		REASON WHY CORRECTION IS OUTSTANDING	DATE CORRECTION WILL BE COMPLETED BY
	A	B	A	B	A	B	A	B		
Tulelake	13	69	1	14	0	0	27	67	A's planned to be completed by end of 2004; B's planned to be corrected by end of 2005	Per note
Alturas	0	0	19	10	0	0	7	15	A's planned to be completed by end of 2004; B's planned to be corrected by end of 2005	Per note
Crescent City	34	44	3	68	0	0	10	87	A's planned to be completed by end of 2004; B's planned to be corrected by end of 2005	Per note
Yreka/Mt. Shasta	128	407	48	37	0	42	173	817	A's planned to be completed by end of 2004; B's planned to be corrected by end of 2005	Per note
California Total	175	520	71	129	0	42	217	986		

PacifiCorp Street Light Conditions

DISTRICT	CONDITIONS FOUND		CONDITIONS CORRECTED		REMOVED FROM SYSTEM		CONDITIONS OUTSTANDING		REASON WHY CORRECTION IS OUTSTANDING	DATE CORRECTION WILL BE COMPLETED BY
	A	B	A	B	A	B	A	B		
Tulelake	0	5	0	12	0	0	0	0		
Alturas	0	0	0	11	0	0	0	0		
Crescent City	0	0	0	1	0	0	0	0		
Yreka/Mt. Shasta	1	34	0	22	0	42	1	33	B's planned to be corrected by end of 2005	12/31/2005
California Total	1	39	0	46	0	42	1	33		

TABLE B-2
2003 GENERAL ORDER 165 ANNUAL REPORT

Reporting Period: 01/01/03 - 12/31/03

PacifiCorp Equipment Conditions

DISTRICT	Type	CONDITION RATING FOUND		CORRECTIVE ACTIONS COMPLETED		REMOVED FROM SYSTEM		CONDITIONS OUTSTANDING		REASON WHY CORRECTION IS OUTSTANDING	DATE CORRECTION WILL BE COMPLETED BY
		A	B	A	B	A	B	A	B		
Tulelake											
Transformers	Overhead	0	8	0	3	0	2	0	3	Scheduled next calendar year.	12/31/2004
Switch/Protect Device	Overhead	0	0	0	0	0	0	0	0		
Regs/Caps	Overhead	0	0	0	0	0	0	0	0		
All	Padmounted	0	0	0	0	0	0	0	0		
Alturas											
Transformers	Overhead	0	0	0	2	0	0	0	1	Scheduled next calendar year.	12/31/2004
Switch/Protect Device	Overhead	0	0	0	0	0	0	0	0		
Regs/Caps	Overhead	0	0	0	0	0	0	0	0		
All	Padmounted	0	0	0	0	0	0	0	0		
Crescent City											
Transformers	Overhead	0	5	0	2	0	0	0	5	Scheduled next calendar year	12/31/2004
Switch/Protect Device	Overhead	0	1	0	1	0	0	0	4	Scheduled next calendar year	12/31/2004
Regs/Caps	Overhead	0	0	0	0	0	0	0	0		
All	Padmounted	2	0	2	0	0	0	0	0		
Yreka/Mt. Shasta											
Transformers	Overhead	0	3	0	1	0	0	0	4	Scheduled next calendar year	12/31/2004
Switch/Protect Device	Overhead	0	2	0	1	0	0	0	3	Scheduled next calendar year	12/31/2004
Regs/Caps	Overhead	0	0	0	0	0	0	0	0		
All	Padmounted	0	0	0	0	0	0	0	0		
CA Total											
Transformers	Overhead	0	16	0	8	0	2	0	13		
Switch/Protect Device	Overhead	0	3	0	2	0	0	0	7		
Regs/Caps	Overhead	0	0	0	0	0	0	0	0		
All	Padmounted	2	0	2	0	0	0	0	0		
California Totals		2	19	2	10	0	2	0	20		