

TABLE A-1
2005 GENERAL ORDER 165 ANNUAL REPORT

Reporting Period: 01/01/05 - 12/31/05

PacifiCorp Wood Pole Inspections

DISTRICT	NO. OF FACILITIES		INSPECTION TYPE					
	Distribution Poles	Transmission Poles	O/H Safety (Patrol)	% Comp.	O/H Detail	% Comp.	O/H Test & Treat (Intrusive)	% Comp.
Inspection Cycle			2 Yrs	50%	5 Yrs	20%	15 Yrs	7%
Tulelake	13,488	1,719	7,435	49%	3,335	22%	1,008	7%
Alturas	4,567	1,127	2,307	41%	739	13%	3	0%
Crescent City	9,456	909	3,458	33%	197	2%	0	0%
Yreka/Mt. Shasta	34,328	2,846	27,984	75%	7,809	21%	2,436	7%
Main Grid	0	3,702	6,903	186%	3,591	97%	1,958	53%
California Totals	61,839	10,303	48,087	67%	15,671	22%	5,405	7%

TABLE A-2
2005 GENERAL ORDER 165 ANNUAL REPORT

Reporting Period: 01/01/05- 12/31/05

PacifiCorp Line Equipment Inspections

District/Equipment	Type	QTY	Safety (Patrol) Rural ⁽¹⁾			Detailed Rural ⁽¹⁾		
			Plan ⁽²⁾	Actual	% Complete	Plan ⁽²⁾	Actual	% Complete
			2 Yrs		50%	4 or 5 Yrs		20-25%
Tulelake								
Transformers	Overhead	2590	1,295	1,633	49%	518	733	22%
Switch/Protect Device	Overhead	702	351			140		
Regs/Caps	Overhead	49	25			10		
All	Pad Mounted	76				19	10	13%
Total			1,671	1,633		687	742	22%
Alturas								
Transformers	Overhead	1044	522	483	41%	209	155	13%
Switch/Protect Device	Overhead	147	74			29		
Regs/Caps	Overhead	1	1			0		
All	Pad Mounted	45				11	7	15%
Total			596	483		250	161	13%
Crescent City								
Transformers	Overhead	3499	1,750	1,758	33%	700	100	2%
Switch/Protect Device	Overhead	1768	884			354		
Regs/Caps	Overhead	1	1			0		
All	Pad Mounted	1135				284	261	23%
Total			2,634	1,758		1,337	361	6%
Yreka/Mt. Shasta								
Transformers	Overhead	9202	4,601	11,514	75%	1,840	3,213	21%
Switch/Protect Device	Overhead	6049	3,025			1,210		
Regs/Caps	Overhead	44	22			9		
All	Pad Mounted	3295				824	790	24%
Total			7,648	11,514		3,883	4,003	22%
California Totals								
Transformers	Overhead	16335	8,168	15,388	67%	3,267	4,200	22%
Switch/Protect Device	Overhead	8666	4,333			1,733		
Regs/Caps	Overhead	95	48			19		
All	Pad Mounted	4551				1,138	1,068	23%
Total			12,548	15,388		6,157	5,268	18%

NOTES:

1. PacifiCorp has no Urban area in its California service territory. Urban is defined as those areas with a population of more than 1,000 persons per square mile and Rural as those with a population less than 1,000 persons per square mile as determined by the U.S. Bureau of the Census.

U. S. Bureau of the Census reports the population densities below (using 2000 Census data) Each of these counties is reported to have a reducing population

7.0 persons/sq.mi.	Siskiyou County (Tulelake, Yreka, Mt. Shasta)
27.3 persons/sq.mi.	Del Norte County (Crescent City)
2.4 persons/sq.mi.	Modoc County (Alturas)

2. Planned inspection cycles:	<u>Patrol</u>	<u>Detailed</u>
Overhead	2 years	5 years
Pad Mounted		4 years

3. Due to calendar year reporting vs. fiscal year operations, some variances to plan are artifacts of timing differences.

TABLE B-1
2005 GENERAL ORDER 165 ANNUAL REPORT

Reporting Period: 01/01/05 - 12/31/05

PacifiCorp Wood Pole Conditions

DISTRICT	CONDITIONS FOUND		CONDITIONS CORRECTED		REMOVED FROM SYSTEM		CONDITIONS OUTSTANDING		REASON WHY CORRECTION IS OUTSTANDING	DATE CORRECTION WILL BE COMPLETED BY
	A	B	A	B	A	B	A	B		
Tulelake	12	34	11	138	0	3	12	76	'A' priority conditions repaired immediately, lower priority conditions per company policy.	Per note
Alturas	0	0	1	6	0	0	0	0	'A' priority conditions repaired immediately, lower priority conditions per company policy.	Per note
Crescent City	0	22	8	130	0	0	7	35	'A' priority conditions repaired immediately, lower priority conditions per company policy.	Per note
Yreka/Mt. Shasta	32	156	121	181	9	57	68	905	'A' priority conditions repaired immediately, lower priority conditions per company policy.	Per note
California Total	44	212	141	455	9	60	87	1016		

3

PacifiCorp Street Light Conditions

DISTRICT	CONDITIONS FOUND		CONDITIONS CORRECTED		REMOVED FROM SYSTEM		CONDITIONS OUTSTANDING		REASON WHY CORRECTION IS OUTSTANDING	DATE CORRECTION WILL BE COMPLETED BY
	A	B	A	B	A	B	A	B		
Tulelake	0	1	0	0	0	0	0	1	'A' priority conditions repaired immediately, lower priority conditions per company policy.	Per note
Alturas	0	0	0	0	0	0	0	16	'A' priority conditions repaired immediately, lower priority conditions per company policy.	Per note
Crescent City	0	0	0	68	0	0	0	1	'A' priority conditions repaired immediately, lower priority conditions per company policy.	Per note
Yreka/Mt. Shasta	0	35	0	20	0	3	1	90	'A' priority conditions repaired immediately, lower priority conditions per company policy.	Per note
California Total	0	36	0	88	0	3	1	108		

TABLE B-2
2005 GENERAL ORDER 165 ANNUAL REPORT

Reporting Period: 01/01/05 - 12/31/05

PacifiCorp Equipment Conditions

DISTRICT	Type	CONDITION RATING FOUND		CORRECTIVE ACTIONS COMPLETED		REMOVED FROM SYSTEM		CONDITIONS OUTSTANDING		REASON WHY CORRECTION IS OUTSTANDING	DATE CORRECTION WILL BE COMPLETED BY
		A	B	A	B	A	B	A	B		
Tulelake											
Transformers	Overhead	0	0	1	2	0	0	0	3	'A' priority conditions repaired immediately, lower priority conditions per company policy.	Per note
Switch/Protect Device	Overhead	2	1	0	0	0	0	2	1	'A' priority conditions repaired immediately, lower priority conditions per company policy.	Per note
Regs/Caps	Overhead	0	0	0	0	0	0	0	0		
All	Padmounted	11	1	11	1	0	0	0	0	'A' priority conditions repaired immediately, lower priority conditions per company policy.	Per note
Alturas											
Transformers	Overhead	0	0	0	1	0	0	0	1	'A' priority conditions repaired immediately, lower priority conditions per company policy.	Per note
Switch/Protect Device	Overhead	1	0	0	0	0	0	1	0	'A' priority conditions repaired immediately, lower priority conditions per company policy.	Per note
Regs/Caps	Overhead	0	0	0	0	0	0	0	0		
All	Padmounted	0	0	0	0	0	0	0	0		
Crescent City											
Transformers	Overhead	2	0	0	3	0	0	2	5	'A' priority conditions repaired immediately, lower priority conditions per company policy.	Per note
Switch/Protect Device	Overhead		0	0	4	0	0	0	0	'A' priority conditions repaired immediately, lower priority conditions per company policy.	Per note
Regs/Caps	Overhead	0	0	0	0	0	0	0	0		
All	Padmounted	0	1	0	0	0	0	0	1	'A' priority conditions repaired immediately, lower priority conditions per company policy.	Per note
Yreka											
Transformers	Overhead	3	105	0	5	0	6	9	109	'A' priority conditions repaired immediately, lower priority conditions per company policy.	Per note
Switch/Protect Device	Overhead	0	0	0	1	0	0	0	7	'A' priority conditions repaired immediately, lower priority conditions per company policy.	Per note
Regs/Caps	Overhead	0	0	0	0	0	0	0	0		
All	Padmounted	1	7	0	0	0	0	3	12	'A' priority conditions repaired immediately, lower priority conditions per company policy.	Per note
Mt. Shasta											
Transformers	Overhead	0	0	0	0	0	0	0	0		
Switch/Protect Device	Overhead	0	0	0	0	0	0	0	0		
Regs/Caps	Overhead	0	0	0	0	0	0	0	0		
All	Padmounted	0	0	0	0	0	0	0	0		
CA Total											
Transformers	Overhead	5	105	1	11	0	6	11	118		
Switch/Protect Device	Overhead	3	1	0	5	0	0	3	8		
Regs/Caps	Overhead	0	0	0	0	0	0	0	0		
All	Padmounted	12	9	11	1	0	0	3	13		
California Totals		20	115	12	17	0	6	17	139		