



Bear Valley
Electric Service
A Division of Golden State Water Company

June 24, 2014

Ben Brinkman
California Public Utilities Commission
Safety Enforcement Division
505 Van Ness Avenue
San Francisco, CA 94102-3298

Dear Mr. Brinkman:

In compliance with General Order 165, Inspection Requirements for Electric Distribution and Transmission Facilities, Section III.D, please find attached Bear Valley Electric Service 2014 Annual Report for the year 2013.

Sincerely,

Harry Scarborough
Director
Bear Valley Electric Service
A Division of Golden State Water Company

Enclosure: BVES GO 165 Inspection Report – 2013
BVES Officer Verification

Bear Valley Electric Service (BVES)

BVES GO 165 Inspection Report - 2013

Type of Inspections	Completed	Outstanding	Units
Patrols	19	0	Circuits
OH Detailed	1619	0	Poles
UG Detailed	279	0	Circuits
Wood Pole Intrusive	0	0	Poles

Notes:

OH Detailed includes both Distribution and Transmission Poles

21 UG circuits/3 yr cycle

9500 poles total/ 10 yrs= 950 poles/yr Intrusive Schedule

VERIFICATION

I, the undersigned say: I am an officer of Golden State Water Company, a corporation, DBA Bear Valley Electric Service, and am authorized to make this verification for and on behalf of said corporation, and I make this verification for the following reason: I have read the foregoing:

**BEAR VALLEY ELECTRIC SERVICE
GENERAL ORDER 165 ANNUAL INSPECTION REPORT
FOR 2013 SUBMITTED PURSUANT TO CPUC
DECISION NO. 97-03-070, DECISION NO. 09-08-029, AND
DECISION NO. 12-01-032**

And I am informed and believe matters therein are true and on that ground I allege that the matters stated therein are true. I declare under penalty of perjury that the foregoing is true and correct.

Executed in San Dimas, California, this 24th day of June, 2014.



Keith Switzer
Vice President Regulatory Affairs

Golden State Water Company
DBA Bear Valley Electric Service
630 East Foothill Blvd
San Dimas, California 91773