

**BEFORE THE PUBLIC UTILITIES COMMISSION
OF THE STATE OF CALIFORNIA**

Order Instituting Rulemaking to Revise and Clarify Commission Regulations Relating to the Safety of Electric Utility and Communications Infrastructure Provider Facilities.

Rulemaking 08-11-005
(Filed November 6, 2008)

**SOUTHERN CALIFORNIA GAS COMPANY'S (U904G) GENERAL ORDER 165
COMPLIANCE MAINTENANCE PROGRAM REPORT FOR 2013 SUBMITTED
PURSUANT TO CPUC DECISION NO. 12-01-032**

ALBERT GARCIA

Attorney for:

SOUTHERN CALIFORNIA GAS COMPANY

555 West Fifth Street, GT14E7

Los Angeles, CA 90013-1034

Telephone: (213) 244-2958

Facsimile: (213) 629-9620

Email: agarcia6@semprautilities.com

July 1, 2014

EXHIBIT 1



GENERAL ORDER 165

COMPLIANCE MAINTENANCE PROGRAM

REPORT FOR

2013

Introduction

In compliance with the California Public Utilities Commission (CPUC) Decision (D.) 12-01-032 and General Order (GO) 165, Southern California Gas Company (SoCalGas) submits its second annual GO 165 Compliance Maintenance Program Report. D.12-01-032 extended the inspection and reporting requirements of GO 165 to electric distribution facilities owned by SoCalGas.

The Compliance Maintenance Program at SoCalGas is administered by the operating groups with electrical distribution systems at their facilities. The required inspections are performed in accordance with GO 165 requirements, and any necessary follow-up maintenance work to correct deficiencies is completed by licensed electrical contractors.

This report contains the results of SoCalGas' inspection and maintenance of electric distribution facilities covering the period from January 1, 2013 through December 31, 2013.

Summary of the 2013 Year-end Report

In 2013, SoCalGas performed over 400 inspections of its electrical distribution system in accordance with the requirements of GO 165. In the event SoCalGas finds electrical distribution equipment that requires maintenance or replacement in accordance with GO 165, SoCalGas' goal is to undertake that work within 12 months from the date of inspection. Equipment that may pose a hazard to the public and/or to operating personnel is repaired within a shorter timeframe, based upon the severity of the problem. Equipment involving matters or issues outside of SoCalGas' control, such as those involving private property owners or environmental issues, may require more time to resolve. In this case, work that may be unresolved and nearing their 12-month due date would be labeled "Deferred". Work that is deferred is tracked by the operating group and is monitored until the work can be performed. SoCalGas' inspection activities resulted in no deferred work in 2013.

SOCALGAS GENERAL ORDER 165

2013 MAINTENANCE REPORT

Type of Inspection by Facility	Facilities Due	Facilities Outstanding
Overhead Detailed	436	0
Underground Detailed	0	0
Wood Pole Intrusive	0	0
Type of Inspection by Grid	Grids Due	Facilities Outstanding
Patrols	14	0

SoCalGas' Electric Distribution Systems and Inspections

SoCalGas has a limited number of electric distribution systems which are located at our four underground natural gas storage facilities and two natural gas compressor stations. These facilities all support SoCalGas' primary mission—safe and reliable delivery of natural gas. SoCalGas' electric distribution systems generally consist of power poles and distribution lines that distribute electricity within each facility. When new electrical distribution equipment is added, it is regarded as “inspected” at the date of installation. The new piece of equipment is then scheduled for inspection during the next applicable inspection cycle. All equipment in the current inventory is scheduled for inspection at the required interval.

All equipment on a given structure is inspected at the same time and the inspection record is documented in the structure record. The maintenance goals for the year historically have been determined by the system-wide counts of facilities in each inspection type, divided by the number of years in the cycle length. This practice created inspection cycles setting the maintenance goals for the year. The goals for the year are determined by the last inspection date. SoCalGas' maintenance cycles are designed to meet or exceed the GO 165 requirements. The following section describes SoCalGas' maintenance cycles.

Description of Major SoCalGas GO-165 Cycles

OVERHEAD VISUAL

- OHVI (Overhead Visual, 5-year)

This cycle consists of a detailed inspection of all distribution power poles, pole-mounted facilities with primary and secondary conductors, and distribution equipment on transmission poles. These inspections identify conditions that are out of compliance with GO 95. This is a five-year cycle.

ABOVE GROUND 5 (INTERNAL AND EXTERNAL INSPECTIONS)

This cycle consists of Above Ground Dead-front (AGE) and Above Ground Live-front (AGI) detailed inspections.

- AGE (Above Ground Dead-front, 5-year)

This cycle consists of a detailed external and internal inspection of dead-front pad-mounted facilities to identify conditions out of compliance with GO 128. This is a five-year inspection cycle. Originally, the AGE cycle only required an external inspection; however, changes in 1999 modified this requirement to include an internal inspection. The cycle is still named AGE to separate the dead-front equipment data from live-front equipment data.

- AGI (Above Ground Live-front, 5-year)

This cycle consists of a detailed external and internal inspection of live-front pad-mounted facilities to identify conditions out of compliance with GO 128. This is a five-year inspection cycle.

SUBSURFACE, WITH EQUIPMENT

- SS3 (Subsurface, 3-year)

This cycle consists of a detailed inspection of subsurface structures (manholes, vaults, primary hand-holes and subsurface enclosures) containing distribution equipment. Thus, structures with only cable taps, splices or pass-throughs are excluded as they are not required by GO 165. The SS3 cycle consists of a detailed inspection of these facilities to identify conditions out of compliance with GO 128. This is a three-year inspection cycle.

WOOD POLE INTEGRITY

- Pole (10/20 year)

These inspections are performed on a 10-year cycle. Each pole is inspected visually, and if conditions warrant, intrusively. Any pole 15 years of age or older is inspected intrusively. The intrusive inspection is normally an excavation around the pole base and/or a sound and bore of the pole at ground line. Treatment is applied at this time in the form of ground line pastes and/or internal pastes. The 10-year cycle fulfills the requirements of GO 165, which are: (1) all poles over 15 years of age are intrusively inspected within 10 years; and (2) all poles which previously passed intrusive inspection are to be inspected intrusively again on a 20-year cycle.

The wood pole integrity inspections are currently performed by a SoCalGas contractor who also applies wood preservative treatments and installs mechanical reinforcements (C-truss). The type of treatment is dependent upon the age of the pole, the individual inspection history, and the overall condition of the structure.

If a pole that appears to need replacement is found on a compliance inspection, SoCalGas' contractor for wood pole integrity inspections may bore into the pole to determine if it needs reinforcement or replacement based on the remaining shell thickness. The choice to restore a pole rather than replace the pole is based on the strength of the pole (measured by remaining shell thickness). SoCalGas follows SDG&E's Transmission Engineering and Electric Distribution Standards Specification for Inspection, Treatment and Reinforcement of In-Service Wood Poles (Specification NO. TE-0108 and Specification NO. 337), which specifies the criteria for the rejection of a pole. It also addresses a pole's suitability for C-truss based on the remaining shell thickness for various lengths of pole. If a pole does not have sufficient shell thickness for C-truss, it is rejected and replaced.

PATROL, URBAN

- Patrol 1 (urban patrol, 1 year)

The purpose of the urban patrol is to identify obvious structural problems and hazards. This cycle consists of a simple-visual inspection of every applicable overhead, aboveground and underground facilities deemed urban area. Under agreement of interpretation with the CPUC, "urban" is defined as incorporated areas (GO 165 defined "urban" as those areas with 1,000 persons or more per square mile). GO 165 defines a "patrol" as "a simple visual inspection, of applicable utility equipment and structures, that is designed to identify obvious structural problems and hazards." When Patrols have been completed, any identified structural problems and hazards are recorded in SoCalGas tracking system.

PATROL, RURAL

- Patrol 2 (rural patrol, 2 year)

The purpose of the rural patrol is to identify obvious structural problems and hazards. This cycle consists of a simple visual inspection of every applicable overhead, aboveground and underground. Under agreement of interpretation with the CPUC, "rural" is defined as unincorporated areas (GO 165 defined "rural" as those areas with less than 1,000 persons per square mile). GO 165 defines a "patrol" as a "simple visual inspection, of applicable utility equipment and structures, that is designed to identify obvious structural problems and hazards." When Patrols have been completed, any identified structural problems and hazards are recorded in SoCalGas tracking system. However, SoCalGas performs annual patrols on all its power poles.

SoCalGas GO-165
INSPECTION CYCLES

SoCalGas System
Inspection Cycles
(Maximum intervals
in years)

	PATROL		DETAILED		INTRUSIVE	
	Urban	Rural	Urban	Rural	Urban	Rural
Transformers						
Overhead	Patrol1	Patrol2*	OHVI 5	OHVI 5		
Underground (Subsurface)	Patrol1	Patrol2*	SS 3	SS 3		
Pad Mounted (live front)	Patrol1	Patrol2*	AGI 5	AGI 5		
Pad Mounted (dead front)	Patrol1	Patrol2*	AGE 5	AGE 5		
Switching/Protective Devices						
Overhead	Patrol1	Patrol2*	OHVI 5	OHVI 5		
Underground (Subsurface)	Patrol1	Patrol2*	SS 3	SS 3		
Pad Mounted (live front)	Patrol1	Patrol2*	AGI 5	AGI 5		
Pad Mounted (dead front)	Patrol1	Patrol2*	AGI 5	AGI 5		
Regulators/Capacitors						
Overhead	Patrol1	Patrol2*	OHVI 5	OHVI 5		
Underground (Subsurface)	Patrol1	Patrol2*	SS 3	SS 3		
Pad Mounted (live front)	Patrol1	Patrol2*	AGI 5	AGI 5		
Pad Mounted (dead front)	Patrol1	Patrol2*	AGE 5	AGE 5		
Overhead Conductors and Cables	Patrol1	Patrol2*	OHVI 5	OHVI 5		
Wood Poles under 15 years	Patrol1	Patrol2	X	X	X	X
Wood Poles over 15 years which have not been subject to intrusive inspection	Patrol1	Patrol2	X	X	Wood Pole Intrusive 10	Wood Pole Intrusive 10
Wood Poles which passed intrusive inspection					Wood Pole Intrusive 20	Wood Pole Intrusive 20

*Patrol inspections are conducted once per year as noted on page 8.

OFFICER VERIFICATION

I, Douglas M. Schneider, declare the following:

I am an officer of Southern California Gas Company and am authorized to make this verification on its behalf. I am informed and believe that the matters stated in the foregoing 2013 General Order 165 Compliance Maintenance Program Report are true to my own knowledge, except as to matters which are therein stated on information and belief, and as to those matters I believe them to be true.

I declare under penalty of perjury under the laws of the State of California that the foregoing is true and correct. Executed this 1st day of July, 2014 in Los Angeles, California.

/s/ Douglas M. Schneider

Douglas M. Schneider
Vice President,
Gas Engineering and System Integrity
Southern California Gas Company