

# ANZA ELECTRIC COOPERATIVE, Inc.

A Touchstone Energy® Cooperative 

Phone: (951) 763-4333

P.O. Box 391909 (58470 Highway 371) Anza, California 92539-1909

FAX: (951) 763-5297

May 4, 2015

Raymond Cho  
Safety and Enforcement Division  
California Public Utilities Commission  
505 Van Ness Ave  
San Francisco, CA 94102

Re: General Order 165 Annual Report for Year 2014

Mr. Cho

Anza Electric Cooperative Inc. has its entire system broken into map grids. Anza has 218 map grids containing all facilities associated with our GIS Mapping System. The units below are individual map grids.

|                     | <u>Due</u> | <u>Outstanding</u> |  |
|---------------------|------------|--------------------|--|
| Patrols             | 218        | 0                  | Anza completed patrolling all of the required map grids for year 2014  |
| OH Detailed         | 0          | 0                  | All map grids have had a "Detailed" inspection between 2010-2013. Detailed Inspections will resume in 2015.  |
| UG Detailed         | 0          | 0                  | All map grids have had a "Detailed" inspection between 2010-2013. Detailed Inspections will resume in 2015.  |
| Wood Pole Intrusive | 0          | 0                  | Anza has had all of its poles intrusive tested between 2003 -2011. Anza has currently started intrusive testing the 2003 poles to satisfy Rural Utilities Services (RUS) pole testing requirements of 10% annually. For year 2014 Anza has tested 838 poles and YTD for 2015, 484 poles. |

Please feel free to contact me directly if you have any questions or need more documentation.

Sincerely



**Eli Higgins**

Operations Manager  
Anza Electric Cooperative Inc.  
P.O. Box 391909 Anza, CA 92539  
(951) 763-4333  
elih@anzaelectric.org