



July 16, 2015

Ben Brinkman
California Public Utilities Commission
Safety Enforcement Division
505 Van Ness Avenue
San Francisco, CA 94102-3298

Dear Mr. Brinkman:

In compliance with General Order 165, Inspection Requirements for Electric Distribution and Transmission Facilities, Section III.D, please find attached Bear Valley Electric Service 2015 Annual Report for the year 2014.

Sincerely,

Harry Scarborough
Director
Bear Valley Electric Service
A Division of Golden State Water Company

Enclosure: BVES GO 165 Inspection Report - 2014

Bear Valley Electric Service (BVES)

BVES GO 165 INSPECTION REPORT – 2014

Type of Inspections	Completed	Outstanding	Units
Patrols	5	0	Circuits
OH Detailed	649	0	Poles
UG Detailed	0	0	Circuits
Wood Pole Intrusive	1813	0	Poles

Notes:

OH Detailed includes both Distribution and Transmission poles

1 UG circuit/3 year cycle (Georgia circuit)

All other UG circuits qualify for the 5 year Padmount category (no equipment underground)

9500 poles total/ 10 years = 950 poles per year as an Intrusive Schedule baseline


VERIFICATION

I, the undersigned say: I am an officer of Golden State Water Company, a corporation, DBA Bear Valley Electric Service, and am authorized to make this verification for and on behalf of said corporation, and I make this verification for the following reason: I have read the foregoing:

BEAR VALLEY ELECTRIC SERVICE GENERAL
ORDER 165 ANNUAL INSPECTION REPORT
FOR 2014 SUBMITTED PURSUANT TO CPUC
DECISION NO. 97-03-070, DECISION NO. 09-08-029,
AND DECISION NO. 12-01-032

And I am informed and believe matters therein are true and on that ground I allege that the matters stated therein are true. I declare under penalty of perjury that the foregoing is true and correct.

Executed in San Dimas, California, this 16th day of July, 2015.


Keith Switzer
Vice President Regulatory Affairs

Golden State Water Company
DBA Bear Valley Electric Service
630 East Foothill Blvd
San Dimas, California 91773