



Valley Electric Association, Inc.

A Touchstone Energy® Cooperative



June 15, 2015

Raymond Cho
Safety and Enforcement Division
California Public Utilities Commission
505 Van Ness Ave.
San Francisco, CA 94102

Re: Valley Electric Association, Inc. General Order 165 Annual Report for 2014

Dear Mr. Cho:

Pursuant to Section III.D of General Order 165, please find attached the annual report for Valley Electric Association, Inc. regarding its 2014 inspections. Note that a detailed inspection was completed on 100% of Valley Electric's system in California during the prior reporting period. As a result, no patrol or detailed inspections were due in the current reporting period.

If you require additional information, please call me at (775) 727-2161.

Respectfully,

A handwritten signature in black ink, appearing to read "John Perra".

John Perra
Manager of Operations
Valley Electric Association, Inc.



Valley Electric Association - Annual GO 165 Report

Reporting Period 7/1/14 - 6/30/15

	Quantity	Patrol Inspections			Detailed Inspections		
		Due	Completed	Outstanding	Due	Completed	Outstanding
Transformers (each)	101						
Overhead	98	0	0	0	0	0	0
Padmounted	3	0	0	0	0	0	0
Switching / Protective Devices (each)	120						
Overhead	120	0	0	0	0	0	0
Padmounted	0	n/a	n/a	n/a	n/a	n/a	n/a
Regulators / Capacitors (each)	1						
Overhead	1	0	0	0	0	0	0
Padmounted	0	n/a	n/a	n/a	n/a	n/a	n/a
Overhead Conductor and Cables (mi)	18.8						
Overhead Conductor and Cables	18.8	0	0	0	0	0	0
Streetlighting (each)	2						
Streetlights	2	0	0	0	0	0	0
Wood Poles (each)	318						
Wood Poles	318	0	0	0	n/a	n/a	n/a

- Notes
- 1) Valley Electric Association's service territories in California are considered rural.
 (Population density based on U.S. Bureau of the Census 2010 data)
 Mono County 4.7 persons/sq. mi.
 Inyo County 1.8 persons/sq. mi.
 - 2) Inspection frequency: Patrol = 2 years, Detailed = 5 years (VEA has no underground facilities).



Valley Electric Association - Annual GO 165 Report

Reporting Period 7/1/14 - 6/30/15

	Quantity	Intrusive Inspections		
		Due	Completed	Outstanding
Wood Pole Intrusive Inspection	318			
Wood Poles < 15 years	0	n/a	n/a	n/a
Wood Poles > 15 years w/o intrusive	0	0	0	0
Wood Poles which passed intrusive	318	0	0	0