

**BEFORE THE PUBLIC UTILITIES COMMISSION  
OF THE STATE OF CALIFORNIA**

**In the Matter of the Application of SOUTHERN  
CALIFORNIA EDISON COMPANY (U338E) for a  
Permit to Construct Electrical Facilities: Colorado  
River Substation Expansion Project.**

**Application 10-11-005  
(Filed November 3, 2010)**

**CALIFORNIANS FOR RENEWABLE ENERGY'S INITIAL COMMENTS  
ON SUPPLEMENTAL DRAFT ENVIRONMENTAL IMPACT REPORT  
FOR COLORADO RIVER SUBSTATION EXPANSION  
(California SCH 2005101104)**

Date: April 8, 2011.

Submitted by: BRIGGS LAW CORPORATION [file: 1190.10]  
Cory J. Briggs  
99 East "C" Street, Suite 111  
Upland, CA 91786  
Telephone: 909-949-7115  
Facsimile: 909-949-7121  
E-mail: [service@briggslawcorp.com](mailto:service@briggslawcorp.com)

Attorneys for Californians for Renewable Energy

CALifornians for Renewable Energy now respectfully submits the following initial comments on the supplemental draft environmental impact report for the Colorado River Substation Expansion (California SCH 2005101104). The initial comments are from Bill Powers, P.E., and Robert M. Sarvey and are attached hereto as Exhibits 1 and 2, respectively.

Date: April 8, 2011.

Submitted by: BRIGGS LAW CORPORATION

By: s/ Cory J. Briggs  
Cory J. Briggs

## **VERIFICATION**

I am the attorney for CALifornians for Renewable Energy (“CARE”) in this proceeding. My client is absent from the County of San Bernardino, California, where my office is located. I make this verification on behalf of my client for that reason.

The factual statements in the foregoing document and attachments hereto are true of my own knowledge or based on information and belief, and as to those matters I believe them to be true.

I declare under penalty of perjury under the laws of the State of California that the foregoing is true and correct.

Date: April 8, 2011.

s/ Cory J. Briggs

**CALIFORNIANS FOR RENEWABLE ENERGY'S INITIAL COMMENTS  
ON SUPPLEMENTAL DRAFT ENVIRONMENTAL IMPACT REPORT  
FOR COLORADO RIVER SUBSTATION EXPANSION**  
(California SCH 2005101104)

Exhibit 1

**ON BEHALF OF CALIFORNIANS FOR RENEWABLE ENERGY**

**COMMENTS OF BILL POWERS, P.E.**

**ON DEVERS TO PALO VERDE 2 TRANSMISSION LINE DRAFT SUPPLEMENTAL  
EIR**

April 8, 2011

Bill Powers, P.E.  
Powers Engineering  
4452 Park Blvd., Suite 209  
San Diego, CA 92116  
Direct: 619-295-2072  
Fax: 619-295-2073  
[bpowers@powersengineering.com](mailto:bpowers@powersengineering.com)

1 **I. Introduction**

2 I am a registered professional mechanical engineer in California with over 25 years of  
3 experience in the energy and environmental fields. I have permitted five 50 MW peaking  
4 turbine installations in California, as well as numerous gas turbine, microturbine, and  
5 engine cogeneration plants around the state. I organized conferences on permitting gas  
6 turbine power plants (2001) and dry cooling systems for power plants (2002) as chair of the  
7 San Diego Chapter of the Air & Waste Management Association. I am the author of the  
8 October 2007 strategic energy plan for the San Diego region titled “San Diego Smart  
9 Energy 2020.” The plan uses the state’s Energy Action Plan as the framework for  
10 accelerated introduction of local renewable and cogeneration distributed resources to  
11 reduce greenhouse gas emissions from power generation in the San Diego region by 50  
12 percent by 2020. I am the author of several articles in Natural Gas & Electricity Journal on  
13 use of large-scale distributed solar PV in urban areas as a cost-effective substitute for new  
14 gas turbine peaking capacity and large, remote solar power plants.

15  
16 My comments address: 1) the inadequate analysis of the distributed photovoltaic (PV)  
17 alternative to Devers to Palo Verde 2 Transmission Project (DPV2) project in the February  
18 2011 DPV2 Draft Supplemental EIR and 2) the proposed Westlands Water District  
19 Competitive Renewable Energy Zone, located on retired farmland in the Central Valley  
20 and served by 5,000 MW of existing transmission capacity, as a superior location for the  
21 1,250 MW of solar capacity that the DPV2 transmission line is proposed to serve.

22  
23 The DPV2 Draft Supplemental EIR makes no pretense of evaluating a non-transmission  
24 alternative to DPV2. The Draft Supplemental EIR simply states (p. C-16):

25  
26 “The No Project Alternative scenario is the circumstance under which the Proposed Project  
27 does not proceed. (CEQA Guidelines §15126.6(e)(3)(B).) The analysis of the No Project  
28 Alternative compares the environmental effects of the property remaining in its existing  
29 state, against environmental effects which would occur if the Proposed Project is approved.

30 Disapproval of the Proposed Project would likely lead SCE and/or the solar project  
31 developers to pursue other actions to achieve the objectives of the Proposed Project. The

1 events or actions that are reasonably expected to occur in the foreseeable future without the  
2 CRS expansion include the following:

3  
4 • The approved 500 kV transmission from Colorado River Substation to Devers  
5 Substation would be constructed as already approved by the CPUC (and as anticipated to  
6 be approved by the BLM).

7  
8 • The approved solar power projects (1,000 MW Blythe Solar Power Project - BSPP and  
9 250 MW Genesis Solar Energy Project - GSEP) would have substantial delays in their  
10 online dates because their projects would have to be redesigned and the changes re-  
11 evaluated under CEQA and NEPA due to the need for substantially larger and more  
12 inefficient infrastructure. Specifically:

13  
14 • The BSPP project would likely have to be redesigned to incorporate a larger onsite  
15 substation and a 500 kV gentie line, rather than a 230 kV gentie line to the expanded CRS  
16 substation, in order for BSPP to interconnect to the regional transmission system. The  
17 additional cost of this larger substation and the delays associated with CEQA and NEPA  
18 review of the changes may affect the financial viability of the project and its ability to  
19 qualify for financing.

20  
21 • The approved GSEP project would use an existing 230 kV transmission line along  
22 much of the route between the Genesis solar project site and the CRS. In the No Project  
23 scenario, both a larger onsite substation and a new, additional 500 kV line would have to be  
24 installed (rather than the current approved plan, which would require only installation of a  
25 second circuit onto existing 230 kV towers).”

26  
27 There is no analysis of non-transmission alternatives in the DPV2 Draft Supplemental EIR.  
28 The construction of BSPP and GSEP are assumed to be inevitable, despite both projects  
29 being subject to National Historic Preservation Act Section 106 lawsuits. In contrast, the  
30 Draft and October 2008 Final EIR/EIS prepared by the California Public Utilities  
31 Commission (CPUC) and Bureau of Land Management (BLM) for San Diego Gas &  
32 Electric’s (SDG&E) proposed Sunrise Powerlink transmission line includes voluminous

1 analysis of multiple non-transmission alternatives to the proposed project. See the complete  
2 Sunrise Powerlink Final EIS/EIS at:  
3 <http://www.cpuc.ca.gov/environment/info/aspen/sunrise/toc-feir.htm>.

4  
5 The conclusion of the CPUC/BLM Final EIR/EIS for the Sunrise Powerlink was that either  
6 of the two non-transmission in-basin alternatives was environmentally superior to the  
7 proposed project or any transmission alternative to the proposed project. The DPV2 Draft  
8 Supplemental EIR avoids a similar conclusion by failing to analyze any non-transmission  
9 alternative to DPV2.

10  
11 The failure of the DPV2 Draft Supplemental EIR to analyze non-transmission alternatives  
12 is a substantial omission. SCE is already constructing a 500 MW distributed PV project.  
13 Distributed PV is clearly a viable non-transmission alternative. The major controversy  
14 surrounding both BSPP and GSEP is the use of undeveloped public lands for these  
15 projects. There are hundreds of thousands of acres of retired agricultural lands and  
16 brownfields in the Mojave Desert and Central Valley located on or near existing  
17 transmission lines. Comments by Powers Engineering on the CEC's June 2010 Revised  
18 Staff Assessment (RSA) for the GSEP are used as a case study in this comment letter to  
19 demonstrate the cost and siting advantages of non-transmission alternatives to DPV2.

## 20 21 **II. Rooftop PV Is at the Top of the Energy Action Plan Loading Order**

22 The California Energy Commission (CEC), in discussing the conservation and demand-  
23 side management alternative to solar thermal projects in the Mojave Desert such as ISEGS  
24 and GSEP, that cost-effective energy efficiency is the resource of first choice in meeting  
25 California's energy needs (p. B.2-84, GSEP Revised Staff Assessment - RSA):

26  
27 "Conservation and demand-side management consist of a variety of approaches to  
28 reduce of electricity use, including energy efficiency and conservation, building and  
29 appliance standards, and load management and fuel substitution. In 2005 the Energy  
30 Commission and CPUC's Energy Action Plan II declared cost effective energy efficiency  
31 as the resource of first choice for meeting California's energy needs."

32



1 The CEC and the CPUC developed the “Energy Action Plan” in 2003 to guide strategic  
2 energy decisionmaking in California. The Energy Action Plan establishes the energy  
3 resource “loading order,” or priority list that defines how California’s energy needs are to  
4 be met. Energy Action Plan I was published in May 2003.<sup>1</sup> Energy Action Plan I describes  
5 the loading order in the following manner (p. 4):

6  
7 “The Action Plan envisions a “loading order” of energy resources that will guide  
8 decisions made by the agencies jointly and singly. First, the agencies want to  
9 optimize all strategies for increasing conservation and energy efficiency to minimize  
10 increases in electricity and natural gas demand. Second, recognizing that new  
11 generation is both necessary and desirable, the agencies would like to see these  
12 needs met first by renewable energy resources and distributed generation. Third,  
13 because the preferred resources require both sufficient investment and adequate  
14 time to “get to scale,” the agencies also will support additional clean, fossil fuel,  
15 central-station generation. Simultaneously, the agencies intend to improve the bulk  
16 electricity transmission grid and distribution facility infrastructure to support growing  
17 demand centers and the interconnection of new generation.”

18  
19 Energy Action Plan I, Under “Optimize Energy Conservation and Resource Efficiency,”  
20 states (p. 5):

21  
22 “Incorporate distributed generation or renewable technologies into energy efficiency  
23 standards for new building construction.”

24  
25 Energy Action Plan I identifies rooftop PV as a de facto energy efficiency measure with  
26 this statement. As noted in the GSEP RSA (p. B.2-84), energy efficiency is at the top of the  
27 loading order. Energy Action Plan I also states, Under “Promote Customer and Utility-  
28 Owned Distributed Generation,” (p. 7):

29  
30 “Distributed generation is an important local resource that can enhance reliability and  
31 provide high quality power, without compromising environmental quality. The state is

---

<sup>1</sup> Energy Action Plan I: [http://www.energy.ca.gov/energy\\_action\\_plan/2003-05-08\\_ACTION\\_PLAN.PDF](http://www.energy.ca.gov/energy_action_plan/2003-05-08_ACTION_PLAN.PDF)

1 promoting and encouraging clean and renewable customer and utility owned distributed  
2 generation as a key component of its energy system. Clean distributed generation should  
3 enhance the state’s environmental goals. This determined and aggressive commitment to  
4 efficient, clean and renewable energy resources will provide vision and leadership to others  
5 seeking to enhance environmental quality and moderate energy sector impacts on climate  
6 change. Such resources, by their characteristics, are virtually guaranteed to serve California  
7 load. With proper inducements distributed generation will become economic.

- 8
- 9 • Promote clean, small generation resources located at load centers.
- 10 • Determine system benefits of distributed generation and related costs.
- 11 • Develop standards so that renewable distributed generation may participate in the  
12 Renewable Portfolio Standard program.”
- 13

14 Energy Action Plan I prioritizes rooftop PV as the preferable renewable resource, but  
15 indicates obliquely that it is costly and that in any case distributed PV is not eligible to  
16 participate in the Renewable Portfolio Standard (RPS) program. Therefore investor-owned  
17 utilities have no incentive to develop distributed PV resources. Since Energy Action Plan I  
18 was approved in 2003, PV cost has dropped dramatically. Commercial distributed PV is  
19 half the cost it was in 2003 and costs continue to drop. Residential PV is following quickly  
20 behind. Distributed PV is also now eligible for the RPS program.<sup>2</sup>

21

22 Energy Action Plan II was adopted in September 2005.<sup>3</sup> The purpose of Energy Action  
23 Plan II is stated as (p. 1): “EAP II is intended to look forward to the actions needed in  
24 California over the next few years, and to refine and strengthen the foundation prepared by  
25 EAP I.” Energy Action Plan II reaffirms the loading order stating (p. 2):

26

27 “EAP II continues the strong support for the loading order – endorsed by Governor  
28 Schwarzenegger – that describes the priority sequence for actions to address increasing  
29 energy needs. The loading order identifies energy efficiency and demand response as

---

<sup>2</sup> CPUC Press Release – Docket A.08-03-015, *CPUC Approves Edison Solar Roof Program*, June 18, 2009. “The energy generated from the project will be used to serve Edison’s retail customers and the output from these facilities will be counted towards Edison’s RPS goals.”

<sup>3</sup> Energy Action Plan II: [http://www.energy.ca.gov/energy\\_action\\_plan/2005-09-21\\_EAP2\\_FINAL.PDF](http://www.energy.ca.gov/energy_action_plan/2005-09-21_EAP2_FINAL.PDF)

1 the State’s preferred means of meeting growing energy needs. After cost-effective  
2 efficiency and demand response, we rely on renewable sources of power and distributed  
3 generation, such as combined heat and power applications. To the extent efficiency,  
4 demand response, renewable resources, and distributed generation are unable to satisfy  
5 increasing energy and capacity needs, we support clean and efficient fossil-fired  
6 generation.”

7  
8 The CEC’s *2009 Integrated Energy Policy Report (IEPR) – Final Committee Report*  
9 (December 2009), underscores the integration of building PV as a critical component of  
10 “net zero” energy use targets for new residential and commercial construction, under the  
11 heading “Energy Efficiency and the Environment,” explaining:<sup>4</sup>

12  
13 “With the focus on reducing GHG emissions in the electricity sector, energy efficiency  
14 takes center stage as a zero emissions strategy. One of the primary strategies to reduce  
15 GHG emissions through energy efficiency is the concept of zero net energy buildings. In  
16 the 2007 IEPR, the Energy Commission recommended increasing the efficiency standards  
17 for buildings so that, when combined with on-site generation, newly constructed buildings  
18 could be zero net energy by 2020 for residences and by 2030 for commercial buildings.

19  
20 A zero net energy building merges highly energy efficient building construction and state-  
21 of-the-art appliances and lighting systems to reduce a building’s load and peak  
22 requirements and includes on-site renewable energy such as solar PV to meet remaining  
23 energy needs. The result is a grid-connected building that draws energy from, and feeds  
24 surplus energy to, the grid. The goal is for the building to use net zero energy over the  
25 year.”

26  
27 The GSEP RSA acknowledges the state’s commitment to net zero residential and  
28 commercial buildings, stating (RSA, p. B.2-84):

29  
30 “The CPUC, with support from the Governor’s Office, the Energy Commission, and the  
31 California Air Resources Board, among others, adopted the California Long-Term

---

<sup>4</sup> CEC, *2009 Integrated Energy Policy Report (IEPR) – Final Committee Report*, December 2009, p. 56.

1 Energy Efficiency Strategy Plan for 2009 to 2020 in September 2008 (CPUC 2008). The  
2 plan is a framework for all sectors in California including industry, agriculture, large and  
3 small businesses, and households. Major goals of the plan include:

- 4
- 5 • All new residential construction will be zero net energy by 2020;
- 6 • All new commercial construction will be zero net energy by 2030;
- 7 • Heating, ventilation, and air conditioning industries will be re-shaped to deliver  
8 maximum performance systems;
- 9 • Eligible low-income customers will be able to participate in the Low Income  
10 Energy Efficiency program and will be provided with cost-effective energy efficiency  
11 measures in their residences by 2020.”
- 12

13 The GSEP RSA is flawed in its failure to identify rooftop PV as a higher priority in the  
14 Energy Action Plan loading order, and California’s long-term energy efficiency strategy  
15 plan, than utility-scale remote solar resources like GSEP. Rooftop (or parking lot)  
16 distributed PV is an integral component of the long-term energy efficiency strategy plan  
17 adopted by the CPUC in 2008. Energy Action Plan II declares cost-effective energy  
18 efficiency as the resource of first choice for meeting California’s energy needs. The CEC  
19 rejection of distributed PV as a superior alternative to the proposed GSEP solar thermal  
20 projects ignores the integral role of distributed PV in the CEC’s own definition of energy  
21 efficiency and net zero buildings in the 2009 IEPR.

### 22

23 **III. GSEP RSA Rationale for Eliminating Rooftop PV is Flawed**

24 The GSEP RSA correctly describes that a distributed rooftop PV alternative has essentially  
25 no environmental impact, stating (p. B.2-68):

- 26
- 27 • Distributed solar PV is assumed to be located on already existing structures or  
28 disturbed areas so little to no new ground disturbance would be required and there would  
29 be few associated biological impacts.
- 30
- 31 • Relatively minimal maintenance and washing of the solar panels would be required.
- 32

1 • Because most PV panels are black to absorb sun, rather than mirrored to reflect it,  
2 glare would be minimal relative to reflective technologies (like GSEP)

3  
4 • Additionally, the distributed solar PV alternative would not require the additional  
5 operational components, such as dry-cooling towers, substations, transmission  
6 interconnection, maintenance and operation facilities with corresponding visual impacts.

7  
8 The GSEP RSA then eliminates distributed PV, citing a number of reasons why achieving  
9 250 MW of distributed PV is not a feasible substitute for GSEP (RSA, p. B.2-69):

10  
11 • Would require accelerated deployment of distributed PV at more than double the  
12 historic rate of deployment under the California Solar Initiative.

13  
14 • Would require lower PV cost - distributed PV is higher cost than central station  
15 solar thermal.

16  
17 • Integrating large amounts of distributed PV on distribution systems throughout  
18 California presents challenges – will require development of a new transparent distribution  
19 planning framework.

20  
21 Each of these justifications for elimination of distributed PV is flawed, as explained in the  
22 following paragraphs.

23  
24 **A. Distributed PV Is Already Being Deployed at a Much Faster Rate in California**  
25 **than Central Station Solar Thermal**

26 The GSEP RSA notes that more than 540 MW of distributed PV was in operation in  
27 California through May 2009, and that the PV installation rate doubled between 2008 and  
28 2007. California has approximately 360 MW of installed solar thermal capacity as of June  
29 2010. With the exception of the 5 MW eSolar power tower demonstration project that came

1 | online in 2009 (p. B.2-68), all of this solar thermal capacity was installed between 1984  
2 | and 1990.<sup>5</sup>

3 |  
4 | The GSEP RSA correctly describes that both SCE and PG&E, the two largest investor-  
5 | owned utilities (IOU) in California, are constructing large distributed PV projects (p. B.2-  
6 | 67). SDG&E has a much smaller distributed PV project in development. The 500 MW SCE  
7 | urban PV project was approved by the CPUC in June 2009. The 500 MW PG&E  
8 | distributed PV project was approved by the CPUC in April 2010. These projects are RPS-  
9 | eligible and will consist of a 250 MW IOU-owned component and a 250 MW third-party  
10 | component. The power purchase agreement (PPA) between GSEP and PG&E is same type  
11 | of contract mechanism that will be used by SCE and PG&E to contract for the 250 MW  
12 | third-party component of their respective distributed PV projects.

13 |  
14 | Progress in distributed PV installation rates under the California Solar Initiative (CSI)  
15 | program provides no insight into the ability of the solar industry to carry-out multiple  
16 | large-scale distributed PV projects simultaneously, in the range of 250 to 500 MW each, in  
17 | California. The CSI program is not the vehicle that will be used to build these projects.  
18 | These projects will be built under long-term PPAs between the distributed PV project  
19 | developer and a utility within the framework of the RPS program.

20 |  
21 | An example is the PPA between PG&E and Sempra Generation for 10 MW of fixed thin-  
22 | film PV in Nevada.<sup>6</sup> Sempra Resources is the holding company that owns both Sempra  
23 | Generation and SDG&E. The PG&E/Sempra PPA is a technology-differentiated renewable  
24 | energy contract at a price incrementally higher than the market price referent (MPR) to  
25 | assure that the project developer, Sempra Generation, makes a reasonable return on its  
26 | investment. The contract is in effect the equivalent of a technology differentiated feed-in  
27 | tariff for solar power. No incentives beyond the federal investment tax credit and  
28 | accelerated depreciation available to any solar energy project were necessary. No  
29 | incentives beyond those already available would be necessary to build 250 MW of  
30 | distributed PV under a long-term PPA to substitute for GSEP.

---

<sup>5</sup> CEC, Large Solar Energy Projects webpage: <http://www.energy.ca.gov/siting/solar/index.html>

<sup>6</sup> CPUC Resolution E-4240, *Approval of a power purchase agreement (PPA) for generation from a new solar photovoltaic facility between PG&E and El Dorado Energy, LLC (Sempra Generation)*, May 18, 2009.

1  
2 Sempra Generation touts the cost of power generated by its 10 MW PV installation in  
3 Nevada as “the lowest cost solar energy in the world.”<sup>7</sup> The company specifically mentions  
4 solar thermal projects like GSEP as producing higher-cost solar energy and being  
5 commercially unproven, stating:<sup>8</sup>

6  
7 “Sempra has also evaluated solar thermal power technologies, which use a field of mirrors  
8 to concentrate the sunlight to produce heat for electricity generation. The company has  
9 found that using solar panels is the cheaper option, (CEO) Allman said. He noted that some  
10 of the solar thermal power technologies, such as the use of a central tower for harvesting  
11 the heat and generating steam, have yet to be proven commercially.”

12  
13 SCE has a similar RPS-eligible PPA with NRG for the output of a 21 MW fixed thin-film  
14 PV array in Blythe, California.<sup>9</sup> This project began operation in December 2009.

15  
16 **B. IOUs and California’s Energy Policy Makers Acknowledge the Obvious Benefits**  
17 **of Large-Scale Distributed PV Projects as a Direct Complement/Substitute for**  
18 **Remote Central Station Renewable Energy and Associated Transmission**

19 SCE expressed confidence in its March 2008 application to the CPUC for a 250 to 500  
20 MW urban PV project that it can absorb thousands of MW of distributed PV without  
21 additional distribution substation infrastructure, stating “SCE’s Solar PV Program is  
22 targeted at the vast untapped resource of commercial and industrial rooftop space in SCE’s  
23 service territory”<sup>10</sup> and “SCE has identified numerous potential (rooftop) leasing partners  
24 whose portfolios contain several times the amount of roof space needed for even the 500  
25 MW program.”<sup>11</sup>  
26

---

<sup>7</sup> GreenTech Media, *Sempra Wants 300 MW Plus of Solar in Arizona*, April 22, 2009. “The electricity we are getting out of the 10-megawatt is the lowest cost solar energy ever generated from anywhere in the world.” (CEO Michael Allman).

<sup>8</sup> Ibid.

<sup>9</sup> First Solar press release, *First Solar Sells California Solar Power Project to NRG*, November 23, 2009.

<sup>10</sup> SCE Application A.08-03-015, *Solar Photovoltaic (PV) Program Application*, March 27, 2008, p. 6.

<sup>11</sup> SCE Application A.08-03-015, *Solar Photovoltaic (PV) Program Testimony*, March 27, 2008, p. 44.

1 SCE stated it has the ability to balance loads at the distribution substation level to avoid  
2 having to add additional distribution infrastructure to handle this large influx of distributed  
3 PV power.<sup>12</sup> SCE explains:

4  
5 “SCE can coordinate the Solar PV Program with customer demand shifting using existing  
6 SCE demand reduction programs on the same circuit. This will create more fully utilized  
7 distribution circuit assets. Without such coordination, much more distribution equipment  
8 may be needed to increase solar PV deployment. SCE is uniquely situated to combine solar  
9 PV Program generation, customer demand programs, and advanced distribution circuit  
10 design and operation into one unified system. This is more cost-effective than separate and  
11 uncoordinated deployment of each element on separate circuits.”<sup>13</sup>

12  
13 SCE also notes that it will be able to remotely control the output from individual PV arrays  
14 to prevent overloading distribution substations or affecting grid reliability:<sup>14</sup>

15  
16 “The inverter can be configured with custom software to be remotely controlled. This  
17 would allow SCE to change the system output based on circuit loads or weather  
18 conditions.”

19  
20 As SCE states, “Because these installations will interconnect at the distribution level, they  
21 can be brought on line relatively quickly without the need to plan, permit, and construct the  
22 transmission lines.”<sup>15</sup> This statement was repeated and expanded in the CPUC’s June 18,  
23 2009 press release regarding its approval of the 500 MW SCE urban PV project:<sup>16</sup>

24  
25 Added Commissioner John A. Bohn, author of the decision, “This decision is a major step  
26 forward in diversifying the mix of renewable resources in California and spurring the  
27 development of a new market niche for large scale rooftop solar applications. Unlike other  
28 generation resources, these projects can get built quickly and without the need for  
29 expensive new transmission lines. And since they are built on existing structures, these

---

<sup>12</sup> SCE Application A.08-03-015, *Solar Photovoltaic (PV) Program Application*, March 27, 2008, pp. 8-9.

<sup>13</sup> *Ibid.*, p. 9.

<sup>14</sup> SCE Application A.08-03-015, *Solar Photovoltaic (PV) Program Testimony*, March 27, 2008, p. 27.

<sup>15</sup> *Ibid.*, p. 6.

<sup>16</sup> CPUC Press Release – Docket A.08-03-015, *CPUC Approves Edison Solar Roof Program*, June 18, 2009.



1 projects are extremely benign from an environmental standpoint, with neither land use,  
2 water, or air emission impacts. By authorizing both utility-owned and private development  
3 of these projects we hope to get the best from both types of ownership structures,  
4 promoting competition as well as fostering the rapid development of this nascent market.”

5  
6 The CPUC made a similar observation with its approval of the PG&E 500 MW distributed  
7 PV project in April 2010:<sup>17</sup>

8  
9 “This solar development program has many benefits and can help the state meet its  
10 aggressive renewable power goals,” said CPUC President Michael R. Peevey. “Smaller  
11 scale projects can avoid many of the pitfalls that have plagued larger renewable projects in  
12 California, including permitting and transmission challenges. Because of this, programs  
13 targeting these resources can serve as a valuable complement to the existing Renewables  
14 Portfolio Standard program.”

15  
16 The use of the term “smaller scale” in the CPUC press release is a misnomer. Clearly a 500  
17 MW distributed PV project is larger-scale than the 250 MW GSEP solar thermal project.  
18 Individual rooftop PV arrays in a large distributed PV project are functionally equivalent to  
19 single rows of reflective mirrors in a solar thermal project. Each rooftop or row is a small  
20 contributor to a much bigger whole.

21  
22 **C. IOUs Need Only Provide a Basic Level of Existing Information on Individual IOU**  
23 **Substation Capacities to PV Developers to Interconnect Over 13,000 MW of**  
24 **Distributed PV with Minimal Interconnection Cost**

25 The CPUC has also calculated, for the entire inventory of approximately 1,700 existing  
26 IOU substations, the amount of distributed PV that could be accommodated with minimal  
27 interconnection cost based on the following reasoning:<sup>18</sup>

28  

---

<sup>17</sup> CPUC Press Release – Docket A.09-02-019, *CPUC Approves Solar PV Program for PG&E*, April 22, 2010.

<sup>18</sup> CPUC Rulemaking R.08-08-009 – California RPS Program, Administrative Law Judge’s Ruling on Additional Commission Consideration of a Feed-In Tariff, *Attachment A - Energy Division FIT Staff Proposal*, March 27, 2009, p. 15.

1 “Rule 21 specifies maximum generator size relative to the peak load on the load at the  
2 point of interconnection at 15%. So, for example, if a generator is interconnected on the  
3 low side of a distribution substation bank with a peak load of 20 MW, the maximum Rule  
4 21 interconnection criteria would allow a 3 MW system ( $3 \text{ MW} = 15\% * 20 \text{ MW}$ ).

5  
6 However, the 15% criterion, which is established for all generators regardless of type, was  
7 adjusted to 30% for the purposes of determining the technical potential of PV. The 15%  
8 limit is established at a level where it is unlikely the generator would have a greater output  
9 than the load at the line segment, even in the lowest load hours in the off-peak hours and  
10 seasons (such as the middle of the night and in the spring). Since the peak output for  
11 photovoltaics is during the middle of the day, PV is unlikely to have any output when loads  
12 are lowest. Therefore, a 30% criterion was used for technical interconnection potential  
13 estimates. The discussion was held with utility distribution engineers, however, we did not  
14 consider formal engineering studies or Rule 21 committee deliberation since the purpose of  
15 the analysis was only to define potential.”

16  
17 As a component of the DG FIT development process, the CPUC requested data on peak  
18 loads at all IOU substations from the IOUs and compiled that information graphically as  
19 shown in Figure 1. According to the CPUC, this data was obtained from IOU distribution  
20 engineers.<sup>19</sup> I calculate that approximately 13,300 MW of PV can be connected directly to  
21 IOU substation load banks based on the data in Figure 1. The supporting calculations for  
22 this estimate are provided in Table 1.

23  
24 The IOUs provide about two-thirds of electric power supplied in California, with publicly-  
25 owned utilities like the Los Angeles Department of Water & Power and the Sacramento  
26 Municipal Utility District and others providing the rest.<sup>20</sup> Assuming the substation capacity  
27 pattern in Figure 1 is also representative of the non-IOU substations, the total California-  
28 wide PV that could be interconnected at substation low-side load banks with no substantive  
29 substation upgrades would be  $[13,300/(2/3)] = 19,950 \text{ MW}$ .


---

<sup>19</sup> CPUC Rulemaking R.08-08-009 – California RPS Program, Administrative Law Judge’s Ruling on Additional Commission Consideration of a Feed-In Tariff, *Attachment A - Energy Division FIT Staff Proposal*, March 27, 2009, pp. 15-16.

<sup>20</sup> CEC, *2007 Integrated Energy Policy Report*, December 2007, Figure 1-11, p. 27.

1  
2  
3

**Figure 1. IOU Substation Peak Loads, 30% of Peak Load, and 10 MW Reference Line**



1 **Table 1. Calculation of Distributed PV Interconnection Capacity to Existing IOU**  
 2 **Substations with Minimal Interconnection Cost from Data in Figure 1**

| Substation range      | Number of substations | Calculation of distributed PV that could be interconnected with minimal substation upgrades (MW) | Total distributed PV potential (MW) |
|-----------------------|-----------------------|--|-------------------------------------|
| 1-200                 | 200                   | average peak ~60 MW x 0.30 = 18 MW   | 3,600                               |
| 201-500               | 300                   | average peak ~45 MW x 0.30 = 13.5 M  | 4,000                               |
| 501-800               | 300                   | average peak ~30 MW x 0.30 = 9 MW  | 2,700                               |
| 801-1,000             | 200                   | average peak ~20 MW x 0.30 = 6 MW  | 1,200                               |
| 1,001-1,600           | 600                   | average peak ~10 MW x 0.30 = 3 MW  | 1,800                               |
| Distributed PV total: |                       |  | 13,300                              |

3  
 4 In sum, approximately 20,000 MW of distributed PV interconnection capacity is available  
 5 now in California that would require little or no substation upgrading to accommodate the  
 6 PV.

7  
 8 **D. Cost to Upgrade Existing Distribution Substations and Associated Distribution**  
 9 **Feeders to Maximize Distributed PV Deployment is Minimal**

10 An upgrade at the substation would be necessary to accommodate the higher power flows  
 11 in cases where distributed PV, concentrated on clusters of large rooftops, could provide up  
 12 to 100 percent of a single substation’s peak load. A typical 12 kV/69 kV substation can be  
 13 upgraded to allow two-way (bidirectional) power flows for up to 100 MW of  
 14 interconnected distributed PV. SDG&E estimates the cost to build a new 12 kV/69 kV  
 15 substation is \$25 million.<sup>21</sup>

16  
 17 The upgrades necessary to allow problem-free bidirectional power flow across an existing  
 18 substation is far less than the cost of a new substation. The upgrade would consist of  
 19 retrofitting substation metering and protective equipment from one-way power flow to  
 20 bidirectional power flow. The cost of such an upgrade for a typical 100 MW distribution

---

<sup>21</sup> Ibid, p. 5.21.

1 substation would be approximately \$500,000.<sup>22</sup> This is well under 1 percent of the gross  
2 capital cost of 100 MW of state-of-the-art PV at 2010 prices.

3  
4 Even the cost of a new 100 MW distribution substation, at \$25 million, is less than 10  
5 percent of the gross capital cost of 100 MW of state-of-the-art PV at 2010 prices. The  
6 substation upgrade cost would be relatively minor compared to the gross capital cost of 100  
7 MW of PV arrays, and would not present a substantive financial hurdle to developing a 100  
8 MW distributed PV resource concentrated in an area served by a single existing substation.

9  
10 The 2007 IEPR makes clear that incorporating bidirectional capability into distribution  
11 substation is a commonsense need in a smart grid environment where higher-and-higher  
12 levels of distributed generation are encouraged and expected.<sup>23</sup>

13  
14 “Utilities spend approximately three-fourths of their total capital budgets on distribution  
15 assets, with about two-thirds spent on upgrades and new infrastructure in most years. These  
16 investments will remain for 20 to 30 or more years. As utilities throughout the state plan to  
17 build new distribution assets and replace old assets, the magnitude of these investments  
18 suggests that the state must understand what it is investing in and whether these  
19 investments will result in a distribution system that will serve customers in the future.  
20 Planning for investment in these assets should include requiring utilities, before  
21 undertaking investments in non-advanced grid technologies, to demonstrate that alternative  
22 investments in advanced  
23 grid technologies that will support grid flexibility have been considered, including from a  
24 standpoint of cost effectiveness.”

25  
26 The CPUC assumes that larger PV arrays will be connected directly to the substation low-  
27 side (12 kV) load bank. SDG&E estimated that the cost of a 10 MW feeder is \$0.6 million

---

<sup>22</sup> E-mail from M. Martyak, PowerSecure ([www.powersecure.com](http://www.powersecure.com)), to B. Powers, Powers Engineering, January 13, 2010. Approximate cost to upgrade older 100 MW distribution substation to full bidirectional flow, assuming four 25 MW load banks with four circuit breakers each (16 total), would be \$400,000 to \$450,000.

<sup>23</sup> CEC, *2007 Integrated Energy Policy Report*, December 2007, pp. 155-156.

1 per mile.<sup>24</sup> The cost of a 3-mile long dedicated feeder from multiple rooftop PV arrays with  
2 a combined capacity of 10 MW to the low-side bus of the substation would be less than \$2  
3 million based on SDG&E's cost estimate.

4  
5 The current capital cost for state-of-the-art commercial rooftop PV is approximately  
6 \$3,700/kW<sub>ac</sub>. The gross capital cost of 10 MW of rooftop PV at current prices would be  
7 \$3,700/kW x (1,000 kW/MW) x 10 MW = \$37 million. The cost to construct a dedicated  
8 feeder to interconnect 10 MW of rooftop PV would be approximately 5 percent of the gross  
9 project capital cost. This is a relatively minor cost and represents no financial impediment  
10 to developing urban rooftop PV resources.

11  
12 **E. There Is No Security Justification for IOU's Withholding Information on**  
13 **Substation Capacities and Locations from Private PV Developers, and No Economic**  
14 **or Technical Justification for Failure to Incorporate Smart Grid Features in New and**  
15 **Upgraded Distribution Substations**

16 The GSEP RSA notes that accommodating large quantities of distributed generation PV  
17 located at customer sites efficiently and cost-effectively will require the development of a  
18 new, transparent distribution planning framework (p. B.2-70). Transparent distribution  
19 planning by the IOUs is a reasonable expectation. Lack of transparent distribution planning  
20 is not a credible justification by an IOU or the CEC to reject distributed PV as a substitute  
21 for GSEP.

22  
23 The CEC is already on record advocating that IOUs must incorporate smart grid elements,  
24 including bidirectional power flow, into new and upgraded distribution substations.<sup>25</sup> It  
25 would likely come as a surprise to most California ratepayers that it is not already standard  
26 practice for California IOUs to incorporate bidirectional power flow capability into any  
27 new distribution substation or major upgrade of an existing substation. As noted,  
28 approximately 20,000 MW of distributed PV can flow into California distribution  
29 substations without retrofitting these substations for bidirectional power flow. The lack of

---

<sup>24</sup> Application No. 06-08-010, Matter of the Application of San Diego Gas & Electric Company (U-902-E) for a Certificate of Public Convenience and Necessity for the Sunrise Powerlink Transmission Project, *Chapter 5: Prepared Rebuttal Testimony of SDG&E in Response to Phase 2 Testimony of Powers Engineering*, March 28, 2008, p. 5.20.

<sup>25</sup> CEC, *2007 Integrated Energy Policy Report*, December 2007, pp. 155-156.

1 | bidirectional power flow capability on California distribution substations is not a short- or  
2 | mid-term impediment to maximizing distributed PV deployment.

3 |  
4 | However, at some point over the operational lifetime of a new or upgraded distribution  
5 | substation it is prudent to assume that failure to equip the substation to accommodate  
6 | bidirectional power flow will act as an artificial brake on the quantity of distributed PV the  
7 | substation can accept. Equipping a distribution substation for bidirectional power flow is  
8 | not expensive, costing in the range of \$500,000 for a typical 100 MW distribution  
9 | substation. Failure of IOUs to incorporate smart grid features as standard elements in new  
10 | and upgraded distribution substations is not a credible justification by an IOU or the CEC  
11 | to reject distributed PV as a substitute for GSEP.

12 |  
13 | The rationale put forth for restricting information to private distributed PV project  
14 | developers includes “Providing details on distribution system could compromise homeland  
15 | security” and “Information on peak loads and system configuration may be considered  
16 | commercially sensitive.”<sup>26</sup> There is no sound basis for these two justifications.

17 |  
18 | In the first instance, climate change is seen as a major threat to national security by the U.S.  
19 | defense establishment.<sup>27</sup> Withholding information that would allow rapid progress on  
20 | addressing climate change on homeland security grounds is contrary to the national  
21 | security interest. Secondly, all IOU expenditures are passed on to customers. The  
22 | withholding of information on peak loads and system configuration by the IOU to protect  
23 | unsubstantiated commercial sensitivity concerns, to the extent it prevents the rapid  
24 | deployment of competitively-bid distributed PV in urban centers at or near the point-of-  
25 | use, would have a potentially substantial negative impact on ratepayers and slow progress  
26 | on addressing climate change.

27 |  
28 | Much of the necessary information is already in the public domain in some form and  
29 | should be compiled and made available to distributed PV developers in a transparent and

---

<sup>26</sup> E3 and Black & Veatch, *Straw proposal of solution to address short-term problem of information gap*, presentation at CPUC Re-DEC Working Group Meeting, December 9, 2009, p. 9. Online at: <http://www.cpuc.ca.gov/PUC/energy/Renewables/Re-DEC.htm>

<sup>27</sup> New York Times, *Climate Change Seen as Threat to U.S. Security*, August 9, 2009.

1 efficient format. For example, the CPUC already has the data on IOU substation  
2 interconnection limitations as shown in Figure 1. Another example is information on the  
3 location of IOU substations. Maps showing the location of all IOU substations are readily  
4 available for purchase from the CEC Cartography Unit.

5  
6 The province of Ontario (Canada) makes publicly-available information on substation  
7 location and available capacity to facilitate the development of distributed PV in the  
8 province.<sup>28</sup> This same information protocol should be followed by California IOUs.

9  
10 Finally, SCE must provide this type of information to third-party PV developers for the 250  
11 MW private PV developer set-aside component of its 500 MW urban PV project approved  
12 by the CPUC in June 2009.

13  
14 **F. There is Sufficient Existing Large Commercial Roof Space in PG&E and SCE**  
15 **Territories to Build at Least Thirty GSEP Plants**

16 The 2009 IEPR Final Committee Report recognizes the huge technical potential of rooftop  
17 distributed PV to meet California’s renewable energy targets, stating:<sup>29</sup>

18  
19 “Recent studies indicate substantial technical potential for distribution-level generation  
20 resources located at or near load. A 2007 estimate from the Energy Commission suggests  
21 that there is roof space for over 60,000 MW of PV capacity, although the study did not  
22 factor in roof space that is shaded or being used for another purpose.”

23  
24 60,000 MW is approximately the peak summertime load for all of California, and 250  
25 times the 250 MW capacity of GSEP. It is important to note that the 2009 IEPR document  
26 is incorrect in asserting the 2007 rooftop PV estimate did not factor in roof shading or other  
27 limitations. The 60,000 MW estimate assumes only 24 percent of the rooftop of a typical  
28 tilt-roof residential rooftop is available for PV, and only 60 to 65 percent of flat-roof

---

<sup>28</sup> E3 and Black & Veatch, *Straw proposal of solution to address short-term problem of information gap*, presentation at CPUC Re-DEC Working Group Meeting, December 9, 2009, p. 8.

<sup>29</sup> CEC, *2009 Integrated Energy Policy Report (IEPR) – Final Committee Report*, December 2009, p. 193.



1 commercial rooftops are available for PV. The rationale for these estimates is explained in  
2 the 2007 (Navigant) estimate.<sup>30</sup>

3  
4 The 60,000 MW rooftop PV estimate by Navigant does not account for any of the  
5 distributed PV described in the Renewable Energy Transmission Initiative (RETI) process.  
6 RETI is California's ongoing renewable energy transmission siting process. RETI  
7 evaluated a distributed PV alternative that would produce 27,500 MWac from 20 MW  
8 increments of ground-mounted PV arrays at 1,375 non-urban substations around the state.<sup>31</sup>  
9 This is similar to the approach that PG&E is following. Constructing distributed PV arrays  
10 around substations is the primary focus of PG&E's 500 MW distributed PV project.<sup>32</sup>

11  
12 Black & Veatch is the engineering contractor preparing the RETI reports. Energy &  
13 Environmental Economics, Inc. (E3) is the engineering contractor that prepared the June  
14 2009 CPUC preliminary analysis of the cost to reach 33 percent renewable energy by 2020.  
15 These two firms now lead the CPUC's renewable distributed generation ("Re-DEC")  
16 working group process. The presentation of E3 and Black & Veatch at the December 9,  
17 2009 initial meeting of the Re-DEC Working Group included an estimate of over 8,000  
18 MWac of large commercial roof space in SCE and PG&E service territories in close  
19 proximity to existing distribution substations.<sup>33</sup>

20  
21 Black & Veatch used GIS to identify large roofs in California and count available large  
22 roof area. The criteria used to select rooftops included:

- 23  
24 • Urban areas with little available land  
25 • Flat roofs larger than ~1/3 acre  
26 • Assume 65 percent usable space on roof  
27 • Within 3 miles of distribution substation

---

<sup>30</sup> See: <http://www.energy.ca.gov/2007publications/CEC-500-2007-048/CEC-500-2007-048.PDF>

<sup>31</sup> Renewable Energy Transmission Initiative, *RETI Phase 1B Final Report*, January 2009, p. 6-25.

<sup>32</sup> PG&E Application A.09-02-019, *Application of Pacific Gas and Electric Company to Implement Its Photovoltaic Program*, February 24, 2009.

<sup>33</sup> E3 and Black & Veatch, *Summary of PV Potential Assessment in RETI and the 33% Implementation Analysis*, presentation at Re-DEC Working Group Meeting, December 9, 2009, p. 24. Online at: <http://www.cpuc.ca.gov/PUC/energy/Renewables/Re-DEC.htm>

1 The Black & Veatch estimate for PG&E territory is 2,922 MWac. The estimate for SCE  
2 territory is 5,243 MWac. This is a combined rooftop PV capacity of over 8,000 MWac. The  
3 combined large commercial rooftop capacity is more than 30 times the 250 MW capacity  
4 of GSEP.

5  
6 Large commercial rooftop PV capacity is a subset of the universe of all commercial rooftop  
7 capacity, which includes medium and small commercial rooftops as well. A 2004 Navigant  
8 study prepared for the Energy Foundation estimated the 2010 commercial rooftop PV  
9 capacity in California at approximately 37,000 MWdc.<sup>34</sup> There is a tremendous amount of  
10 commercial roof space available for PV.

11  
12 **G. GSEP RSA Uses Outdated PV Cost Assumption to Erroneously Assert GSEP is**  
13 **Lower Cost than Equivalent Distributed PV Capacity**

14 There is no justification for the GSEP RSA using an obsolete cost assumption to eliminate  
15 large-scale distributed PV as an alternative to the GSEP. The GSEP RSA relies on the June  
16 2009 CPUC *33% Renewables Portfolio Standard Implementation Analysis Preliminary*  
17 *Results* assertion that the cost of a high distributed PV case is significantly higher than the  
18 other 33 percent RPS alternative cases (p. B2-69). The 33 percent reference case includes  
19 10,000 MW of remote central station solar plants like GSEP. The assertion that the high  
20 distributed generation case is significantly higher cost than the reference case was incorrect  
21 in June 2009 and is definitively obsolete in April 2011.

22  
23 The CPUC erroneously assumed a distributed PV cost of over \$7/Wac in its June 2009  
24 analysis.

25  
26 However, the CPUC also analyzed a sensitivity case with the capital cost of fixed thin-film  
27 PV at \$3.70/Wac. The CPUC determined that at \$3.70/Wac, the cost of the 33 percent  
28 standard remote case and the high DG alternative are similar. RETI has confirmed that the  
29 PV pricing cited by the CPUC in its sensitivity analysis is commercially available and not a  
30 projection, stating, “Thin film solar PV was previously treated as a sensitivity study, but

---

<sup>34</sup> Navigant, *PV Grid Connected Market Potential under a Cost Breakthrough Scenario*, prepared for The Energy Foundation, September 2004, p. 83. California commercial rooftop PV potential estimated at approximately 37,000 MWp.

1 due to falling costs and the increased prevalence of thin film, it is now being considered as  
2 one of the available commercial technologies in addition to tracking crystalline PV.”<sup>35</sup>  
3

4 Accurate PV pricing data has been available from the SCE urban solar PV application for  
5 over three years. SCE provided an installed cost of \$3.50/Wdc (~\$4/Wac) in its March  
6 2008 application to the CPUC to build a 250 MW urban PV project. RETI states that the  
7 commercially available thin-film PV has a capital cost range of \$3.60 to \$4/Wac, and  
8 commercially available single-axis tracking polysilicon PV has a cost range of \$4 to  
9 \$5/Wac.<sup>36</sup>  
10

11 These PV costs compare to a capital cost range for solar thermal, assumed to be dry-  
12 cooled, of \$5.35 to \$5.55/Wac. RETI indicates the capacity factor for thin-film PV is  
13 essentially the same as for dry-cooled solar thermal (assuming the same location). The  
14 capacity factor for single-axis tracking polysilicon PV is significantly better than that of  
15 dry-cooled solar thermal (assuming the same location). Operations and maintenance cost  
16 for either fixed thin-film PV or single-axis tracking polysilicon PV is lower than for dry-  
17 cooled solar thermal. This RETI data is summarized in Table 2 below.  
18

19 **Table 2. RETI Capital Cost, Capacity Factor, and O&M Cost – Dry-Cooled Solar**  
20 **Thermal, Fixed Thin-Film PV, and Single-Axis Tracking Polysilicon PV**

| Solar Technology                       | Capital Cost<br>(\$/kWac) | Capacity<br>Factor (%) | O&M Cost<br>(\$/MWh) |
|--|---------------------------|------------------------|----------------------|
| Dry-cooled solar thermal               | 5,350 – 5,550             | 20 – 28                | 30                   |
| Fixed thin-film PV                     | 3,600 – 4,000             | 20 - 27                | 20 - 27              |
| Single-axis tracking<br>polysilicon PV | 4,000 – 5,000             | 23 - 31                | 17 - 25              |

21  
22 The GSEP RSA comment on the capacity factors of solar thermal and rooftop PV is out-of-  
23 date (p. B.2-67): “The Renewable Energy Transmission Initiative (RETI) assumed a

<sup>35</sup> RETI, *Phase 2B Final Report*, May 2010, p. 4-6.

<sup>36</sup> *Ibid*, Tables 4-5, 4-7, 4-8, pp. 4-6 and 4-7.

1 capacity factor of approximately 30 percent for solar thermal technologies and tracking  
 2 solar PV and  
 3 approximately 20 percent capacity factor for rooftop solar PV which is assumed to be  
 4 non-tracking, for viable solar generation project locations (B&V 2008; CEC 2009).” As  
 5 shown in Table 2, the RETI capacity factors of solar thermal and fixed (rooftop) solar PV  
 6 are essentially the same assuming the same location.

7  
 8 The effect of the values in Table 2 on the levelized cost-of-energy (COE) for dry-cooled  
 9 solar thermal, fixed thin-film PV, and single-axis tracking polysilicon PV is shown in  
 10 Table 3.<sup>37</sup> The average levelized COE for either fixed thin-film PV or single-axis tracking  
 11 polysilicon PV is significantly lower than the levelized COE of dry-cooled solar thermal  
 12 plants.

13 **Table 3. RETI Cost-of-Energy (COE) Comparison - Dry-Cooled Solar Thermal,**  
 14 **Fixed Thin-Film PV, and Single-Axis Tracking Polysilicon PV**

| Solar Technology                       | Levelized COE (\$/MWh)    |
|--|---------------------------|
| Dry-cooled solar thermal               | \$195 – 226 (mean: \$210) |
| Fixed thin-film PV                     | \$135 – 214 (mean: \$175) |
| Single-axis tracking polysilicon<br>PV | \$138 – 206 (mean: \$172) |

15  
 16 The CPUC determined that there would be little difference in the cost of meeting state  
 17 renewable energy targets by relying predominantly on distributed PV, when current state-  
 18 of-the-art pricing is assumed, instead of building 10,000 MW of remote solar capacity  
 19 under the 33 percent RPS reference case.<sup>38</sup> This conclusion was reached despite a number  
 20 of controversial cost assumptions by the CPUC that favored the 33 percent RPS reference  
 21 case.<sup>39</sup> An additional controversial assumption is the low assumed cost of new transmission  
 22 to realize the 33 percent reference case. The CPUC assumed the total cost of new

<sup>37</sup> Ibid, Figure 4-1, p. 4-8.

<sup>38</sup> CPUC, *33% Renewables Portfolio Standard Implementation Analysis Preliminary Results*, June 2009, p. 31.

<sup>39</sup> RightCycle Inc. comment letter, working group member response to June 2009 *33% Renewables Portfolio Standard Implementation Analysis Preliminary Results*, in response to CPUC request for comments, August 28, 2009.

1 transmission would be \$12 billion. The current estimate is over \$27 billion.<sup>40</sup> When current  
2 projections regarding the cost of new transmission and associated upgrades are used, the  
3 high distributed generation alternative is more cost-effective than the 33 percent reference  
4 case.

5  
6 The RETI capital cost values for PV assume 20 MW systems located at distribution  
7 substations. However, even the cost of individual commercial rooftop PV installations is  
8 now lower than the RETI cost of \$5.35 to \$5.55/Wac for dry-cooled solar thermal plants.

9  
10 The May 2010 DOE Solar Vision Study (draft) projection of current commercial rooftop  
11 PV capital cost is provided in Figure 3.<sup>41</sup> These capital cost values are provided in Wdc. As  
12 shown in Figure 2, the current capital cost of commercial rooftop polysilicon PV (multi Si  
13 and mono Si) is approximately \$4/Wdc. RETI identifies the range of dc-to-ac conversion  
14 factors of 0.77 to 0.85.<sup>42</sup> Using an average dc-to-ac conversion factor of 0.80, the capital  
15 cost of commercial rooftop polysilicon PV is approximately  $\$4/\text{Wdc} \div 0.80 = \$5/\text{Wac}$ . This  
16 is incrementally less than the \$5.35 to \$5.55/Wac capital cost of dry-cooled solar thermal,  
17 and the commercial rooftop PV array could be as little as 1/1,000<sup>th</sup> the size of the solar  
18 thermal plant. The most common form of thin-film PV, CdTe (cadmium-telluride), is lower  
19 in cost than polysilicon PV at approximately \$3.60/Wdc. This converts to  $\$3.60/\text{Wdc} \div$   
20  $0.80 = \$4.50/\text{Wac}$ .


21 **Figure 2. Cost of Commercial Rooftop PV Identified by DOE**

---

<sup>40</sup> J. Firooz, P.E., CAISO: *How Its Transmission Planning Process has Lost Sight of the Public's Interest*, April 2010, Table 2, p. 10. Total new transmission and upgrades necessary to realize 33 percent RPS reference case as of September 2009 - \$27.544 billion.

<sup>41</sup> DOE, *DOE Solar Vision Study – DRAFT*, May 28, 2010, Chapter 4, Figure 4-4, p. 7.

<sup>42</sup> RETI, *Phase 1A Final Report*, August 2008, Appendix B, p. 5-5.



1 a-Si: amorphous silicon thin-film PV; CIGS: copper-indium-gallium-selenide thin-film PV.

2  
3 **H. Market Price Referent with Adjustment for Time-of-Delivery would be Sufficient**  
4 **Price to Assure Rapid Construction of 250 MW Distributed PV Alternative to GSEP**

5 The CPUC has established that the levelized cost-of-energy (LCOE) from a new natural  
6 gas-fired combined cycle unit is the representative market price of electricity that  
7 renewable energy resource costs are compared to in the California RPS program. This  
8 representative LCOE is called the “Market Price Referent - MPR.”<sup>43</sup> The MPR consists of  
9 the LCOE for a new combined cycle plant plus an adder of \$15 per ton of CO<sub>2</sub> emissions.<sup>44</sup>  
10 The concept behind the MPR is that ratepayers should be protected from excessive green  
11 energy costs by requiring that renewable energy resources be no more costly than the  
12 conventional brown power they will replace.

13  
14 Combined cycle units operate as intermediate-load plants in California. They typically  
15 operate at capacity factors of 60 to 70 percent.<sup>45</sup> The fleet average capacity factor in 2008  
16 was 65 percent.<sup>46,47</sup> “Capacity factor” is a measure of actual annual electricity production

<sup>43</sup> MPR is the cost-of-energy for a new natural gas-fired combined cycle that includes a greenhouse gas emissions adder. See CPUC MPR website: <http://www.cpuc.ca.gov/PUC/energy/Renewables/mpr>

<sup>44</sup> CPUC MPR webpage, 2009 MPR Documents, 2009 MPR Model, Appendix F – Non-Gas Inputs: <http://www.cpuc.ca.gov/PUC/energy/Renewables/mpr>

<sup>45</sup> William Marcus, JBS Energy, Inc. on behalf of TURN, *MPR Capacity Factor*, PowerPoint presentation given at CPUC MPR workshop, R.06-02-012, March 27, 2008.

<sup>46</sup> CEC, *Comparative Costs of California Central Station Electricity Generation*, January 2010, p. C-12. Table C-5: Combined Cycle Facility Capacity Factors. Average capacity factor for 15 California combined cycle plants in 2008 is 65 percent.

<sup>47</sup> CPUC assumes 65% capacity factor for combined cycle units in *Inputs and Assumptions to 33% Renewables Portfolio Standard Implementation Analysis*, prepared by E3 for CPUC, July 2009.

1 compared to maximum possible output if the unit is operated every hour of the year at  
2 maximum output. Combined cycle units generally do not operate during off-peak, low  
3 demand periods. Low demand periods include midnight to 6 am most workdays as well as  
4 weekends. Lower-cost nuclear, large hydroelectric, and coal plants are available to meet  
5 the need during these periods. Combined cycle units are not the high-cost generation  
6 resource during summer peak periods, as simple cycle peaking turbines and older  
7 conventional steam plants with higher operating costs are online.

8  
9 A representative avoided cost for a solar PV system in PG&E service territory can be  
10 calculated using: 1) the MPR, adjusted to reflect a typical 65 percent capacity factor for a  
11 combined cycle plant and adjusted for the TOD of solar generation, and 2) the line losses  
12 and transmission and distribution (T&D) costs that are avoided by the typical solar PV  
13 system.

14  
15 The CPUC and the CEC have both developed estimates of the LCOE for a new 500 MW  
16 combined cycle plant. The CPUC derived its combined cycle installed cost estimate by  
17 looking at three projects that were either operational (Palomar, Consumnes) or under  
18 construction (Colusa) at the time 2009 MPR was developed.<sup>48</sup> The dates of the installed  
19 cost estimates for these projects are: Palomar –June 2004, Consumnes – January 2006, and  
20 Colusa – February 2008. The 2009 MPR calculation assumes a January 2010 online date.

21  
22 In contrast, the CEC used a non-project specific combined cycle pricing model to develop  
23 LCOE projections for 2009 and 2018 online dates.<sup>49</sup> The CEC also examines a range of  
24 capacity factors. LCOE projections were developed for capacity factors of 55 percent, 75  
25 percent, and 90 percent for an unfired 500 MW combined cycle unit. LCOE projections  
26 were also developed for capacity factors of 50 percent, 70 percent, and 85 percent for a  
27 duct-fired 550 MW combined cycle unit.<sup>50</sup>

28  

---

<sup>48</sup> CPUC MPR webpage, 2009 MPR Documents, 2009 MPR Model, “Install\_Cap” tab:  
<http://www.cpuc.ca.gov/PUC/energy/Renewables/mpr>.

<sup>49</sup> CEC, *Comparative Costs of California Central Station Electricity Generation*, January 2010, Appendix B.

<sup>50</sup> Ibid, Tables 11 - 13.

1 The CPUC currently assumes a hypothetical capacity factor of 92 percent for a combined  
 2 cycle unit when calculating the MPR.<sup>51</sup> However, the CPUC uses a capacity factor of 65  
 3 percent when calculating the actual expected electricity production from California’s fleet  
 4 of combined cycle plants.<sup>52</sup> The effect of using the unrealistically high capacity factor of 92  
 5 percent in the MPR calculation is to make the MPR reference price artificially low. The  
 6 effect of capacity factor on the LCOE for a new 500 MW combined cycle plant is shown in  
 7 Table 4 using the CEC combined cycle LCOE estimates.<sup>53</sup>

8  
 9 Use of a MPR based on a 65 percent capacity factor would accurately reflect typical usage  
 10 rates of operating combined cycle plants in California. This value is \$134/MWh for an  
 11 online date of 2009, and is projected by the CEC to rise to \$183/MWh for an online date of  
 12 2018. Powers Engineering has taken the mid-point between these two values to estimate  
 13 the MPR for an online date in the 2013 to 2014 timeframe. This MPR value is \$158/MWh.

14  
 15 Four new gas-fired power plants have PPAs and are planned for construction over the next  
 16 few years in Northern California alone. The proposed start dates for 600 MW Russell City,  
 17 624 MW Oakley, 760 MW Marsh Landing, and 200 MW Mariposa are 2013, 2016, 2013,  
 18 and 2012 respectively.<sup>54</sup> Given the average start-up date for this gas-fired capacity that  
 19 could be substituted with DG is 2013 to 2014, the appropriate MPR value is for a combined  
 20 cycle unit that will be online in 2013 or 2014. This is an MPR of \$158/MWh.

21  
 22 **Table 4. Effect of Capacity Factor on LCOE from New Combined Cycle Plant**

| Capacity factor (%) | LCOE, 2009<br>(\$/MWh) | LCOE, 2013/2014<br>(\$/MWh) | LCOE, 2018<br>(\$/MWh) |
|---------------------|------------------------|-----------------------------|------------------------|
| 92                  | 118                    | 140                         | 161                    |
| 75                  | 124                    | 147                         | 169                    |

<sup>51</sup> CPUC MPR webpage, 2009 MPR Documents, 2009 MPR Model:

<http://www.cpuc.ca.gov/PUC/energy/Renewables/mpr>.

<sup>52</sup> CPUC assumes 65 percent capacity factor for combined cycle units in *Inputs and Assumptions to 33% Renewables Portfolio Standard Implementation Analysis*, prepared by E3 for CPUC, July 2009.

<sup>53</sup> CEC, *Comparative Costs of California Central Station Electricity Generation*, January 2010, Table 1, Table 5, Figure A-8. A 500 MW unfired merchant combined cycle plant with a 75 percent capacity factor is the average case in the CEC report. Note – the dates shown in the table, 2009 and 2018, are commercial start dates.

<sup>54</sup> CPUC Application A.09-09-021, Application by PG&E for Approval of 2008 Long-Term Request for Offers Results, *Alternate Proposed Decision of Commissioner Bohn*, November 2, 2010.



|    |     |     |     |
|----|-----|-----|-----|
| 65 | 134 | 158 | 183 |
| 55 | 146 | 173 | 199 |

1 Note: CEC provides LCOE values for online dates of 2009 and 2018. The values included  
2 for 2013/2014 were calculated by Powers Engineering and are the average of the 2009 and  
3 2018 values.

4  
5 SCE applies a TOU factor for PV of 1.32.<sup>55</sup> The adjusted MPR for PV, which includes the  
6 time-of-delivery value of PV, is  $1.32 \times \$158/\text{MWh} = \$209/\text{MWh}$  ( $\$0.209/\text{kWh}$ ).

7  
8 The T&D system is designed to meet peak demand loads. The addition of distributed  
9 generation of any kind that reduced demand on the T&D system under peak conditions  
10 either delays or eliminates the need for existing substation upgrades or new T&D  
11 infrastructure. Energy and Environmental Economics, Inc. (E3), a CPUC contractor,  
12 developed the model adopted by the CPUC to determine the T&D avoided costs associated  
13 with energy efficiency programs.<sup>56</sup> The approximate weighted average (population based)  
14 T&D benefit of energy efficiency programs in PG&E territory is about  $\$20/\text{MWh}$ .<sup>57</sup>

15  
16 *California Solar Initiative* fixed PV systems in PG&E service territory have a demonstrated  
17 availability during the 4-5 pm peak hour of summer demand of more than 50 percent.<sup>58</sup> The  
18 peak availability of fixed PV is conservatively assumed to be 50 percent in this cost  
19 calculation. The full avoided T&D value of  $\$20/\text{MWh}$  must be multiplied by 0.50 to  
20 accurately reflect the avoided T&D value of fixed PV. This means that the solar PV T&D  
21 avoided cost would be  $\$10/\text{MWh}$ , or  $\$0.10/\text{kWh}$ .

22

---

<sup>55</sup> CPUC A.10-03-012, Application of PG&E to Implement Assembly Bill 920 (2009) Setting Terms and Conditions for Compensation for Excess Energy Deliveries by Net Metered Customers, *Proposal of the Solar Alliance and Vote Solar Initiative for a Net Surplus Compensation Rate and Responses to Scoping Memo Questions*, June 21, 2010, Table 2, p. 4.

<sup>56</sup> CPUC R.06-02-12, Rulemaking to Develop Additional Methods to Implement the California Renewables Portfolio Standard Program, *Pre-Workshop Comments of GreenVolts, Cleantech America, and Community Environmental Council on the 2008 Market Price Referent*, March 6, 2008, p.15. Table - E3 Model T&D Values (Levelized 20-year in 2008\$).

<sup>57</sup> Ibid.

<sup>58</sup> Itron, *CPUC Self-Generation Incentive Program—Ninth-Year Impact Evaluation Report – Final Report*, submitted to PG&E, June 2010, Table 5-14, p. 5-32. PG&E peak hour fixed PV capacity factor in 2009 was 54 percent, July 14, 2009, 4-5 pm.

1 An MPR-adjusted price of \$0.209/kWh, plus an average transmission & distribution  
2 benefit of approximately \$0.010/kWh, is equivalent to an overall value to the IOU of  
3 approximately \$0.22/kWh. Any price paid for distributed PV by an IOU below this price  
4 threshold should result in a net benefit to all of the IOU's ratepayers. A distributed PV  
5 price in the range \$0.22/kWh would be more than sufficient to create a dynamic market for  
6 third party development of large-scale distributed PV in California urban areas.

7  
8 **I. Rooftop Commercial PV is More Space Efficient than GSEP and has None of the**  
9 **Environmental Impacts of GSEP**

10 The GSEP RSA states, without citation: "However, based on SCE's use of 600,000-square-  
11 feet for 2 MW(ac) of energy, 75 million square feet (approximately 1,750 acres) would be  
12 required for 250 MW" (p. B2-67). SCE states in its March 2008 solar PV program  
13 testimony that 125,000 square feet of polysilicon panels are required to generate 1  
14 MWdc.<sup>59</sup> This converts to about 150,000 square feet per MWac, or approximately 3.5 acres  
15 per MWac.<sup>60</sup> This is one-half the square-footage per MWac that the GSEP RSA  
16 erroneously attributes to SCE rooftop installations. SCE has signed contracts with  
17 SunPower and Trina Solar, both suppliers of polysilicon PV panels, to provide a combined  
18 total of 245 MW of the 250 MW of PV capacity that will be owned by SCE.<sup>61,62</sup>

19  
20 Rooftop PV is also approximately twice as space efficient as the GSEP project. The GSEP  
21 RSA states that 1,800 acres will be developed to produce 250 MWac (p. B1-2). This is  
22 more than 7 acres per MWac.

23  
24 The predominant advantage of rooftop (or parking lot) PV is that it represents a compatible  
25 dual use of existing developed structures with no environmental impacts. As the GSEP  
26 RSA correctly notes, "Distributed solar PV is assumed to be located on already existing  
27 structures or disturbed areas so little to no new ground disturbance would be required and  
28 there would be few associated biological impacts" (p. B.2-68).

---

<sup>59</sup> SCE Application A.08-03-015, *Solar Photovoltaic (PV) Program Testimony*, March 27, 2008, p. 32.

<sup>60</sup> There are 43,560 square feet per acre. Therefore, 150,000 square feet per MWac ÷ 43,560 square feet per acre = 3.44 acre/MWac.

<sup>61</sup> SNL Financial, *SoCalEd orders 200 MW of solar panels, plans solicitation for 250 MW more*, March 10, 2010.

<sup>62</sup> SNL Financial, *SoCalEd taps Trina Solar to supply 45 MW of PV modules*, June 9, 2010.

1  
2 **J. GSEP RSA Concerns about Sufficient PV Panel Manufacturing Capacity Are**  
3 **Baseless**

4 The concerns expressed in the GSEP RSA regarding the availability of distributed solar PV  
5 are without foundation. The GSEP RSA states (p. B.2-70): “While it will very likely be  
6 possible to achieve 250 MW of distributed solar energy over the coming years, the very  
7 limited number of existing facilities make it difficult to conclude with confidence that it  
8 will happen within the timeframe required for the GSEP. As a result, this technology is  
9 eliminated from detailed analysis in this GSEP RSA.” Over 21,000 MW of PV systems,  
10 most of them distributed PV systems, were operational worldwide by the end of 2009.<sup>63</sup>  
11 More than 7,000 MW of PV was installed worldwide in 2009 alone.<sup>64</sup> In contrast, only 127  
12 MW of solar thermal plants were constructed in 2009.<sup>65</sup>

13  
14 Thin-film PV manufacturing capacity is projected to reach 7,400 MW per year in 2010.<sup>66</sup>  
15 First Solar alone manufactured and shipped more than 1,000 MW of thin-film panels in  
16 2009.<sup>67</sup>

17  
18 Worldwide conventional polysilicon PV production capacity reached 13,300 MW a year in  
19 2008.<sup>68</sup> It is projected to reach 20,000 MW a year in 2010. The 2010 projections were  
20 made just as the economic slump began in late 2008. It is likely there will be some scale-  
21 back on the 2010 capacity additions due to the state of the world economy. Nonetheless,  
22 there is a tremendous amount of available worldwide PV manufacturing capacity.

23  
24 PV panel manufacturing capacity has greatly expanded worldwide in the last 2 to 3 years.  
25 The current estimated oversupply of PV panel manufacturing capacity for 2010 is 8,000

---

<sup>63</sup> Worldwatch Institute, *Record Growth in Photovoltaic Capacity and Momentum Builds for Concentrating Solar Power*, June 3, 2010.

<sup>64</sup> Ibid.

<sup>65</sup> Ibid.

<sup>66</sup> Schreiber, D. - EuPD Research, *PV Thin-film Markets, Manufacturers, Margins*, presentation at 1<sup>st</sup> Thin-Film Summit, San Francisco, December 1-2, 2008.

<sup>67</sup> First Solar press release, *First Solar Becomes First PV Company to Produce 1GW in a Single Year*, December 15, 2009.

<sup>68</sup> Schreiber, D. - EuPD Research, *PV Thin-film Markets, Manufacturers, Margins*, presentation at 1<sup>st</sup> Thin-Film Summit, San Francisco, December 1-2, 2008.

1 MW.<sup>69</sup> As a result of this oversupply, the cost of conventional polysilicon PV panels has  
2 dropped precipitously and is approaching the cost of thin-film PV panels (see Figure 3).

3  
4 The GSEP RSA states that California added 158 MW of distributed PV in 2008 (p. B.2-  
5 66). California is a relatively minor player on the world PV stage. Spain added  
6 approximately 2,500 MW of primarily distributed ground-mounted PV resources in 2008.<sup>70</sup>  
7 Spain has a smaller economy than California. Germany, approximately the same size as  
8 California and with considerably lower solar intensity, added approximately 1,500 MW of  
9 distributed PV resources in 2008 and 3,800 MW in 2009.<sup>71,72</sup> Germany had an installed PV  
10 capacity of nearly 9,000 MW at the end of 2009 and has set a target PV installation rate of  
11 3,500 MW per year.<sup>73</sup>

12  
13 The GSEP RSA expresses concerns regarding the feasibility of California doubling its 158  
14 MW per year (2008) distributed PV installation rate as a substitute for GSEP, stating (p.  
15 B.2-69): “This would require an even more aggressive deployment of PV at more than  
16 double the historic rate of solar PV implementation than the California Solar Initiative  
17 program currently employs.” This doubling of distributed PV deployment is equivalent to  
18 going from 1/20<sup>th</sup> to 1/10<sup>th</sup> the current German distributed PV installation rate. The  
19 feasibility concern expressed in the RSA is unfounded in light of German success with a  
20 high rate of distributed PV deployment.

21  
22 The high distributed PV alternative studied by the CPUC anticipates the installation of  
23 15,000 MW of distributed PV by 2020.<sup>74</sup> RETI has gradually dropped the amount of new  
24 renewable energy resources needed to reach 33 percent by 2020, the “net short,” from  
25 74,650 gigawatt-hours (GWh) per year initially to a current “low load” net short of 36,926

---

<sup>69</sup> B. Murphy – Fulcrum Technologies, Inc., *The Power and Potential of CdTe (thin-film) PV*, presented at 2<sup>nd</sup> Thin-Film Summit, San Francisco, December 1-2, 2009.

<sup>70</sup> PV Tech, *Worldwide photovoltaics installations grew 110% in 2008, says Solarbuzz*, March 16, 2009.

<sup>71</sup> PV Tech, *German market booming: Inverter and module supplies running out at Phoenix Solar*, November 15, 2009.

<sup>72</sup> Worldwatch Institute, *Record Growth in Photovoltaic Capacity and Momentum Builds for Concentrating Solar Power*, June 3, 2010.

<sup>73</sup> Chadbourne & Parke Project Finance Newswire, *Germany Cuts Solar Subsidy*, April 2010.

<sup>74</sup> CPUC, *33% Renewables Portfolio Standard Implementation Analysis Preliminary Results*, June 2009.

1 MW.<sup>75</sup> The low load net short is one-half the net short used by the CPUC in June 2009 to  
2 estimate the cost of achieving 33 percent by 2020. 15,000 MW of distributed PV would  
3 provide about 30,000 GWh/yr.<sup>76</sup> 15,000 MW of distributed PV would provide over 80  
4 percent of the low load net short of 36,926 MW.

5  
6 California could easily install 15,000 MW of distributed PV by 2020 if it approached the  
7 annual distributed PV installation rates that have already been achieved in practice in Spain  
8 and Germany. Existing worldwide PV manufacturing capacity, either thin-film alone or  
9 thin-film and conventional polysilicon, could readily supply a PV demand of 1,500 to  
10 2,500 MW a year in California.

11  
12 **K. Slight Reduction in Output from Distributed PV in Los Angeles, Central Valley,**  
13 **or Bay Area Is Offset by Transmission Losses from GSEP to These Load Centers**

14 The GSEP RSA implies that the superior solar intensity at the GSEP location in the Mojave  
15 Desert is a substantive reason for eliminating distributed PV from consideration, stating (p.  
16 B.2-67):

17  
18 “The location of the distributed solar PV would impact the capacity factor of the distributed  
19 solar PV. Capacity factor depends on a number of factors including the insolation of the  
20 site. Because a distributed solar PV alternative would be located throughout the state of  
21 California, the insolation at some of these locations may be less than in the Mojave  
22 Desert.”

23  
24 The solar insolation at the GSEP site is about 10 to 15 percent better than the composite  
25 solar insolation for Los Angeles, the Central Valley, and Oakland.<sup>77,78</sup> However, the CEC

---

<sup>75</sup> RETI discussion draft, *RETI Net Short Update - Evaluating the Need for Expanded Electric Transmission Capacity for Renewable Energy*, February 22, 2010. Low load scenario, net short = 36,926 MW.

<sup>76</sup> The CPUC reference case assumes 3,235 MW of solar PV will generate 6,913 GWh per year under ideal Southern California desert solar insolation conditions. This is a production ratio of 2,137 GWh per MWac. However, solar insolation in the Central Valley and California urban areas will on average be approximately 10 less than ideal desert sites. For this reason a production ratio of 2,000 GWh per year per MWac is assumed for the Central Valley and urban areas.

<sup>77</sup> U.S. DOE, *Stand-Alone Flat-plate Photovoltaic Systems: System Sizing and Life-Cycle Costing Methodology for Federal Agencies*, 1984, Appendix, p. A-27.

<sup>78</sup> NREL, *Solar Radiation Data Manual for Flat-Plate and Concentrating Collectors*, California cities data: <http://rredc.nrel.gov/solar/pubs/redbook/PDFs/CA.PDF>

1 estimates average transmission losses in California at 7.5 percent and peak transmission  
2 losses at 14 percent.<sup>79</sup> The incrementally better solar insolation at the GSEP site is almost  
3 completely negated by the losses incurred by transmitting GSEP solar power to California  
4 urban areas. In contrast, distributed PV has minimal losses between generation and user.

5  
6 **L. CEC Has Already Determined Distributed PV Can Compete Cost-Effectively with**  
7 **Other Forms of Generation**

8 The CEC denied an application for a 100-megawatt natural-gas-fired gas turbine power  
9 plant, the Chula Vista Energy Upgrade Project (CVEUP), in June 2009 in part because  
10 rooftop solar PV could potentially achieve the same objectives for comparable cost.<sup>80</sup>

11  
12 This June 2009 CEC decision implies that any future applications for gas-fired generation  
13 in California, or any other type of generation including remote central station renewable  
14 energy generation like GSEP that require public land and new transmission to reach  
15 demand centers, should be measured against using urban PV to meet the power need. The  
16 CEC's final decision in the CVEUP case stated:<sup>81</sup>

17  
18 "Photovoltaic arrays mounted on existing flat warehouse roofs or on top of vehicle  
19 shelters in parking lots do not consume any acreage. The warehouses and parking lots  
20 continue to perform those functions with the PV in place. (Ex. 616, p. 11.)...Mr.  
21 Powers (expert for intervenor) provided detailed analysis of the costs of such PV,  
22 concluding that there was little or no difference between the cost of energy provided by  
23 a project such as the CVEUP (gas turbine peaking plant) compared with the cost of  
24 energy provided by PV. (Ex. 616, pp. 13 – 14.)...PV does provide power at a time  
25 when demand is likely to be high—on hot, sunny days. Mr. Powers acknowledged on  
26 cross-examination that the solar peak does not match the demand peak, but testified that  
27 storage technologies exist which could be used to manage this. The essential points in  
28 Mr. Powers' testimony about the costs and practicality of PV were uncontroverted."  
29

---

<sup>79</sup> E-mail communication between Don Kondoleon, manager - CEC Transmission Evaluation Program, and Bill Powers of Powers Engineering, January 30, 2008.

<sup>80</sup> CEC, Chula Vista Energy Upgrade Project - Application for Certification (07-AFC-4) San Diego County, *Final Commission Decision*, June 2009.

<sup>81</sup> *Ibid*, pp. 29-30.

1 | The CEC concluded in the CVEUP final decision that PV arrays on rooftops and over  
2 | parking lots may be a viable alternative to the gas turbine project proposed in that case, and  
3 | that if the gas turbine project proponent opted to file a new application a much more  
4 | detailed analysis of the PV alternative would be required.

1 **IV. Locating GSEP in the Proposed Westlands Water District CREZ would Avoid**  
2 **Environmental Impacts at the GSEP Site**

3  
4 The Westlands Water District (“Westlands”), on the west side of the Central Valley, is  
5 undergoing study by RETI as a Competitive Renewable Energy Zone (CREZ) capable of  
6 providing 5,000 MW of utility-scale solar development. Westlands covers over 600,000  
7 acres of farmland in western Fresno and Kings Counties. The proposed “Central California  
8 Renewable Master Plan” will utilize permanently retired farmlands in Westlands for solar  
9 development. An overview of this master plan is attached. As stated in the master plan  
10 overview, “Due to salinity contamination issues, a portion of this disturbed land has been  
11 set aside for retirement and will be taken out of production under an agreement between  
12 Westlands and the U.S. Department of Interior.” Approximately 30,000 acres of disturbed  
13 Westlands land, equivalent to 5,000 MW of solar capacity, will be allocated for renewable  
14 energy development under the plan.

15  
16 Transmission Pathway 15 passes through Westlands. Path 15 can transmit 5,400 MW from  
17 south-to-north.<sup>82</sup> The transmission capacity from north-to-south is 3,400 MW. The location  
18 of Westlands relative to Path 15 is shown in Figure 3.

19  
20 **Figure 3. Location of Westlands Water District and Path 15<sup>83,84</sup>**


---

<sup>82</sup> Transmission & Distribution World, California bulks up to provide more transmission capacity, June 1, 2004.

<sup>83</sup> Anthem Group press release, Central California Renewable Master Plan, March 2010.

<sup>84</sup> CEC, *Strategic Transmission Investment Plan*, November 2005, p. 11.





1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14

5,000 MW of solar power can be developed in Westlands with potentially no expansion of the existing Path 15 high voltage transmission capacity that serves Westlands now.

5,000 MW is half of the total remote in-state utility-scale solar contemplated in the June 2009 CPUC 33 percent reference case.<sup>85</sup> The remote in-state solar component of the reference case consists of 3,235 MW central station PV and 6,764 MW central station solar thermal. The anticipated energy output of 5,000 MW of fixed PV in Westlands would be about 10,000 GWh/yr.<sup>86</sup> This is approximately 30 percent of the RETI low load net short of 36,926 MW.

The GSEP RSA states that the Gabrych disturbed lands alternative near the GSEP site does not meet project objectives due to the inability to assure site control of multiple private parcels by the end of 2010 (p. B.2-53). Site control would not be an issue in the proposed

<sup>85</sup> CPUC, *33% RPS Implementation Analysis Preliminary Results*, June 2009, Appendix C, p. 87.

<sup>86</sup> The CPUC reference case assumes 3,235 MW of solar PV will generate 6,913 GWh per year under ideal Southern California desert solar insolation conditions. This is a production ratio of 2,137 GWh per MWac. However, solar insolation in the Central Valley and California urban areas will on average be approximately 10 less than ideal desert sites. For this reason a production ratio of 2,000 GWh per year per MWac is assumed for the Central Valley and urban areas.

1 Westlands CREZ. Westlands is actively marketing the 30,000-acre area for development of  
2 central station solar power plants. Development of solar projects on the Westlands property  
3 is intended (by Westlands) to serve as a source of income on land that has been  
4 permanently retired from agricultural production.

5  
6 Prioritizing distributed PV projects, combined with the location of central station solar  
7 projects in Westlands, would allow California to achieve its 33 percent by 2020 renewable  
8 energy target with almost no environmental impacts related to the solar energy component  
9 of the renewable energy portfolio.

## 10 11 **V. Conclusions**

12  
13 The DPV2 Draft Supplemental EIR is inadequate for failure to conduct an analysis of non-  
14 transmission alternatives to the DPV2. In contrast, the Draft and October 2008 Final  
15 EIR/EIS prepared by the CPUC and BLM for SDG&E's proposed Sunrise Powerlink  
16 transmission line includes voluminous analysis of multiple non-transmission alternatives to  
17 the proposed project. The CPUC/BLM Final EIR/EIS for the Sunrise Powerlink concluded  
18 that either of the two non-transmission in-basin alternatives studied were environmentally  
19 superior to the proposed project or any transmission alternative to the proposed project.  
20 The DPV2 Draft Supplemental EIR avoids a similar conclusion by failing to analyze in  
21 detail any non-transmission alternative to the DPV2.

22  
23 This comment letter uses comments provided by Powers Engineering on alternatives to  
24 GSEP as a case study to show that non-transmission alternatives are more cost-effective  
25 than the solar thermal projects that DPV2 is being built to serve. The GSEP RSA analysis  
26 of the distributed PV alternative to GSEP used flawed logic and outdated data to  
27 improperly eliminate distributed PV as an alternative. The DPV2 Draft Supplemental EIR  
28 contains no analysis of any kind. Distributed PV is a fully viable and cost-effective  
29 alternative that eliminates the environmental impacts that would be caused by the DPV2  
30 transmission line and the associated GSEP and BSPP solar projects.

31

1 Beyond the issue of distributed PV being a superior alternative to GSEP + BSPP + DPV2  
2 on cost and environmental grounds, there are lower-impact sites in California for central  
3 station solar projects like GSEP and BSPP. The Westlands Water District is a low impact  
4 “shovel ready” alternative to the GSEP and BSPP sites for central station solar projects.  
5 Westlands requires no new high voltage transmission to move up to 5,000 MW of solar  
6 power to California load centers.

7  
8 This means solar projects located in Westlands will not face project delays due to lack of  
9 high voltage transmission capacity. The steadily declining renewable energy net short to  
10 achieve the 33 percent by 2020 target, now as low as 36,926 MW, means fewer renewable  
11 projects overall are necessary to meet the 33 percent target. The CPUC should not approve  
12 transmission projects like DPV2 serving high-cost solar thermal projects with  
13 unmitigatable impacts, when 5,000 MW of otherwise unusable disturbed land with no  
14 environmental issues and 5,000 MW of high voltage transmission capacity sits idle.

15

**CALIFORNIANS FOR RENEWABLE ENERGY'S INITIAL COMMENTS  
ON SUPPLEMENTAL DRAFT ENVIRONMENTAL IMPACT REPORT  
FOR COLORADO RIVER SUBSTATION EXPANSION**  
(California SCH 2005101104)

Exhibit 2

**ON BEHALF OF CALIFORNIANS FOR RENEWABLE ENERGY  
COMMENTS OF ROBERT M. SARVEY ON DEVERS TO PALO VERDE 2  
TRANSMISSION LINE DRAFT SUPPLEMENTAL EIR**

April 8, 2011

Robert M. Sarvey  
501 W. Grantline Rd  
Tracy, Ca. 95375  
Phone: (209) 835-7162  
E-mail:  
sarveybob@aol.com

1 **Alternatives**

2 Section 15126.2(d) of the CEQA Guidelines requires that an EIR discuss the  
3 ways in which a proposed project may foster economic or population growth, or  
4 the construction of additional housing, either directly or indirectly, in the  
5 surrounding environment. The discussion must additionally address how a  
6 proposed project may remove obstacles to growth, or encourage and facilitate  
7 other activities that could significantly affect the environment, either individually  
8 or cumulatively.

9  
10 The Proposed Project would facilitate growth indirectly by removing obstacles to  
11 population growth through the additional increased capacity of electric power that  
12 it would make available. As discussed in Sections A.1.1 (Project Background)  
13 and A.1.3 (Project Objectives), the DPV2 Project, including the CRS expansion,  
14 would bring energy resources to Los Angeles from Riverside County by providing  
15 access to remote areas with the potential for significant development of  
16 renewable energy sources.

17  
18 CPUC Decision D.09-11.007, which modifies D.07-01-040, concludes that SCE's  
19 revised stated objective of constructing the California portion of DPV2, including  
20 the Midpoint Substation would be to provide transmission access to potential  
21 future renewable resources in the Blythe area and help enable California to meet  
22 its renewable energy goals. Additionally, SCE has stated that an additional  
23 objective of the CRS would be to complete substation construction in a timely  
24 fashion to allow interconnection with the Blythe Solar Power Project (BSPP) and  
25 Genesis Solar Energy Project (GSEP) by the Large Generator Interconnection  
26 Agreements (LGIA) target dates.

27  
28 The CAISO's interconnection queue lists generation facilities that would like  
29 access to California's transmission system. There are currently thousands of  
30 megawatts of wind and solar facilities in eastern Riverside County listed in the  
31 queue, and there is not adequate transmission capacity for these projects to be

1 constructed. While the development of renewable energy sources has the benefit  
2 of reducing the use of older and more polluting conventional generation facilities,  
3 the renewable facilities could not be constructed without adequate transmission  
4 and a substation access point to the grid. So while the CRS may not induce  
5 urban growth, it would encourage the development of renewable projects in the  
6 Blythe area. The CRS expansion would not be needed without the construction  
7 of solar generation in the Blythe area.

### 8 9 **Biological Resources**

10 Implementation of the CRS expansion would additionally require the permanent  
11 loss of approximately 54.1 acres of vegetation and habitat, which equals 61.6  
12 percent of the total land (87.8 acres) disturbed for construction. Direct and  
13 indirect loss of sand dune habitat within an active sand transport corridor would  
14 result in a significant and unmitigable direct impacts to the Mojave fringe toed  
15 lizard.<sup>1</sup> There are also cumulative impacts from the project in combination of  
16 other projects which the expansion of the CRS enables. These include  
17 consideration of the magnitude of threats to MFTL from existing and reasonably  
18 foreseeable future projects, the substantial habitat loss and downwind habitat  
19 degradation/elimination from the CRS project, which would ultimately result in range  
20 contraction of the species, would be cumulatively considerable. New Mitigation Measure  
21 B-9j (Provide compensatory mitigation and restoration/enhancement of protected land  
22 for impacts to sand dune habitat) would reduce the Proposed Project's contribution to  
23 cumulative MFTL habitat loss by securing and preserving unprotected private lands or  
24 enhancing/sand dunes already conserved or on BLM land that is not slated for  
25 development. Even with the implementation of mitigation, when combined with impacts  
26 of past, present, and reasonably foreseeable projects, the Proposed Project's  
27 contribution to significant cumulative MFTL impacts remains cumulatively considerable  
28 (Class I). Several of these projects are only feasible with the expansion of the CRS and  
29 therefore the EIR should discuss the indirect impacts of the CRS expansion.

30  

---

<sup>1</sup> DEIR Page G-3 [http://www.cpuc.ca.gov/Environment/info/aspen/dpv2/sdeir/g\\_otherceqa.pdf](http://www.cpuc.ca.gov/Environment/info/aspen/dpv2/sdeir/g_otherceqa.pdf)

1 While the DEIR has concluded that the contribution of the CRS expansion to impacts to  
2 the Desert kit Fox, Swainson hawk, and other sensitive species is not cumulatively  
3 considerable the DEIR does not consider that the CRS expansion enables a  
4 cumulatively considerable impact form the other projects that are infeasible without the  
5 expansion to the CRS. These impacts must be examined in the final EIR.

6  
7 Air Quality

8 From the discussion at the prehearing conference it appears that an accelerated  
9 construction schedule is being considered to allow two large solar projects to meet  
10 online dates.

11  
12 *“So NextEra has been attempting to work with SCE and SCE has been also*  
13 *working with NextEra to find ways to accelerate the construction schedule. But in*  
14 *order to do that, it is really important that there be a final decision in this*  
15 *proceeding approving a project, and approving one that is feasible and that can*  
16 *be built on a time frame in order to allow the Genesis project to come online.”<sup>2</sup>*

17  
18 The impacts of an accelerated construction schedule are not reflected in the  
19 DEIR. As the DEIR states, “Pollutant emissions would vary from day to day  
20 depending on the **level of activity**, the specific operations, and the prevailing weather.”<sup>3</sup>  
21 Impacts to air quality could include increased hourly, daily, and annual  
22 construction emissions. The Final EIR must quantify and discuss these impacts.  
23 The current discussion in the DEIR is incomplete without this additional analysis  
24 as an accelerated construction schedule.

25  
26 The DEIR already concludes that, “daily emissions from the Proposed Project would  
27 cause significant and unavoidable impacts in the SCAQMD (Class I).” Despite this  
28 conclusion the DEIR does not require all feasible and cost effective mitigation measures  
29 which can reduce the significant impact. Limiting construction vehicle speeds, use of  
30 electric powered equipment, and many other mitigation measures should be considered  
31 to reduce the identified significant impact. .

---

<sup>2</sup> Prehearing conference transcript Page 46

<sup>3</sup> DEIR Page D.11-37



1  
2 The draft DEIR also concludes that Tower construction would have the potential to  
3 cause significant localized PM10 emission impacts for sensitive receptors located near  
4 the tower sites. The significant impacts, based on the SCAQMD LST lookup table, would  
5 extend to sensitive receptors within and just over 50 meters of the tower sites. Fugitive  
6 dust mitigation measures are assumed to be implemented in these emission estimates;  
7 therefore, the Proposed Project would cause significant and unavoidable (Class I)  
8 localized PM10 impacts for nearby sensitive receptors within SCAQMD jurisdiction, and  
9 all feasible fugitive dust mitigation measures need to be applied within this jurisdiction.<sup>4</sup>  
10

11 According to the DEIR the Proposed Project would exceed the federal General  
12 Conformity *de minimis* thresholds, **assuming the current project schedule** and activity  
13 forecasts. Table D-11.19 shows that the Proposed Project would exceed the SCAB NOx  
14 threshold for General Conformity in 2008. NOx offsets are proposed for this significant  
15 impact. As mentioned above an accelerated construction schedule is reasonably  
16 foreseeable and the impact of increased construction activity must be quantified and  
17 mitigated.<sup>5</sup> The DEIR contains no analysis of the localized PM-10 and NO<sub>2</sub> air quality  
18 impacts. With or without an accelerated construction schedule the projects construction  
19 activities could lead to localized violations of the Federal 24 hour PM 2.5 standard, the  
20 Federal 1-Hour NO<sub>2</sub> standard and other federal and state air quality standards  
21 established to protect the health of the nearby sensitive receptors. A complete analysis  
22 including compliance with state and federal air quality standards is required and the  
23 possible environmental justice considerations must be included in the final EIR.  
24

25 The alternative route proposal fails to discuss whether sensitive receptors are  
26 located near the projects' construction areas so the DEIR fails to inform the  
27 decision makers and the public as to possible localized air quality impacts to  
28 sensitive receptors for the alternative routes. The Final EIR must include an  
29 analysis and discussion of these impacts and their environmental justice  
30 implications in order to inform the public and meet the requirements of an EIR  
31 under CEQA.

---

<sup>4</sup> DEIR Page D. 11-45

<sup>5</sup> DEIR Page D.11-46

1  
2 The DEIR includes a discussion of a net decrease in emissions from power plants in  
3 California and a smaller increase in emissions from power plants in Arizona (described  
4 in Impact AQ-3) would not occur with implementation of No Project Alternative (CAISO,  
5 2005). That discussion is irrelevant to the impacts of the expanded CRS. First the  
6 current proposal is to build only the California portion of the DVP2 so a realized  
7 reduction in California power plant emissions and an increase in power plant  
8 emissions in Arizona will not occur under the current proposal. Second those  
9 emission increase and reductions in power plant emissions are irrelevant on the  
10 expansion of the CRS and only serves to confuse the decision maker and the  
11 public as to the true impacts of the CRS expansions.

12  
13 The DEIR states that the first component of the No Project Alternative is the continuation  
14 of ongoing demand-side actions, including energy conservation and distributed  
15 generation (DG). These actions would result in possible localized air quality impacts as a  
16 result of development of DG units by energy consumers. This would be the case if fossil-  
17 fuel fired or other combustion or thermal DG technologies become more widespread.  
18 The DEIR ignores the potential for rooftop solar and substation located solar arrays  
19 which would eliminate the need for additional transmission lines and large scale solar  
20 generating facilities in the desert environment and eliminates all of the impacts identified  
21 in the DEIR and the significant impacts of these large scale solar projects. The DEIR  
22 also fails to consider the enormous amount of energy consumption that could be  
23 achieved by shifting ratepayer resources away from the central station solar arrays and  
24 large desert renewable projects. .

25  
26 The DEI then speculates that the second component of the No Project Alternative is the  
27 continuation of supply-side actions, resulting in potentially increased generation within  
28 California or increased transmission into California to serve anticipated growth in  
29 electricity consumption.

30  
31 The impacts of new power plants and new transmission lines could add air pollutants  
32 contributing to existing nonattainment conditions or violations of ambient air quality  
33 standards, if they occur in areas of substantial existing pollution. Although construction

1 | and operation of new power plants and transmission lines may occur, their locations and  
2 | development schedules cannot be predicted. This is unlikely if in fact the regulators do  
3 | enforce the loading order and fulfill future electrical demand with energy efficiency  
4 | measure and distributed rooftop and substation solar arrays.

**CERTIFICATE OF SERVICE**

I, the undersigned, certify that I served the foregoing **CALIFORNIANS FOR RENEWABLE ENERGY'S INITIAL COMMENTS ON SUPPLEMENTAL DRAFT ENVIRONMENTAL IMPACT REPORT FOR COLORADO RIVER SUBSTATION EXPANSION** on the persons/parties listed, in the manner indicated, on the attached Service List.

Date: April 8, 2011.

s/ Cory J. Briggs

**Service List for A10-11-005  
(Last Update: 7-Apr-2011)**

robert.pontelle@alston.com  
lcottle@winston.com  
michaelboyd@sbcglobal.net  
rl@eslawfirm.com  
angela.whatley@sce.com  
case.admin@sce.com  
richard.tom@sce.com  
cory@briggslawcorp.com  
cem@newsdata.com  
harron@solarcentury.com  
cressner@solarcentury.com  
bcb@cpuc.ca.gov  
ec2@cpuc.ca.gov  
hsy@cpuc.ca.gov  
dpv2@aspenerg.com

ROBERT  
LISA A.  
MICHAEL E.  
RONALD  
ANGELA  
CASE  
RICHARD  
CORY J.  
California Energy Markets  
ALICE L.  
MICHAEL  
Billie C.  
Elaine Chan  
Hallie  
Billie

PONTELLE  
COTTLE  
BOYD  
LIEBERT  
WHATLEY  
ADMINISTRATION  
TOM  
BRIGGS  
HARRON  
CRESSNER  
Blanchard  
Lau  
Yacknin  
Blanchard