




PROFILE: BELL BLUFF TRUCK TRAIL
SCALE
HORIZ: 1"=20'
VERT: 1"=4'



CENTERLINE DATA TABLE

SYMBOL	DELTA/BEARING	RADIUS	LENGTH
CL60	17°07'03"	200.00'	59.75'
CL61	N69°46'28"W	...	187.91'
CL62	51°35'23"	200.00'	180.08'

- NOTE:
1. LINES/CURVES SHOWN ON THE DATA TABLE ARE NOT BROKEN AT MATCH LINES. LENGTHS ARE COMPREHENSIVE.
 2. CONTRACTOR SHALL USE DEFLECTION COUPLINGS TO INSTALL THE 4" PVC DR14 C-900 WATER PIPELINE ALONG CURVES. ALLOWABLE LENGTHS OF PIPE SECTIONS THROUGH CURVES ARE 20', 10', OR 5'. WATERLINE IS 8.0 FEET LEFT OF CENTERLINE.
 3. TELECOMMUNICATION AND ELECTRICAL LINE PER SEPARATE PLAN.



REVISIONS

NO.	WORK DONE	DATE:	BY:	APP'D:	NO.	WORK DONE	DATE:	BY:	APP'D:	NO.	WORK DONE	DATE:	BY:	APP'D:	NO.	WORK DONE	DATE:	BY:	APP'D:	NO.	

SAN DIEGO GAS & ELECTRIC COMPANY
SAN DIEGO, CALIFORNIA

SUNCREST SUBSTATION ACCESS ROAD
PLAN & PROFILE

DRAWN BY: DHT	DATE: 3/24/10	SCALE: 1"=20'	W.O.I: -	REV: 0
CHECKED BY: PJC	DATE: -	SHEET 18 OF 55		
APPROVED BY: CR	DATE: -	PLOT SCALE: 1"=1'		
CAD NO.: IPPVT18	SCR-C-218			

N:\SD039600\CADD\USFS\CIVIL\IP-PVT\IPV18

