

Southern California Edison
WODUP A.13-10-020

DATA REQUEST SET A.13-10-020 WODUP ED-SCE-01

To: ENERGY DIVISION
Prepared by: Scott Lacy, P.E.
Title: Project Engineer
Dated: 02/21/2014

Question PD-03:

Project Description

PD-3 East of the San Bernardino Substation, a proposed telecommunication line is shown running east-west on the north side of W San Bernardino Avenue. Is this line to be placed as an underbuild on the existing double circuit 66 kV subtransmission line in this area? If not how would this line be supported?

Response to Question PD-03:

Yes, in this area, the new telecommunication line would be installed as underbuild on either the new subtransmission pole line or the existing double circuit subtransmission pole line, or some combination of both as the line is routed through the area. The specific locations (i.e. which pole line) have not yet been determined. Either way, the new telecommunication line will not require a separate pole line.