

Southern California Edison
WODUP A.13-10-020

DATA REQUEST SET A.13-10-020 WODUP ED-SCE-01

To: ENERGY DIVISION
Prepared by: Scott Lacy, P.E.
Title: Project Engineer
Dated: 02/21/2014

Question PD-05 a:

Project Description

- PD-5 a** In SCE's preliminary design mapbook, it appears that an additional 220 kV double circuit structure (EC-SB 0) is added within the substation boundary.
- a. Please explain why this proposed structure is needed.

Response to Question PD-05 a:

This transmission structure is required to support the two circuits and provide adequate vertical clearances over the 220 kV operating bus inside the substation between the substation deadend racks and structure EC-SB 1.