

Notice of Determination

Appendix D

To:

Office of Planning and Research

U.S. Mail: P.O. Box 3044
Sacramento, CA 95812-3044

Street Address: 1400 Tenth St. Rm 113
Sacramento, CA 95814

County Clerk

County of: _____
Address: _____

From:

Public Agency: California Public
Utilities Commission

Address: 505 Van Ness Avenue, San Francisco, CA 94102

Contact: Jensen Uchida

Phone: 415.703.5484

Lead Agency (if different from above): _____

Address: _____

Contact: _____

Phone: _____

SUBJECT: Filing of Notice of Determination in compliance with Section 21108 or 21152 of the Public Resources Code.

State Clearinghouse Number (if submitted to State Clearinghouse): 2011071031

Project Title: SDG&E South Bay Substation Relocation Project

Project Applicant: San Diego Gas & Electric

Project Location (include county): City of Chula Vista, County of San Diego

Project Description:

The South Bay Substation Relocation Project consists of the following major components: construction of a 230/69/12-kilovolt (kV) substation (Bay Boulevard Substation) in the City of Chula Vista; construction of a 230 kV loop-in, an approximately 1,000-foot-long underground interconnection, and an approximately 300-foot-long overhead interconnection of the existing 230 kV tie-line, located east of the proposed Bay Boulevard Substation; relocation of six 69 kV transmission lines; a 138 kV extension of an approximately 3,800-foot underground and approximately 200-foot overhead span from one new steel cable pole to an existing steel lattice structure; and demolition of the existing 138/69 kV South Bay Substation.


This is to advise that the California Public Utilities Commission has approved the above described
 Lead Agency or Responsible Agency

project on September 5, 2013 and has made the following determinations regarding the above described project.
(date)

1. The project will will not] have a significant effect on the environment.
2. An Environmental Impact Report was prepared for this project pursuant to the provisions of CEQA.
 A Negative Declaration was prepared for this project pursuant to the provisions of CEQA.
3. Mitigation measures were were not] made a condition of the approval of the project.
4. A mitigation reporting or monitoring plan was was not] adopted for this project.
5. A statement of Overriding Considerations was was not] adopted for this project.
6. Findings were were not] made pursuant to the provisions of CEQA.

This is to certify that the final EIR with comments and responses and record of project approval, or the negative Declaration, is available to the General Public at: <http://www.cpuc.ca.gov/environment/info/dudek/sbsrp/SouthBaySub.htm>

Signature (Public Agency):



Title: Supervisor, Infrastructure Permitting
and CEQA, Energy Division

Date:

Aug. 29, 2013

Date Received for filing at OPR: _____

Authority cited: Sections 21083, Public Resources Code.
Reference Section 21000-21174, Public Resources Code.

Revised 2011