

Southern California Edison
MESA PTC A.15-03-003

DATA REQUEST SET A.15-03-003 ED-SCE-01 Follow Up

To: ENERGY DIVISION
Prepared by: Rey Gonzales
Title: Environmental Project Manager
Dated: 07/08/2015

Question 36-01:

Water Study

Reference: PEA, Appendix Water Study

Provide the annual quantity (in acre-feet) of water currently being used for operation of the existing Mesa Substation.

Response to Question 36-01:

Based on a review of the billing invoices received from the Monterey Park Municipal Utilities Department, the annual quantity of water usage for the Mesa Substation site in 2013/2014 (approximately 12 months) was approximately 3 acre-feet.