

Southern California Edison
MESA PTC A.15-03-003

DATA REQUEST SET A1503003 ED-SCE-02 Follow-Up

To: ENERGY DIVISION
Prepared by: Daniel Donaldson
Title: Power System Planner
Dated: 08/06/2015

Question 03.B (06-01):

Please describe the actions SCE would take if the proposed project were not implemented.

- B. With short-term solutions implemented, at what time would SCE anticipate a violation of reliability standards?

Response to Question 03.B (06-01):

SCE would anticipate that the system would remain in compliance with reliability standards until existing OTC generation facilities retire. Load shedding is not an acceptable long-term mitigation. Implementation of the items described in Part A as “b-e” may be able to reduce the magnitude of the overloads experienced but would not fully maintain compliance with reliability standards.