

ATTACHMENT B

to the Supplemental Testimony of SDG&E and SoCalGas (February 2017)

Cost-Effectiveness Analysis (Corrected February 2017)

Workpaper - Avoided Cost Model (Corrected February 2017)

Workpaper - Scenario Analysis (Corrected February 2017)

COST-EFFECTIVENESS ANALYSIS
for the
PIPELINE SAFETY & RELIABILITY PROJECT

San Diego Gas & Electric Company

and

Southern California Gas Company

Application A.15-09-013

Volume III

March 2016, as corrected February 2017

PREPARED BY PWC

WITH INPUT AND DATA FROM APPLICANTS AND CONTENT FROM APPLICANTS' CONSULTANTS

**COST-EFFECTIVENESS ANALYSIS FOR THE AMENDED APPLICATION OF SAN
DIEGO GAS & ELECTRIC COMPANY (U 902 G) AND SOUTHERN CALIFORNIA
GAS COMPANY (U 904 G) FOR A CERTIFICATE OF PUBLIC CONVENIENCE
AND NECESSITY FOR THE PIPELINE SAFETY & RELIABILITY PROJECT**

Table of Contents

I. EXECUTIVE SUMMARY	1
II. INTRODUCTION AND APPROACH.....	7
A. Background and Summary.....	7
B. Overview of Methodology.....	8
III. DESCRIPTION OF THE PROPOSED PROJECT AND THE PROJECT ALTERNATIVES.....	11
A. Proposed Project (Pipeline Safety & Reliability Project - PSRP)	11
B. Hydrotest Alternative.....	11
C. Alternative Diameter Pipeline, Various Sizes, Proposed Route	12
D. Replace Line 1600 in Place with a New 16-inch Transmission Pipeline	12
E. Otay Mesa Alternatives.....	13
F. See Alternative E: Otay Mesa Alternatives	13
G. LNG Storage (Peak Shaver) Alternative.....	13
H. Alternate Energy Alternatives.....	14
I. Offshore Route Alternative.....	15
J. Cross-County Pipeline Route Alternatives	16
K. Second Pipeline along Line 3010 Alternative	18
IV. COSTS ANALYSIS	19
A. Methodology	19
B. Estimated Costs of the Proposed Project and Alternatives.....	20
C. Avoided Costs Associated with the Proposed Project and Alternatives.....	27
D. Net Costs of the Proposed Project and Alternatives	32
V. BENEFITS ANALYSIS.....	34
A. Increased Safety	35
B. Increased Reliability	41
C. Increased Operational Flexibility.....	48
D. Increased System Capacity	51
E. Increased Gas Storage through Line Pack	54
F. Reductions in Gas Price for Ratepayers.....	54
G. Other Benefits	55
H. Supporting Analysis.....	58
I. Benefits Analysis Summary.....	72

VI. CONCLUSION.....	74
Table 1 - Ruling Requirements	2
Table 2 - Proposed Project and Alternatives Relative Benefit Ranking and Net Costs.....	3
Table 3 - Costs and Benefits Evaluated and Scored	9
Table 4 - Pipeline Material Thickness by Alternative Proposed Diameter of Line	12
Table 5 - Cost Estimate Classification Matrix for Building and General Construction Industries.....	21
Table 6 - Estimated Fixed and Operating Costs	22
Table 7 - Savings associated with the installation of a 36” or larger pipeline	31
Table 8 - Avoided Costs (Millions of 2015 Dollars)	32
Table 9 - Relative Costs of Proposed Project and Alternatives from Least to Greatest Net Cost	33
Table 10 - Benefits Evaluation Scoring Summary.....	35
Table 11 - Increased Safety Benefits Score	38
Table 12 - Safety Benefits of Alternative Diameter Pipelines.....	40
Table 13 - Safety Benefits of Other Alternatives.....	40
Table 14 - Increased Reliability Benefits Score.....	45
Table 15 - Reliability Benefits of Alternative Diameter Pipelines and the Replace Line 1600 In-Place with a New 16-inch Transmission Pipeline.....	47
Table 16 - Reliability Benefits of Other Alternatives	47
Table 17 - Increased Operational Flexibility Benefits Score	49
Table 18 - Operational Flexibility Benefits of Alternative Diameter Pipelines	50
Table 19 - Operational Flexibility Benefits of Other Alternatives	50
Table 20 - Increased System Capacity Benefits Score	52
Table 21 - System Capacity Benefits of Alternative Diameter Pipelines	53
Table 22 - System Capacity Benefits of Other Alternatives	53
Table 23 - Reduction in Gas Prices to Ratepayers Benefit Scores	54
Table 24 - Summary of Other Benefits Scores	56
Table 25 - Other Benefits of Alternative Diameter Pipelines.....	57
Table 26 - Other Benefits of Other Alternatives.....	57
Table 27 - Incident Rates	60
Table 28 - HCA Miles.....	62
Table 29 - Risk Scores	63
Table 30 - Base Assumptions for Scenario Analysis.....	64
Table 31 - Parameter Sets for Scenario Analysis.....	64
Table 32 - Seasonal Demand Variables for Scenario Analysis	65
Table 33 - Example of 48 Scenarios Analyzed for Alternate Diameter Pipeline 12".....	66
Table 34 - Natural gas customer demand and supply combinations under each seasonal demand conditions.....	67
Table 35 - Electric customer demand and supply combinations under each seasonal demand conditions.....	68
Table 36 - Outputs of Assessed Impacts.....	69

Table 37 - Ranking of Project Alternatives by Average Curtailment.....	71
Table 38 - Best and Worst Performing Alternatives.....	72
Table 39 - Relative Benefits of Proposed Project and Alternatives from Greatest to Least Benefits.....	72
Table 40 - Proposed Project and Alternatives Relative Benefit Ranking and Net Costs.....	74
Figure 1 - Net Costs and Benefits Score for Proposed Project and Alternative Projects.....	6
Figure 2 - Offshore Route Alternative (Conceptual - illustrative purposes only)	16
Figure 3 - Cross County Pipeline Route Alternatives (Conceptual - illustrative purposes only) .	17
Figure 4 - HCA Incidents by Cause	61
Figure 5 - Scenario Analysis Summary Results.....	70

I. EXECUTIVE SUMMARY

On September 30, 2015 San Diego Gas and Electric Company (SDG&E) and Southern California Gas Company (collectively the Applicants) filed Application 15-09-013¹ (Application) with the California Public Utilities Commission (CPUC or Commission) in support of their Pipeline Safety & Reliability Project (PSRP or Proposed Project).

The Proposed Project consists of constructing a new 47 mile long, 36-inch natural gas transmission line, (Line 3602), and de-rating the existing Line 1600.

On January 22, 2016 the Assigned Commissioner and Administrative Law Judge issued a joint ruling² (Ruling) directing the Applicants to file and serve an Amended Application by March 21, 2016 that includes, among other things, a cost analysis that compares the relative costs and benefits of the Proposed Project and various project alternatives (Alternatives).³ Specifically, the Ruling requires that the analysis: 1) quantify seven categories of benefits, and 2) apply quantifiable data to define the relative costs and benefits of the Proposed Project and the Alternatives identified in the Ruling.⁴ The seven categories of benefits that must be quantified are (1) increased safety; (2) increased reliability; (3) increased operational flexibility; (4) increased system capacity; (5) increased ability for gas storage by line packing; (6) reduction in the price of gas for ratepayers; and (7) other benefits identified by the Applicant.⁵

This analysis has been prepared by PricewaterhouseCoopers Advisory Services, LLC (PwC), with input and data from the Applicants, in response to the Ruling (Cost-Effectiveness Analysis). Consistent with the Ruling, the analysis applies quantifiable data to define the relative costs and benefits of the Proposed Project and Alternatives. The costs analysis includes the estimated fixed costs, the on-going operating costs, and the avoided costs (*i.e.*, costs that will not be incurred when the Proposed Project or a particular Alternative is implemented). The benefits analysis evaluates each of the seven types of benefits specifically identified in the Ruling.

¹ Certificate of Public Convenience and Necessity for the Pipeline Safety and Reliability Project, Application (A.) 15-09-013.

² Joint Assigned Commissioner and Administrative Law Judge's Ruling Requiring an Amended Application and Seeking Protests, Responses and Replies (Ruling).

³ Ruling, pages 11-14.

⁴ Ruling, page 12.

⁵ Ruling, page 12.

Table 1 below highlights the requirements in the Ruling that are addressed by this Cost-Effectiveness Analysis.

Table 1 - Ruling Requirements

Ruling Requirement ⁶	Method for Complying with the Ruling	Reference in Cost-Effectiveness Report
<p><i>The analysis will quantify specific benefits including: (1) increased safety; (2) increased reliability; (3) increased operational flexibility; (4) increased system capacity; (5) increased ability for gas storage by line packing; (6) reduction in the price of gas for ratepayers; and (7) other benefits identified by the Applicant. All benefits must be quantified.</i></p>	<p>A benefits scoring model was developed based on quantifiable data for each of the seven benefit types.</p>	<ul style="list-style-type: none"> • Section V: Benefits Analysis • Table 11 - Increased Safety Benefits Score • Table 14 - Increased Reliability Benefits Score • • • Table 17 - Increased Operational Flexibility Benefits Score • Table 20 - Increased System Capacity Benefits Score • Increased Gas Storage through Line Pack – included under Increased System Capacity • Table 23 - Reduction in Gas Prices to Ratepayers Benefit Scores • Table 24 - Summary of Other Benefits Scores
<p><i>The analysis will apply quantifiable data to define the relative costs of the proposed project and, at a minimum, the range of alternatives identified in this Ruling.⁷</i></p>	<p>First, preliminary cost estimates were developed for the Proposed Project and the Alternatives, then an “avoided cost” was calculated for the Proposed Project and each Alternative so that a “net cost” could be derived for each.</p>	<ul style="list-style-type: none"> • Section IV: Cost Analysis • Table 6 - Estimated Fixed and Operating Costs • Section IV, C: Avoided Costs Associated with the Proposed Project and Alternatives • • Table 8 Avoided Costs
<p><i>The analysis will apply quantifiable data to define the relative benefits of the proposed project and, at a minimum, the range of alternatives.</i></p>	<p>A benefit score was developed for the Proposed Project and each Alternative.</p>	<ul style="list-style-type: none"> • Table 2 - Proposed Project and Alternatives Relative Benefit Ranking and Net Costs
<p><i>Include an estimate of costs, both fixed and operating, as required by Rule 3.1(f).</i></p>	<p>Preliminary estimates were developed for both the fixed and operating costs for the Proposed Project and the Alternatives using standard estimating methods based on the known project scope.</p>	<ul style="list-style-type: none"> • Section IV: Cost Estimating • Table 6 - Estimated Fixed and Operating Costs

⁶ Ruling, page 12.

⁷ The range of alternatives refers to the 10 alternative projects labeled A-K in the Ruling, pages 12-13.

The relative costs and benefits of the Proposed Project and Alternatives are summarized in Table 2 below.

Table 2 - Proposed Project and Alternatives Relative Benefit Ranking⁸ and Net Costs⁹

Project Alternatives		Benefit Rank	Net Cost (\$M)
A	Proposed Project (36" pipeline Rainbow to Line 2010 Route)	1	\$256.2
B	Hydrotest Alternative ¹⁰	15	\$118.7
C1	Alt Diameter Pipeline, Proposed Route (10")	18	\$302.7
C2	Alt Diameter Pipeline, Proposed Route (12")	18	\$291.6
C3	Alt Diameter Pipeline, Proposed Route (16")	11	\$241.4
C4	Alt Diameter Pipeline, Proposed Route (20")	10	\$239.2
C5	Alt Diameter Pipeline, Proposed Route (24")	9	\$229.6
C6	Alt Diameter Pipeline, Proposed Route (30")	8	\$233.5
C7	Alt Diameter Pipeline, Proposed Route (42")	1	\$341.9
D	Replace Line 1600 in Place with a 16" Transmission Pipeline Alternative	12	\$460.1
E/F	Otay Mesa Alternatives ¹¹	13	\$876.8
G	LNG Storage (Peak-Shaver) Alternative	14	\$2,584.7
H1	Alternate Energy Alternative: Grid-Scale Batteries	16	\$8,330.1
H2	Alternate Energy Alternative: Smaller-Scale Batteries	16	\$10,010.1
I	Offshore Route	7	\$1,295.5
J1	Blythe to Santee Alternative 1	3	\$1,219.3
J2	Blythe to Santee Alternative 2	3	\$1,157.3
J3	Cactus City to San Diego Alternative	3	\$981.1
K	Second Pipeline Along Line 3010 Alternative	3	\$427.1

After evaluating the net costs and benefits of the Proposed Project and Alternatives, this Cost-Effectiveness Analysis concludes that the Proposed Project is the most cost-effective, prudent alternative. This conclusion is based on the following:

⁸ Ranked from 1 through 19 with 1 being the highest rank.

⁹ Net costs are calculated as: Fixed Costs + Operations & Maintenance Costs + Avoided Costs. Net costs are discussed in Section IV, C.

¹⁰ In the Ruling, Alternative B is referred to as the “No Project Alternative” and defined as hydrotesting Line 1600 in sections and repairing or replacing pipeline segments as needed. The Applicants refer to Alternative B herein as the “Hydrotest Alternative.”

¹¹ The Ruling identifies two alternative projects utilizing the Otay Mesa receipt point: Non-Physical (Contractual) or Minimal Footprint Solutions (Alternative E); and the Northern Baja Alternative (Alternative F). Both of these rely upon the use of Otay Mesa receipt point (Otay Mesa) capacity in place of the Proposed Project. Accordingly, the Applicants will refer to the two alternatives as a single project titled “Otay Mesa Alternatives.” See Prepared Direct Testimony of Gwen Marelli (March 21, 2016).

- The lowest net cost project, the Hydrotest Alternative, was ranked among the lowest in terms of project benefits;
- The Proposed Project and the Alternate Diameter Pipeline (42-inch) are ranked highest in terms of benefits and also among the highest in terms of having the least net costs;
- The difference in net costs between the least-cost, Hydrotest Alternative, and the Proposed Project is approximately \$138 million, which is outweighed by significant, quantifiable benefits that are not offered by the Hydrotest Alternative;
- After the least-cost alternative (Hydrotest Alternative), five projects are clustered in the net cost range of \$225 million to \$260 million and include alternate pipeline diameters of 16-, 20-, 24-, 30- and 36-inches (the Proposed Project);
- In terms of benefits, the Proposed Project scored higher than the four other Alternatives that also ranked in the net cost range of \$225 million to \$260 million (Alternative Diameters Pipelines 16-, 20-, 24- and 30-inch);
- After the cluster that includes the Proposed Project, the next group of projects grouped by least net cost ranges from \$290 million to \$465 million and includes Alternate Diameters of 10-, 12- and 42-inches, the Replace Line 1600 In-Place with a New 16-inch Transmission Pipeline Alternative, and the Second Pipeline Along Line 3010 Alternative;
- The two highest net cost categories include Alternatives with net costs ranging from \$500 million to \$1 billion (Otay Mesa Alternatives, Cactus City to San Diego) and more than \$1 billion (Blythe to Santee Pipeline Route Alternatives 1 and 2, Off-Shore, Liquefied Natural Gas (LNG) Storage, and Alternate Energy Alternatives);
- Four Alternatives rank second highest in terms of benefits: the Cross-Country Pipeline Route Alternatives (Blythe to Santee Pipeline Routes, Alternatives 1 and 2; Cactus City to San Diego Alternative) and the Second Pipeline Along Line 3010 Alternative;
- The 10- and 12-inch Alternative Diameter Pipelines rank lowest in terms of benefits;
- New, larger diameter pipelines, including the Proposed Project, outperform the “least-cost” (Hydrotest Alternative) in six out of the seven benefits categories (safety, reliability, operational flexibility, system capacity, gas storage through line pack, and other benefits) and receive the same score for the category of reduction in gas price for ratepayers;

- As compared to the 16-, 20-, 24- and 30-inch Alternate Diameter Pipelines, the Proposed Project provides additional reliability, operational flexibility, system capacity, gas storage through line pack, and other benefits;
- The 42-inch Alternate Diameter Pipeline offers the same benefits as the Proposed Project but costs approximately \$86 million more.


For these reasons, the Proposed Project is identified as the overall most cost-effective alternative.

The results of this Cost-Effectiveness Analysis – the net costs and benefits - are shown in Figure 1 below.¹²

¹² The following Alternatives have been excluded from the chart in order to manage axis scale:

- LNG Storage - Benefit Score 18.6, net cost \$2.6B
- Alt Energy (Grid Scale) - Benefit Score 16.2, net cost \$8.3B
- Alt Energy (Smaller Scale) - Benefit Score 16.2, net cost \$10B

Figure 1 - Net Costs and Benefits Score for Proposed Project and Alternative Projects



II. INTRODUCTION AND APPROACH

A. Background and Summary

On September 30, 2015 San Diego Gas and Electric Company (SDG&E) and Southern California Gas Company (collectively, the Applicants) submitted an application to the California Public Utilities Commission (CPUC or Commission) for a Certificate of Public Convenience and Necessity (CPCN) for the Pipeline Safety & Reliability Project, Application 15-09-013 (Application). The Proposed Project consists of constructing a new 47 mile long, 36-inch natural gas transmission line (Line 3602), along with the de-rating of existing Line 1600 (Proposed Project).

On January 22, 2016 the Assigned Commissioner and Administrative Law Judge issued the Joint Assigned Commissioner and Administrative Law Judge's Ruling Requiring an Amended Application and Seeking Protests, Responses and Replies. The Ruling directs the Applicants to file and serve an Amended Application by March 21, 2016 that includes, among other things, a cost analysis that compares the relative costs and benefits of the Proposed Project and various Alternatives.¹³ Specifically, the Ruling states:

- [Applicants] shall include a needs analysis in compliance with Rule 3.1(e) and cost analysis comparing the project with any feasible alternative sources of power, in compliance with Section 1003(d) and Rule 3.1(f).¹⁴
- The analysis will quantify specific benefits including: 1) increased safety; 2) increased reliability; 3) increased operational flexibility; 4) increased system capacity; 5) increased ability for gas storage by line packing; 6) reduction in the price of gas for ratepayers; and 7) other benefits identified by Applicant.¹⁵
- The analysis will apply quantifiable data to define the relative costs and benefits of the Proposed Project and, at a minimum, the range of alternatives identified in the Ruling. (For purposes of analysis, the cost analysis shall assume that each of the [identified] alternatives are feasible and include an estimate of costs, both fixed and operating, as required by Rule 3.1(f).)¹⁶

The “range of alternatives” briefly identified in the Ruling¹⁷ is described in Section III of this Cost-Effectiveness Analysis, together with the assumptions made by the Applicants regarding the Alternatives.

¹³ Ruling, pages 11-14.

¹⁴ Ruling, page 11.

¹⁵ Ruling, page 12.

¹⁶ Ruling, page 12.

¹⁷ Ruling, pages 12-13.

This Cost-Effectiveness Analysis has been prepared by PwC, with data and input from the Applicants, to address the requirement that Applicants prepare a cost analysis comparing the Proposed Project with the Alternatives; quantify specific benefit categories; and apply quantifiable data to define the relative costs and benefits of the Proposed Project and Alternatives. Per the Ruling, this Cost-Effectiveness Analysis assumes that each of the Alternatives is feasible.¹⁸

B. Overview of Methodology

Consistent with industry practice and Commission and Federal Energy Regulatory Commission (FERC) precedent,¹⁹ PwC, with input and data from the Applicants, undertook this Cost-Effectiveness Analysis to quantify and compare the relative costs and benefits of the Proposed Project and Alternatives described in the Ruling.

A cost-effectiveness analysis compares the cost of a project to different measures of program benefits.¹² A cost-effectiveness analysis evaluates not only the monetary benefits of a project but also considers benefits that are difficult or impractical to express in monetary terms. These benefits can be expressed in monetary or non-monetary (yet quantitative) units. Cost-effectiveness analyses have been applied to projects with both monetary and non-monetary benefits.

¹⁸ Ruling, page 12.

¹⁹ The CPUC has utilized cost-effectiveness analysis for evaluating the costs and benefits of a project or program. For example, the CPUC requirements for evaluating demand-side management program include:

“All demand-side resources (energy efficiency, demand response, and distributed generation) undergo a cost-effectiveness analysis. While the specific tests and the applications of those tests varies among the resources, the foundation of cost-effectiveness analysis for all demand-side resources is based in the Standard Practice Manual. The Standard Practice Manual contains the Commission’s method of evaluating energy saving investments using various cost-effectiveness tests. The four tests described in the Standard Practice Manual assess the costs and benefits of demand-side resource programs from different stakeholder perspectives, including participants and non-participants.”

(<http://www.cpuc.ca.gov/General.aspx?id=5267>)

FERC has also approved the use of a cost-effectiveness analysis to evaluate transmission planning projects.

“Here, the cost-effectiveness evaluation applies to projects considered not only to provide economic benefits but also to provide reliability benefits and to meet public policy requirements. While the benefits of projects considered purely for economics (e.g. adjusted production cost savings) may be quantified readily and included in a formula, reliability benefits and benefits derived from meeting public policy requirements may not be so readily quantifiable and detailed, and thus cannot easily be included in a formula.”

(<https://ferc.gov/whats-new/comm-meet/2011/072111/e-3.pdf>)

This Cost-Effectiveness Analysis, undertaken to comply with the Ruling, is based on two forms of benefits analysis: quantitative financial analysis and quantitative non-cost, unit-based analysis (unit benefits). The different types of analysis and the mechanisms used to score and compare the benefits are discussed in the following sections of this Cost-Effectiveness Analysis.

The Ruling requires the Applicants to conduct an analysis that will apply quantifiable data to define the relative costs and benefits of the Proposed Project and a range of Alternatives.²⁰ To comply with the requirement to apply quantifiable data to define the relative costs of the projects, PwC reviewed the Applicants’ estimates of both the fixed cost for constructing the Proposed Project and the Alternatives and the on-going estimated costs for operating and maintaining them. Additionally, PwC and the Applicants identified certain avoided costs applicable to the Proposed Project and the Alternatives. PwC and the Applicants then quantified the impact of those avoided costs on the Proposed Project and the Alternatives over time to derive the “net cost” associated with the Proposed Project and each Alternative.

To comply with the requirement to apply quantifiable data to define the relative benefits of the projects, PwC and the Applicants first identified quantifiable characteristics and desirable outcomes associated with the seven benefits categories identified in the Ruling. Next, a scoring mechanism was developed and applied as an objective means to evaluate the Proposed Project and the Alternatives against each of the seven benefit types. The Applicants identified and defined a number of individual benefits within each of the seven benefit categories and applied non-monetary, quantifiable measures (*e.g.*, percent reduction in pipeline failures, percent increase in capacity) as the basis for scoring the Proposed Project and the Alternatives against each benefit. Care was taken to treat each benefit as unique and not count them more than one time in the scoring model. Once each of the projects was scored, PwC ranked them from highest to lowest based on the overall benefit score.

Table 3 lists the costs and benefits evaluated and scored consistent with the requirements of the Ruling.

Table 3 - Costs and Benefits Evaluated and Scored

Description	Type of Assessment		Metric/Measure
	Quantitative Monetary	Quantitative Non-Monetary	
Project Costs - Fixed costs	✓		Dollars
Project Costs - Operating costs	✓		Dollars

²⁰ Ruling, page 12.

Description	Type of Assessment		Metric/Measure
	Quantitative Monetary	Quantitative Non-Monetary	
Avoided Costs - Replacement of Line 1600	✓		Dollars
Avoided Costs - Reduced operation of Moreno Compressor Station	✓		Dollars
Safety – Increased safety margin to prevent pipeline rupture through the de-rating of Line 1600		✓	Defined benefit score
Safety - Long-term safety benefit of transmission pipeline		✓	Defined benefit score
Safety - Reduction in incidents per HCA mile of pipeline		✓	Defined benefit score
Safety - Increased real-time awareness of excavation damage		✓	Defined benefit score
Safety - Achievement of “as soon as practicable” safety objective		✓	Duration by year
Increased Reliability - Redundancy to natural gas transmission system		✓	Defined benefit score
Increased Reliability - Curtailment impact to core gas customers		✓	Percentile of average severity of curtailment scores
Increased Reliability - Curtailment impact to electric generation (EG) gas customers		✓	Percentile of average severity of curtailment scores
Increased Operational Flexibility - Meeting current and future natural gas peak demand		✓	Defined benefit score
Increased Operational Flexibility - Utility operational control of asset		✓	Defined benefit score
Increased System Capacity - Impact to system capacity		✓	Percentage increase in MMcfd of capacity
Increased gas storage through line pack		✓	Proportional to capacity
Reduction in gas prices to ratepayers		✓	Defined benefit score
Other Benefits - Emissions reductions due to reduced operating hours at compressor stations		✓	Percent reduction in net Moreno operating hours

All of the underlying estimates and technical data used to develop the cost estimates, avoided cost estimates and quantifiable benefits analysis were provided by the Applicants.

III. DESCRIPTION OF THE PROPOSED PROJECT AND THE PROJECT ALTERNATIVES

This section briefly summarizes the Proposed Project and the Alternatives identified in the Ruling.

For all of the Alternatives except the Hydrotest Alternative and the Replace Line 1600 in Place with a New 16-inch Transmission Pipeline Alternative, Line 1600 would be de-rated and operated as a distribution asset.

A. Proposed Project (Pipeline Safety & Reliability Project - PSRP)

Line 3602 is the proposed new 36-inch diameter, 47-mile long natural gas transmission pipeline connecting the existing Rainbow Metering Station to Marine Corps Air Station (MCAS) Miramar. Additionally, the Proposed Project includes the de-rating of the existing Line 1600, a 16-inch natural gas transmission pipeline that also runs from Rainbow Station to Miramar.

For additional information regarding the Proposed Project, please reference Applicants' PEA.²¹

B. Hydrotest Alternative

In the Ruling, the No Project Alternative includes hydrotesting Line 1600 in sections and only repairing or replacing pipeline segments as needed.²²

The Hydrotest Alternative involves a complex three year project to test the northern 45-miles of Line 1600, from Rainbow Metering Station to Kearny Villa Station. Line 1600 is an approximately 50-mile, 16-inch diameter, high pressure natural gas transmission pipeline that begins at the Rainbow Metering Station and terminates at Mission Station in San Diego.²³ The Hydrotest Alternative will involve testing 19 different pipeline segments during the shoulder months.²⁴ The Applicants would hydrotest Line 1600 in sections and only repair or replace pipeline segments as needed.

Testing will require installing bypasses and arranging for alternative distribution requirements and could include environmental mitigation and community impacts. It will also require gas to be imported from the gas transmission system receipt point located at Otay Mesa.

²¹ A.15-09-013, Volume II, Proponent's Environmental Assessment (PEA), Chapter 3.0, Project Description and Chapter 5.2.3, pages 5-16.

²² Ruling, page 12.

²³ Line 1600 Hydrotest Study and Cost Estimate. *See* Prepared Direct Testimony of Neil Navin (March 21, 2016), Attachment A, Appendix 12.

²⁴ The shoulder months are from April 1 through June 15, and October 1 through December 15.

For additional information regarding this Alternative, please refer to the Line 1600 Hydrotest Study and Cost Estimate.²⁵

C. Alternative Diameter Pipeline, Various Sizes, Proposed Route

This Alternative requires the Applicants to evaluate the installation of different sized pipelines of alternate diameters. This analysis assumed the same proposed route as the 47-mile Proposed Project from Rainbow Metering Station to MCAS Miramar. The seven alternate diameters addressed in this Cost-Effectiveness Analysis are:

Table 4 - Pipeline Material Thickness by Alternative Proposed Diameter of Line²⁶

No.:	Alternate Diameter ²⁷	Pipeline Specification
C1	Alt. Dia. 10"	Pipe, 10", X-52, 0.365" WT, FBE
C2	Alt. Dia. 12"	Pipe, 12", X-52, 0.375" WT, FBE
C3	Alt. Dia. 16"	Pipe, 16", X-52, 0.375" WT, FBE
C4	Alt. Dia. 20"	Pipe, 20", X-52, 0.375" WT, FBE
C5	Alt. Dia. 24"	Pipe, 24", X-65, 0.375" WT, FBE
C6	Alt. Dia. 30"	Pipe, 30", X-65, 0.50" WT, FBE
C7	Alt. Dia. 42"	Pipe, 42", X-60, 0.750" WT, FBE

Alternative C was included in the Ruling²⁸ but was not included in the PEA.

D. Replace Line 1600 in Place with a New 16-inch Transmission Pipeline

This Alternative requires the removal of the existing Line 1600 and replacing it with a new 16-inch diameter pipeline within existing easements.

Nineteen pipeline segments covering approximately 45 miles would be removed and replaced. Removal and replacement would be conducted in phases.

For additional information regarding Alternative D, please refer to the PEA.²⁹

²⁵ See Prepared Direct Testimony of Neil Navin (March 21, 2016), Attachment B.

²⁶ Provided by the Applicants.

²⁷ The Ruling calls for “an evaluation of pipeline sizes that range in diameter from 10 inches to 40 inches.” On February 9, 2016, the Applicants confirmed with Energy Division staff that standard-sized pipeline diameters within this range should be evaluated and that a 42-inch diameter alternative can be included because 40 inches is not a standard size diameter.

²⁸ Ruling, page 13.

²⁹ PEA, Chapter 5.2.2, Page 5-9.

E. Otay Mesa Alternatives

The Ruling identifies two alternative projects utilizing the Otay Mesa receipt point: Non-Physical (Contractual) or Minimal Footprint Solutions (Alternative E); and the Northern Baja Alternative (Alternative F).³⁰ Both of these rely upon the use of Otay Mesa receipt point (Otay Mesa) capacity in place of the Proposed Project. Accordingly, the Applicants will refer to the two alternatives as a single project titled “Otay Mesa Alternatives.”

In order to deliver 400 million cubic feet per day (MMcfd) on a firm basis, the Otay Mesa Alternatives requires the physical construction of new pipeline facilities³¹ via an expansion on the North Baja pipeline systems. These Alternatives would also require the Applicants to secure a multi-year capacity contract for the transportation of gas supplies.³²

Several variations for Alternative E were described in the Ruling³³ that would also rely upon the use of Otay Mesa capacity; therefore, the Applicants assumed the same costs based on the Otay Mesa Alternatives assumptions above for purposes of this Cost-Effectiveness Analysis, even though these variations would potentially have incremental costs.

Alternative E was not included in the PEA, but was included in the Ruling.³⁴

F. See Alternative E: Otay Mesa Alternatives

Alternative F is discussed in conjunction with Alternative E above. Alternative F was included in the PEA and in the Ruling.³⁵

G. LNG Storage (Peak Shaver) Alternative

This LNG Alternative entails the construction of four independent LNG storage and regasification facilities, each located adjacent to an existing electric generating plant. This alternative is similar to the PEA’s “United States – LNG Alternative,” but at a smaller scale with LNG storage sited at or near natural gas peaker generation sites.”

³⁰ Ruling, page 13.

³¹ The Applicants were ordered in the Ruling to consider other specific options in Alternative E. These options included: 1) use of the Southern System Minimum Flow Requirement; 2) operational flow orders (OFO); 3) system balancing; and 4) tariff discounts.

³² See Prepared Direct Testimony of Gwen Marelli (March 21, 2016).

³³ See Amended Application.

³⁴ Ruling, page 13.

³⁵ Ruling, page 13.

LNG storage would serve three existing gas-fired generation sites in the SDG&E system, which is comprised of combustion turbines, steam turbines at Encina Power Plant (located in Carlsbad), the combined cycle plants at Palomar Energy Center (located in Escondido) and the Otay Mesa Energy Center (located in Otay Mesa), with LNG storage to serve one (1) planned (future) generation site in Pio Pico.

Each LNG facility would require rail or truck deliveries of LNG to support peak capacity shaving requirements or ability for each electric generating plant to operate for at least 5 days from LNG storage.

Alternative G was not included in the PEA but was included in the Ruling.³⁶

H. Alternate Energy Alternatives

1. Alternative H1: Grid-Scale Battery / Energy Storage

The Applicants assume that Alternative H1 – Grid Scale Battery/Energy Storage - envisions the installation of a system of grid-scale batteries and associated equipment that would be sufficient to supply customers with energy equivalent to the Proposed Project.

The Applicants' evaluation of Alternative H1 is based on a scenario under which: the gas supply is lost to all local electric generation during a peak load period; gas supply is unavailable for a four-hour period; and that no customer outages would occur. The Applicants are unaware of a battery storage project of this magnitude being undertaken and, as a result, battery production on this scale would be very difficult, very expensive, very large (requiring approximately 100 acres of land) and would take a very long time to produce.

A system of grid-scale batteries might provide four hours of electric supply under the circumstances that electric generation was unavailable due to the loss of the natural gas supply; however, grid-scale batteries would not provide any energy replacement for the residential and business needs that are currently supplied by natural gas. For example, during the four hour period, customers might still receive electricity service from the grid-scale batteries, but would not have any natural gas service to operate their gas water heaters, gas heating units, gas appliances or any other gas supplied equipment.

In order for the four hours of grid-scale storage to be ready and available if a system wide natural gas outage occurred, the system of batteries would need to be fully charged at all times. It is likely that grid-scale batteries would be charged and discharged on a regular basis and operated by the California Independent System Operator (CAISO) as an ongoing resource it could count

³⁶ Ruling, page 13.

on for grid reliability purposes. Therefore, depending on the timing of a natural gas outage, there is no certainty that the system of batteries would be fully charged when needed.³⁷

2. Alternative H2: Smaller-Scale Battery Storage

The Applicants assume that a smaller-scale, alternative energy battery storage involves the installation of smaller-scale batteries and associated equipment to supplement the gas supply system at times when additional capacity is needed (e.g. unplanned outages, maintenance, peak demand). Similar to the grid-scale battery storage project, the Applicants assume that smaller-scale battery storage would supply four hours of electric supply, including approximately 11,200 MWh of energy storage capacity.

Similar to the issue with the grid-scale battery storage, smaller-scale battery storage would not provide any energy replacement for the residential and business needs that are currently supplied by natural gas. Customers might still receive electricity service from the batteries, but would not have any natural gas service. Likewise, the same issues exist in that the system of batteries would need to be fully charged at all times, but would be charged and discharged on a regular basis and operated by the CAISO as an ongoing resource it could count on for grid reliability purposes. Therefore, depending on the timing of a natural gas outage, there is no certainty that the system of batteries would be fully charged when needed.³⁸

The Applicants could not identify any other reliable alternate energy options that do not require the installation of a new gas transmission pipeline.³⁹

Alternative H was included in the Ruling⁴⁰ but was not included within the PEA.

Henceforth, Alternatives H1 and H2 will be referred to as “Alternative Energy.”

I. Offshore Route Alternative

The Offshore Route Alternative assumes construction of a 36-inch diameter underwater pipeline off of the shore of Southern California, transitioning from offshore to onshore at Line 3010/3011 intersection (receiving point for supply gas to other pipelines in San Diego region). Figure 2 below shows a potential route for this Alternative.

For additional information regarding Alternative I, please refer to the PEA.⁴¹

³⁷ See Prepared Direct Testimony of S. Ali Yari (March 21, 2016).

³⁸ See Prepared Direct Testimony of S. Ali Yari (March 21, 2016).

³⁹ See Prepared Direct Testimony of S. Ali Yari (March 21, 2016).

⁴⁰ Ruling, page 13.

⁴¹ PEA, Chapter 5.2.2, Page 5-6.




Figure 2 - Offshore Route Alternative (Conceptual - illustrative purposes only)

J. Cross-County Pipeline Route Alternatives

The Cross-County Pipeline Route Alternatives comprise three distinguishable routes from Riverside and Imperial counties to the San Diego area. The alternative routes are shown in Figure 3 and discussed below.




Figure 3 - Cross County Pipeline Route Alternatives (Conceptual - illustrative purposes only)

1. Blythe to Santee Alternative 1

This 222 mile cross-county pipeline initiates in the City of Blythe and traverses directly west, veering south near the northwestern corner of the Salton Sea in Riverside County. The route would then shift southwardly through Imperial County until just north of Ocotillo, at which point the route would run in a general westerly direction until its terminus within the community of Spring Valley. Approximately 202 miles of pipeline would be sited cross-county on undeveloped land, including land that is managed by eight different state and federal agencies.⁴²

2. Blythe to Santee Alternative 2

This 223 mile cross-county pipeline initiates in the City of Blythe and travels south until nearly reaching the City of Yuma, Arizona. At the City of Yuma, the route would veer west, following I-8 until its terminus within the community of Spring Valley. This Alternative would run through Riverside, Imperial, and San Diego counties. Approximately 199 miles of pipeline would be sited cross-county on undeveloped land, including land that is managed by eight different state and federal agencies.⁴³

⁴² PEA, Chapter 5.0, page 5-28.

⁴³ PEA, Chapter 5.0, page 5-30.

3. Cactus City to San Diego

This 160 mile cross-county pipeline initiates in Cactus City and travel south until just north of Ocotillo, at which point the route would shift west and travel generally in a western direction until its terminus within the community of Spring Valley. Approximately 120 miles of pipeline would be sited cross-county on undeveloped land that is managed by eight different state and federal agencies.⁴⁴

Alternatives J1-J3 were included in the Ruling as “Cross-County Pipeline Route Alternatives.”⁴⁵ For additional information regarding Alternatives J1-J3, please refer to the PEA.⁴⁶

K. Second Pipeline along Line 3010 Alternative

The Second Pipeline along Line 3010 Alternative would consist of constructing a new 36-inch pipeline approximately 45 miles in length, running adjacent to the existing 30-inch Line 3010. The second pipeline would originate at the existing Rainbow Metering Station and terminate at Line 3010’s interconnect with Line 2010.

For additional information regarding Alternative K, please refer to the PEA.⁴⁷

⁴⁴ PEA, Chapter 5.0, page 5-32.

⁴⁵ Ruling, page 13.

⁴⁶ PEA, Chapter 5.2.3, Pages 5-28, 5-30, 5-32.

⁴⁷ PEA, Chapter 5.2.3, Page 5-33.

IV. COSTS ANALYSIS

A. Methodology

The Ruling⁴⁸ directs Applicants to file an Amended Application that includes a cost analysis comparing the Proposed Project with any feasible alternative sources of power, in compliance with Section 1003(d) and Rule 3.1(f). Section 1003(d) requires “*Every electrical and every gas corporation submitting an application to the commission for a certificate authorizing the new construction of any electrical plant, line, or extension or gas plant, line or extension... shall include all of the following information... (d) a cost analysis comparing the project with any feasible alternative sources of power.*” Rule 3.1(f) requires “*a statement detailing the estimated cost of proposed construction or extension and the estimated annual costs, both fixed and operating associate therewith. In the case of a utility which has not yet commenced service or which has been rendering service for less than 12 months, the applicant shall file as part of the application supporting statements or exhibits showing that the proposed construction is in the public interest, and whether it is economically feasible.*”

In most cases, implementing the Proposed Project or one of the Alternatives will avoid certain costs that would arise if another alternative were implemented. To illustrate, constructing a new pipeline to replace the transmission function of Line 1600 would reduce or avoid certain costs associated with operating the Moreno Valley Compressor Station. The methodology used to account for these “avoided costs” (or savings), and develop a “net cost” for the Proposed Project and each of the Alternatives is expressed in simple terms as follows:

$$\text{Fixed Costs} + \text{O\&M Costs} + \text{Avoided Costs} = \text{Net Costs}$$

For the purposes of this Cost-Effectiveness Analysis, the Applicants’ do not distinguish between capital and expense costs.

The Applicants developed the fixed cost estimate for the Proposed Project and Alternatives using common, industry standard estimating practices, aligned with Association for the Advancement of Cost Engineering Recommended Practices.⁴⁹ The estimates are based on a combination of market research, historical data, parametric modeling, semi-detailed unit costs and order-of-magnitude estimating based on experience and engineering judgment. The level of scope definition and estimating accuracy has been defined by references to the Association for the Advancement of Cost Engineering (AACE) RP 56R-08 Classification system, described below.

For the Proposed Project and all the Alternatives except the Hydrotest Alternative (Alternative B) and Replace Line 1600 in Place with a New 16-inch Transmission Pipeline Alternative

⁴⁸ Ruling, pages 11-12.

⁴⁹ AACE® International Recommended Practice No. 56R-08.

(Alternative D), Line 1600 would be de-rated and operate as a distribution asset. The costs for de-rating Line 1600 are included in the fixed cost estimate for all the Alternatives except Alternatives B and D. The costs for de-rating Line 1600 were developed based on a combination of historical data, semi-detailed unit costs, and engineering experience and judgment. Under the Hydrotest Alternative, it is anticipated that Line 1600 will be replaced within approximately 20 years.

Applicants also estimated the on-going, annual operating costs for the Proposed Project and the Alternatives. The operating costs for the pipeline alternatives also include amounts for complying with Transmission Integrity Management Program (TIMP) requirements. The operating cost estimates were developed using a combination of historical operations and maintenance costs and other estimates based on Applicants' engineering judgment. This analysis assumes that operating costs for the Otay Mesa Alternatives are included in Applicants' contract pricing.

B. Estimated Costs of the Proposed Project and Alternatives

Cost Estimate Classification

In support of the Application filing in September 2015, Applicants developed a cost estimate for the Proposed Project based on a defined route, semi-detailed design and engineering, and a robust environmental assessment. By contrast, the maturity of the estimates for each Alternative is lower, due to the lack of detailed definition for key project cost drivers – such as scope definition, level of completed design and engineering, material and labor requirements, permitting needs, environmental requirements, and schedule/sequence assumptions.

For those Alternatives that were not carried forward by Applicants in the PEA⁵⁰ – the Off-Shore Route Alternative, Existing Alignment Alternatives (Replace Line 1600 In-Place with a New 16-inch Transmission Pipeline Alternative, New 16" or 36" Pipe Parallel to Line 1600), LNG Alternatives, Infrastructure Corridor Alternative, and the Northern Baja Alternative – detailed cost estimates were not prepared. Only high-level cost estimates are available for those Alternatives, which were previously determined by the Applicants to be imprudent as compared to the Proposed Project.

The Applicants' estimating team evaluated each of the project estimates against the AACE International⁵¹ Recommended Practices, specifically, the cost estimate classification system, to classify the level of maturity of each estimate. The AACE classification is based on the

⁵⁰ PEA, Chapter 5.0, pages 5-6 through 5-15.

⁵¹ AACE International developed a guideline for cost estimate classification in the late 1960s to early 1970s. Those guidelines and standards are generally accepted in the engineering and construction communities as a means for evaluating the maturity of a project cost estimate.

relationship between scope definition and estimate accuracy. The estimate accuracy range is based on known scope, but excludes unforeseen risks that could alter that scope.⁵²

The AACE matrix maturity levels are defined on a scale from 1 through 5 based on Primary Characteristics and Secondary Characteristics, as shown below:

Table 5 - Cost Estimate Classification Matrix for Building and General Construction Industries

ESTIMATE CLASS	Primary Characteristic	Secondary Characteristic		
	MATURITY LEVEL OF PROJECT DEFINITION DELIVERABLES Expressed as % of complete definition	END USAGE Typical purpose of estimate	METHODOLOGY Typical estimating method	EXPECTED ACCURACY RANGE Typical variation in low and high ranges ⁵³
Class 5	0% to 2%	Functional area, or concept screening	SF or m ² factoring, parametric models, judgment, or analogy	L: -20% to -30% H: +30% to +50%
Class 4	1% to 15%	Schematic design or concept study	Parametric models, assembly driven models	L: -10% to -20% H: +20% to +30%
Class 3	10% to 40%	Design development, budget authorization, feasibility	Semi-detailed unit costs with assembly level line items	L: -5% to -15% H: +10% to +20%
Class 2	30% to 75%	Control or bid/tender, semi-detailed	Detailed unit costs with forced detailed take-off	L: -5% to -10% H: +5% to +15%
Class 1	65% to 100%	Check estimate or pre bid/tender, change order	Detailed unit costs with detailed take-off	L: -3% to -5% H: +3% to +10%

The cost estimates prepared by the Applicants were developed based on the known and anticipated project scope at the time of the filing (September 2015), along with additional estimating information that was collected or developed for the Proposed Project and certain alternative projects that were subsequently identified in the Ruling. Table 6 below shows the estimated fixed cost and annual operating costs for the Proposed Projects and each of the Alternatives.

⁵² AACE Recommended Practice, No. 56R-08, Cost Estimate Classification System – As Applied for the Building and General Construction Industries, TCM Framework: 7.3 – Cost Estimating and Budgeting, Rev. December 5, 2012. 7 AACE International Recommended Practice, No. 34-R-05, TCM Framework: 7.3 - Cost Estimating and Budgeting, 2007, p. 4.

⁵³ The state of construction complexity and availability of applicable reference cost data affect the range markedly. The +/- value represents typical percentage variation of actual cost from the cost estimate after application of contingency (typically at a 50% level of confidence) for given scope.

The estimated costs for the Proposed Project and the Alternatives include contingency. Per the AACE, contingency is defined as “a cost element of the estimate used to cover the uncertainty and variability associated with a cost estimate, and unforeseeable elements of cost within the defined project scope.”⁵⁴ Including a contingency allows for uncertain cost elements to be included in the project budget, even though the exact contingency-related expenditures and unforeseen events are currently unknown.

Table 6 - Estimated Fixed and Operating Costs⁵⁵

Alt. No.	Project Name	(Millions of 2015 Dollars)	
		Fixed Cost	Annual Operating Cost ⁵⁶
A	Proposed Project (Rainbow to Line 2010 Route)	\$441.9	\$0.3
B	Hydrotest Alternative	\$112.9	\$0.5
C1	Alt Diameter Pipeline, Proposed Route (10")	\$297.6	\$0.3 ⁵⁷
C2	Alt Diameter Pipeline, Proposed Route (12")	\$320.1	\$0.3 ⁵⁸
C3	Alt Diameter Pipeline, Proposed Route (16")	\$337.1	\$0.3
C4	Alt Diameter Pipeline, Proposed Route (20")	\$352.9	\$0.3
C5	Alt Diameter Pipeline, Proposed Route (24")	\$361.2	\$0.3
C6	Alt Diameter Pipeline, Proposed Route (30")	\$392.2	\$0.3
C7	Alt Diameter Pipeline, Proposed Route (42")	\$527.5	\$0.3
D	Replace Line 1600 in-Place with a New 16-inch Transmission Pipeline Alternative	\$556.1	\$0.4
E/F	Otay Mesa Alternatives	\$977.1	\$45 ⁵⁹
G	LNG Storage (Peak-Shaver) Alternative AKA (United States – LNG Alternative)	\$2,669.7	\$1.2
H1	Alternate Energy (Battery) Alternative – Grid Scale	\$8,415.1	\$1.2
H2	Alternate Energy (Battery) Alternative – Smaller Scale	\$10,095.1	\$1.2
I	Offshore Route Alternative	\$1,449.9	\$0.5

⁵⁴ AACE International Recommended Practice No. 34R-05, TCM Framework: 7.3 – Cost Estimating and Budgeting, 2007, p. 4.

⁵⁵ Prepared Direct Testimony of Neil Navin (March 21, 2016), page 31, workpaper Estimated Fixed and Operating Costs for Proposed Project and Alternatives

⁵⁶ Annual Operating Costs includes the costs for complying with TIMP. The Applicants incur TIMP costs once every seven years. TIMP costs were divided by 7 to determine the “annual” TIMP costs. That portion – 1/7 – were added to the annual O&M costs to determine total operating costs.

⁵⁷ The 10-inch and 12-inch alternate diameter pipelines do not meet regulatory requirements for natural gas demand on a 1-in-10 year winter day. It is assumed that these alternatives will require the import of gas via the Otay Mesa receipt point. These additional import costs have been accounted for by including them as O&M costs in order to calculate net costs. This analysis can be seen in Section V, Avoided Cost.

⁵⁸ *Id.*

⁵⁹ Estimated costs to transport natural gas. See Prepared Direct Testimony of Gwen Marelli (March 21, 2016), page 7.

Alt. No.	Project Name	(Millions of 2015 Dollars)	
		Fixed Cost	Annual Operating Cost ⁵⁶
J1	Blythe to Santee Alternative 1	\$1,377.5	\$1.4
J2	Blythe to Santee Alternative 2	\$1,315.5	\$1.4
J3	Cactus City to San Diego Alternative	\$1,143.4	\$1.0
K	Second Pipeline Along Line 3010 Alternative	\$595.2	\$0.3

Cost Estimate Assumptions

Described below are the respective assumptions and inclusion/exclusion considered for the Proposed Project and Alternatives.

Alternative A: Proposed Project (Rainbow to Line 2010 Route)

Applicants developed direct cost estimates for the Proposed Project based on the known and anticipated project scope at the time of the Application’s filing (September 2015). The cost estimates have been updated to include the de-rating of Line 1600 to distribution pressure. The direct cost estimates include costs for material and equipment procurement, construction, engineering and design, environmental permitting and mitigation, other project execution-related activities, and company labor. The cost estimate is within a Class 3 range of accuracy as defined by AACE.⁶⁰

Alternative B: Hydrotest

Cost estimates were developed for this project based on historic information and experience with similar types of projects. The level of contingency was decided using expert judgment, based on the accuracy of the estimate which reflects a Level 4 class estimated as defined by AACE classification system.

Alternative C1: Alternative Diameter Pipeline, Proposed Route (10’)

High-level cost estimates have been developed for this Alternative. Costs for this Alternative were developed from the Proposed Project estimate as a baseline. This project involves the same proposed route and similar components as the Proposed Project though in different sizes. Other costs for activities such as engineering, survey, and right-of-way acquisition, should be comparable, on a unit cost basis, to the estimates developed for the Proposed Project. A 10-inch alternate diameter pipeline does not meet regulatory requirements for natural gas demand on a 1-in-10 year winter day. It is therefore assumed that this Alternative will require the import of gas via the Otay Mesa receipt point.

⁶⁰ See Prepared Direct Testimony of Neil Navin (March 21, 2016), page 16

Alternative C2: Alternative Diameter Pipeline, Proposed Route (12’)

High-level cost estimates have been developed for this Alternative. Costs for this Alternative were developed from the Proposed Project estimate as a baseline. This project involves the same proposed route and similar components as the Proposed Project though in different sizes. The pipeline material specifications for each alternative would be similar to the Proposed Project. Other costs for activities such as engineering, survey, and right-of-way acquisition, should be comparable, on a unit cost basis, to the estimates developed for the Proposed Project. A 12-inch alternate diameter pipeline does not meet regulatory requirements for natural gas demand on a 1-in-10 year winter day. It is therefore assumed that this Alternative will require the import of gas via the Otay Mesa receipt point.

Alternative C3: Alternative Diameter Pipeline, Proposed Route (16’)

High-level cost estimates have been developed for this Alternative. Costs for this Alternative were developed from the Proposed Project estimate as a baseline. This project involves the same proposed route and similar components as the Proposed Project though in different sizes. The costs for activities such as engineering, survey, and right-of-way acquisition, should be comparable, on a unit cost basis, to the estimates developed for the Proposed Project.

Alternative C4: Alternative Diameter Pipeline, Proposed Route (20’)

High-level cost estimates have been developed for this Alternative. Costs for this Alternative were developed from the Proposed Project estimate as a baseline. This project involves the same proposed route and similar components as the Proposed Project though in different sizes. Other costs for activities such as engineering, survey, and right-of-way acquisition, should be comparable, on a unit cost basis, to the estimates developed for the Proposed Project.

Alternative C5: Alternative Diameter Pipeline, Proposed Route (24’)

High-level cost estimates have been developed for this Alternative. Costs for this Alternative were developed from the Proposed Project estimate as a baseline. This project involves the same proposed route and similar components as the Proposed Project though in different sizes. Other costs for activities such as engineering, survey, and right-of-way acquisition, should be comparable, on a unit cost basis, to the estimates developed for the Proposed Project.

Alternative C6: Alternative Diameter Pipeline, Proposed Route (30’)

High-level cost estimates have been developed for this Alternative. Costs for this Alternative were developed from the Proposed Project estimate as a baseline. This project involves the same proposed route and similar components as the Proposed Project though in different sizes. Other costs for activities such as engineering, survey, and right-of-way acquisition, should be comparable, on a unit cost basis, to the estimates developed for the Proposed Project.

Alternative C7: Alternative Diameter Pipeline, Proposed Route (42’)

High-level cost estimates have been developed for this Alternative. Costs for this Alternative were developed from the Proposed Project estimate as a baseline. This project involves the same proposed route and similar components as the Proposed Project though in different sizes. Other costs for activities such as engineering, survey, and right-of-way acquisition, should be comparable, on a unit cost basis, to the estimates developed for the Proposed Project.

Alternative D: Replace Line 1600 in Place with a New 16" Transmission Pipeline Alternative (In-Kind Replacement)

High-level cost estimates have been developed for this Alternative. Costs for this Alternative were developed using the Alternative B and Alternative C3 estimates as a baseline. Other costs for activities such as engineering and survey should be comparable, on a unit cost basis, to the estimates developed for the Proposed Project. Right-of-way acquisition costs for this Alternative are significantly greater than those for the Proposed Project.⁶¹

Alternative E/F: Otay Mesa Alternatives

In evaluating the Otay Mesa Alternatives, the Applicants identified both a low end cost and a high end cost for building out capacity to provide service under these Alternatives. The low end cost is based on existing rates for the pipelines and rates for facilities in service since 2002.⁶² The high end cost is based on recently published pipeline costs for projects proposed or awarded for construction in Arizona and Northern Mexico. The high end cost assumes the North Baja Pipeline System and Gasoducto Rosarito System are looped from Ehrenberg to TGN.

Alternative G: LNG Storage (Peak-Shaver) Alternative AKA (United States – LNG Alternative)

The estimate for this Alternative was based on evaluating the costs for a similar LNG storage facility project, and developing factored estimates for the supply and construction of four LNG storage facilities based on each facility’s operational requirements. These estimates were developed for each LNG storage facility by comparing them to available, actual costs for an existing LNG storage facility. Liquefaction costs were excluded – LNG plant costs have been factored based on re-gasification and storage only.

⁶¹ A feasibility study was conducted to evaluate the feasibility of acquiring the necessary Right of Ways.

⁶² See Prepared Direct Testimony of Gwen Marelli (March 21, 2016), page 7.

Alternative H: Alternate Energy (Battery) and Alternative (Alternative H1 - Grid Scale and Alternative H2 - Smaller Scale)

Costs for both the grid scale and smaller scale alternatives were developed based on a rough order of magnitude estimate. The estimate considered energy storage capacity, amount of land required, number of sites and project complexity.

The Grid Scale Alternative assumes installation of lithium-ion batteries at \$500/kWh (kilowatt hours). For approximately 2,802 MW (megawatts) of power and four hours of energy, approximately 11,200 MWh (megawatt hours) of capacity is required. Between 100 and 125 acres of land is needed for this installation.

The Smaller Scale Alternative assumes approximately 11,200 MWh of energy storage capacity for four hours of electric supply, projected at an installed cost of \$600/ kWh. The difference in cost per kWh accounts for the number of sites required to host the smaller scale battery locations.

Alternative I: Off-Shore Alternative

A high level cost estimate for this Alternative was prepared based on considering broad project assumptions. There is a lack of scope definition. The estimate is based on a productivity efficiency factor for marine project conditions. Permitting costs and costs arising as a result of environmental considerations were assumed to be very high.

Alternative J1: Blythe to Santee Alternative 1

High-level cost estimates have been developed for this Alternative. This project involves similar components as the Proposed Project though in significantly different quantities. Costs for this Alternative were scaled from the Proposed Project on a cost per mile basis and adjusted for population density and terrain type. The pipeline material specifications for each alternative would be similar to the Proposed Project. Class estimate for this Alternative is very high level based on the lack of scope definition and that broad assumptions are considered.

Alternative J2: Blythe to Santee Alternative 2

High-level cost estimates have been developed for this Alternative. This project involves similar components as the Proposed Project though in significantly different quantities. Costs for this Alternative were scaled from the Proposed Project on a cost per mile basis and adjusted for population density and terrain type. The pipeline material specifications for each alternative would be similar to the Proposed Project. Class estimate for this Alternative is very high level based on the lack of scope definition and that broad assumptions are considered.

Alternative J3: Cactus City to San Diego Alternative

High-level cost estimates have been developed for this Alternative. This project involves similar components as the Proposed Project though in significantly different quantities. Costs for this Alternative were scaled from the Proposed Project on a cost per mile basis and adjusted for population density and terrain type. The pipeline material specifications for each alternative would be similar to the Proposed Project. Class estimate for this Alternative is very high level based on the lack of scope definition and that broad assumptions are considered.

Alternative K: Second Pipeline along Line 3010 Alternative

High-level cost estimates have been developed for this Alternative. This project involves similar components as the Proposed Project though in different quantities. The pipeline material specifications for each alternative would be similar to the Proposed Project. Other costs for activities such as engineering and surveying, should be comparable, on a unit cost basis, to the estimates developed for the Proposed Project. Right of way acquisition costs for this Alternative are significantly greater than those for the Proposed Project.⁶³

C. Avoided Costs Associated with the Proposed Project and Alternatives

The Applicants analyzed the total avoided costs that would accrue over an assumed 100 year useful life⁶⁴ for the Proposed Project and Alternatives involving construction of a new pipeline (all Alternatives except the Hydrotest Alternative). This analysis allowed for the evaluation of:

- The anticipated avoided costs over set periods of time;
- Both one-time and recurring avoided costs; and
- The net cost that incorporates both the total cost for installing the project and the avoided costs.

The Applicants' methodology⁶⁵ for calculating the avoided costs is as follows:

- Determine the various cost elements that make up the two types of avoided costs (described in the following section);
- Tabulate the avoided costs on a time line for the Proposed Project and for those Alternatives to which they apply;

⁶³ A feasibility study was conducted to evaluate the feasibility of acquiring the necessary Right of Ways.

⁶⁴ The Role of Pipeline Age in Pipeline Safety, Kiefner and Rosenfield states that "...a well-maintained and periodically assessed pipeline can safely transport natural gas indefinitely." A 100 year lifetime period has been assumed for calculation purposes.

⁶⁵ The Applicants use a conservative methodology for conducting the avoided cost analysis. The Applicants' method is based on conservative assumptions and is commonly used in evaluating the costs of projects over time. Other methods could be used to analyze avoided costs over time.

- Escalate the avoided costs over time by applying an inflation rate of 2.9%;⁶⁶
- Discount the avoided costs back to 2015 at 7.79%,⁶⁷ resulting in avoided costs presented in 2015 values; and

Calculate the net cost by adding the estimated fixed cost plus the present value of operating expenses and avoided costs over 100 years shown in

- Table 8.

It is assumed that avoided costs will begin to accrue from the year that the Proposed Project and Alternatives become operational.⁶⁸

Two avoided costs are associated with not having to hydrotest Line 1600, and are accounted for in this analysis, as follows:

Avoided Cost 1: Future Replacement of Line 1600

Even if Line 1600 is hydrotested, it is prudent to assume that it will need to be replaced eventually. Thus, this set of avoided costs include the cost associated with replacing Line 1600 at some point in the future. The Applicants have established a 20-year interval as a reasonable expectation for the expiration of the benefits from pressure testing. This interval is based upon engineering judgment, and Line 1600 would likely either need to be replaced or re-evaluated depending upon a number of factors that would ultimately include coating degradation, cathodic protection performance, time-dependent threat growth, leakage maintenance program demands, and time-independent threat rates.⁶⁹

The avoided costs analysis assumes Line 1600 operating as a transmission asset will be replaced in 20 years. These avoided costs are realized by the Proposed Project and the Alternatives that contemplate derating Line 1600.

⁶⁶ Inflation rate based on IHS Fourth Quarter 2015 Construction Cost Index Forecasts for Gas Utility Construction: Pacific Region for Transmission Plant averaged from 2017 through 2025.

⁶⁷ SDG&E discount rate. *See* Prepared Direct Testimony of Michael Woodruff (March 21, 2016).

⁶⁸ *See* Prepared Direct Testimony of Neil Navin (March 21, 2016), page 31: Workpaper – Estimated Fixed and Operating Costs for Proposed Project and Alternatives.

⁶⁹ *See* Prepared Direct Testimony of Travis Sera (March 21, 2016), page 24.

Avoided Cost 2: Moreno Compressor Station Operations

For the Proposed Project, or certain Alternatives (C4, C5, C6, C7, I, J1, J2, J3, K)⁷⁰ there can be a potential impact on the costs associated with the annual operations and maintenance of the Moreno Compressor Station^{71,72} as well as the amounts expended for emissions.

The following sections describe these avoided cost elements in more detail.

1. Future Replacement of Line 1600

Overview of Current Costs

Line 1600, if hydrotested and maintained at transmission level service (the Hydrotest Alternative), will be abandoned and/or replaced earlier than the Proposed Project or any of the Alternatives that would allow Line 1600 to be de-rated because Line 1600 will have a shorter usable asset lifespan. The estimated cost of installing a new 16-inch diameter pipeline along the same route as the Proposed Project, which is the most efficient replacement option from a cost perspective, is \$337.1M. The estimated remaining life of Line 1600 is assumed to be 20 years or less.

Source of Avoided Cost

The Proposed Project and Alternatives except the Hydrotest Alternative will have a useful life in excess of Line 1600 if it is maintained as a transmission asset. This analysis assumes that the Proposed Project and the Alternatives will have a service life of 100 years. Over the life of the Proposed Project and the Alternatives, the costs related to the eventual replacement of Line 1600 will be avoided.

Assumptions

For the purpose of this avoided costs analysis, it is assumed that Line 1600 will be replaced with a 16-inch diameter transmission pipeline along the same route as the Proposed Project. It is assumed that the physical replacement work will take two years.

⁷⁰ The cross county lines (J1, J2 and J3) are not directly connected to the Moreno Compressor Station, but are assumed to provide similar benefits with regards to avoided costs as the Proposed Project, due to the additional capacity inherent to a 36" pipeline. Due to the length of these lines, it is possible that additional compression may be needed to balance the gas flow in the system. However, at this stage in the design, it is not known whether this additional compression will be required.

⁷¹ See Prepared Direct Testimony of Neil Navin (March 21, 2016), Attachment A – PSRP Report at Attachment XII - Moreno Compressor Station PSRP Report.

⁷² For the Proposed Project, it is assumed that the Moreno Compressor Station would only require reduced operations to function minimally as a safeguard during extreme or unplanned capacity interruption scenarios. See Prepared Direct Testimony of Neil Navin (March 21, 2016), Attachment A – PSRP Report at Attachment XII - Moreno Compressor Station PSRP Report.

The costs for replacing Line 1600 in the future make up the avoided costs for future Line 1600 Replacement in the cost avoidance analysis.

2. Moreno Compressor Station Operations

Overview of Current Costs⁷³

The Proposed Project and certain Alternatives would reduce the need for compression at Moreno Compressor Station. Although compression at Moreno would likely still be needed at certain times, many of the operating costs could potentially be avoided or reduced. The associated avoided costs include the following:

Emission Fees and Permitting: Based on average annual costs for emissions, emissions subjected to fee, and applied fee rates. Average cost from 2011 to 2014 is \$44,748.

Operations and Maintenance: Based on average annual costs for labor and non-labor costs. Average annual costs for 2010 to 2015 is \$2,613,907.

Fuel: Based on the average cost of fuel used, with the average price per dekatherm for the California border in 2021 assumed to be \$3.23.⁷⁴ Average annual costs based on usage for 2011 to 2013 is \$1,400,000.

NOx Sales and Purchases: Each year, the Applicants are allocated a fixed number of credits for NOx RECLAIM emissions.⁷⁵ When emissions are exceeded, additional credits have to be purchased. Similarly, unused credits can be sold at spot market prices. Average annual emissions at Moreno Compressor Station from 2012 to 2015 were 139,338 lbs. The average cost for emission credits is approximately \$14 per lb.

GHG Costs: Applicants pay for greenhouse gas (GHG) emissions arising from Moreno Compressor Station operations.⁷⁶ The average annual GHG emissions from 2012 to 2014 were 25,159 metric tons. Projected annual GHG costs are \$1,320,830 per annum based on a levelized price per ton of \$52 per metric ton.

⁷³ Based on the figures provided within the Prepared Direct Testimony of Neil Navin (March 21, 2016), Attachment A – PSRP Report at Attachment XII - Moreno Compressor Station PSRP Report.

⁷⁴ Based on CMEGroup Globex Futures.

⁷⁵ See Assembly Bill (AB) 32 (California Global Warming Solutions Act of 2006) - <http://www.arb.ca.gov/cc/ab32/ab32.htm>

⁷⁶ Pursuant to AB 32 and the Governor's Executive Order S-01-07.

Source of Avoided Cost

The estimated annual cost savings resulting from assuming reduced operations at Moreno Compressor Station for the Proposed Project and certain Alternatives is approximately \$5.87 million, calculated as:⁷⁷

Table 7 - Savings associated with the installation of a 36" or larger pipeline

Cost Element	Annual Savings
O&M Non-Labor	(\$295,077)
Fuel	(\$1,363,626)
NOx Purchases	(\$1,162,000)
NOx Sales	(\$691,125)
GHG Cap & Trade Cost	(\$1,254,789)
Capital Spending	(\$1,100,000)
Annual Sum	(\$5,866,617)

Assumptions

Avoided costs relating to the Moreno Compressor Station will be incurred for the Proposed Project and Alternatives C4, C5, C6, C7, I, J1, J2, J3 and K, as follows:

- Alternative C7 (42" pipeline) and Alternatives I (Off-shore), J1, J2, and J3 (Cross-County Alternatives)⁷⁸ and K (Second Pipeline along Line 3010) will provide the same reduction in operational requirements to the Moreno Compressor Station as the Proposed Project.

⁷⁷ The Moreno Compressor Station PSRP Report (Prepared Direct Testimony of Neil Navin (March 21, 2016), Attachment A – PSRP Report at Attachment XII) makes the following assumptions with regards to cost saving should the Proposed Project be implemented:

- The Moreno Compressor Station operations will be reduced by 95% to function minimally as a safe guard during extreme or unplanned capacity interruption scenarios for a 36" line.
- Fuel, NOx credit purchases and sales, and GHG costs are reduced in direct proportion (*i.e.*, 1:1) as the reduction in operation;
- Emission fees and permitting costs will remain unchanged due to the need of maintaining permitting for the compressor the station;
- Labor costs will remain unchanged, and Non-labor costs will be reduced by \$300,000 (or 20% of annual cost average); and
- \$1.1M in capital spending will be avoided (based on historical capital spending).

⁷⁸ The cross county lines (J1, J2 and J3) are not directly connected to the Moreno Compressor Station, but are assumed to provide similar benefits with regards to avoided costs as the Proposed Project, due to the additional capacity inherent to a 36" pipeline. Due to the length of these lines, it is possible that additional compression may be needed to balance the gas flow in the system. However, at this stage in the design, it is not known whether this additional compression will be required.

- Alternatives C4, C5 and C6 (20", 24" and 30" pipelines, respectively) will provide some reduction in operational requirements to the Moreno Compressor Station, assumed to be in direct proportion to the reduction in pipeline diameter.⁷⁹

The analysis assumes that the remaining Alternatives will not have any effect on the current state operational output of the Moreno Compressor Station and, therefore, do not accrue avoided costs.

D. Net Costs of the Proposed Project and Alternatives

The table below shows the avoided costs associated the Proposed Project and the Alternatives:

Table 8 - Avoided Costs (Millions of 2015 Dollars)

Alt No.	Project Name	Fixed Cost	Total O&M Cost ⁸⁰	Avoided Cost	Net Cost
A	Proposed Project (36" pipeline Rainbow to Line 2010 Route)	\$441.9	\$4.6	(\$190.3)	\$256.2
B	Hydrotest Alternative	\$112.9	\$5.8	\$0.0	\$118.7
C1	Alt Diameter Pipeline, Proposed Route (10")	\$297.6	\$105.3	(\$100.3)	\$302.7
C2	Alt Diameter Pipeline, Proposed Route (12")	\$320.1	\$71.8	(\$100.3)	\$291.6
C3	Alt Diameter Pipeline, Proposed Route (16")	\$337.1	\$4.6	(\$100.3)	\$241.4
C4	Alt Diameter Pipeline, Proposed Route (20")	\$352.9	\$4.6	(\$118.3)	\$239.2
C5	Alt Diameter Pipeline, Proposed Route (24")	\$361.2	\$4.6	(\$136.3)	\$229.6
C6	Alt Diameter Pipeline, Proposed Route (30")	\$392.2	\$4.6	(\$163.3)	\$233.5
C7	Alt Diameter Pipeline, Proposed Route (42")	\$527.5	\$4.6	(\$190.3)	\$341.9
D	Replace Line 1600 in Place with a New 16" Transmission Pipeline	\$556.1	\$4.4	(\$100.3)	\$460.1
E/F	Otay Mesa Alternatives	\$977.1	\$0.0	(\$100.3)	\$876.8
G	LNG Storage (Peak-Shaver) Alternative	\$2,669.7	\$15.3	(\$100.3)	\$2,584.7
H1	Alternate Energy Alternative: Grid-Scale Batteries	\$8,415.1	\$15.3	(\$100.3)	\$8,330.1
H2	Alternate Energy Alternative: Smaller-Scale Batteries	\$10,095.1	\$15.3	(\$100.3)	\$10,010.1
I	Offshore Route	\$1,449.9	\$5.1	(\$159.5)	\$1,295.5
J1	Blythe to Santee Alternative 1	\$1,377.5	\$16.7	(\$175.0)	\$1,219.3
J2	Blythe to Santee Alternative 2	\$1,315.5	\$16.8	(\$175.0)	\$1,157.3
J3	Cactus City to San Diego Alternative	\$1,143.4	\$12.7	(\$175.0)	\$981.1
K	Second Pipeline Along Line 3010 Alternative	\$595.2	\$3.5	(\$171.6)	\$427.1

⁷⁹ The Moreno Compressor Station PSRP Report (Prepared Direct Testimony of Neil Navin (March 21, 2016), Attachment A – PSRP Report at Attachment XII) shows a straight line reduction in operations in proportion to pipeline diameter between 36" and 16" diameters.

⁸⁰ Present value of O&M and TIMP costs over 100 years. Also includes present value of gas transportation costs via Otay Mesa for Alternatives C1 and C2.

The results of the costs analysis show that the “least-cost” alternative is the Hydrottest Alternative, which has an estimated net cost of \$118.7 million. Table 9 shows the Proposed Project and remaining Alternatives grouped together by range of net costs. After the Hydrottest Alternative, the next group of least-cost alternatives are clustered together in the \$225 million to \$260 million range. This second least-cost category includes alternate diameter sizes ranging from 16- to 36-inches (*i.e.*, the Proposed Project). The third least-cost category has a larger range, from \$290 million to \$465 million, and includes Alternative Diameters of 10-, 12- and 42-inches, the Replace Line 1600 In-Place with a New 16-Inch Transmission Pipeline Alternative, and the Second Pipeline Along Line 3010 Alternative.

The remaining two categories of Alternatives far exceed the net costs of the Proposed Project. These last two “greatest cost” categories include Alternatives whose net costs range from \$500 million to \$1 billion (Otay Mesa Alternatives and Cactus City to San Diego Alternative) and over \$1 billion (Blythe to Santee Pipeline Routes, Alternatives 1 and 2, Off-Shore, LNG Storage, and Alternative Energy Alternatives).

Table 9 - Relative Costs of Proposed Project and Alternatives from Least to Greatest Net Cost

Net Cost Range	Alt No.	Project Name	Net Cost
\$100 M to \$200 M	B	Hydrottest	\$118.7 M
\$225 M to \$260 M	C5	Alt Diameter Pipeline 24"	\$229.6 M
	C6	Alt Diameter Pipeline 30"	\$233.5 M
	C4	Alt Diameter Pipeline 20"	\$239.2 M
	C3	Alt Diameter Pipeline 16"	\$241.4M
	A	Proposed Project (36" Diameter)	\$256.2 M
\$290 M to \$465 M	C2	Alt Diameter Pipeline 12"	\$291.6 M
	C1	Alt Diameter Pipeline 10"	\$302.7 M
	C7	Alt Diameter Pipeline 42"	\$341.9 M
	K	Second Pipeline Along Line 3010 Alternative	\$427.1 M
	D	Replace Line 1600 In Place with a New 16-inch Transmission Pipeline	\$460.1M
\$500 M to \$1Billion	E/F	Otay Mesa Alternatives	\$876.8 M
	J3	Cactus City to San Diego Alternative	\$981.1 M
Over \$1 Billion	J2	Blythe to Santee Alternative 2	\$1,157.3 M
	J1	Blythe to Santee Alternative 1	\$1,219.3 M
	I	Offshore Route Alternative	\$1,295.5 M
	G	LNG Storage Alternative	\$2,584.7 M
	H2	Alternate Energy Alternative: Smaller Scale Batteries	\$10,010.1 M
	H1	Alternative Energy Alternative: Grid Scale Battery	\$8,330.1 M

V. BENEFITS ANALYSIS⁸¹

This Cost-Effectiveness Analysis included an evaluation of the different types of benefits across the seven benefit types set forth in the Ruling. The benefits were quantified and scored using a benefits evaluation model that was developed by PwC, with input and data from the Applicants. This evaluation complies with the requirement in the Ruling to apply quantifiable data to define the relative benefits of the Proposed Project and the Alternatives.⁸² In addition to the quantifiable benefits, the Applicants identified a few project benefits that could not be readily quantified.

Approach and Methodology

To comply with the requirement to apply quantifiable data to define the relative benefits of the projects, PwC and the Applicants developed a model (referred to herein as the “benefits evaluation model”) to quantitatively evaluate and score the relative benefits of the Proposed Project and each of the Alternatives. PwC and the Applicants first considered desirable outcomes (*e.g.*, enhanced safety) and quantifiable characteristics (*e.g.*, percent reduction in incidents per High Consequence Area (HCA) mile) associated with the seven benefits categories identified in the Ruling. The model was then created to evaluate 16 specific benefits, each of which falls within one of the seven categories identified in the Ruling. Care was taken to treat each benefit as unique and not counted more than one time in the scoring model.

After the benefits were defined, PwC and the Applicants developed quantifiable scoring criteria so that benefits could be objectively evaluated and scored. The types of quantifiable metrics used in the scoring criteria include the percentage or measurable increase/reduction in a known quantity or unit of measure/metric that is used to define a benefit. For instance, a quantitative threshold expressed in terms of MMcfd is used to quantify the increases expected in system capacity for the Proposed Project and each of the Alternatives. Similarly, the number of incidents per HCA mile is one metric relied on to quantify and score safety performance.

The complete list of benefits included in the scoring model and the metric or measure used to quantify and score each one, is listed in Table 10 of this Cost-Effectiveness Analysis.

The scoring criteria are generally applied on a 1 to 5 scale. In the scoring benefits model, 1 is the lowest (worst) score and 5 is the highest (best) score. The scores were averaged within each of the seven benefit categories and then those seven average scores were summed to determine the final benefit score for the Proposed Project and the Alternatives.

⁸¹ The avoided costs associated with the Proposed Project and each Alternative may also be viewed as a benefit. In order to avoid double-counting, however, avoided costs are not discussed in this section.

⁸² Ruling, page 12.

For certain benefits, there is no obvious measure or metric against which the benefit is generally compared. For those benefits, the scoring scale was defined to allow for an objective evaluation of the Proposed Project and the Alternatives against the scale and a quantitative measure of the benefit defined. For instance, measuring long-term safety benefits of a transmission pipeline is an important benefit and must be included in the overall analysis. Because there is no standard measure or metric for evaluating this benefit, the Applicants defined this benefit on an objective scale, defined by technical insight. This benefit type can then be scored and that score included in the overall quantitative benefits evaluation.

Once the scoring was complete for the Proposed Project and the Alternatives across each benefit category, the total benefit score was determined and a relative quantifiable benefit ranking was prepared.

Table 10 - Benefits Evaluation Scoring Summary

Benefits Criteria	Proposed Project - 36"	Hydrotest	Alt Diameter Pipelines - 10"	Alt Diameter Pipelines - 12"	Alt Diameter Pipelines - 16"	Alt Diameter Pipelines - 20"	Alt Diameter Pipelines - 24"	Alt Diameter Pipelines - 30"	Alt Diameter Pipelines - 42"	Replace Line 1600 In-Place	Otay Mesa Alternatives	LNG Storage	Alt Energy - Grid Scale	Alt Energy - Smaller Scale	Offshore Route	Blythe to Santee Alt 1	Blythe to Santee Alt 2	Cactus City to SD	2nd Pipeline Along Line 3010
1. Safety	5	3	5	5	5	5	5	5	5	4	4	3	3	3	4	4	4	4	4
2. Reliability	5	1	1	1	3	4	4	5	5	3	1	2	2	2	5	5	5	5	5
3. Operational Flexibility	5	4	4	4	4	5	5	5	5	4	3	4	4	4	5	5	5	5	5
4. System Capacity	5	3	2	2	3	4	4	5	5	3	5	3	3	3	5	5	5	5	5
5. Gas Storage thru Line Pack	5	3	2	2	3	4	4	5	5	3	5	3	3	3	5	5	5	5	5
6. Reduction in Gas Price for Ratepayers	3	3	3	3	3	3	3	3	3	3	1	1	3	3	3	3	3	3	3
7. Other Benefits	5	3	1	1	3	4	4	4	5	3	5	5	1	1	5	5	5	5	5
Total of Average Scores	27.6	17.0	15.5	15.5	20.6	24.1	24.5	25.9	27.6	20.4	19.0	18.6	16.2	16.2	27.0	27.2	27.2	27.2	27.2
Overall Relative Rank	1	15	18	18	11	10	9	8	1	12	13	14	16	16	7	3	3	3	3

(1 is the lowest (worst) score and 5 is the highest (best) score; Overall Relative Rank – 1 is the highest and 18 is the lowest)

A. Increased Safety

Increased safety benefits were scored against the criteria in the benefits evaluation model. For the purposes of this evaluation it is assumed that the Proposed Project and all of the Alternatives will comply with State laws to pressure test or replace Line 1600.

1. Evaluating Benefits using the Benefits Evaluation Model

The increased safety benefits and the respective scoring criteria are described below.

- 1.1 Increased safety margin to prevent pipeline rupture through the de-rating of Line 1600:⁸³

Evaluating the increased safety margins in terms of the percentage of specified minimum yield strength (SMYS) on Line 1600.

1. N/A
2. Line 1600 operating at 800 psi (49% of SMYS) - Transmission Function
3. Line 1600 operating at 640 psi (39% of SMYS) - Transmission Function
4. Line 1600 operating at 320 psi (<20% of SMYS) - Distribution Function
5. Removal of Line 1600

- 1.2 Long-term Safety Benefit of Transmission Pipeline Project: Ability to sustain safety over the life of the transmission pipeline due to aspects such as:

- Presence of known significant anomalies,
- Presence of known anomalies, and
- Future resiliency or strength of design:
 - Thickness of material
 - Corrosion protection
 - Protective coating
 - Installation techniques that prevent damage to the pipe

The scale for scoring the projects against this benefit is:

1. Anomalies persist in transmission pipeline
2. N/A
3. No transmission pipeline is part of the project
4. N/A
5. Meets or exceeds modern design standards

- 1.3 Reduction in incidents per HCA mile of pipeline:⁸⁴ Using the Department of Transportation's (DOT) Pipeline and Hazardous Materials Safety Administration (PHMSA) data, age, type of pipeline material, wall thickness, and other parameters, a percentage reduction or increase in the number of incidents per HCA mile was able to be quantified.

The scale for scoring the projects against this benefit is:

1. > 25% increase in potential incidents/ HCA mile
2. 0-25% increase in potential incidents/HCA mile
3. No change in potential incidents/HCA mile likelihood
4. 0-25% reduction in incidents/ HCA mile
5. > 25% reduction in incidents/ HCA mile

⁸³ See Prepared Direct Testimony of Travis Sera (March 21, 2016).

⁸⁴ See Section V.H, Pipeline Failure Analysis

- 1.4 Increased real-time awareness of excavation damage: Ability to detect excavation damage in real-time to prevent or mitigate larger incidents from occurring.

The scale for scoring the projects against this benefit is:

1. Reduced capabilities for real-time awareness of excavation damage
2. N/A
3. No change in capabilities for real-time awareness of excavation damage
4. N/A
5. Increased capabilities for real-time awareness of excavation damage

- 1.5 Achievement of “as soon as practicable” safety objective:⁸⁵ Based on estimated completion or in-service year.

The scale for scoring the projects against this benefit is:

1. Beyond 2026
2. Complete by 2026
3. Complete by 2024
4. Complete by 2022
5. Complete by 2020

⁸⁵ In Decision (D.) 11-06-017, Ordering Paragraph 5, the Commission directed pipeline operators to develop a plan to test or replace all transmission pipelines that do not have documentation of a pressure test “as soon as practicable.”

The results of the safety benefits scoring are shown in Table 11 below.

Table 11 - Increased Safety Benefits Score

Safety Benefits	Proposed Project - 36"	Hydrotest	Alt Diameter - 10"	Alt Diameter - 12"	Alt Diameter - 16"	Alt Diameter - 20"	Alt Diameter - 24"	Alt Diameter - 30"	Alt Diameter - 42"	Replace Line 1600 In-Place	Otay Mesa Alternatives	LNG Storage	Alt Energy – Grid Scale	Alt Energy – Smaller Scale	Offshore Route	Blythe to Santee Alt 1	Blythe to Santee Alt 2	Cactus City to SD	2nd Pipeline Along Line 3010
1.1 Increased safety margin to prevent pipeline rupture through the de-rating of Line 1600 ⁸⁶	4	3	4	4	4	4	4	4	4	5	4	4	4	4	4	4	4	4	4
1.2 Long-term Safety Benefit of Transmission Pipeline	5	1	5	5	5	5	5	5	5	5	3	3	3	3	5	5	5	5	5
1.3 Reduction in incidents per HCA mile of pipeline	5	3	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5
1.4 Increased real-time awareness of excavation damage	5	3	5	5	5	5	5	5	5	5	3	3	3	3	5	5	5	5	5
1.5 Achievement of “as soon as practicable” safety objective	4	4	4	4	4	4	4	4	4	2	3	2	2	2	1	2	2	2	2
Average Score	5	3	5	5	5	5	5	5	5	4	4	3	3	3	4	4	4	4	4

(1 is the lowest (worst) score and 5 is the highest (best) score)

⁸⁶ Line 1600 will be de-rated for all Alternatives except the Hydrotest Alternative and the Line 1600 Replace in Place with a New 16-inch Pipeline.

Results of the increased safety benefits evaluation are discussed below.

a) *Proposed Project*

The Proposed Project eliminates the need to operate Line 1600 at a higher pressure and instead allows for its de-rating at a lower and safer pressure that will improve overall system safety margins.

The Proposed Project will feature a new 36” pipeline (in addition to the de-rated Line 1600) that meets or exceeds design standards and ensures the longer term safety benefit of the transmission system.

The Proposed Project will also reduce the number of incidents per HCA mile in the system.^{87,88}

Ability to achieve “as soon as practicable” safety objective based on completion or in-service year.

b) *Hydrotest*

If Line 1600 remains a transmission asset, the risks of long seam weld hook crack failures, exposure to time dependent threats (such as corrosion), and other material and design related factors that can interact with non-state-of-the-art vulnerabilities to create increased risk remain as well, and therefore do not support the long term safety benefit of transmission pipeline.

Additionally, there are no significant changes in incidents per HCA mile if Line 1600 is hydrotested and remains in transmission level service.

No improvements in real-time awareness of excavation damages.

Ability to achieve “as soon as practicable” safety objective based on completion or in-service year.

⁸⁷ See Section V.H, Pipeline Failure Analysis.

⁸⁸ See Section V.H, Pipeline Failure Analysis.

c) *Alternative Diameter Pipelines*

Table 12 - Safety Benefits of Alternative Diameter Pipelines

Project	Safety Benefits
Alternative Diameter Pipelines 10" through 42" (with a de-rated Line 1600 at distribution pressure)	<p>De-rating of Line 1600 to distribution service will improve overall system safety margin.</p> <p>The new transmission pipeline meets or exceeds modern design standards for longer term safety benefit of transmission pipeline safety.</p> <p>Fewer incidents per HCA mile due to the use of state-of-the-art materials and fabrication techniques.</p> <p>Increased capability for real-time awareness of excavation damages.</p> <p>Ability to achieve "as soon as practicable" safety objective based on completion or in-service year.</p>

d) *Other Alternative Projects*

Table 13 - Safety Benefits of Other Alternatives

Project	Safety Benefits
Replace Line 1600 In-Place with a New 16-inch Transmission Pipeline (with removal of Line 1600)	<p>The removal and replacement of Line 1600 will improve overall system safety margin.</p> <p>The new transmission pipeline meets or exceeds modern design standards for longer-term safety benefit of transmission pipeline safety.</p> <p>Fewer incidents per HCA mile due to the use of state-of-the-art materials and fabrication techniques.</p> <p>Increased capability for real-time awareness of excavation damages.</p> <p>Unable to achieve "as soon as practicable" safety objective based on completion or in-service year.</p>
<p>De-rated Line 1600 is assumed for each of the below options (but no transmission pipeline is part of the project):</p> <ul style="list-style-type: none"> • Otay Mesa Alternatives • LNG Storage • Alternate Energy – Grid Scale • Alternate Energy – Smaller Scale 	<p>De-rating of Line 1600 to distribution service will improve overall system safety margin.</p> <p>There is no new transmission pipeline to meet or exceed modern design standards for longer-term safety benefit of transmission pipeline safety.</p> <p>Fewer incidents per HCA mile due a de-rated distribution Line 1600.</p> <p>No improvements in real-time awareness of excavation damages.</p> <p>Low ability to achieve "as soon as practicable" safety objective based on completion or in-service year for the Otay Mesa, the</p>

Project	Safety Benefits
	LNG and Alternate Energy Alternatives.
Alternative Pipelines – 36” (with a de-rated Line 1600) <ul style="list-style-type: none"> • Blythe to Santee Alt 1 • Blythe to Santee Alt 2 • Cactus City to SD • 2nd Pipeline Along Line 3010 • Offshore Route 	De-rating of Line 1600 to distribution service will improve overall system safety margin. The new transmission pipeline meets or exceeds modern design standards for longer term safety benefit of transmission pipeline safety. Fewer incidents per HCA mile due to the use of state-of-the-art materials and fabrication techniques. Increased capability for real-time awareness of excavation damages (for the Offshore Alternative this applies to segments that are on land). Low ability to achieve “as soon as practicable” safety objective based on completion or in-service year varies with these projects, with the Offshore Pipeline scoring the worst at 1, and the Cross County lines and the 2 nd Pipeline Along 3010 scoring 2s.

B. Increased Reliability

System reliability refers to the ability to maintain safe, consistent, and continuous service to customers. System reliability is insured by maintaining safe operating pressures, which in turn result from having sufficient supply to meet demand and sufficient pipeline and storage capacity.

Using modern design standards and state-of-the-art materials and technology can increase the reliability of the physical gas transmission asset. Additionally, extra capacity as a result of a larger pipe diameter and the ability to operate safely at a higher pressure, can help improve the inherent reliability of a system during events when (a) projected daily demand exceeds forecast levels or (b) intra-day demands fluctuate in a manner that exceeds current operating parameters.

The Proposed Project and Alternatives were evaluated and scored in terms of their impact on increasing the current reliability/redundancy of the Applicants’ gas transmission system. The three main distinctions in assessing the impacts to reliability/redundancy are as follows:

- No change to system reliability/redundancy;
- Increased system reliability/redundancy, and
- Decreased system reliability/redundancy.

1. Evaluating Benefits using the Benefits Evaluation Model

Please note, system capacity-related reliability benefits are implicit in the evaluation of increased reliability. These benefits are included in the “Increased System Capacity” section below in order to avoid double-counting the benefits.

Increased reliability benefits have been assessed by evaluating and scoring the reliability aspects of the Proposed Project and Alternatives using the benefits evaluation model described above.

The increased reliability benefits of the respective scoring criteria are described below.

- 2.1 Redundancy to natural gas transmission system:

Ability for a project to provide redundancy to the natural gas system should an unplanned event occur and place any of the two primary gas transmission assets (Line 3010 and Moreno Compression Station) out of service. The scale for scoring the projects against this benefit is:

1. Reduced Level of System Redundancy
2. Existing Level of System Redundancy
3. Increased System Redundancy
4. Complete Redundancy for Line 3010
5. Complete Redundancy for Line 3010 or Moreno Compressor Station

- 2.2 Curtailment impact to core gas customers: An outage scenario analysis⁸⁹ has been performed to model the impact of the Alternatives on overall system reliability. The analysis evaluates curtailments to gas customers in the case of an outage or reduction in pressure of Line 3010 under current conditions, given the hypothetical availability of the Proposed Project or Alternates. A range of scenarios were modeled across variabilities in gas supply from Otay Mesa and seasonal variations in gas demand. SDG&E Gas Rule 14⁹⁰ was used to segregate impact to the key customer classes in order of their curtailment priority. The scenario analysis methodology and approach is discussed in detail in Section H, Supporting Analysis.

The scale for scoring the Alternatives against this benefit is based on a normalization of the average curtailment measured across all scenarios modeled for each Project Alternative. The average percentage of gas curtailment identified under each Project Alternative was normalized from 0% to 100%, and the following scores (1 through 5) were applied accordingly.

1. Normalized curtailment impacts are above 81% of the maximum in all Project Alternatives⁹¹

⁸⁹ See Section H for a detailed description of the scenario analysis performed.

⁹⁰ See Prepared Direct Testimony of Gwen Marelli (March 21, 2016), page 2.

⁹¹ Scores are based on a normalization of the average curtailment impacts under each Project Alternate, compared to the maximum impact for all Project Alternates. The maximum curtailment impact to the

2. Normalized curtailment impacts are between 61% and 80% of the maximum in all Project Alternatives
 3. Normalized curtailment impacts are between 41% and 60% of the maximum in all Project Alternatives
 4. Normalized curtailment impacts are between 21% and 40% of the maximum in all Project Alternatives
 5. Normalized curtailment impacts are between 0% and 20% of the maximum in all Project Alternatives
- 2.3 Curtailment impact to electric generation (EG) gas customers: An outage scenario analysis⁹² has been performed to model the impact of the Alternatives on overall system reliability. The analysis evaluates curtailments to customers in the case of an outage or reduction in pressure of Line 3010 under current conditions, given the hypothetical availability of the Proposed Project or Alternatives. A range of scenarios were modeled across variabilities in gas supply from Otay Mesa and seasonal variations in gas demand. SDG&E Gas Rule 14⁹³ was used to segregate impact to the key customer classes in order of their curtailment priority. The scenario analysis methodology and approach is discussed in detail in Section H, Supporting Analysis.

The scale for scoring the Alternatives against this benefit is based on a normalization of the average curtailment measured across all scenarios modeled for each Project Alternative. The average percentage of gas curtailment identified under each Project Alternative was normalized from 0% to 100%, and the following scores (1 through 5) were applied accordingly.

1. Normalized curtailment impacts are above 81% of the maximum in all Project Alternatives⁹⁴
2. Normalized curtailment impacts are between 61% and 80% of the maximum in all Project Alternatives
3. Normalized curtailment impacts are between 41% and 60% of the maximum in all Project Alternatives
4. Normalized curtailment impacts are between 21% and 40% of the maximum in all Project Alternatives
5. Normalized curtailment impacts are between 0% and 20% of the maximum in all Project Alternatives

core gas customer class, as an average across the 48 unique scenarios modeled per Project Alternate, was a 20.8% curtailment of gas services.

⁹² See Section H for a detailed description of the scenario analysis performed.

⁹³ See Prepared Direct Testimony (March 21, 2016) of Gwen Marelli, page 2.

⁹⁴ Scores are based on a normalization of the average curtailment impacts under each Project Alternate, compared to the maximum impact for all Project Alternates. The maximum curtailment impact to the electric generation (EG) gas customer class, as an average across the 48 unique scenarios modeled per Project Alternative, was a 46.6% curtailment of gas services.

- 2.4 Curtailment impact to non-core, non-EG gas customers: An outage scenario analysis⁹⁵ has been performed to model the impact of the Alternatives on overall system reliability. The analysis evaluates gas curtailments to customers in the case of an outage or reduction in pressure of Line 3010 under current conditions, given the hypothetical availability of the Proposed Project or Alternatives. A range of scenarios were modeled across variabilities in gas supply from Otay Mesa and seasonal variations in gas demand. SDG&E Gas Rule 14⁹⁶ was used to segregate impact to the key customer classes in order of their curtailment priority. The scenario analysis methodology and approach is discussed in detail in Section H, Supporting Analysis.

The scale for scoring the Alternatives against this benefit is based on a normalization of the average curtailment measured across all scenarios modeled for each Project Alternative. The average percentage of gas curtailment identified under each Project Alternative was normalized from 0 to 100%, and the following scores (1 through 5) were applied accordingly.

1. Normalized curtailment impacts are above 81% of the maximum in all Project Alternatives⁹⁷
 2. Normalized curtailment impacts are between 61% and 80% of the maximum in all Project Alternatives
 3. Normalized curtailment impacts are between 41% and 60% of the maximum in all Project Alternatives
 4. Normalized curtailment impacts are between 21% and 40% of the maximum in all Project Alternatives
 5. Normalized curtailment impacts are between 0% and 20% of the maximum in all Project Alternatives
- 2.5 Curtailment impact to electric customers: An outage scenario analysis⁹⁸ has been performed to model the impact of the Alternatives on overall system reliability. The analysis evaluates electric curtailments to customers in the case of an outage or reduction in pressure of Line 3010 under current conditions, given the hypothetical availability of the Proposed Project or Alternatives. A range of scenarios were modeled across variabilities in gas supply from Otay Mesa and seasonal variations in gas and electric demand. SDG&E Gas Rule 14⁹⁹ was used to segregate impact to the key customer classes in order of their curtailment priority. The scenario analysis methodology and approach is discussed in detail in Section H, Supporting Analyses.

⁹⁵ See Section H for a detailed description of the scenario analysis performed.

⁹⁶ See Prepared Direct Testimony of Gwen Marelli, (March 21, 2016), page 2.

⁹⁷ Scores are based on a normalization of the average curtailment impacts under each Project Alternate, compared to the maximum impact for all Project Alternates. The maximum curtailment impact to the non-core, non-EG gas customer class, as an average across the 48 unique scenarios modeled per Project Alternative, was a 63.2% curtailment of gas services.

⁹⁸ See Section H for a detailed description of the scenario analysis performed.

⁹⁹ See Prepared Direct Testimony of Gwen Marelli, (March 21, 2016), page 2.

The scale for scoring the Alternatives against this benefit is based on a normalization of the average curtailment measured across all scenarios modeled for each Project Alternative. The average percentage of curtailment required under each Project Alternative was normalized from 0 to 100%, and the following scores (1 through 5) were applied accordingly.

1. Normalized curtailment impacts are above 81% of the maximum in all Project Alternatives¹⁰⁰
2. Normalized curtailment impacts are between 61% and 80% of the maximum in all Project Alternatives
3. Normalized curtailment impacts are between 41% and 60% of the maximum in all Project Alternatives
4. Normalized curtailment impacts are between 21% and 40% of the maximum in all Project Alternatives
5. Normalized curtailment impacts are between 0% and 20% of the maximum in all Project Alternatives

The results of the increased reliability benefits scoring are shown in Table below.

Table 14 - Increased Reliability Benefits Score

Reliability Benefits	Proposed Project - 36"	Hydrotest	Alt Diameter - 10"	Alt Diameter - 12"	Alt Diameter - 16"	Alt Diameter - 20"	Alt Diameter - 24"	Alt Diameter - 30"	Alt Diameter - 42"	Replace Line 1600 In-Place	Otay Mesa Alternatives	LNG Storage	Alt Energy – Grid Scale	Alt Energy – Smaller Scale	Offshore Route	Blythe to Santee Alt 1	Blythe to Santee Alt 2	Cactus City to SD and Pipeline Along Line 3010	
2.1 Redundancy to natural gas transmission system	5	2	1	1	2	3	3	4	5	2	3	3	1	1	5	5	5	5	5
2.2 Curtailment impact to core gas customers	5	1	3	3	5	5	5	5	5	5	1	1	1	1	5	5	5	5	5
2.3 Curtailment impact to electric generation (EG) gas customers	5	1	1	1	3	4	5	5	5	3	1	1	1	1	5	5	5	5	5

¹⁰⁰ Scores are based on a normalization of the average curtailment impacts under each Project Alternative, compared to the maximum impact for all Project Alternatives. The maximum curtailment impact to the electric customer class, as an average across the 48 unique scenarios modeled per Project Alternative, was a 4.2% curtailment of electric services.

Reliability Benefits	Proposed Project - 36"	Hydrotest	Alt Diameter - 10"	Alt Diameter - 12"	Alt Diameter - 16"	Alt Diameter - 20"	Alt Diameter - 24"	Alt Diameter - 30"	Alt Diameter - 42"	Replace Line 1600 In-Place	Otay Mesa Alternatives	LNG Storage	Alt Energy – Grid Scale	Alt Energy – Smaller Scale	Offshore Route	Blythe to Santee Alt 1	Blythe to Santee Alt 2	Cactus City to SD 4000 Pipe along Line 3010	
2.4 Curtailment impact to non-core, non-EG gas customers	5	1	1	1	2	3	4	5	5	2	1	1	1	1	5	5	5	5	5
2.5 Curtailment impact to electric customers	5	1	1	1	3	5	5	5	5	3	1	5	5	5	5	5	5	5	5
Average Score	5	1	1	1	3	4	4	5	5	3	1	2	2	2	5	5	5	5	5

(1 is the lowest (worst) score and 5 is the highest (best) score)

Results of the increased reliability benefits evaluation are discussed below.

a) Proposed Project

The Proposed Project will provide significant benefits in system reliability and resiliency.

The Proposed Project will provide complete redundancy to Line 3010 or Moreno Compressor Station in the event of a loss of either facility.

Based on a detailed outage and curtailment scenario analysis, the Proposed Project is expected to be amongst the projects that are estimated to result in the least amount of potential curtailment of customers across curtailment priorities defined by SDG&E Gas Rule 14.¹⁰¹

b) Hydrotest

Hydrotesting Line 1600 does not provide any significant additional benefits to system reliability to what is currently available to the gas system.

Based on a detailed outage and curtailment scenario analysis, the Proposed Project is expected to be amongst the projects that are estimated to result in the greatest amount of potential curtailment of customers across curtailment priorities defined by SDG&E Gas Rule 14.

¹⁰¹ See Prepared Direct Testimony of Gwen Marelli (March 21, 2016), page 2.

c) Alternative Diameter Pipelines

Table 15 - Reliability Benefits of Alternative Diameter Pipelines and the Replace Line 1600 In-Place with a New 16-inch Transmission Pipeline

Project	Reliability/Redundancy Benefits
Alternative diameter 10" through 12" (with a de-rated Line 1600 at distribution pressure)	Reduced level of system redundancy. See scoring Table for average curtailment percentages as defined by SDG&E's customer groups by order of service interruption priority.
Alternative diameter 16" (with a de-rated Line 1600 at distribution pressure) and the Replace Line 1600 In-Place with a New 16-inch Transmission Pipeline Alternative (no Line 1600)	Existing level of system redundancy. See scoring Table for average curtailment percentages as defined by SDG&E's customer groups by order of service interruption priority.
Alternative diameter pipelines 20" and 24" (with a de-rated Line 1600 at distribution pressure)	Increased System Redundancy. See scoring Table for average curtailment percentages as defined by SDG&E's customer groups by order of service interruption priority.
Alternative diameter pipeline 30" (with a de-rated Line 1600 at distribution pressure)	Complete Redundancy for Line 3010. See scoring Table for average curtailment percentages as defined by SDG&E's customer groups by order of service interruption priority.
Alternative diameter pipeline 42" (with a de-rated Line 1600 at distribution pressure)	Complete Redundancy for Line 3010 or Moreno Compressor Station. See scoring Table for average curtailment percentages as defined by SDG&E's customer groups by order of service interruption priority.

d) Other Alternatives

Table 16 - Reliability Benefits of Other Alternatives

Project	Reliability/Resiliency Benefits
Otay Mesa Alternatives (with a de-rated Line 1600 at distribution pressure)	Increased System Redundancy. See scoring Table for average curtailment percentages as defined by SDG&E's customer groups by order of service interruption priority.
Alternative pipelines: <ul style="list-style-type: none"> • Blythe-Santee Alt 1 • Blythe-Santee Alt 2 • Cactus City to SD • 2nd Pipeline Along Line 3010 • Offshore Route (with a de-rated Line 1600 at distribution pressure)	Complete Redundancy for Line 3010 or Moreno Compressor Station. See scoring Table for average curtailment percentages as defined by SDG&E's customer groups by order of service interruption priority.
<ul style="list-style-type: none"> • LNG Storage • Alternate Energy – Grid 	Increased System Redundancy for the LNG Storage option with Reduced System Redundancy for the Alternate Energy Alternatives.

Project	Reliability/Resiliency Benefits
Scale • Alternate Energy – Smaller Scale (Includes a de-rated Line 1600 at distribution pressure for all three above)	See scoring Table for average curtailment percentages as defined by SDG&E's customer groups by order of service interruption priority.

C. Increased Operational Flexibility

Increased operational flexibility is defined as the ability of the system to respond to operational (supply or demand) uncertainty in a manner that sustains normal operations with minimal impact to customers. Incremental pipeline capacity can provide flexibility to operate the Applicants' system by expanding the options available to handle stress conditions on a daily and hourly basis that put system integrity and customer service at risk.

Operational flexibility¹⁰² can be improved through the following means:

1. Increased capacity to handle intra-day or peak demand fluctuations; and
2. The ability to control day-to-day operations of the system without reliance on external systems or entities (complete asset control)

2. Evaluating Benefits using the Benefits Evaluation Model

Increased operational flexibility benefits have been assessed by evaluating and scoring the operational flexibility aspects of the Proposed Project and Alternatives using the benefits evaluation model described above.

The increased operational flexibility benefits of the respective scoring criteria are described below.

- 3.1 Meeting current and future natural gas peak demand: Ability to meet increasingly volatile daily and hourly peak demand due to: increased reliance on gas-fired EG to supplement closure of the San Onofre Nuclear Generating Station (SONGS) and dependence on intermittent renewable power; need to meet future peak demand due to increases in the use of renewable energy sources (up to 50% renewable generation by 2030); forecasted growth in the population of the San Diego greater metropolitan area (up by 1 million people by 2035).

The scale for scoring the projects against this benefit is:

1. No ability to meet current peak or future peak demand.
2. Decrease in the ability to meet current peak or future peak demand.
3. No increase in the ability to meet current peak or future peak demand.
4. Improved ability to meet current peak demand, but unlikely to meet future forecast peak demand.

¹⁰² See Prepared Direct Testimony of Davis Bisi (March 21, 2016).

5. Ability to meet and/or exceed the demands of current and all predicted future peak demand through 2035.

- 3.2 Utility Operational Control of Asset: Ability to control the physical asset by SDG&E.

The scale for scoring the projects against this benefit is binary:

1. Utility does not have operational control over asset
2. N/A
3. N/A
4. N/A
5. Utility has operational control over asset

The results of the increased operational flexibility scoring are shown in

Table 17 below.

Table 17 - Increased Operational Flexibility Benefits Score

Operational Flexibility Benefits	Proposed Project - 36"	Hydrotest	Alt Diameter - 10"	Alt Diameter - 12"	Alt Diameter - 16"	Alt Diameter - 20"	Alt Diameter - 24"	Alt Diameter - 30"	Alt Diameter - 42"	Replace Line 1600 In-Place	Otay Mesa Alternatives	Alt Energy – Grid Scale	Alt Energy – Smaller Scale	Offshore Route	Blythe to Santee Alt 1	Blythe to Santee Alt 2	Cactus City to SD	2nd Pipeline Along Line 3010
3.1 Meeting current and future natural gas peak demand	5	3	2	2	3	4	4	4	5	3	5	3	3	5	5	5	5	5
3.2 Utility Operational Control of Asset	5	5	5	5	5	5	5	5	5	5	1	5	5	5	5	5	5	5
Average Score	5	4	4	4	4	5	5	5	5	4	3	4	4	5	5	5	5	5

(1 is the lowest (worst) score and 5 is the highest (best) score)

Results of the increased operational flexibility benefits evaluation are discussed below.

a) *Proposed Project*

The Proposed Project will replace an existing 16-inch diameter pipeline with a 36-inch diameter pipeline, which will increase the transmission capacity of the gas system in San Diego County by approximately 200 MMcfd. This increase in capacity will enhance the Applicants’ ability to reliably manage the fluctuating peak demand of core and noncore customers, including electric generation (EG) and clean transportation. The new line would provide incremental system capacity and increase operational flexibility by expanding the options available to handle stress conditions on a daily and hourly basis that put customer service at risk.

The Proposed Project is able to meet and/or exceed the demands of current and all predicted future peak demand through 2035.

Under the Proposed Project, the Applicants retain operational control of the asset.

b) *Hydrotest*

There will be no increase in system capacity after the hydrotesting on Line 1600 is complete, and a potential short-term decrease in system capacity during the hydrotesting of Line 1600. In order to backfill the loss of supply from Line 1600 (~100 MMcfd), natural gas would have to be imported from Otay Mesa.

The lack of any increase in system capacity results in no change to the current operational flexibility and therefore no increase in the ability to meet current peak or future peak demand. Under this option the Applicants retain operational control of the asset.

c) *Alternative Diameter Pipelines*

Table 18 - Operational Flexibility Benefits of Alternative Diameter Pipelines

Project	Operational Flexibility Benefits
Alternative diameter 10" through 12" (with a de-rated Line 1600 at distribution pressure)	Decrease in the ability to meet current peak or future peak demand. Under this option the Applicants retain operational control of the asset.
Alternative diameter 16" (with a de-rated Line 1600 at distribution pressure)	No increase in the ability to meet current peak or future peak demand. Under this option the Applicants retain operational control of the asset.
Alternative diameter 20" through 30" (with a de-rated Line 1600 at distribution pressure)	Improved ability to meet current peak demand, but unlikely to meet future forecast peak demand through 2035. Under this option the Applicants retain operational control of the asset.
Alternative diameter 42" (with a de-rated Line 1600 at distribution pressure)	Ability to meet and/or exceed the demands of current and all predicted future peak demand through 2035. Under this option the Applicants retain operational control of the asset.

d) *Other Alternative Projects*

Table 19 - Operational Flexibility Benefits of Other Alternatives

Project	Operational Flexibility Benefits
Replace Line 1600 In-Place with a New 16-inch Transmission Pipeline Replacement (no Line)	No increase in the ability to meet current peak or future peak demand. Under this option the Applicants retain operational control of the asset.

Project	Operational Flexibility Benefits
1600)	
Otay Mesa Alternatives (with a de-rated Line 1600 at distribution pressure)	<p>Ability to meet and/or exceed the demands of current and all predicted future peak demand through 2035.</p> <p>Under this option the Applicants do not retain operational control of the asset as the lines are owned and operated by third-party entities.</p>
<p>Alternative pipelines:</p> <ul style="list-style-type: none"> • Blythe to Santee Alt 1 • Blythe to Santee Alt 2 • Cactus City to SD • 2nd Pipeline Along Line 3010 • Offshore Route <p>(with a de-rated Line 1600 at distribution pressure for all cases above)</p>	<p>Ability to meet and/or exceed the demands of current and all predicted future peak demand through 2035.</p> <p>Under this option the Applicants retain operational control of the asset.</p>
<ul style="list-style-type: none"> • LNG Storage • Alternative Energy (with a de-rated Line 1600 at distribution pressure for both cases above) 	<p>No increase in the ability to meet current peak or future peak demand.</p> <p>Under this option the Applicants retain operational control of the asset.</p>

D. Increased System Capacity

The Proposed Project and Alternatives were evaluated in terms of increased system capacity. The three elements of operational flexibility are:

- No change to system capacity
- Increased system capacity
- Decreased system capacity

1. Evaluating Benefits using the Benefits Evaluation Model

Increased system capacity benefits have been assessed by evaluating and scoring the capacity aspects of the Proposed Project and Alternatives using the benefits evaluation model described above.

The increased system capacity benefits of the respective scoring criteria are described below.

- 4.1 Impact to system capacity:¹⁰³ Ability of the project option to increase current system capacity. This impact is based on the diameter of the pipe and other critical design features. Increased system capacity can also help improve the system’s ability to meet additional load demands if the need arises. During intra-day, peak or extreme weather demand fluctuations, extra capacity can help bridge the gap between design and higher load scenarios.

The scale for scoring the projects against this benefit is:

1. Reduces system capacity by more than 20%
2. Reduces system capacity by up to 20%
3. No change to system capacity
4. Increases system capacity by up to 20%
5. Increases system capacity by more than 20%

The results of the increased capacity scoring are shown in Table 20 below.

Table 20 - Increased System Capacity Benefits Score

System Capacity Benefits	Proposed Project - 36"	Hydrotest	Alt Diameter - 10"	Alt Diameter - 12"	Alt Diameter - 16"	Alt Diameter - 20"	Alt Diameter - 24"	Alt Diameter - 30"	Alt Diameter - 42"	Replace Line 1600 In-Place	Otay Mesa Alternatives	LNG Storage	Alt Energy – Grid Scale	Alt Energy – Smaller Scale	Offshore Route	Blythe to Santee Alt 1	Blythe to Santee Alt 2	Cactus City to SD	2nd Pipeline Along Line 3010
4.1 Impact to system capacity	5	3	2	2	3	4	4	5	5	3	5	3	3	3	5	5	5	5	5

(1 is the lowest (worst) score and 5 is the highest (best) score)

Results of the increased capacity benefits evaluation are discussed below.

a) Proposed Project

The Proposed Project will increase overall gas system capacity. This increase in capacity will improve the ability to manage intra-day and peak load. To this end, the installation of a new 36” pipeline¹⁰⁴ is projected to add an additional 200 MMcfd (30%)¹⁰⁵ of system capacity.

¹⁰³ See Prepared Direct Testimony of David Bisi (March 21, 2016).

¹⁰⁴ In this scenario, Line 1600 will be consequentially de-rated to distribution operating pressures and no longer be considered a transmission asset.

¹⁰⁵ Current system capacity = 630 MMcfd in the winter operating season.

b) *Hydrotest*

A hydrotested Line 1600 will not add any incremental capacity to the system and will therefore not provide any of the benefits applicable to the Proposed Project above or the Alternatives.

c) *Alternate Diameter Pipelines*

Table 21 - System Capacity Benefits of Alternative Diameter Pipelines

Project	System Capacity Benefits
Alternate diameter 10" through 12" (with a de-rated Line 1600 at distribution pressure)	Reduces system capacity by up to 20%.
Alternate diameter 16" (with a de-rated Line 1600 at distribution pressure)	No change to system capacity.
Alternate diameter 20" and 24" (with a de-rated Line 1600 at distribution pressure)	Increases system capacity by up to 20%.
Alternate diameter 30" through 42"	Increases system capacity by more than 20%.

d) *Other Alternatives*

Table 22 - System Capacity Benefits of Other Alternatives

Project	System Capacity Benefits
Replace Line 1600 In-Place with a New 16-inch Transmission Pipeline Alternative (with no Line 1600)	No change to system capacity.
Otay Mesa Alternatives (with a de-rated Line 1600 at distribution pressure)	Increases system capacity by more than 20%.
Alternative pipelines: <ul style="list-style-type: none"> • Blythe to Santee Alt 1 • Blythe to Santee Alt 2 • Cactus City to SD • 2nd Pipeline Along Line 3010 • Offshore Route (with a de-rated Line 1600 at distribution pressure for cases above)	Increases system capacity by more than 20%.
<ul style="list-style-type: none"> • LNG Storage • Alternate Energy – Grid Scale • Alternate Energy – Smaller Scale (with a de-rated Line 1600 at distribution pressure for cases above)	No change to system capacity.

E. Increased Gas Storage through Line Pack

All additional pipelines on the SDG&E system incrementally increase the system line pack to greater or lesser extents. Line pack simply provides an operational buffer to changes in customer demand, and any incremental benefit that line pack provides is implicitly captured by the potential increases in system capacity provided in Section D above.

F. Reductions in Gas Price for Ratepayers

Reduction in gas prices to ratepayers is not expected for any of the project options and under two projects there is a potential for increases to ratepayer gas prices as discussed below.

- 6.1 Reduction in gas prices to ratepayers: Reduction in gas prices to ratepayers is not expected for any of the options being discussed presently and for two of the Alternatives (Otay Mesa and LNG Storage) there is a potential for an increase in gas prices to ratepayers owing to transportation costs to fill LNG tanks and the incremental transportation costs for supply from Otay Mesa.

This benefit was scored as follows:¹⁰⁶

1. Increase in gas prices to ratepayers expected
2. N/A
3. No change in gas prices to ratepayers expected
4. N/A
5. Potential reduction in gas prices to ratepayers

Table 23 - Reduction in Gas Prices to Ratepayers Benefit Scores

Gas Prices to Ratepayers	Proposed Project - 36"	Hydrotest	Alt Diameter - 10"	Alt Diameter - 12"	Alt Diameter - 16"	Alt Diameter - 20"	Alt Diameter - 24"	Alt Diameter - 30"	Alt Diameter - 42"	Replace Line 1600 In-Place	Otay Mesa Alternatives	LNG Storage	Alt Energy – Grid Scale	Alt Energy – Smaller Scale	Offshore Route	Blythe to Santee Alt 1	Blythe to Santee Alt 2	Cactus City to SD	2nd Pipeline Along Line 3010
6.1 Reduction in gas prices to ratepayers	3	3	3	3	3	3	3	3	3	3	1	1	3	3	3	3	3	3	3

(1 is the lowest (worst) score and 5 is the highest (best) score)

¹⁰⁶ See Prepared Direct Testimony of Gwen Marelli (March 21, 2016) for further details.

G. Other Benefits

Other benefits assessed in this study include environmental and other external or societal impacts as a result of any of the project options. The primary topics evaluate emissions reductions, air quality improvements, and the environmental and jurisdictional zoning impacts of route or site selection. Of these, net emissions reductions as a benefit is scored below.

1. Evaluating Benefits using the Benefits Evaluation Model

Other benefits have been assessed by evaluating and scoring the different aspects of benefits generated by the Proposed Project and Alternatives using the benefits evaluation model described above.

The other benefits and their respective scoring criteria are described below.

- 7.1 Emissions reductions due to reduced operating hours at Moreno Compressor Station:¹⁰⁷
The ability to manage excess capacity or load demand with minimal compression can lead to significant reductions in emissions at Moreno Compressor Station and a consequential reduction in combustion emissions of GHGs such as carbon dioxide, as well as a reduction in emissions of other pollutants such as nitrous oxides.

The scale for scoring the projects against this benefit is:

1. Potential increase in net emissions at Moreno Compressor Station
2. N/A
3. 0% reduction in net emissions at Moreno Compressor Station
4. 0% to 75% reduction in net emissions at Moreno Compressor Station
5. 75% or greater reduction in net emissions at Moreno Compressor Station

¹⁰⁷ Based on the figures provided within the Moreno Compressor Station – PSRP Report. *See* Prepared Direct Testimony of Neil Navin (March 21, 2016), Attachment A – PSRP Report at Attachment XII.

2. Results of Analyses

Table 24 - Summary of Other Benefits Scores

Other benefits	Proposed Project - 36"	Hydrotest	Alt Diameter - 10"	Alt Diameter - 12"	Alt Diameter - 16"	Alt Diameter - 20"	Alt Diameter - 24"	Alt Diameter - 30"	Alt Diameter - 42"	Replace Line 1600 In-Place	Otay Mesa Alternatives	LNG Storage	Alt Energy – Grid Scale	Alt Energy – Smaller Scale	Offshore Route	Blythe to Santee Alt 1	Blythe to Santee Alt 2	Cactus City to SD	2nd Pipeline Along Line 3010
7.1 Emissions reductions due to reduced operating hours at compressor stations	5	3	1	1	3	4	4	4	5	3	5	5	1	1	5	5	5	5	5

(1 is the lowest (worst) score and 5 is the highest (best) score)

Results of the other benefits evaluation are discussed below.

a) *Proposed Project*

The Proposed Project will reduce net emissions at the Moreno Compressor Station by 75% or greater.¹⁰⁸ The reduced operating hours at Moreno Compressor Station will result in a net reduction in emissions of GHGs such as carbon dioxide and methane, as well as a reduction in emissions of other pollutants such as nitrous oxides.

b) *Hydrotest*

A hydrotested Line 1600 is not expected to change the current level of emissions at Moreno Compressor Station as a result of no incremental redundancy or capacity offered by this option.

¹⁰⁸ It is assumed that the Moreno Compressor Station would only require reduced operations to function minimally as a safeguard during extreme or unplanned capacity interruption scenarios. The Moreno Compressor Station PSRP Report uses a high case of reduced operations by 95%. See Prepared Direct Testimony of Neil Navin (March 21, 2016), Attachment A – PSRP Report at Attachment XII.

c) *Alternative Diameter Pipelines*

Table 25 - Other Benefits of Alternative Diameter Pipelines

Project	Net Emissions at Moreno Compressor Station
Alternative diameter 10" through 12" (with a de-rated Line 1600 at distribution pressure)	Potential increase in net emissions at Moreno Compressor Station.
Alternative diameter 16" (with a de-rated Line 1600 at distribution pressure)	0% reduction in net emissions at Moreno Compressor Station.
Alternative diameter 20" through 30" (with a de-rated Line 1600 at distribution pressure)	0% to 75% reduction in net emissions at Moreno Compressor Station.
Alternative diameter 42" (with a de-rated Line 1600 at distribution pressure)	75% or greater reduction in net emissions at Moreno Compressor Station.

d) *Other Alternatives*

Table 26 - Other Benefits of Other Alternatives

Project	Net Emissions at Moreno Compressor Station
Replace Line 1600 In-Place with a New 16-ince Transmission Pipeline Alternative (no Line 1600)	0% reduction in net emissions at Moreno Compressor Station.
Otay Mesa Alternatives (with a de-rated Line 1600 at distribution pressure)	75% or greater reduction in net emissions at Moreno Compressor Station.
Alternative pipelines ¹⁰⁹ : <ul style="list-style-type: none"> • Blythe to Santee Alt 1 • Blythe to Santee Alt 2 • Cactus City to SD • 2nd Pipeline Along Line 3010 • Offshore Route (with a de-rated Line 1600 at distribution pressure for cases above)	75% or greater reduction in net emissions at Moreno Compressor Station.
<ul style="list-style-type: none"> • LNG Storage • Alternate Energy (with a de-rated Line 1600 at distribution pressure for cases above)	75% or greater reduction in net emissions at Moreno Compressor Station for the LNG Storage Alternative. Potential increase in net emissions at Moreno Compressor Station for the Alternate Energy solutions owing to the de-rating of Line 1600 and no addition of new transmission pipeline under this Alternative.

¹⁰⁹ The Cross County lines (J1, J2 and J3) are not directly connected to the Moreno Compressor Station, but are assumed to provide similar benefits with regards to avoided costs as the Proposed Project, due to the additional capacity inherent to a 36" pipeline. Due to the length of these lines, it is possible that additional compression may be needed to balance the gas flow in the system. However, at this stage in the design, it is not known whether this additional compression will be required.

H. Supporting Analysis

This section describes the approach and methodology used to estimate the impact of the various project options on overall system reliability introduced in Section VI.B above.

1. Pipeline Failure Analysis

Davies Consulting, LLC, with input and data from the Applicants, analyzed the potential failure rates for the existing Line 1600, the Proposed Project, and two proposed Alternatives: the 30” diameter pipeline (Alternative C5) and the 42” diameter pipeline (Alternative C6).

The Applicants’ method for comparing alternatives is by calculating the likelihood of an incident in an HCA mile as represented by the risk score in the equation below:

$$\text{Risk} = \text{Likelihood of Incident} \times \text{HCA Miles}$$

Where in accordance with Title 49 of the Code of Federal Regulations (49 CFR) Part 191.3, an “incident” is currently defined as any of the following events:

1. An event that involves a release of gas from a pipeline and
 - a) A death, or personal injury necessitating in-patient hospitalization; or
 - b) Estimated property damage, including cost of gas lost, of the operator or others, or both, of \$50,000 or more.
2. An event that is significant, in the judgment of the operator, even though it did not meet the criteria of paragraph.

a) *Likelihood of Pipeline Incidents*

To calculate the likelihood of pipeline incidents, the Applicants used historical pipeline incident and mileage data from PHMSA.¹¹⁰ The Applicants downloaded PHMSA’s Gas Transmission and Gathering Incident Data from 1970-1984, 1984-2001, 2002-2009, and 2010-present (filtering 2010 to present to only show incidents up to 2014, as all 2015 incidents may not yet be included). For each data set, the Applicants filtered the data to exclude gathering pipelines, offshore incidents,¹¹¹ and incidents attributable to a compressor or compressor station, all of which were not relevant to this analysis.

To analyze the risk of an incident on a pipeline like Line 1600, the Applicants filtered the data to remove any pipelines constructed after 1960 or having a diameter other than 16 inches. The year

¹¹⁰ <http://www.phmsa.dot.gov/pipeline/library/data-stats/raw-data>

¹¹¹ Prior to 1984, the incident data did not include a flag by which to identify offshore versus onshore incidents so the filtering of offshore incidents was only applicable to 1984 and beyond.

1960 was chosen based on “Integrity Characteristics of Vintage Pipelines,” which identifies 1960 as approximately the cutoff date for “historic” versus “modern” pipeline manufacturing.¹¹² More specifically, the report indicates that between 1950 and 1970, modern manufacturing techniques for pipelines were introduced, and “historic” practices were phased out. The report indicates that the use of flash welding, which was used in constructing Line 1600, peaked in 1950 and was phased out by 1970. To calculate the number of incidents on historic pipelines similar to Line 1600, the Applicants used all of the remaining unfiltered records for each dataset. The total remaining incidents, for the period 1970 to 2014, on onshore transmission pipelines constructed prior to 1960, is 125.

The PHMSA annual mileage report provides the total miles of pipeline by decade of installation and, separately, by diameter. The incident rate for pre-1960 16-inch pipelines was determined using the PHMSA reported information.¹¹³ Eight percent of all installed pipe has a diameter of 16 inches. The Applicants multiplied the total number of pre-1960 vintage pipeline miles by 8% to determine the number of mile-years needed to calculate the incident rate. The incident rate was then calculated to be **35.4E-05, or about 0.354 per thousand mile-years.**

To determine the incident rate on a new/modern pipeline, similar to the Proposed Project, the Applicants relied on a similar methodology to that described above. The team selected an incident and installation mileage date range of 2000 to 2014. Applying this filter to 36-inch pipe resulted in the identification of one incident. In order to increase the sample size to provide a more meaningful result, the Applicants expanded the diameter filter to include pipelines between 30-inches and 42-inches. The PHMSA incident data, reported 6 incidents that occurred on pipelines with diameters between 30-inch to 42-inch installed between 2000 and 2014. It should be noted, however, that one of these incidents was attributable to stripped threads, and the Proposed Project will not be subject to such failures by design. Thus, the comparable number of incidents of pipelines similar to the Proposed Project would be 5.

To determine the mile-years needed in the calculation of incident rate, the team collected the miles of 30-inch to 42-inch pipeline constructed between 2000 and 2009 and the miles constructed between 2010 and 2014. The share of 30-inch to 42-inch pipeline in the system is approximately 25%. Thus, the incident rate for onshore transmission 30-inch to 42-inch pipelines installed between 2000 and 2014 is **6.4 E-05, or 0.064 per thousand mile-years.**

Between the historic period in which Line 1600 was installed and the current modern period in which the proposed pipeline (Line 3602) will be installed, many improvements have been made in terms of testing, maintenance, and operations. These improvements, in addition to the new material and design, may have further reduced the likelihood of an incident on newly installed pipelines. Thus, to be conservative, it may be better to compare the incident rate over the same time period of 2000 to 2014.

¹¹² Clark, E. B., B. N. Leis, and R. J. Eiber. “Integrity Characteristics of Vintage Pipelines.” 2010. P7.

¹¹³ The PHMSA definition of incident was used for the Applicants’ analysis.

Once again, when identifying onshore transmission line incidents during the period between 2000 and 2014, there was insufficient data to use pipelines exactly 16 inches in diameter. Thus, the Applicants expanded the consideration to include pipelines with diameters between 12 and 20 inches. The share of pipelines between 12 and 20 inches is approximately 28%. Thus, the incident rate for onshore transmission 12-inch to 20-inch pipelines installed between 2000 and 2014 is **9.15E-05, or 0.0915 per thousand mile-years**.

As illustrated in Table 27, pipelines similar to Line 1600 have higher incident rates as compared to lines similar to the Proposed Project (Line 3602).

Table 27 - Incident Rates

Line	Incident Period	Incident Rate per Thousand Mile Years
Line similar to 1600	1970 – 2014	0.354
Line similar to 1600	2000 – 2014	0.0915
Line similar to 3602 ¹¹⁴	2000 - 2014	0.064

b) Consideration of Cause-Specific Incidents

In addition to a decrease in the probability of an incident based on year of installation, the Proposed Project will also have a reduced likelihood of an incident compared to Line 1600 because it will be less susceptible to corrosion, will be installed with features that reduce the likelihood of third-party damage (e.g., mesh and intrusion detection monitoring), and thicker pipe wall necessarily implies much greater puncture resistance.¹¹⁵ The European Gas Pipeline Incident Data Group (EGIG)¹¹⁶ has collected data on 1,060 incidents on over 100,000 kilometers of natural gas pipeline. This data shows that “[f]or pipelines having a wall thickness of 15 millimeters or thicker, there have been no corrosion or third-party damage incidents reported.”¹¹⁷ Because the Proposed Project will have a minimum thickness of 0.625 inches (15.875 millimeter), the EGIG data suggests that the likelihood of corrosion and third party damage is negligible.¹¹⁸

¹¹⁴ The Proposed Project, because of its modern construction and safety practices, is likely to have a lower incident rate.

¹¹⁵ For a detailed list of additional safety-enhancing features of the Proposed Project, see Prepared Direct Testimony of Deanna Haines (March 21, 2016).


¹¹⁶ Horalek V., Bolt R, EGIG Pipeline Incident Database: Safety Performances Determines the Acceptability of Cross Country Gas Transmission Systems

¹¹⁷ Horalek V., Bolt R, EGIG Pipeline Incident Database: Safety Performances Determines the Acceptability of Cross Country Gas Transmission Systems

¹¹⁸ See Prepared Direct Testimony of Neil Navin (March 21, 2016), for the physical specifications of the Proposed Project.

As shown in

Figure 4 below, nationwide 39% (and in California, 43%) of all incidents are a result of corrosion or third party damage.¹¹⁹ According to EGIG data, no incidents caused by corrosion or third parties have been reported on a pipeline with a wall thickness greater than 15 millimeters. Assuming that this data is accurate for future incidents in California, the incident rate for



pipelines with a wall thickness greater than 15 millimeters should be 43% lower.

Figure 4 - HCA Incidents by Cause

A 43% reduction, however, is larger than the difference in incident rates calculated for Lines 1600 and the Proposed Project from the PHMSA database. The calculated incident rates of 9.15E-05 for thinner pipelines like Line 1600 and 6.4 E-05 for thicker pipelines like the Proposed Project results in a decrease of 29%. The Applicants' analysis uses the more conservative 29% decrease rate.

c) Additional Considerations

There are several other factors that support the finding that the Proposed Project will have a reduced likelihood of incident than a pipeline like Line 1600. They are presented here for consideration, but are not used in the risk score calculation as they are not quantifiable due to data limitations.

Modern steels have greatly improved fracture toughness which also diminishes the likelihood of puncture and the tendency for burst.¹²⁰ In other words, modern pipes are much more likely to leak than to rupture.

¹¹⁹ Information compiled at the federal level by PHMSA and published at location <http://primis.phmsa.dot.gov/gasimp/performanceasures.htm>

¹²⁰ See B.N. Leis, O.C. Chang, T.A. Bubenik. "Leak versus Rupture Considerations for Steel Low-Stress Pipelines, GRI Report-00/0232." 2001. P11. See B.N. Leis and X.K. Zhu. "Leak vs. Rupture Boundary for Pipes with a Focus on Low Toughness and/or Ductility, PRCI Report PR-003-063526." 2012. A-3, A-8.

Modern manufacturing techniques may also further reduce the likelihood of an incident. The EGIG report finds that “the observed failure frequencies for pipelines constructed before 1964 are significantly higher than pipelines constructed after 1964.”¹²¹ According to Figure 4, better manufacturing of the new pipe would potentially eliminate the likelihood by an additional 7.1% of incidents, as the incidents attributable to non-state-of-the-art manufacturing and construction would be eliminated.

In addition, A.O. Smith, the company that manufactured the pipe for Line 1600, was the manufacturer for pipe involved in 415 incidents due to manufacturing, according to the PHMSA incident records. Most of the causes of these incidents are attributed to either corrosion or to manufacturing defects.

d) HCA Miles of Proposed Alternatives

The impact of an incident depends on whether the incident occurs in a high consequence area (HCA). Comparing potential impacts of an incident on each of the Alternatives requires a calculation of number of HCA miles affected by the incident. The HCA for a pipeline is a function of the proximity of structures to the pipeline, the size of the pipeline, and the pressure at which the pipeline is operating. For Line 1600, which operates at a transmission pressure of 640 psi, the HCA is 32.7 miles. Operating at distribution pressure of 320 psi, the HCA for Line 1600 is 2.3 miles.¹²² The Proposed Project, operating at 800 psi, has an HCA of 32.1 miles.¹²³

Table 28 - HCA Miles

Pipeline Option	HCA Miles
Line 1600 Transmission Pressure	32.7
Line 1600 De-rated at 320 psi.	2.3
Proposed Line 3602	32.1

e) Risk Score of Proposed Alternatives

The risk score of the Alternatives is calculated as the product of the likelihood of an incident (incident rate) on the pipeline and the HCA mileage of the pipeline. Table presents the risk scores for each component of the Alternatives analyzed.

¹²¹ Horalek V., Bolt R, EGIG Pipeline Incident Database: Safety Performances Determines the Acceptability of Cross Country Gas Transmission Systems, p.8.

¹²² Line 1600, once de-rated, will be a distribution line and will therefore not be subject to Subpart O and TIMP regulations. Using HCA comparison for a de-rated Line 1600 is shown for comparability purposes only.

¹²³ Calculated pursuant to 49 CFR 192.903.

Table 29 - Risk Scores

Pipeline Option	Likelihood of Incident	HCA Miles	Risk Score
Line 1600 Transmission Pressure	0.0915	32.7	2.99
Line 1600 De-rated	0.0915	2.3	0.21
Proposed Project 3602	0.064	32.1	2.05

Note that even without accounting for the potential incident rate reduction of derating Line 1600, the risk score of the de-rated line is only 7% of the line at transmission pressure.

Combining the risk scores of the Proposed Project and the de-rated Line 1600 results in:

$$\text{Risk Score of Proposed Alternative} = \sqrt{0.21^2 + 2.05^2} = 2.06$$

The risk score for the Hydrotest Alternative is:

$$\text{Risk Score of (Hydrotest) Alternative} = 2.99$$

The Proposed Project – a new 36-inch pipeline plus a de-rated Line 1600 operating at distribution-level operating pressure – has a total risk score of 2.06. Line 1600, operating at transmission-level operating pressure, has a risk score of 2.99. Therefore, the Proposed Project has a reduced incident rate of 31% in HCA miles, while increasing the capacity of the transmission pipeline serving SDG&E’s service territory.

2. Scenario Analysis

a) Analysis Overview

One of the primary drivers for the Proposed Project is to alleviate the current reliance on Line 3010 for transmission duties on the SDG&E gas system. To more clearly delineate the implications of this current reliance and the value of the proposed system redundancy, an analysis has been performed on scenarios where Line 3010 is operational in combination with the Proposed Project and each of the Alternatives. The objectives of the analysis are to assess the gas and electric curtailment impacts associated with an outage or reduction in pressure of Line 3010 if each of the Alternatives is also in place.

The analysis identifies impacts under various demand conditions and for a variety of available supply combinations. The basis of the analysis is explained in more detail below, and the results are discussed at the close of this section.

It is important to note, the Applicants’ gas transmission system is designed to meet a 1 in 10 design criterion. The Ruling, however, requires the Applicants to “apply quantifiable data to define the relative [reliability benefits]” of the Proposed Project. For purposes of identifying and quantifying the potential reliability benefits of the Proposed Project, PwC, with input from Applicants, generated a series of plausible scenarios in addition to the 1-in-10 design criterion. The assumptions used to generate these scenarios reflect engineering judgment and historical experience operating the gas transmission system. These scenarios were generated for the limited purpose of complying with the Ruling within a short timeframe and do not constitute the basis of new design criteria.

b) Assumptions, Parameters, and Variables

The scenario analysis is performed for a variety of cases, but the following assumptions apply universally.

Table 30 - Base Assumptions for Scenario Analysis

Base Assumptions
The impact is based on a 1-day outage or reduction in pressure of Line 3010, which can be extrapolated as needed
Moreno Compressor Station is functioning
An impact to Line 3010 has occurred in the northern section of the pipeline

The scenario analysis is performed across 3 main parameter sets as indicated in the table below.

Table 31 - Parameter Sets for Scenario Analysis

Project Alternatives Parameter Set	Line 3010 Parameter Set	Otay Mesa Supply Parameter Set
Line 1600 (Pre/Post Hydrotesting)	Line 3010 Complete Outage	Otay Mesa Full Supply
Line 1600 (During Hydrotesting)	Line 3010 at 80%	Otay Mesa Medium Supply
Line 3602 (Proposed Project)		Otay Mesa Low Supply
Alternate Diameter Pipeline 10"		Otay Mesa No Supply
Alternate Diameter Pipeline 12"		
Alternate Diameter Pipeline 16"		
Alternate Diameter Pipeline 20"		
Alternate Diameter Pipeline 24"		
Alternate Diameter Pipeline 30"		
Alternate Diameter Pipeline 42"		
Replace L1600 In-Place Alternative		
Otay Mesa Alternatives		
LNG Storage Alternative		
Alt Energy Alternative (Grid-Scale)		
Alt Energy Alternative (Smaller-Scale)		
Offshore Route		
Blythe to Santee Alternative 1		
Blythe to Santee Alternative 2		
Cactus City to San Diego Alternative		
Second Pipeline Along L3010 Alternative		

Each scenario has variables applied related to the time of year under which the scenario occurs and the supply available from Otay Mesa.

Table 32 - Seasonal Demand Variables for Scenario Analysis

Seasonal Demand Variables		
	Natural Gas Demand	Electric Demand
Example Summer Day With Low Electrical Generation	Example Summer day for Core, Electric Generation and Non-Core, Non-EG customers with low Natural Gas demand for Electrical Generation.	Example Summer day with low electric demand.
Example Summer Day With High Electrical Generation	Example Summer day for Core, Electric Generation and Non-Core, Non-EG customers with high Natural Gas demand for Electrical Generation.	Example Summer day with high electric demand.
Example Winter Day	Example Winter day for Core, Electric Generation and Non-Core, Non-EG customers.	Example Winter day for electric demand.
Winter 1 in 10 Year Day	Example Winter 1 in 10 Year day for Core, Electric Generation and Non-Core, Non-EG customers.	Example Winter 1 in 10 Year day for electric demand.
Example Spring Day	Example Spring day for Core, Electric Generation and Non-Core, Non-EG customers.	Example Spring day for electric demand.
Example Fall Day	Example Fall day for Core, Electric Generation and Non-Core, Non-EG customers.	Example Fall day for electric demand.

The base assumptions and variables result in 48 unique scenarios for each of the 20 identified situations: Line 1600 Pre or Post Hydrotesting, Line 1600 During Hydrotesting, the Proposed Project (Line 3602), and the 17 Project Alternatives. This results in a total of 960 unique scenarios for analysis.

Illustrated in Table 33 below is an example of the unique 48 scenarios for one Alternative (Alternate Diameter Pipeline 12"), which is replicated against each of the Alternatives.

Table 33 - Example of 48 Scenarios Analyzed for Alternate Diameter Pipeline 12"

		1. Example Summer Low-EG Day								2. Example Summer High-EG Day								3. Example Winter Day							
Scenario ID		4.1.1.1	4.2.1.1	4.1.2.1	4.2.2.1	4.1.3.1	4.2.3.1	4.1.4.1	4.2.4.1	4.1.1.2	4.2.1.2	4.1.2.2	4.2.2.2	4.1.3.2	4.2.3.2	4.1.4.2	4.2.4.2	4.1.1.3	4.2.1.3	4.1.2.3	4.2.2.3	4.1.3.3	4.2.3.3	4.1.4.3	4.2.4.3
Project Alternate	Alt. 12"	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Line 3010	80%	✓		✓		✓		✓		✓		✓		✓		✓		✓		✓		✓		✓	
	0%		✓		✓		✓		✓		✓		✓		✓		✓		✓		✓		✓		✓
Otay Mesa Supply	High	✓	✓							✓	✓							✓	✓						
	Medium			✓	✓							✓	✓							✓	✓				
	Low					✓	✓							✓	✓							✓	✓		
	None							✓	✓							✓	✓							✓	✓

		4. Winter 1-in-10 Year Day								5. Example Spring Day								6. Example Fall Day							
Scenario ID		4.1.1.4	4.2.1.4	4.1.2.4	4.2.2.4	4.1.3.4	4.2.3.4	4.1.4.4	4.2.4.4	4.1.1.5	4.2.1.5	4.1.2.5	4.2.2.5	4.1.3.5	4.2.3.5	4.1.4.5	4.2.4.5	4.1.1.6	4.2.1.6	4.1.2.6	4.2.2.6	4.1.3.6	4.2.3.6	4.1.4.6	4.2.4.6
Project Alternate	Alt. 12"	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Line 3010	80%	✓		✓		✓		✓		✓		✓		✓		✓		✓		✓		✓		✓	
	0%		✓		✓		✓		✓		✓		✓		✓		✓		✓		✓		✓		✓
Otay Mesa Supply	High	✓	✓							✓	✓							✓	✓						
	Medium			✓	✓							✓	✓							✓	✓				
	Low					✓	✓							✓	✓							✓	✓		
	None							✓	✓							✓	✓							✓	✓

c) **Summary Methodology**

A first step in the analysis involved a comparison of SDG&E’s natural gas supply and customer demand under each of the six seasonal demand conditions. The table below presents SDG&E’s customer natural gas demand data, as well as the various natural gas supply combinations analyzed in the study.¹²⁴

Table 34 - Natural gas customer demand and supply combinations under each seasonal demand conditions¹²⁵

	1. Example Summer Low-EG Day MMcfd	2. Example Summer High-EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd
--	---	--	---	---	---	------------------------------------

Project Alternatives Capacity [MMcfd]						
Core Demand	100	100	310	350	170	180
Electric Generation (EG) Demand	100	300	165	165	220	270
Non-Core, Non-EG Demand	75	75	62	62	75	75
Total Demand	275	475	537	577	465	525

Natural Gas Supply Combinations [MMcfd]						
Project Alternatives Capacity						
Line 1600 (Pre/Post Hydrotesting)	150	150	150	150	150	150
Line 1600 (During Hydrotesting)	0	0	0	0	0	0
Line 3602 (Proposed Project)	680	680	680	680	680	680
Alternate Diameter Pipeline 10"	50	50	50	50	50	50
Alternate Diameter Pipeline 12"	70	70	70	70	70	70
Alternate Diameter Pipeline 16" ¹²⁶	160	160	160	160	160	160
Alternate Diameter Pipeline 20"	250	250	250	250	250	250

¹²⁴ Natural gas supply from Otay Mesa Receipt Point was determined through an analysis of 2014-2015 flow data from the Gasoducto Rosarito pipeline that feeds into it.

¹²⁵ The gas transmission system is designed to meet a 1 in 10 design criterion. The Ruling, however, requires the Applicants to “apply quantifiable data to define the relative [reliability benefits]” of the Proposed Project. For purposes of identifying and quantifying the potential reliability benefits of the Proposed Project, PwC, with input from the Applicants, generated a series of plausible scenarios in addition to the 1 in 10 design criterion. The assumptions used to generate these scenarios reflect engineering judgment and historical experience operating the gas transmission system. These scenarios were generated for the limited purpose of complying with the Ruling within a short timeframe and do not constitute the basis of new design criteria.

¹²⁶ This scenario analysis uses 160 MMcfd and reflects the capacity of a new 16-inch pipeline operating at 800 psi. The remainder of the Cost-Effectiveness Analysis assumes 150 MMcfd for all 16-inch pipelines. The capacity difference between a 16-inch pipeline at 640 psi and 800 psi is considered negligible and does not significantly impact the outcome of this analysis.

	1. Example Summer Low-EG Day MMcfd	2. Example Summer High-EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd
--	---	--	---	---	---	------------------------------------

Project Alternatives Capacity [MMcfd]						
Alternate Diameter Pipeline 24"	400	400	400	400	400	400
Alternate Diameter Pipeline 30"	600	600	600	600	600	600
Alternate Diameter Pipeline 42"	710	710	710	710	710	710
Replace Line 1600 In-Place Alternative	160	160	160	160	160	160
Otay Mesa Alternatives	400	400	400	400	400	400
LNG Storage Alternative	0	0	0	0	0	0
Alt Energy Alternative (Grid-Scale)	0	0	0	0	0	0
Alt Energy Alternative (Smaller-Scale)	0	0	0	0	0	0
Offshore Route	680	680	680	680	680	680
Blythe to Santee Alternative 1	680	680	680	680	680	680
Blythe to Santee Alternative 2	680	680	680	680	680	680
Cactus City to San Diego Alternative	680	680	680	680	680	680
Second Pipeline Along Line 3010 Alternative	680	680	680	680	680	680
Line 3010 Parameter						
Line 3010 Complete Outage	0	0	0	0	0	0
Line 3010 at 80%	380	380	380	380	380	380
Otay Mesa Supply¹²⁷						
Otay Mesa Full Supply	295	86	313	313	329	324
Otay Mesa Medium Supply	156	60	230	230	244	247
Otay Mesa Low Supply	33	33	148	148	130	168
Otay Mesa No Supply	0	0	0	0	0	0

Table 35 - Electric customer demand and supply combinations under each seasonal demand conditions

	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1- in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW
Electric Demand (MW)¹²⁸						
Peak Electric Demand	3,062	3,723	2,969	3,328	2,693	3,019
Electric Supply Combinations (MW)						
Natural Gas Fired Electric Generation	562	1,686	1,124	1,124	1,236	1,517

¹²⁷ Otay Mesa supply provided over various seasonal conditions (source: SoCalGas/SDG&E Gas Transmission Planning Department).

¹²⁸ The Scenario Analysis applies the order of gas customer curtailments as described in the Prepared Direct Testimony of Gwen Marelli (March 21, 2016), page 2.

	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1- in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW
Renewable Electric Generation	70	70	70	70	70	70
Electric Import Capacity	2,500	2,500	2,500	2,500	2,500	2,500

Subsequently, supply combinations are established for each of the 960 scenarios, and then analyzed against the customer demand under those conditions. The following key outputs are gathered.

Table 36 - Outputs of Assessed Impacts

Outputs of Assessed Impacts	
General Impacts	<ul style="list-style-type: none"> Is immediate curtailment at Electrical Generation stations required? Overall capacity shortfalls in MMcfd
Curtailment to Gas Customers ¹²⁹	<ul style="list-style-type: none"> Curtailment for Core Customers (% of service impacted, # of customers affected)¹³⁰ Curtailment for Electric Generation (EG) Customers (% of service impacted) Curtailment for Non-Core, Non-EG Customers (% of service impacted)
Curtailment to Electric Meters	<ul style="list-style-type: none"> Curtailment to Electric Meters (% of service impacted, # of meters affected)

d) Summary Results

Outcomes of the 960 scenarios analyzed have been summarized in Figure 5 below. The graph presents the average percentage of curtailment for each gas customer class and outages to electric customers for the 20 situations.

¹²⁹ The Scenario Analysis applies the order of gas customer curtailments as described in the Prepared Direct Testimony of Gwen Marelli (March 21, 2016), page 2.

¹³⁰ Operational activities related to an outage are not factored in determining the number of core customers affected.

Figure 5 - Scenario Analysis Summary Results




Table 37 - Ranking of Project Alternatives by Average Curtailment

Project Alternative	Scoring of Average Curtailment Severity (Relative to other Project Alternatives, with range 1-Worst to 5-Best)			
	Gas Non-Core, Non-EG Customers	Gas Electric Generation (EG) Customers	Gas Core Customers	Electric
Line 1600 (Pre/Post Hydrotesting)	2	3	5	3
Line 1600 (During Hydrotesting)	1	1	1	1
Line 3602 (Proposed Project)	5	5	5	5
Alt Diameter Pipeline 10"	1	1	3	1
Alt Diameter Pipeline 12"	1	1	3	1
Alt Diameter Pipeline 16"	2	3	5	3
Alt Diameter Pipeline 20"	3	4	5	5
Alt Diameter Pipeline 24"	4	5	5	5
Alt Diameter Pipeline 30"	5	5	5	5
Alt Diameter Pipeline 42"	5	5	5	5
Replace Line 1600 in Place with a New 16" Transmission Pipeline	2	3	5	3
Otay Mesa Alternatives	1	1	1	1
LNG Storage Alternative	1	1	1	5
Alt Energy (Grid-Scale)	1	1	1	5
Alt Energy (Smaller-Scale)	1	1	1	5
Offshore Route	5	5	5	5
Blythe to Santee Alt 1	5	5	5	5
Blythe to Santee Alt 2	5	5	5	5
Cactus City to San Diego Alt	5	5	5	5
Second Pipeline Along Line 3010	5	5	5	5

From the graph and table above, it is evident that the highest and lowest reliability impacts were observed as follows.

Table 38 - Best and Worst Performing Alternatives

Best Performing	Worst Performing
Line 3602 (Proposed Project)	Line 1600 (Pre/Post Hydrotesting)
Alternate Diameter Pipeline 24"	Line 1600 (During Hydrotesting)
Alternate Diameter Pipeline 30"	Alt Diameter Pipeline 10"
Otay Mesa Alternatives	Alt Diameter Pipeline 12"
Offshore Route	Alt Diameter Pipeline 16"
Blythe to Santee Alternative 1	Replace Line 1600 in Place with a New 16" Transmission Pipeline
Blythe to Santee Alternative 2	LNG Storage Alternative
Cactus City to San Diego Alternative	Alt Energy (Grid-Scale)
Second Pipeline Along Line 3010 Alternative	Alt Energy (Smaller-Scale)

I. Benefits Analysis Summary

The following table provides the relative rank of the Proposed Project and Alternatives.

Table 39 - Relative Benefits of Proposed Project and Alternatives from Greatest to Least Benefits

Alt No.	Project Name	Benefits Rank
A	Proposed Project (36" Diameter)	1
C7	Alt Diameter Pipeline 42"	1
J1	Blythe to Santee Alternative 1	3
J2	Blythe to Santee Alternative 2	3
J3	Cactus City to San Diego Alternative	3
K	Second Pipeline Along Line 3010 Alternative	3
I	Offshore Route Alternative	7
C6	Alt Diameter Pipeline 30"	8
C5	Alt Diameter Pipeline 24"	9
C4	Alt Diameter Pipeline 20"	10
C3	Alt Diameter Pipeline 16"	11
D	Replace Line 1600 In Place with a New 16-inch Transmission Pipeline	12
E/F	Otay Mesa Alternatives	13
G	LNG Storage Alternative	14
B	Hydrotest	15
H1	Alternative Energy Alternative: Grid Scale Battery	16
H2	Alternate Energy Alternative: Smaller Scale Batteries	16
C1	Alt Diameter Pipeline 10"	18
C2	Alt Diameter Pipeline 12"	18

The results of the benefits analysis show that the Proposed Project and 42-inch Alternative Diameter Pipeline offer the most benefits. Four Alternatives comprise the next highest-ranked

group, the Cross-Country Pipeline Route Alternatives (Blythe to Santee Pipeline Routes, Alternatives 1 and 2; Cactus City to San Diego Alternative) and the Second Pipeline Along Line 3010 Alternative. The Off-Shore Route offers the third-most benefits, followed in descending order by several Alternative Diameter Pipelines (30-, 24-, 20-, and 16-inches), Replace Line 1600 In Place with a New 16-inch Alternative, the Otay Mesa Alternatives. The LNG Storage Alternative ranked 14th in terms of benefits, followed by the Hydrotest Alternative and the Alternative Energy Alternatives. The Alternative Diameter Pipelines of 10- and 12-inches offer the least benefits of all the Alternatives.

New, larger diameter pipelines outperform the “least-cost” (Hydrotest Alternative) in six out of the seven categories (safety, reliability, operational flexibility, system capacity, gas storage through line pack, and other benefits) and receive the same score for the category of reduction in gas price for ratepayers. As compared to other larger diameter pipelines, the Proposed Project provides additional reliability, operational flexibility, system capacity, gas storage through line pack, and other benefits.

VI. CONCLUSION

With data and input from the Applicants, PwC prepared this Cost-Effectiveness Analysis to comply with the Ruling. The analysis applies quantifiable data to define the relative costs and benefits of the Proposed Project and the range of Alternatives identified in the Ruling. The relative costs and benefits of the Proposed Project and Alternatives are set forth in the following table.

Table 40 - Proposed Project and Alternatives Relative Benefit Ranking and Net Costs

	Description	Benefit Rank	Net Cost (\$M)
A	Proposed Project (Rainbow to Line 2010 Route)	1	\$256.2
B	Hydrotest Alternative	15	\$118.7
C1	Alt Diameter Pipeline, Proposed Route (10")	18	\$302.7
C2	Alt Diameter Pipeline, Proposed Route (12")	18	\$291.6
C3	Alt Diameter Pipeline, Proposed Route (16")	11	\$241.4
C4	Alt Diameter Pipeline, Proposed Route (20")	10	\$239.2
C5	Alt Diameter Pipeline, Proposed Route (24")	9	\$229.6
C6	Alt Diameter Pipeline, Proposed Route (30")	8	\$233.5
C7	Alt Diameter Pipeline, Proposed Route (42")	1	\$341.9
D	Replace Line 1600 in Place with a New 16" Transmission Pipeline	12	\$460.1
E/F	Otay Mesa Alternatives	13	\$876.8
G	LNG Storage (Peak-Shaver) Alternative AKA (United States – LNG Alternative)	14	\$2,584.7
H1	Alternate Energy (Battery) Alternative – Grid Scale	16	\$8,330.1
H2	Alternate Energy (Battery) Alternative – Smaller Scale	16	\$10,010.1
I	Offshore Route Alternative	7	\$1,295.5
J1	Blythe to Santee Alternative 1	3	\$1,219.3
J2	Blythe to Santee Alternative 2	3	\$1,157.3
J3	Cactus City to San Diego Alternative	3	\$981.1
K	Second Pipeline Along Line 3010 Alternative	3	\$427.1

When considering both net project costs and benefits, the Proposed Project is the most cost-effective, prudent Alternative, as it provides more benefits than any of the Alternatives except for the 42-inch diameter pipeline, which provides the same level of benefits but costs \$86 million more (on a net cost basis) than the Proposed Project.

Although the costs analysis concludes that the “least-cost” alternative is the Hydrotest Alternative, which is estimated to cost \$118.7 million on a net cost basis, the group of “second least-cost” alternatives ranges from \$225 million to \$260 million and includes the Proposed Project. The third least-cost group has a larger range, from \$290 million to \$465 million, and the remaining two groups of Alternatives far exceed the net costs of the Proposed Project. These two “greatest cost” categories include Alternatives whose net costs range from \$500 million to

\$1 billion (Otay Mesa Alternatives, Cactus City to San Diego Alternative) and more than \$1 billion (Blythe to Santee Pipeline Routes, Alternatives 1 and 2, Off-Shore, LNG Storage, and Alternative Energy Alternatives).

In terms of benefits, the Proposed Project and 42-inch diameter pipeline ranked highest. Four Alternatives comprise the next highest-ranked group, the Cross-Country Pipeline Route Alternatives (Blythe to Santee Pipeline Routes, Alternatives 1 and 2; Cactus City to San Diego Alternative) and the Second Pipeline Along Line 3010 Alternative. The remaining projects are ranked in descending order, with the 10- and 12-inch Alternative Diameter Pipelines ranking lowest in terms of benefits. The “least-cost” Hydrotest Alternative ranked 15th out of 19.

New, larger diameter pipelines outperform the “least-cost” (Hydrotest Alternative) in six out of the seven benefits categories (safety, reliability, operational flexibility, system capacity, gas storage through line pack, and other benefits) and receive the same score for the category of reduction in gas price for ratepayers. As compared to other larger diameter pipelines, the Proposed Project provides additional reliability, operational flexibility, system capacity, gas storage through line pack, and other benefits.

The Proposed Project would provide more benefits than the 16-, 20-, 24- and 30-inch Alternate Diameter Pipelines without adding significantly higher costs. By contrast, the 42-inch Alternate Diameter Pipeline offers the same benefits as the Proposed Project but costs approximately \$86 million more. For these reasons, the Proposed Project is identified as the overall most cost-effective alternative.

PSRP Cost-Effectiveness Analysis Change Log – February 2017

Document	Witness	Page	Location	Revision Detail
CEA	Anthony Caletka	Cover	N/A	Added “as corrected February 2017”
CEA	Anthony Caletka	3	Table 2	For Alternative D, changed “\$560.4” to “\$460.1”
CEA	Anthony Caletka	4	6 th bullet point	Modified sentence as follows: “After the cluster that includes the Proposed Project, the next group of projects grouped by least net cost ranges from \$290 million to \$430 <u>\$465</u> million and includes Alternate Diameters of 10-, 12- and 42-inches, <u>the Replace Line 1600 In-Place with a New 16-inch Transmission Pipeline Alternative, and as well as the Second Pipeline Along Line 3010 Alternative;</u> ”
CEA	Anthony Caletka	4	7 th bullet point	Modified sentence as follows: “The two highest net cost categories include Alternatives with net costs ranging from \$500 million to \$1 billion (Replace Line 1600 In-Place with a New 16-inch Transmission Pipeline Alternative, Otay Mesa Alternatives, Cactus City to San Diego) and more than \$1 billion (Blythe to Santee Pipeline Route Alternatives 1 and 2, Off-Shore, Liquefied Natural Gas (LNG) Storage, and Alternate Energy Alternatives);”
CEA	Anthony Caletka	6	Figure 1	This figure is corrected to reflect the correction in Table 2. See the position of Alternative D: “1600 In-Kind Replacement”
CEA	Anthony Caletka	11	Section III.B second paragraph, first sentence	Modified sentence as follows: “The Hydrotest Alternative involves a complex four <u>three</u> year project to test the northern 45-miles of Line 1600, from Rainbow Metering Station to Kearny Villa Station.”

Document	Witness	Page	Location	Revision Detail
CEA	Anthony Caletka	23	Under Alternative C1: second and third sentence	Modified sentences as follows: “Costs for this Alternative were sealed <u>developed</u> from the Proposed Project on a cost per mile basis <u>estimate as a baseline</u> . This project involves the same proposed route and similar components as the Proposed Project though in different quantities <u>sizes</u> .”
CEA	Anthony Caletka	24	Under Alternative C2: second and third sentence	Modified sentences as follows: “Costs for this Alternative were sealed <u>developed</u> from the Proposed Project on a cost per mile basis <u>estimate as a baseline</u> . This project involves the same proposed route and similar components as the Proposed Project though in different quantities <u>sizes</u> .”
CEA	Anthony Caletka	24	Under Alternative C3: second and third sentence	Modified sentences as follows: “Costs for this Alternative were sealed <u>developed</u> from the Proposed Project on a cost per mile basis <u>estimate as a baseline</u> . This project involves the same proposed route and similar components as the Proposed Project though in different quantities <u>sizes</u> .”
CEA	Anthony Caletka	24	Under Alternative C4: second and third sentence	Modified sentences as follows: “Costs for this Alternative were sealed <u>developed</u> from the Proposed Project on a cost per mile basis <u>estimate as a baseline</u> . This project involves the same proposed route and similar components as the Proposed Project though in different quantities <u>sizes</u> .”
CEA	Anthony Caletka	24	Under Alternative C5: second and third sentence	Modified sentences as follows: “Costs for this Alternative were sealed <u>developed</u> from the Proposed Project on a cost per mile basis <u>estimate as a baseline</u> . This project involves the same proposed route and similar components as the Proposed Project though in different quantities <u>sizes</u> .”

Document	Witness	Page	Location	Revision Detail
CEA	Anthony Caletka	24	Under Alternative C6: second and third sentence	Modified sentences as follows: “Costs for this Alternative were sealed <u>developed</u> from the Proposed Project on a cost per mile basis <u>estimate</u> as a <u>baseline</u> . This project involves the same proposed route and similar components as the Proposed Project though in different quantities <u>sizes</u> .”
CEA	Anthony Caletka	25	Under Alternative C7: second and third sentence	Modified sentences as follows: “Costs for this Alternative were sealed <u>developed</u> from the Proposed Project on a cost per mile basis <u>estimate</u> as a <u>baseline</u> . This project involves the same proposed route and similar components as the Proposed Project though in different quantities <u>sizes</u> .”
CEA	Anthony Caletka	25	Under Alternative D: second and third sentence	Modified sentences as follows: “Costs for this Alternative were sealed from developed <u>using the Proposed Project Alternative B and Alternative C3 estimates</u> as a <u>baseline</u> . on a cost per mile basis. This project involves similar components as the Proposed Project though in different quantities.
CEA	Anthony Caletka	27	Section C first sentence	Modified sentence as follows: “The Applicants analyzed the total avoided costs that would accrue over an assumed 100 year useful life ⁶⁴ for the Proposed Project and Alternatives involving construction of a new pipeline (all Alternatives except the Hydrotest Alternative and the Replace Line 1600 In Place with a 16” Pipeline Alternative).”
CEA	Anthony Caletka	32	Table 8	For Alternative D: Avoided Cost – changed “\$0.0” to “(\$100.3)” Net Cost – changed “\$560.4” to “\$460.1”

Document	Witness	Page	Location	Revision Detail
CEA	Anthony Caletka	33	First paragraph, last sentence	Modified sentence as follows: <p>“The third least-cost category has a larger range, from \$290 million to \$430<u>\$465</u> million, and includes Alternative Diameters of 10-, 12- and 42-inches, <u>the Replace Line 1600 In-Place with a New 16-inch Transmission Pipeline Alternative, and as well as the Second Pipeline Along Line 3010 Alternative.</u>”</p>
CEA	Anthony Caletka	33	Second paragraph, second sentence	Modified sentence as follows: <p>“These last two “greatest cost” categories include Alternatives whose net costs range from \$500 million to \$1 billion (Replace Line 1600 in Place with a New 16-inch Pipeline, Otay Mesa Alternatives and Cactus City to San Diego Alternative) and over \$1 billion (Blythe to Santee Pipeline Routes, Alternatives 1 and 2, Off-Shore, LNG Storage, and Alternative Energy Alternatives).”</p>
CEA	Anthony Caletka	33	Table 9	Net Cost Range for Alternatives C2, C1, C7, K and D – change from “\$290 M to \$430 M” to “\$290 M to \$465 M” Change Net Cost for Alternative D from “\$560.4 M” to “\$460.1 M”
CEA	Anthony Caletka	68	Table 34	Change heading from “Natural Gas Demand [MMcfd]” to “Project Alternatives Capacity [MMcfd]”
CEA	Anthony Caletka	68	Footnote 127	Footnote 127 was missing in the original CEA and should read: “Otay Mesa supply provided over various seasonal conditions (source: SoCalGas/SDG&E Gas Transmission Planning Department).”
CEA	Anthony Caletka	68	Footnote 128	Footnote 128 was missing in the original CEA and should read: “The Scenario Analysis applies the order of gas customer curtailments as described in the Prepared Direct Testimony of Gwen Marelli (March 21, 2016), page 2.”

Document	Witness	Page	Location	Revision Detail
CEA	Anthony Caletka	70	Figure 5	This figure is corrected to reflect the corrections in Table 37. See the scores for the Otay Mesa Alternatives
CEA	Anthony Caletka	71	Table 37	The scores for the Otay Mesa Alternatives are modified as follows: Gas Non-Core, Non-EG Customers – change “4” to “1” Gas Electric Generation (EG) Customers – change “5” to “1” Gas Core Customers – change “5” to “1” Electric – change “5” to “1”
CEA	Anthony Caletka	74	Table 40	For Alternative D, changed “\$560.4” to “\$460.1”
CEA	Anthony Caletka	74	Last paragraph, second sentence	Modified sentence as follows: “The third least-cost group has a larger range, from \$290 million to \$430 <u>\$465</u> million, and the remaining two groups of Alternatives far exceed the net costs of the Proposed Project.”
CEA	Anthony Caletka	74-75	Last paragraph, last sentence	Modified sentence as follows: “These two “greatest cost” categories include Alternatives whose net costs range from \$500 million to \$1 billion (Replace Line 1600 in Place with a New 16-inch Pipeline , Otay Mesa Alternatives, Cactus City to San Diego Alternative) and more than \$1 billion (Blythe to Santee Pipeline Routes, Alternatives 1 and 2, Off-Shore, LNG Storage, and Alternative Energy Alternatives).”
CEA Workpaper Avoided Cost Model	Anthony Caletka	Inputs Tab Page 1, line 23	Second column	Change heading from “Capacity Needed to Meet PSEP 1-in-10 Year Winter Day Requirements (MMcfd)” to “Current System Capacity (MMcfd)”
CEA Workpaper Avoided Cost Model	Anthony Caletka	Inputs Tab Page 1, line 23	Fourth column	Change heading as follows: “Capacity Shortfall of Min Req [MMcfd]”

Document	Witness	Page	Location	Revision Detail
CEA Workpaper Avoided Cost Model	Anthony Caletka	Costs over 100 Yrs Tab, Page 2, Line 127,	Years 2039 and 2040	Updated the Avoided Cost Model, Alternative D, by adding in the costs for replacing Line 1600 as a transmission pipeline. The resulting output is shown on the “Outputs” tab, Line 14, Column “Avoided Cost – Line 1600 Replacement” (-\$100.3M) and Line 14, Column “Net Cost” (\$460.1M)
CEA Workpaper Scenario Analysis	Anthony Caletka	Gas Tab, Line 25	Columns C through H	Changed the fixed gas supply from the Otay Mesa Alternative from 400 MMcfd to 0 MMcfd. The resulting output is shown on the “Scoring” tab, Line 15, Columns M through P. The scores for the Otay Mesa Alternatives are modified as follows: Gas Non-Core, Non-EG Customers – change “4” to “1” Gas Electric Generation (EG) Customers – change “5” to “1” Gas Core Customers – change “5” to “1” Electric – change “5” to “1”

A.15-09-013 Cost-Effectiveness Analysis
Workpaper - Avoided Cost Model
corrected February 2017

WORK PAPER TABLE - AVOIDED COST MODEL INPUTS (AC 1.1)
INPUTS AND ASSUMPTIONS FOR AVOIDED COST MODEL, BY PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

Model Inputs	Assumptions / Sources:
Fixed Input Data	
MCS O&M and Emissions Cost	(\$5,866,617) Source: Moreno Valley Compressor Station – PSRP Benefit Analysis Final - 3-4-2016 Lou Pagdanganan 3-4-2016. Assumes 95% reduction in operations.
Future L1600 Replacement Cos	(\$337,050,844) Based on 16" Alternate Diameter Pipeline running same route as the Proposed Project. Includes 11.9% contingency. This is the more cost effective option than "Replace Line 1600 In-Place With a 16-Inch Pipeline (In-Kind Replacement)"
Discount Rate	7.79% SDG&E Business Finance. Authorized Cost of Capital (to change in 2011)
Inflation Rate	2.90% IHS Power Plant Q4 2014 Forecast - Construction Cost Indexes, Cost Trends of Gas Utility Construction, Pacific Region. Average percent change for Transmission Plant from 2017-2025. Provided by SDG&E Fina
L1600 Hydrotesting Duration (yrs)	3 Hydrotesting occurring on shoulder seasons only. See Prepared Direct Testimony of Neil Navin (March 21, 201
Est Useful Life of L1600 After Hydrotesting (yrs)	20 From Cost Effectiveness Analysis. Installation of new L1600 starts 20 years after hydrotesting and is completed 2 years after t
Project Lifetime Period (yrs)	100 The Role of Pipeline Age in Pipeline Safety, Kiefner and Rosenfield states that "...a well-maintained and periodically assessed pipeline can safely transport natural gas indefinitely." A 100 year lifetime period has been assumed for calculation pu

Inputs by Project Alternative

Footnotes	Avoided Cost Inputs	Proposed Project (Line 3602)	Hydrotest (Line 1600)	Alt. Diameter Pipelines							Replace Line 1600 In-Place	Otay Mesa Alternative	LNG Storage (Peak-Shaver)	Alternate Energy		Offshore Route	Cross-County Pipeline Alts			Second Pipeline Along Line 3010
				10"	12"	16"	20"	24"	30"	42"				Grid-Scale Batteries	Smaller-Scale Batteries		Blythe to Santee 1	Blythe to Santee 2	Cactus City to San Diego	
		A	B	C1	C2	C3	C4	C5	C6	C7	D	E/F	G	H1	H2	I	J1	J2	J3	K
N/A	Future L1600 Replacement Cos	✓	x	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
6	MCS O&M and Emissions Cost	✓	x	✓	✓	x	✓	✓	✓	✓	x	✓	x	x	x	✓	✓	✓	✓	✓
6	MCS Usage %	100%	0%	0%	0%	20%	40%	70%	100%	0%	0%	0%	0%	0%	0%	100%	100%	100%	100%	100%
2	Est Time Until Operational (From 2015)	6	6	6	6	6	6	6	6	6	11	9	10	10	10	15	10	10	10	11
2, 3, 5	Annual O&M Cost	\$240.0 K	\$300.0 K	\$240.0 K	\$240.0 K	\$240.0 K	\$240.0 K	\$240.0 K	\$240.0 K	\$240.0 K	\$300.0 K	\$ 0 K	\$1200.0 K	\$1200.0 K	\$1200.0 K	\$450.0 K	\$1138.1 K	\$1139.1 K	\$819.3 K	\$230.3 K
2, 4	TIMP Cost (Pigging Every 7 Years)	\$500.0 K	\$1400.0 K	\$500.0 K	\$500.0 K	\$500.0 K	\$500.0 K	\$500.0 K	\$500.0 K	\$500.0 K	\$500.0 K	\$ 0 K	\$ 0 K	\$ 0 K	\$ 0 K	\$500.0 K	\$1500.0 K	\$1500.0 K	\$1500.0 K	\$500.0 K

Importing Gas¹

Alternative Pipeline Size	Current System Capacity (MMcfd)	System Capacity w/ Line 3010 (MMcfd)	Capacity Shortfall (MMcfd)	NG Incremental Transport Cost (\$/dekaltherm)	NG Incremental Transport Cost (\$/MMcft)	Annual Cost to Import NG (2015 \$)
10 inch	630	570	60	0.3	300	6,570,000
12 inch	630	590	40	0.3	300	4,380,000
16 inch	630	630	0	0.3	300	-

Footnotes

- The 10-inch and 12-inch alternate diameter pipelines do not meet regulatory requirements for natural gas demand on a one in ten year winter day. It is assumed that these alternatives will require the import of gas via the Otay Mesa receipt point. The fixed costs used for these alternatives include the present value of gas required for the period analyzed, assuming a 2015 rate of \$0.30/dekaltherm, assuming a 60 MMcfd shortfall for the 10-inch pipeline and a 40 MMcfd shortfall for the 12-inch pipeline. It was assumed for either option that the required import capacity would have to be contracted for the entire year.
- See Prepared Direct Testimony of Neil Navin (March 21, 2016), page 31, workpaper Estimated Fixed and Operating Costs for Proposed Project and Alterna
- Following derating, Line 1600 maintenance will fall under the DIMP requirements. These have not been considered as part of this analysis
- Costs for pigging Line 1600 after hydrotesting were provided by SDG&E. They are much higher than TIMP costs associated with other options because of multi-diameter segments, potential retrofits of certain segments, and the need to import gas during hydro
- The O&M costs of small-scale batteries were assumed to be the same as or similar to the grid-scale opt
- Savings are based on the "best case" (95%) savings identified in the Moreno Valley Compressor Station - PSRP Benefit Analysis, Pagdanganan, 3-4-2016. Savings for pipelines between 16" and 36" are allocated on a straightline basis. Compression is assumed to not be required for pipelines with a diameter of 36" or greater. It is assumed that no additional compression is required for pipelines with a diameter of 16" or less.

WORK PAPER TABLE - AVOIDED COST MODEL - COSTS OVER 100 YEARS (AC 1.2)
ANNUAL COSTS BY PROJECT ALTERNATE, FOR AVOIDED COSTS AND O&M COSTS
A.15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.	PV (X years after operational)	0	1	2	3	4	5	6	7	8	9	10	11	12	13
1															
2															
3															
4															
5															
6															
7															
8															
9															
10															
11															
12															
13															
14															
15															
16															
17															
18															
19															
20															
21															
22															
23															
24															
25															
26															
27															
28															
29															
30															
31															
32															
33															
34															
35															
36															
37															
38															
39															
40															
41															
42															
43															
44															
45															
46															
47															
48															
49															
50															
51															
52															
53															
54															
55															
56															
57															
58															
59															
60															
61															
62															
63															
64															
65															
66															
67															
68															
69															
70															
71															
72															
73															
74															
75															
76															
77															
78															
79															
80															
81															
82															
83															
84															
85															
86															
87															
88															
89															
90															
91															
92															
93															
94															
95															
96															
97															

WORK PAPER TABLE - AVOIDED COST MODEL - COSTS OVER 100 YEARS (AC 1.2)
ANNUAL COSTS BY PROJECT ALTERNATE, FOR AVOIDED COSTS AND O&M COSTS
A.15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 21)

Line No.		PV (X years after operational)												
		27	28	29	30	31	32	33	34	35	36	37	38	39
	100													
	A Proposed Project (Line 3602)													
	PV	2042	2043	2044	2045	2046	2047	2048	2049	2050	2051	2052	2053	2054
	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-	-
	1 Future L1600 Replacement Cost	\$	(89,988,194)	(12,694,127)	(13,062,257)	(13,441,063)	(13,830,853)	(14,231,948)	(14,644,675)	(15,069,370)	(15,506,382)	(15,956,067)	(16,418,793)	(16,894,638)
	2 MCS O&M and Emissions Cost	\$	(190,253,617)	(12,694,127)	(13,062,257)	(13,441,063)	(13,830,853)	(14,231,948)	(14,644,675)	(15,069,370)	(15,506,382)	(15,956,067)	(16,418,793)	(16,894,638)
	3 Total Avoided Costs	\$	(190,253,617)	(12,694,127)	(13,062,257)	(13,441,063)	(13,830,853)	(14,231,948)	(14,644,675)	(15,069,370)	(15,506,382)	(15,956,067)	(16,418,793)	(16,894,638)
	Manual PV calc over 100 yrs for L3602 (Columns H to JJ)	\$	(190,253,617)	(1,593,836)	(1,483,346)	(1,416,053)	(1,351,812)	(1,290,496)	(1,231,942)	(1,176,053)	(1,122,701)	(1,071,768)	(1,023,146)	(976,730)
	4 Annual O&M Cost	\$	3,680,546	519,310	534,370	549,866	565,812	582,221	599,105	616,479	634,357	652,754	671,684	691,162
	5 Pigning to Occur	N/A	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE
	6 TIMP Cost	\$	904,581	1,081,896	-	-	-	-	-	1,321,578	-	-	-	-
	7 Total O&M Costs	\$	4,585,126	1,691,205	534,370	549,866	565,812	582,221	599,105	616,479	1,955,935	652,754	671,684	691,162
	B Hydrotest Alternate (Line 1600)													
	PV	2042	2043	2044	2045	2046	2047	2048	2049	2050	2051	2052	2053	2054
	\$	-	-	-	-	-	-	-	-	-	-	-	-	-
	1 Future L1600 Replacement Cost	\$	-	-	-	-	-	-	-	-	-	-	-	-
	2 MCS O&M and Emissions Cost	\$	-	-	-	-	-	-	-	-	-	-	-	-
	3 Total Avoided Costs	\$	-	-	-	-	-	-	-	-	-	-	-	-
	4 Annual O&M Cost	\$	4,242,275	519,310	534,370	549,866	565,812	582,221	599,105	616,479	634,357	652,754	671,684	691,162
	5 Pigning to Occur	N/A	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE
	6 TIMP Cost	\$	1,574,602	-	-	-	-	-	-	1,284,332	-	-	-	-
	7 Total O&M Costs	\$	5,816,876	519,310	534,370	549,866	565,812	582,221	599,105	1,900,812	634,357	652,754	671,684	691,162
	C1 Alternative Diameter Pipeline (10")													
	PV	2042	2043	2044	2045	2046	2047	2048	2049	2050	2051	2052	2053	2054
	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-	-
	1 Future L1600 Replacement Cost	\$	-	-	-	-	-	-	-	-	-	-	-	-
	2 MCS O&M and Emissions Cost	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-
	3 Total Avoided Costs	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-
	4 Annual O&M Cost	\$	3,680,546	519,310	534,370	549,866	565,812	582,221	599,105	616,479	634,357	652,754	671,684	691,162
	5 Pigning to Occur	N/A	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE
	6 TIMP Cost	\$	904,581	1,081,896	-	-	-	-	-	1,321,578	-	-	-	-
	7 Cost of Importing Gas	\$	100,754,039	14,716,101	14,628,368	15,052,590	15,489,115	15,938,300	16,400,510	16,876,125	17,365,382	17,869,133	18,387,338	18,920,571
	8 Total O&M Costs	\$	105,340,065	1,691,205	534,370	549,866	565,812	582,221	599,105	616,479	1,955,935	652,754	671,684	691,162
	C2 Alternative Diameter Pipeline (12")													
	PV	2042	2043	2044	2045	2046	2047	2048	2049	2050	2051	2052	2053	2054
	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-	-
	1 Future L1600 Replacement Cost	\$	-	-	-	-	-	-	-	-	-	-	-	-
	2 MCS O&M and Emissions Cost	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-
	3 Total Avoided Costs	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-
	4 Annual O&M Cost	\$	3,680,546	519,310	534,370	549,866	565,812	582,221	599,105	616,479	634,357	652,754	671,684	691,162
	5 Pigning to Occur	N/A	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE
	6 TIMP Cost	\$	904,581	1,081,896	-	-	-	-	-	1,321,578	-	-	-	-
	7 Cost of Importing Gas	\$	67,169,659	9,477,400	9,752,245	10,035,092	10,326,077	10,625,633	10,933,674	11,250,750	11,577,025	11,912,755	12,258,225	12,613,714
	8 Total O&M Costs	\$	71,755,086	1,691,205	534,370	549,866	565,812	582,221	599,105	616,479	1,955,935	652,754	671,684	691,162
	C3 Alternative Diameter Pipeline (16")													
	PV	2042	2043	2044	2045	2046	2047	2048	2049	2050	2051	2052	2053	2054
	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-	-
	1 Future L1600 Replacement Cost	\$	-	-	-	-	-	-	-	-	-	-	-	-
	2 MCS O&M and Emissions Cost	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-
	3 Total Avoided Costs	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-
	4 Annual O&M Cost	\$	3,680,546	519,310	534,370	549,866	565,812	582,221	599,105	616,479	634,357	652,754	671,684	691,162
	5 Pigning to Occur	N/A	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE
	6 TIMP Cost	\$	904,581	1,081,896	-	-	-	-	-	1,321,578	-	-	-	-
	7 Cost of Importing Gas	\$	67,169,659	9,477,400	9,752,245	10,035,092	10,326,077	10,625,633	10,933,674	11,250,750	11,577,025	11,912,755	12,258,225	12,613,714
	8 Total O&M Costs	\$	71,755,086	1,691,205	534,370	549,866	565,812	582,221	599,105	616,479	1,955,935	652,754	671,684	691,162
	C4 Alternative Diameter Pipeline (20")													
	PV	2042	2043	2044	2045	2046	2047	2048	2049	2050	2051	2052	2053	2054
	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-	-
	1 Future L1600 Replacement Cost	\$	-	-	-	-	-	-	-	-	-	-	-	-
	2 MCS O&M and Emissions Cost	\$	(17,993,677)	(2,538,925)	(2,612,451)	(2,688,213)	(2,766,171)	(2,846,390)	(2,928,935)	(3,013,874)	(3,101,276)	(3,191,213)	(3,283,759)	(3,378,888)
	3 Total Avoided Costs	\$	(118,279,110)	(2,538,925)	(2,612,451)	(2,688,213)	(2,766,171)	(2,846,390)	(2,928,935)	(3,013,874)	(3,101,276)	(3,191,213)	(3,283,759)	(3,378,888)
	4 Annual O&M Cost	\$	3,680,546	519,310	534,370	549,866	565,812	582,221	599,105	616,479	634,357	652,754	671,684	691,162
	5 Pigning to Occur	N/A	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE
	6 TIMP Cost	\$	904,581	1,081,896	-	-	-	-	-	1,321,578	-	-	-	-
	7 Total O&M Costs	\$	4,585,126	1,691,205	534,370	549,866	565,812	582,221	599,105	616,479	1,955,935	652,754	671,684	691,162
	C5 Alternative Diameter Pipeline (24")													
	PV	2042	2043	2044	2045	2046	2047	2048	2049	2050	2051	2052	2053	2054
	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-	-
	1 Future L1600 Replacement Cost	\$	-	-	-	-	-	-	-	-	-	-	-	-
	2 MCS O&M and Emissions Cost	\$	(35,487,253)	(5,077,651)	(5,224,903)	(5,376,425)	(5,532,341)	(5,692,779)	(5,857,870)	(6,022,748)	(6,202,553)	(6,382,427)	(6,567,517)	(6,757,675)
	3 Total Avoided Costs	\$	(136,272,737)	(5,077,651)	(5,224,903)	(5,376,425)	(5,532,341)	(5,692,779)	(5,857,870)	(6,022,748)	(6,202,553)	(6,382,427)	(6,567,517)	(6,757,675)
	4 Annual O&M Cost	\$	3,680,546	519,310	534,370	549,866	565,812	582,221	599,105	616,479	634,357	652,754	671,684	691,162
	5 Pigning to Occur	N/A	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE
	6 TIMP Cost	\$	904,581	1,081,896	-	-	-	-	-	1,321,578	-	-	-	-
	7 Total O&M Costs	\$	4,585,126	1,691,205	534,370	549,866	565,812	582,221	599,105	616,479	1,955,935	652,754	671,684	691,162

WORK PAPER TABLE - AVOIDED COST MODEL - COSTS OVER 00 YEARS (AC 1.2)
ANNUAL COSTS BY PROJECT ALTERNATE, FOR AVOIDED COSTS AND O&M COSTS
A.15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2)

Line No.	PV (X years after operational)	40	41	42	43	44	45	46	47	48	49	50	51	52
A Proposed Project (Line 3602)														
	PV	2055	2056	2057	2058	2059	2060	2061	2062	2063	2064	2065	2066	2067
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ (89,988,134)	\$ (18,407,836)	\$ (18,941,663)	\$ (19,490,971)	\$ (20,056,209)	\$ (20,637,839)	\$ (21,236,337)	\$ (21,852,190)	\$ (22,485,904)	\$ (23,137,995)	\$ (23,808,997)	\$ (24,499,458)	\$ (25,209,942)
3	Total Avoided Costs	\$ (190,253,617)	\$ (18,407,836)	\$ (18,941,663)	\$ (19,490,971)	\$ (20,056,209)	\$ (20,637,839)	\$ (21,236,337)	\$ (21,852,190)	\$ (22,485,904)	\$ (23,137,995)	\$ (23,808,997)	\$ (24,499,458)	\$ (25,209,942)
	Manual PV calc over 100 yrs for L3602 (Columns H to DJ)	\$ (190,253,617)	\$ (849,739)	\$ (811,189)	\$ (774,389)	\$ (739,258)	\$ (705,721)	\$ (673,705)	\$ (643,142)	\$ (613,965)	\$ (586,112)	\$ (559,522)	\$ (534,139)	\$ (509,907)
B Hydrotect Alternate (Line 1600)														
	PV	2055	2056	2057	2058	2059	2060	2061	2062	2063	2064	2065	2066	2067
1	Future L1600 Replacement Cost	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
3	Total Avoided Costs	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
4	Annual O&M Cost	\$ 3,680,546	\$ 753,054	\$ 774,893	\$ 797,365	\$ 820,488	\$ 844,282	\$ 868,767	\$ 893,961	\$ 919,886	\$ 946,562	\$ 974,013	\$ 1,002,259	\$ 1,031,325
5	Pigging to Occur	N/A	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE
6	TIMP Cost	\$ 904,581	\$ -	\$ 1,614,360	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 1,972,005	\$ -	\$ -	\$ -	\$ -
7	Total O&M Costs	\$ 4,585,126	\$ 753,054	\$ 2,389,253	\$ 797,365	\$ 820,488	\$ 844,282	\$ 868,767	\$ 893,961	\$ 919,886	\$ 2,916,567	\$ 974,013	\$ 1,002,259	\$ 1,031,325
C1 Alternative Diameter Pipeline (10")														
	PV	2055	2056	2057	2058	2059	2060	2061	2062	2063	2064	2065	2066	2067
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
3	Total Avoided Costs	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
4	Annual O&M Cost	\$ 4,242,275	\$ 753,054	\$ 774,893	\$ 797,365	\$ 820,488	\$ 844,282	\$ 868,767	\$ 893,961	\$ 919,886	\$ 946,562	\$ 974,013	\$ 1,002,259	\$ 1,031,325
5	Pigging to Occur	N/A	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE
6	TIMP Cost	\$ 1,574,602	\$ 1,568,863	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 1,916,428	\$ -	\$ -	\$ -	\$ -
7	Total O&M Costs	\$ 5,816,876	\$ 2,321,917	\$ 774,893	\$ 797,365	\$ 820,488	\$ 844,282	\$ 868,767	\$ 893,961	\$ 2,836,314	\$ 946,562	\$ 974,013	\$ 1,002,259	\$ 1,031,325
C2 Alternative Diameter Pipeline (12")														
	PV	2055	2056	2057	2058	2059	2060	2061	2062	2063	2064	2065	2066	2067
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
3	Total Avoided Costs	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
4	Annual O&M Cost	\$ 3,680,546	\$ 753,054	\$ 774,893	\$ 797,365	\$ 820,488	\$ 844,282	\$ 868,767	\$ 893,961	\$ 919,886	\$ 946,562	\$ 974,013	\$ 1,002,259	\$ 1,031,325
5	Pigging to Occur	N/A	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE
6	TIMP Cost	\$ 904,581	\$ -	\$ 1,614,360	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 1,972,005	\$ -	\$ -	\$ -	\$ -
7	Cost of Importing Gas	\$ 105,754,639	\$ 20,614,899	\$ 21,124,689	\$ 21,827,867	\$ 22,460,865	\$ 23,112,230	\$ 23,782,485	\$ 24,472,177	\$ 25,181,870	\$ 25,912,145	\$ 26,663,597	\$ 27,436,841	\$ 28,232,509
8	Total O&M Costs	\$ 165,340,665	\$ 753,054	\$ 2,389,253	\$ 797,365	\$ 820,488	\$ 844,282	\$ 868,767	\$ 893,961	\$ 919,886	\$ 2,916,567	\$ 974,013	\$ 1,002,259	\$ 1,031,325
C3 Alternative Diameter Pipeline (16")														
	PV	2055	2056	2057	2058	2059	2060	2061	2062	2063	2064	2065	2066	2067
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
3	Total Avoided Costs	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
4	Annual O&M Cost	\$ 3,680,546	\$ 753,054	\$ 774,893	\$ 797,365	\$ 820,488	\$ 844,282	\$ 868,767	\$ 893,961	\$ 919,886	\$ 946,562	\$ 974,013	\$ 1,002,259	\$ 1,031,325
5	Pigging to Occur	N/A	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE
6	TIMP Cost	\$ 904,581	\$ -	\$ 1,614,360	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 1,972,005	\$ -	\$ -	\$ -	\$ -
7	Cost of Importing Gas	\$ 67,169,659	\$ 13,743,339	\$ 14,141,785	\$ 14,551,026	\$ 14,973,010	\$ 15,408,154	\$ 15,854,990	\$ 16,314,785	\$ 16,787,914	\$ 17,274,763	\$ 17,775,731	\$ 18,291,227	\$ 18,821,673
8	Total O&M Costs	\$ 71,755,686	\$ 753,054	\$ 2,389,253	\$ 797,365	\$ 820,488	\$ 844,282	\$ 868,767	\$ 893,961	\$ 919,886	\$ 2,916,567	\$ 974,013	\$ 1,002,259	\$ 1,031,325
C4 Alternative Diameter Pipeline (20")														
	PV	2055	2056	2057	2058	2059	2060	2061	2062	2063	2064	2065	2066	2067
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ (17,893,677)	\$ (3,681,567)	\$ (3,788,333)	\$ (3,898,194)	\$ (4,011,242)	\$ (4,127,568)	\$ (4,247,267)	\$ (4,370,438)	\$ (4,497,181)	\$ (4,627,599)	\$ (4,761,799)	\$ (4,899,892)	\$ (5,041,988)
3	Total Avoided Costs	\$ (118,279,110)	\$ (3,681,567)	\$ (3,788,333)	\$ (3,898,194)	\$ (4,011,242)	\$ (4,127,568)	\$ (4,247,267)	\$ (4,370,438)	\$ (4,497,181)	\$ (4,627,599)	\$ (4,761,799)	\$ (4,899,892)	\$ (5,041,988)
4	Annual O&M Cost	\$ 3,680,546	\$ 753,054	\$ 774,893	\$ 797,365	\$ 820,488	\$ 844,282	\$ 868,767	\$ 893,961	\$ 919,886	\$ 946,562	\$ 974,013	\$ 1,002,259	\$ 1,031,325
5	Pigging to Occur	N/A	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE
6	TIMP Cost	\$ 904,581	\$ -	\$ 1,614,360	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 1,972,005	\$ -	\$ -	\$ -	\$ -
7	Total O&M Costs	\$ 4,585,126	\$ 753,054	\$ 2,389,253	\$ 797,365	\$ 820,488	\$ 844,282	\$ 868,767	\$ 893,961	\$ 919,886	\$ 2,916,567	\$ 974,013	\$ 1,002,259	\$ 1,031,325
C5 Alternative Diameter Pipeline (24")														
	PV	2055	2056	2057	2058	2059	2060	2061	2062	2063	2064	2065	2066	2067
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ (35,887,253)	\$ (7,363,134)	\$ (7,576,665)	\$ (7,796,388)	\$ (8,022,484)	\$ (8,255,136)	\$ (8,494,535)	\$ (8,740,876)	\$ (8,994,362)	\$ (9,253,599)	\$ (9,523,599)	\$ (9,799,783)	\$ (10,083,977)
3	Total Avoided Costs	\$ (136,272,737)	\$ (7,363,134)	\$ (7,576,665)	\$ (7,796,388)	\$ (8,022,484)	\$ (8,255,136)	\$ (8,494,535)	\$ (8,740,876)	\$ (8,994,362)	\$ (9,253,599)	\$ (9,523,599)	\$ (9,799,783)	\$ (10,083,977)
4	Annual O&M Cost	\$ 3,680,546	\$ 753,054	\$ 774,893	\$ 797,365	\$ 820,488	\$ 844,282	\$ 868,767	\$ 893,961	\$ 919,886	\$ 946,562	\$ 974,013	\$ 1,002,259	\$ 1,031,325
5	Pigging to Occur	N/A	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE
6	TIMP Cost	\$ 904,581	\$ -	\$ 1,614,360	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 1,972,005	\$ -	\$ -	\$ -	\$ -
7	Total O&M Costs	\$ 4,585,126	\$ 753,054	\$ 2,389,253	\$ 797,365	\$ 820,488	\$ 844,282	\$ 868,767	\$ 893,961	\$ 919,886	\$ 2,916,567	\$ 974,013	\$ 1,002,259	\$ 1,031,325

WORK PAPER TABLE - AVOIDED COST MODEL - COSTS OVER 00 YEARS (AC 1.2)
ANNUAL COSTS BY PROJECT ALTERNATE, FOR AVOIDED COSTS AND O&M COSTS
A.15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2)

Line No.	PV (X years after operation)	53	54	55	56	57	58	59	60	61	62	63	64	65
1	A Proposed Project (Line 3602)													
2														
3														
4														
5														
6	1 Future L1600 Replacement Cost													
7	2 MCS O&M and Emissions Cost													
8	3 Total Avoided Costs													
9														
10	Manual PV calc over 100 yrs for L3602 (Columns H to DJ)													
11														
12														
13														
14	4 Annual O&M Cost													
15	5 Piggung to Occur													
16	6 TIMP Cost													
17	7 Total O&M Costs													
18														
19														
20	B Hydrotest Alternate (Line 1600)													
21	1 Future L1600 Replacement Cost													
22	2 MCS O&M and Emissions Cost													
23	3 Total Avoided Costs													
24														
25														
26	4 Annual O&M Cost													
27	5 Piggung to Occur													
28	6 TIMP Cost													
29	7 Total O&M Costs													
30														
31														
32	C1 Alternative Diameter Pipeline (10")													
33	1 Future L1600 Replacement Cost													
34	2 MCS O&M and Emissions Cost													
35	3 Total Avoided Costs													
36														
37														
38	4 Annual O&M Cost													
39	5 Piggung to Occur													
40	6 TIMP Cost													
41	7 Cost of Importing Gas													
42	8 Total O&M Costs													
43														
44														
45														
46	C2 Alternative Diameter Pipeline (12")													
47														
48	1 Future L1600 Replacement Cost													
49	2 MCS O&M and Emissions Cost													
50	3 Total Avoided Costs													
51														
52														
53	4 Annual O&M Cost													
54	5 Piggung to Occur													
55	6 TIMP Cost													
56	7 Cost of Importing Gas													
57	8 Total O&M Costs													
58														
59														
60	C3 Alternative Diameter Pipeline (16")													
61	1 Future L1600 Replacement Cost													
62	2 MCS O&M and Emissions Cost													
63	3 Total Avoided Costs													
64														
65														
66														
67	4 Annual O&M Cost													
68	5 Piggung to Occur													
69	6 TIMP Cost													
70	7 Total O&M Costs													
71														
72														
73	C4 Alternative Diameter Pipeline (20")													
74	1 Future L1600 Replacement Cost													
75	2 MCS O&M and Emissions Cost													
76	3 Total Avoided Costs													
77														
78														
79	4 Annual O&M Cost													
80	5 Piggung to Occur													
81	6 TIMP Cost													
82	7 Total O&M Costs													
83														
84														
85	C5 Alternative Diameter Pipeline (24")													
86	1 Future L1600 Replacement Cost													
87	2 MCS O&M and Emissions Cost													
88	3 Total Avoided Costs													
89														
90														
91	4 Annual O&M Cost													
92	5 Piggung to Occur													
93	6 TIMP Cost													
94	7 Total O&M Costs													
95														
96														
97														

WORK PAPER TABLE - AVOIDED COST MODEL - COSTS OVER 00 YEARS (AC 1.2)
ANNUAL COSTS BY PROJECT ALTERNATE, FOR AVOIDED COSTS AND O&M COSTS
A.15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2)

Line No.	PV (X years after operation)	66	67	68	69	70	71	72	73	74	75	76	77	78
	100													
	PV	2081	2082	2083	2084	2085	2086	2087	2088	2089	2090	2091	2092	2093
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ (89,988,134)	\$ (38,708,155)	\$ (39,830,691)	\$ (40,985,781)	\$ (42,174,369)	\$ (43,397,426)	\$ (44,655,951)	\$ (45,950,974)	\$ (47,283,552)	\$ (48,654,775)	\$ (50,065,764)	\$ (51,517,671)	\$ (53,011,683)
3	Total Avoided Costs	\$ (190,253,617)	\$ (38,708,155)	\$ (39,830,691)	\$ (40,985,781)	\$ (42,174,369)	\$ (43,397,426)	\$ (44,655,951)	\$ (45,950,974)	\$ (47,283,552)	\$ (48,654,775)	\$ (50,065,764)	\$ (51,517,671)	\$ (53,011,683)
	Manual PV calc over 100 yrs for L3602 (Columns H to DJ)	\$ (190,253,617)	\$ (254,124)	\$ (242,595)	\$ (231,069)	\$ (221,063)	\$ (211,053)	\$ (201,479)	\$ (192,339)	\$ (183,613)	\$ (175,283)	\$ (167,331)	\$ (159,740)	\$ (152,493)
4	Annual O&M Cost	\$ 3,680,546	\$ 1,583,529	\$ 1,629,451	\$ 1,676,705	\$ 1,725,330	\$ 1,775,364	\$ 1,826,850	\$ 1,879,828	\$ 1,934,344	\$ 1,990,439	\$ 2,048,162	\$ 2,107,559	\$ 2,168,678
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE
6	TI&P Cost	\$ 904,581	\$ -	\$ -	\$ -	\$ 3,594,437	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 4,390,748	\$ -
7	Total O&M Costs	\$ 4,585,126	\$ 1,583,529	\$ 1,629,451	\$ 1,676,705	\$ 5,319,767	\$ 1,775,364	\$ 1,826,850	\$ 1,879,828	\$ 1,934,344	\$ 1,990,439	\$ 2,048,162	\$ 6,498,307	\$ 2,168,678
	PV	2081	2082	2083	2084	2085	2086	2087	2088	2089	2090	2091	2092	2093
1	Future L1600 Replacement Cost	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
3	Total Avoided Costs	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
4	Annual O&M Cost	\$ 4,242,275	\$ 1,583,529	\$ 1,629,451	\$ 1,676,705	\$ 1,725,330	\$ 1,775,364	\$ 1,826,850	\$ 1,879,828	\$ 1,934,344	\$ 1,990,439	\$ 2,048,162	\$ 2,107,559	\$ 2,168,678
5	Pigging to Occur	N/A	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE
6	TI&P Cost	\$ 1,574,602	\$ -	\$ -	\$ 3,493,138	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 4,267,005	\$ -	\$ -
7	Total O&M Costs	\$ 5,816,876	\$ 1,583,529	\$ 1,629,451	\$ 5,169,841	\$ 1,725,330	\$ 1,775,364	\$ 1,826,850	\$ 1,879,828	\$ 1,934,344	\$ 1,990,439	\$ 6,315,167	\$ 2,107,559	\$ 2,168,678
	PV	2081	2082	2083	2084	2085	2086	2087	2088	2089	2090	2091	2092	2093
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
3	Total Avoided Costs	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
4	Annual O&M Cost	\$ 3,680,546	\$ 1,583,529	\$ 1,629,451	\$ 1,676,705	\$ 1,725,330	\$ 1,775,364	\$ 1,826,850	\$ 1,879,828	\$ 1,934,344	\$ 1,990,439	\$ 2,048,162	\$ 2,107,559	\$ 2,168,678
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE
6	TI&P Cost	\$ 904,581	\$ -	\$ -	\$ -	\$ 3,594,437	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 4,390,748	\$ -
7	Cost of Importing Gas	\$ 100,754,039	\$ 43,340,102	\$ 44,606,226	\$ 45,899,806	\$ 47,230,901	\$ 48,600,597	\$ 50,010,014	\$ 51,460,305	\$ 52,952,653	\$ 54,488,280	\$ 56,069,441	\$ 57,698,425	\$ 59,367,564
8	Total O&M Costs	\$ 165,340,065	\$ 1,583,529	\$ 1,629,451	\$ 1,676,705	\$ 5,319,767	\$ 1,775,364	\$ 1,826,850	\$ 1,879,828	\$ 1,934,344	\$ 1,990,439	\$ 2,048,162	\$ 6,498,307	\$ 2,168,678
	PV	2081	2082	2083	2084	2085	2086	2087	2088	2089	2090	2091	2092	2093
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
3	Total Avoided Costs	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
4	Annual O&M Cost	\$ 3,680,546	\$ 1,583,529	\$ 1,629,451	\$ 1,676,705	\$ 1,725,330	\$ 1,775,364	\$ 1,826,850	\$ 1,879,828	\$ 1,934,344	\$ 1,990,439	\$ 2,048,162	\$ 2,107,559	\$ 2,168,678
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE
6	TI&P Cost	\$ 904,581	\$ -	\$ -	\$ -	\$ 3,594,437	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 4,390,748	\$ -
7	Cost of Importing Gas	\$ 67,169,659	\$ 28,899,401	\$ 29,737,484	\$ 30,599,871	\$ 31,487,267	\$ 32,400,398	\$ 33,340,009	\$ 34,306,670	\$ 35,301,769	\$ 36,325,520	\$ 37,378,960	\$ 38,462,560	\$ 39,576,376
8	Total O&M Costs	\$ 71,755,086	\$ 1,583,529	\$ 1,629,451	\$ 1,676,705	\$ 5,319,767	\$ 1,775,364	\$ 1,826,850	\$ 1,879,828	\$ 1,934,344	\$ 1,990,439	\$ 2,048,162	\$ 6,498,307	\$ 2,168,678
	PV	2081	2082	2083	2084	2085	2086	2087	2088	2089	2090	2091	2092	2093
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
3	Total Avoided Costs	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
4	Annual O&M Cost	\$ 3,680,546	\$ 1,583,529	\$ 1,629,451	\$ 1,676,705	\$ 1,725,330	\$ 1,775,364	\$ 1,826,850	\$ 1,879,828	\$ 1,934,344	\$ 1,990,439	\$ 2,048,162	\$ 2,107,559	\$ 2,168,678
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE
6	TI&P Cost	\$ 904,581	\$ -	\$ -	\$ -	\$ 3,594,437	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 4,390,748	\$ -
7	Total O&M Costs	\$ 4,585,126	\$ 1,583,529	\$ 1,629,451	\$ 1,676,705	\$ 5,319,767	\$ 1,775,364	\$ 1,826,850	\$ 1,879,828	\$ 1,934,344	\$ 1,990,439	\$ 2,048,162	\$ 6,498,307	\$ 2,168,678
	PV	2081	2082	2083	2084	2085	2086	2087	2088	2089	2090	2091	2092	2093
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ (17,993,677)	\$ (7,741,631)	\$ (7,966,138)	\$ (8,197,156)	\$ (8,434,874)	\$ (8,679,485)	\$ (8,931,190)	\$ (9,190,195)	\$ (9,456,710)	\$ (9,730,955)	\$ (10,013,153)	\$ (10,303,534)	\$ (10,602,337)
3	Total Avoided Costs	\$ (118,279,110)	\$ (7,741,631)	\$ (7,966,138)	\$ (8,197,156)	\$ (8,434,874)	\$ (8,679,485)	\$ (8,931,190)	\$ (9,190,195)	\$ (9,456,710)	\$ (9,730,955)	\$ (10,013,153)	\$ (10,303,534)	\$ (10,602,337)
4	Annual O&M Cost	\$ 3,680,546	\$ 1,583,529	\$ 1,629,451	\$ 1,676,705	\$ 1,725,330	\$ 1,775,364	\$ 1,826,850	\$ 1,879,828	\$ 1,934,344	\$ 1,990,439	\$ 2,048,162	\$ 2,107,559	\$ 2,168,678
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE
6	TI&P Cost	\$ 904,581	\$ -	\$ -	\$ -	\$ 3,594,437	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 4,390,748	\$ -
7	Total O&M Costs	\$ 4,585,126	\$ 1,583,529	\$ 1,629,451	\$ 1,676,705	\$ 5,319,767	\$ 1,775,364	\$ 1,826,850	\$ 1,879,828	\$ 1,934,344	\$ 1,990,439	\$ 2,048,162	\$ 6,498,307	\$ 2,168,678
	PV	2081	2082	2083	2084	2085	2086	2087	2088	2089	2090	2091	2092	2093
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ (35,487,253)	\$ (15,483,282)	\$ (15,932,277)	\$ (16,394,313)	\$ (16,869,748)	\$ (17,358,970)	\$ (17,862,380)	\$ (18,380,300)	\$ (18,913,421)	\$ (19,461,910)	\$ (20,026,305)	\$ (20,607,068)	\$ (21,204,573)
3	Total Avoided Costs	\$ (135,772,737)	\$ (15,483,282)	\$ (15,932,277)	\$ (16,394,313)	\$ (16,869,748)	\$ (17,358,970)	\$ (17,862,380)	\$ (18,380,300)	\$ (18,913,421)	\$ (19,461,910)	\$ (20,026,305)	\$ (20,607,068)	\$ (21,204,573)
4	Annual O&M Cost	\$ 3,680,546	\$ 1,583,529	\$ 1,629,451	\$ 1,676,705	\$ 1,725,330	\$ 1,775,364	\$ 1,826,850	\$ 1,879,828	\$ 1,934,344	\$ 1,990,439	\$ 2,048,162	\$ 2,107,559	\$ 2,168,678
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE
6	TI&P Cost	\$ 904,581	\$ -	\$ -	\$ -	\$ 3,594,437	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 4,390,748	\$ -
7	Total O&M Costs	\$ 4,585,126	\$ 1,583,529	\$ 1,629,451	\$ 1,676,705	\$ 5,319,767	\$ 1,775,364	\$ 1,826,850	\$ 1,879,828	\$ 1,934,344	\$ 1,990,439	\$ 2,048,162	\$ 6,498,307	\$ 2,168,678

WORK PAPER TABLE - AVOIDED COST MODEL - COSTS OVER 00 YEARS (AC 1.2)
ANNUAL COSTS BY PROJECT ALTERNATE, FOR AVOIDED COSTS AND O&M COSTS
A.15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2)

Line No.		PV (X years after operation)	79	80	81	82	83	84	85	86	87	88	89	90	91	
1		100														
A Proposed Project (Line 3602)																
			2094	2095	2096	2097	2098	2099	2100	2101	2102	2103	2104	2105	2106	
4	Future L1600 Replacement Cost	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-	-	
5	MCS O&M and Emissions Cost	\$	(89,988,134)	(66,130,944)	(57,758,741)	(69,433,744)	(61,157,323)	(62,930,885)	(64,755,881)	(66,633,802)	(68,566,182)	(70,554,601)	(72,600,685)	(74,706,104)	(76,872,581)	(79,101,886)
6	Total Avoided Costs	\$	(190,253,617)	(66,130,944)	(57,758,741)	(69,433,744)	(61,157,323)	(62,930,885)	(64,755,881)	(66,633,802)	(68,566,182)	(70,554,601)	(72,600,685)	(74,706,104)	(76,872,581)	(79,101,886)
7	<i>Manual PV calc over 100 yrs for L3602 (Columns H to DJ)</i>															
8		\$	(190,253,617)	(138,977)	(132,667)	(126,648)	(120,903)	(115,418)	(110,182)	(105,163)	(100,411)	(95,856)	(91,508)	(87,356)	(83,393)	(79,670)
4	Annual O&M Cost	\$	3,680,546	2,296,285	2,362,878	2,431,401	2,501,912	2,574,467	2,649,127	2,725,951	2,805,004	2,886,349	2,970,053	3,056,185	3,144,814	3,236,014
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE
6	TI&P Cost	\$	904,581	-	-	-	-	5,363,473	-	-	-	-	-	-	6,551,696	-
7	Total O&M Costs	\$	4,585,126	2,296,285	2,362,878	2,431,401	2,501,912	7,937,940	2,649,127	2,725,951	2,805,004	2,886,349	2,970,053	3,056,185	3,144,814	3,236,014
B Hydrotest Alternate (Line 1600)																
			2094	2095	2096	2097	2098	2099	2100	2101	2102	2103	2104	2105	2106	
4	Future L1600 Replacement Cost	\$	-	-	-	-	-	-	-	-	-	-	-	-	-	
5	MCS O&M and Emissions Cost	\$	-	-	-	-	-	-	-	-	-	-	-	-	-	
6	Total Avoided Costs	\$	-	-	-	-	-	-	-	-	-	-	-	-	-	
4	Annual O&M Cost	\$	4,242,275	2,296,285	2,362,878	2,431,401	2,501,912	2,574,467	2,649,127	2,725,951	2,805,004	2,886,349	2,970,053	3,056,185	3,144,814	3,236,014
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE
6	TI&P Cost	\$	1,574,602	-	-	-	-	5,212,316	-	-	-	-	-	6,367,051	-	-
7	Total O&M Costs	\$	5,816,876	2,296,285	2,362,878	2,431,401	7,714,228	2,574,467	2,649,127	2,725,951	2,805,004	2,886,349	2,970,053	9,423,236	3,144,814	3,236,014
C1 Alternative Diameter Pipeline (10")																
			2094	2095	2096	2097	2098	2099	2100	2101	2102	2103	2104	2105	2106	
4	Future L1600 Replacement Cost	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-	-	
5	MCS O&M and Emissions Cost	\$	-	-	-	-	-	-	-	-	-	-	-	-	-	
6	Total Avoided Costs	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-	-	
4	Annual O&M Cost	\$	3,680,546	2,296,285	2,362,878	2,431,401	2,501,912	2,574,467	2,649,127	2,725,951	2,805,004	2,886,349	2,970,053	3,056,185	3,144,814	3,236,014
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	
6	TI&P Cost	\$	904,581	-	-	-	-	5,363,473	-	-	-	-	-	-	6,551,696	-
7	Cost of Importing Gas	\$	100,754,039	62,880,810	64,683,774	66,509,603	68,409,832	70,476,037	72,519,842	74,622,917	76,786,862	79,013,805	81,305,205	83,663,056	86,099,284	88,585,874
8	Total O&M Costs	\$	165,340,665	2,296,285	2,362,878	2,431,401	2,501,912	7,937,940	2,649,127	2,725,951	2,805,004	2,886,349	2,970,053	3,056,185	3,144,814	3,236,014
C2 Alternative Diameter Pipeline (12")																
			2094	2095	2096	2097	2098	2099	2100	2101	2102	2103	2104	2105	2106	
4	Future L1600 Replacement Cost	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-	-	
5	MCS O&M and Emissions Cost	\$	-	-	-	-	-	-	-	-	-	-	-	-	-	
6	Total Avoided Costs	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-	-	
4	Annual O&M Cost	\$	3,680,546	2,296,285	2,362,878	2,431,401	2,501,912	2,574,467	2,649,127	2,725,951	2,805,004	2,886,349	2,970,053	3,056,185	3,144,814	3,236,014
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	
6	TI&P Cost	\$	904,581	-	-	-	-	5,363,473	-	-	-	-	-	-	6,551,696	
7	Cost of Importing Gas	\$	67,169,659	41,907,207	43,122,516	44,373,069	45,659,888	46,984,026	48,346,581	49,748,612	51,191,321	52,675,870	54,203,470	55,775,371	57,392,586	
8	Total O&M Costs	\$	71,755,086	2,296,285	2,362,878	2,431,401	2,501,912	7,937,940	2,649,127	2,725,951	2,805,004	2,886,349	2,970,053	3,056,185	3,144,814	3,236,014
C3 Alternative Diameter Pipeline (16")																
			2094	2095	2096	2097	2098	2099	2100	2101	2102	2103	2104	2105	2106	
4	Future L1600 Replacement Cost	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-	-	
5	MCS O&M and Emissions Cost	\$	-	-	-	-	-	-	-	-	-	-	-	-	-	
6	Total Avoided Costs	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-	-	
4	Annual O&M Cost	\$	3,680,546	2,296,285	2,362,878	2,431,401	2,501,912	2,574,467	2,649,127	2,725,951	2,805,004	2,886,349	2,970,053	3,056,185	3,144,814	3,236,014
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	
6	TI&P Cost	\$	904,581	-	-	-	-	5,363,473	-	-	-	-	-	-	6,551,696	
7	Total O&M Costs	\$	4,585,126	2,296,285	2,362,878	2,431,401	2,501,912	7,937,940	2,649,127	2,725,951	2,805,004	2,886,349	2,970,053	3,056,185	3,144,814	3,236,014
C4 Alternative Diameter Pipeline (20")																
			2094	2095	2096	2097	2098	2099	2100	2101	2102	2103	2104	2105	2106	
4	Future L1600 Replacement Cost	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-	-	
5	MCS O&M and Emissions Cost	\$	(17,993,672)	(11,226,189)	(11,551,748)	(11,886,749)	(12,231,465)	(12,586,177)	(12,951,176)	(13,326,760)	(13,713,236)	(14,110,920)	(14,520,137)	(14,941,221)	(15,374,516)	(15,820,377)
6	Total Avoided Costs	\$	(118,279,110)	(11,226,189)	(11,551,748)	(11,886,749)	(12,231,465)	(12,586,177)	(12,951,176)	(13,326,760)	(13,713,236)	(14,110,920)	(14,520,137)	(14,941,221)	(15,374,516)	(15,820,377)
4	Annual O&M Cost	\$	3,680,546	2,296,285	2,362,878	2,431,401	2,501,912	2,574,467	2,649,127	2,725,951	2,805,004	2,886,349	2,970,053	3,056,185	3,144,814	3,236,014
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	
6	TI&P Cost	\$	904,581	-	-	-	-	5,363,473	-	-	-	-	-	-	6,551,696	
7	Total O&M Costs	\$	4,585,126	2,296,285	2,362,878	2,431,401	2,501,912	7,937,940	2,649,127	2,725,951	2,805,004	2,886,349	2,970,053	3,056,185	3,144,814	3,236,014
C5 Alternative Diameter Pipeline (24")																
			2094	2095	2096	2097	2098	2099	2100	2101	2102	2103	2104	2105	2106	
4	Future L1600 Replacement Cost	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-	-	
5	MCS O&M and Emissions Cost	\$	(35,497,253)	(22,462,377)	(23,103,498)	(23,773,498)	(24,462,929)	(25,172,354)	(25,902,352)	(26,653,521)	(27,426,473)	(28,221,840)	(29,040,274)	(29,882,442)	(30,749,033)	(31,640,755)
6	Total Avoided Costs	\$	(135,772,737)	(22,462,377)	(23,103,498)	(23,773,498)	(24,462,929)	(25,172,354)	(25,902,352)	(26,653,521)	(27,426,473)	(28,221,840)	(29,040,274)	(29,882,442)	(30,749,033)	(31,640,755)
4	Annual O&M Cost	\$	3,680,546	2,296,285	2,362,878	2,431,401	2,501,912	2,574,467	2,649,127	2,725,951	2,805,004	2,886,349	2,970,053	3,056,185	3,144,814	3,236,014
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	
6	TI&P Cost	\$	904,581	-	-	-	-	5,363,473	-	-	-	-	-	-	6,551,696	
7	Total O&M Costs	\$	4,585,126	2,296,285	2,362,878	2,431,401	2,501,912	7,937,940	2,649,127	2,725,951	2,805,004	2,886,349	2,970,053	3,056,185	3,144,814	3,236,014

WORK PAPER TABLE - AVOIDED COST MODEL - COSTS OVER 00 YEARS (AC 1.2)
ANNUAL COSTS BY PROJECT ALTERNATE, FOR AVOIDED COSTS AND O&M COSTS
A.15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2)

Line No.	PV (X years after operation)	92	93	94	95	96	97	98	99	100	101	102	103	104
1	100													
2														
3														
4														
5														
6														
7														
8														
9														
10														
11														
12														
13														
14														
15														
16														
17														
18														
19														
20														
21														
22														
23														
24														
25														
26														
27														
28														
29														
30														
31														
32														
33														
34														
35														
36														
37														
38														
39														
40														
41														
42														
43														
44														
45														
46														
47														
48														
49														
50														
51														
52														
53														
54														
55														
56														
57														
58														
59														
60														
61														
62														
63														
64														
65														
66														
67														
68														
69														
70														
71														
72														
73														
74														
75														
76														
77														
78														
79														
80														
81														
82														
83														
84														
85														
86														
87														
88														
89														
90														
91														
92														
93														
94														
95														
96														
97														

WORK PAPER TABLE - AVOIDED COST MODEL - COSTS OVER 100 YEARS (AC 1.2)
ANNUAL COSTS BY PROJECT ALTERNATE, FOR AVOIDED COSTS AND O&M COSTS
A.15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 21)

Line No.	PV (X years after operation)	105	106	107	108	109	110	111	112	113	114	115	116
	100												
A Proposed Project (Line 3602)	PV	2120	2121	2122	2123	2124	2125	2126	2127	2128	2129	2130	2131
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ (89,988,134)	\$ (118,032,631)	\$ (121,455,577)	\$ (124,977,789)	\$ (128,602,145)	\$ (132,331,607)	\$ (136,169,223)	\$ (140,118,131)	\$ (144,181,557)	\$ (148,362,822)	\$ (152,665,344)	\$ (157,092,638)
3	Total Avoided Costs	\$ (190,253,617)	\$ (118,032,631)	\$ (121,455,577)	\$ (124,977,789)	\$ (128,602,145)	\$ (132,331,607)	\$ (136,169,223)	\$ (140,118,131)	\$ (144,181,557)	\$ (148,362,822)	\$ (152,665,344)	\$ (157,092,638)
	<i>Manual PV calc over 100 yrs for L3602 (Columns H to J)</i>	<i>\$ (190,253,617)</i>	<i>\$ (41,967)</i>	<i>\$ (39,675)</i>									
4	Annual O&M Cost	\$ 3,680,546	\$ 4,828,648	\$ 4,968,679	\$ 5,112,771	\$ 5,261,041	\$ 5,413,612	\$ 5,570,606	\$ 5,732,154	\$ 5,898,386	\$ 6,069,440	\$ 6,245,453	\$ 6,426,571
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE
6	TIMP Cost	\$ 904,581	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
7	Total O&M Costs	\$ 4,585,126	\$ 4,828,648	\$ 4,968,679	\$ 5,112,771	\$ 5,261,041	\$ 5,413,612	\$ 5,570,606	\$ 5,732,154	\$ 5,898,386	\$ 6,069,440	\$ 6,245,453	\$ 6,426,571
B Hydrotect Alternate (Line 1600)	PV	2120	2121	2122	2123	2124	2125	2126	2127	2128	2129	2130	2131
1	Future L1600 Replacement Cost	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
3	Total Avoided Costs	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
4	Annual O&M Cost	\$ 4,242,275	\$ 4,828,648	\$ 4,968,679	\$ 5,112,771	\$ 5,261,041	\$ 5,413,612	\$ 5,570,606	\$ 5,732,154	\$ 5,898,386	\$ 6,069,440	\$ 6,245,453	\$ 6,426,571
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE
6	TIMP Cost	\$ 1,574,602	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
7	Total O&M Costs	\$ 5,816,876	\$ 4,828,648	\$ 4,968,679	\$ 5,112,771	\$ 5,261,041	\$ 5,413,612	\$ 5,570,606	\$ 5,732,154	\$ 5,898,386	\$ 6,069,440	\$ 6,245,453	\$ 6,426,571
C1 Alternative Diameter Pipeline (10")	PV	2120	2121	2122	2123	2124	2125	2126	2127	2128	2129	2130	2131
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
3	Total Avoided Costs	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
4	Annual O&M Cost	\$ 3,680,546	\$ 4,828,648	\$ 4,968,679	\$ 5,112,771	\$ 5,261,041	\$ 5,413,612	\$ 5,570,606	\$ 5,732,154	\$ 5,898,386	\$ 6,069,440	\$ 6,245,453	\$ 6,426,571
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE
6	TIMP Cost	\$ 904,581	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
7	Cost of Importing Gas	\$ 100,754,039	\$ 132,184,263	\$ 136,017,596	\$ 139,862,106	\$ 144,021,007	\$ 148,197,616	\$ 152,496,347	\$ 156,917,712	\$ 161,468,326	\$ 166,150,908	\$ 170,969,284	\$ 175,927,393
8	Total O&M Costs	\$ 165,340,065	\$ 4,828,648	\$ 4,968,679	\$ 5,112,771	\$ 5,261,041	\$ 5,413,612	\$ 5,570,606	\$ 5,732,154	\$ 5,898,386	\$ 6,069,440	\$ 6,245,453	\$ 6,426,571
C2 Alternative Diameter Pipeline (12")	PV	2120	2121	2122	2123	2124	2125	2126	2127	2128	2129	2130	2131
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
3	Total Avoided Costs	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
4	Annual O&M Cost	\$ 3,680,546	\$ 4,828,648	\$ 4,968,679	\$ 5,112,771	\$ 5,261,041	\$ 5,413,612	\$ 5,570,606	\$ 5,732,154	\$ 5,898,386	\$ 6,069,440	\$ 6,245,453	\$ 6,426,571
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE
6	TIMP Cost	\$ 904,581	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
7	Cost of Importing Gas	\$ 87,169,669	\$ 88,122,836	\$ 90,678,307	\$ 93,308,071	\$ 96,014,005	\$ 98,798,411	\$ 101,663,565	\$ 104,611,809	\$ 107,645,551	\$ 110,767,272	\$ 113,979,523	\$ 117,284,929
8	Total O&M Costs	\$ 71,755,086	\$ 4,828,648	\$ 4,968,679	\$ 5,112,771	\$ 5,261,041	\$ 5,413,612	\$ 5,570,606	\$ 5,732,154	\$ 5,898,386	\$ 6,069,440	\$ 6,245,453	\$ 6,426,571
C3 Alternative Diameter Pipeline (16")	PV	2120	2121	2122	2123	2124	2125	2126	2127	2128	2129	2130	2131
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
3	Total Avoided Costs	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
4	Annual O&M Cost	\$ 3,680,546	\$ 4,828,648	\$ 4,968,679	\$ 5,112,771	\$ 5,261,041	\$ 5,413,612	\$ 5,570,606	\$ 5,732,154	\$ 5,898,386	\$ 6,069,440	\$ 6,245,453	\$ 6,426,571
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE
6	TIMP Cost	\$ 904,581	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
7	Cost of Importing Gas	\$ 67,169,669	\$ 88,122,836	\$ 90,678,307	\$ 93,308,071	\$ 96,014,005	\$ 98,798,411	\$ 101,663,565	\$ 104,611,809	\$ 107,645,551	\$ 110,767,272	\$ 113,979,523	\$ 117,284,929
8	Total O&M Costs	\$ 71,755,086	\$ 4,828,648	\$ 4,968,679	\$ 5,112,771	\$ 5,261,041	\$ 5,413,612	\$ 5,570,606	\$ 5,732,154	\$ 5,898,386	\$ 6,069,440	\$ 6,245,453	\$ 6,426,571
C4 Alternative Diameter Pipeline (20")	PV	2120	2121	2122	2123	2124	2125	2126	2127	2128	2129	2130	2131
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ (17,993,677)	\$ (23,606,526)	\$ (24,291,115)	\$ (24,995,558)	\$ (25,720,429)	\$ (26,466,321)	\$ (27,233,845)	\$ (28,023,626)	\$ (28,836,311)	\$ (29,672,564)	\$ (30,533,069)	\$ (31,418,528)
3	Total Avoided Costs	\$ (118,279,110)	\$ (23,606,526)	\$ (24,291,115)	\$ (24,995,558)	\$ (25,720,429)	\$ (26,466,321)	\$ (27,233,845)	\$ (28,023,626)	\$ (28,836,311)	\$ (29,672,564)	\$ (30,533,069)	\$ (31,418,528)
4	Annual O&M Cost	\$ 3,680,546	\$ 4,828,648	\$ 4,968,679	\$ 5,112,771	\$ 5,261,041	\$ 5,413,612	\$ 5,570,606	\$ 5,732,154	\$ 5,898,386	\$ 6,069,440	\$ 6,245,453	\$ 6,426,571
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE
6	TIMP Cost	\$ 904,581	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
7	Total O&M Costs	\$ 4,585,126	\$ 4,828,648	\$ 4,968,679	\$ 5,112,771	\$ 5,261,041	\$ 5,413,612	\$ 5,570,606	\$ 5,732,154	\$ 5,898,386	\$ 6,069,440	\$ 6,245,453	\$ 6,426,571
C5 Alternative Diameter Pipeline (24")	PV	2120	2121	2122	2123	2124	2125	2126	2127	2128	2129	2130	2131
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ (35,987,253)	\$ (47,213,052)	\$ (48,582,231)	\$ (49,991,115)	\$ (51,440,858)	\$ (52,932,643)	\$ (54,467,689)	\$ (56,047,252)	\$ (57,672,623)	\$ (59,345,129)	\$ (61,066,137)	\$ (62,837,055)
3	Total Avoided Costs	\$ (136,272,737)	\$ (47,213,052)	\$ (48,582,231)	\$ (49,991,115)	\$ (51,440,858)	\$ (52,932,643)	\$ (54,467,689)	\$ (56,047,252)	\$ (57,672,623)	\$ (59,345,129)	\$ (61,066,137)	\$ (62,837,055)
4	Annual O&M Cost	\$ 3,680,546	\$ 4,828,648	\$ 4,968,679	\$ 5,112,771	\$ 5,261,041	\$ 5,413,612	\$ 5,570,606	\$ 5,732,154	\$ 5,898,386	\$ 6,069,440	\$ 6,245,453	\$ 6,426,571
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE
6	TIMP Cost	\$ 904,581	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
7	Total O&M Costs	\$ 4,585,126	\$ 4,828,648	\$ 4,968,679	\$ 5,112,771	\$ 5,261,041	\$ 5,413,612	\$ 5,570,606	\$ 5,732,154	\$ 5,898,386	\$ 6,069,440	\$ 6,245,453	\$ 6,426,571

WORK PAPER TABLE - AVOIDED COST MODEL - COSTS OVER 00 YEARS (AC 1.2)
ANNUAL COSTS BY PROJECT ALTERNATE, FOR AVOIDED COSTS AND O&M COSTS
A.15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.	PV (X years after operational)	0	1	2	3	4	5	6	7	8	9	10	11	12	13	
100																
		2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	
1	Future L1600 Replacement Cost	100,285,483														
2	MCS O&M and Emissions Cost	62,977,694														
3	Total Avoided Costs	163,263,177														
4	Annual O&M Cost	3,680,546						284,907	293,170	301,671	310,420	319,422	328,686	338,217	348,026	
5	Pegging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	
6	TIWP Cost	904,581													725,053	
7	Total O&M Costs	4,585,126						284,907	293,170	301,671	310,420	319,422	328,686	338,217	1,073,079	
110																
111		2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	
112																
113	1	Future L1600 Replacement Cost	100,285,483													
114	2	MCS O&M and Emissions Cost	89,988,134													
115	3	Total Avoided Costs	190,273,617													
116																
117	4	Annual O&M Cost	3,680,546						284,907	293,170	301,671	310,420	319,422	328,686	338,217	348,026
118	5	Pegging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	
119	6	TIWP Cost	904,581												725,053	
120	7	Total O&M Costs	4,585,126						284,907	293,170	301,671	310,420	319,422	328,686	338,217	1,073,079
125																
126		2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	
127																
128	1	Future L1600 Replacement Cost	100,285,483													
129	2	MCS O&M and Emissions Cost	89,988,134													
130	3	Total Avoided Costs	190,273,617													
131																
132	4	Annual O&M Cost	3,647,596										410,857	422,772	435,032	
133	5	Pegging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	
134	6	TIWP Cost	717,196												725,053	
135	7	Total O&M Costs	4,364,792										410,857	422,772	435,032	
137																
138		2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	
139																
140	1	Future L1600 Replacement Cost	100,285,483													
141	2	MCS O&M and Emissions Cost	89,988,134													
142	3	Total Avoided Costs	190,273,617													
143																
144	4	Annual O&M Cost														
145	5	Pegging to Occur														
146	6	TIWP Cost														
147	7	Total O&M Costs														
148																
149		2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	
150																
151	1	Future L1600 Replacement Cost	100,285,483													
152	2	MCS O&M and Emissions Cost	89,988,134													
153	3	Total Avoided Costs	190,273,617													
154																
155	4	Annual O&M Cost	15,283,747									1,597,111	1,643,427	1,691,086	1,740,128	
156	5	Total O&M Costs	15,283,747									1,597,111	1,643,427	1,691,086	1,740,128	
159																
160		2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	
161																
162	1	Future L1600 Replacement Cost	100,285,483													
163	2	MCS O&M and Emissions Cost	89,988,134													
164	3	Total Avoided Costs	190,273,617													
165																
166	4	Annual O&M Cost	15,283,747									1,597,111	1,643,427	1,691,086	1,740,128	
167	5	Total O&M Costs	15,283,747									1,597,111	1,643,427	1,691,086	1,740,128	
170																
171		2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	
172																
173	1	Future L1600 Replacement Cost	100,285,483													
174	2	MCS O&M and Emissions Cost	89,988,134													
175	3	Total Avoided Costs	190,273,617													
176																
177	4	Annual O&M Cost	15,283,747									1,597,111	1,643,427	1,691,086	1,740,128	
178	5	Total O&M Costs	15,283,747									1,597,111	1,643,427	1,691,086	1,740,128	
181																
182		2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	
183																
184	1	Future L1600 Replacement Cost	100,285,483													
185	2	MCS O&M and Emissions Cost	89,988,134													
186	3	Total Avoided Costs	190,273,617													
187																
188	4	Annual O&M Cost	4,544,076													
189	5	Pegging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	
190	6	TIWP Cost	595,634													
191	7	Total O&M Costs	5,139,710													
193																
194		2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	
195																
196	1	Future L1600 Replacement Cost	100,285,483													
197	2	MCS O&M and Emissions Cost	74,719,007													
198	3	Total Avoided Costs	175,004,490													
199																
200	4	Annual O&M Cost	14,495,118									1,514,701	1,558,627	1,603,828	1,650,339	
201	5	Pegging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	
202	6	TIWP Cost	2,453,804													
203	7	Total O&M Costs	16,948,922									1,514,701	1,558,627	1,603,828	1,650,339	
206																
207		2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	

WORK PAPER TABLE - AVOIDED COST MODEL - COSTS OVER 00 YEARS (AC 1.2)
 ANNUAL COSTS BY PROJECT ALTERNATE, FOR AVOIDED COSTS AND O&M COSTS
 A.15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2)

Line No.	PV (X years after operational)	14	15	16	17	18	19	20	21	22	23	24	25	26
1	PV	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041
2		100												
3														
4	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ (34,683,589)	\$ (34,389,413)
5	MCS O&M and Emissions Cost	\$ (62,977,694)	\$ (6,127,750)	\$ (6,305,455)	\$ (6,488,313)	\$ (6,676,474)	\$ (6,870,092)	\$ (7,069,324)	\$ (7,274,336)	\$ (7,485,290)	\$ (7,702,364)	\$ (7,925,732)	\$ (8,155,578)	\$ (8,392,090)
6	Total Avoided Costs	\$ (163,263,177)	\$ (6,127,750)	\$ (6,305,455)	\$ (6,488,313)	\$ (6,676,474)	\$ (6,870,092)	\$ (7,069,324)	\$ (7,274,336)	\$ (7,485,290)	\$ (7,702,364)	\$ (7,925,732)	\$ (8,155,578)	\$ (8,392,090)
7	Annual O&M Cost	\$ 3,680,546	\$ 358,118	\$ 368,504	\$ 379,190	\$ 390,187	\$ 401,502	\$ 413,146	\$ 425,127	\$ 437,456	\$ 450,142	\$ 463,196	\$ 476,629	\$ 490,451
8	Paging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE
9	TIMP Cost	\$ 904,581	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 885,681	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
10	Total O&M Costs	\$ 4,585,126	\$ 358,118	\$ 368,504	\$ 379,190	\$ 390,187	\$ 401,502	\$ 413,146	\$ 437,456	\$ 450,142	\$ 463,196	\$ 476,629	\$ 490,451	\$ 504,674
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ (34,683,589)	\$ (34,389,413)
2	MCS O&M and Emissions Cost	\$ (62,977,694)	\$ (6,127,750)	\$ (6,305,455)	\$ (6,488,313)	\$ (6,676,474)	\$ (6,870,092)	\$ (7,069,324)	\$ (7,274,336)	\$ (7,485,290)	\$ (7,702,364)	\$ (7,925,732)	\$ (8,155,578)	\$ (8,392,090)
3	Total Avoided Costs	\$ (163,263,177)	\$ (6,127,750)	\$ (6,305,455)	\$ (6,488,313)	\$ (6,676,474)	\$ (6,870,092)	\$ (7,069,324)	\$ (7,274,336)	\$ (7,485,290)	\$ (7,702,364)	\$ (7,925,732)	\$ (8,155,578)	\$ (8,392,090)
4	Annual O&M Cost	\$ 3,680,546	\$ 358,118	\$ 368,504	\$ 379,190	\$ 390,187	\$ 401,502	\$ 413,146	\$ 425,127	\$ 437,456	\$ 450,142	\$ 463,196	\$ 476,629	\$ 490,451
5	Paging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE
6	TIMP Cost	\$ 904,581	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 885,681	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
7	Total O&M Costs	\$ 4,585,126	\$ 358,118	\$ 368,504	\$ 379,190	\$ 390,187	\$ 401,502	\$ 413,146	\$ 437,456	\$ 450,142	\$ 463,196	\$ 476,629	\$ 490,451	\$ 504,674
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ (34,683,589)	\$ (34,389,413)
2	MCS O&M and Emissions Cost	\$ (62,977,694)	\$ (6,127,750)	\$ (6,305,455)	\$ (6,488,313)	\$ (6,676,474)	\$ (6,870,092)	\$ (7,069,324)	\$ (7,274,336)	\$ (7,485,290)	\$ (7,702,364)	\$ (7,925,732)	\$ (8,155,578)	\$ (8,392,090)
3	Total Avoided Costs	\$ (163,263,177)	\$ (6,127,750)	\$ (6,305,455)	\$ (6,488,313)	\$ (6,676,474)	\$ (6,870,092)	\$ (7,069,324)	\$ (7,274,336)	\$ (7,485,290)	\$ (7,702,364)	\$ (7,925,732)	\$ (8,155,578)	\$ (8,392,090)
4	Annual O&M Cost	\$ 3,680,546	\$ 358,118	\$ 368,504	\$ 379,190	\$ 390,187	\$ 401,502	\$ 413,146	\$ 425,127	\$ 437,456	\$ 450,142	\$ 463,196	\$ 476,629	\$ 490,451
5	Paging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE
6	TIMP Cost	\$ 904,581	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 885,681	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
7	Total O&M Costs	\$ 4,585,126	\$ 358,118	\$ 368,504	\$ 379,190	\$ 390,187	\$ 401,502	\$ 413,146	\$ 437,456	\$ 450,142	\$ 463,196	\$ 476,629	\$ 490,451	\$ 504,674
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ (34,683,589)	\$ (34,389,413)
2	MCS O&M and Emissions Cost	\$ (62,977,694)	\$ (6,127,750)	\$ (6,305,455)	\$ (6,488,313)	\$ (6,676,474)	\$ (6,870,092)	\$ (7,069,324)	\$ (7,274,336)	\$ (7,485,290)	\$ (7,702,364)	\$ (7,925,732)	\$ (8,155,578)	\$ (8,392,090)
3	Total Avoided Costs	\$ (163,263,177)	\$ (6,127,750)	\$ (6,305,455)	\$ (6,488,313)	\$ (6,676,474)	\$ (6,870,092)	\$ (7,069,324)	\$ (7,274,336)	\$ (7,485,290)	\$ (7,702,364)	\$ (7,925,732)	\$ (8,155,578)	\$ (8,392,090)
4	Annual O&M Cost	\$ 3,647,596	\$ 447,648	\$ 460,630	\$ 473,988	\$ 487,734	\$ 501,878	\$ 516,432	\$ 531,409	\$ 546,820	\$ 562,677	\$ 578,995	\$ 595,796	\$ 613,064
5	Paging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE
6	TIMP Cost	\$ 717,196	\$ -	\$ -	\$ -	\$ -	\$ 836,463	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 1,021,773	\$ -
7	Total O&M Costs	\$ 4,364,792	\$ 447,648	\$ 460,630	\$ 473,988	\$ 487,734	\$ 1,338,341	\$ 516,432	\$ 531,409	\$ 546,820	\$ 562,677	\$ 578,995	\$ 595,796	\$ 1,634,837
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ (34,683,589)	\$ (34,389,413)
2	MCS O&M and Emissions Cost	\$ (62,977,694)	\$ (6,127,750)	\$ (6,305,455)	\$ (6,488,313)	\$ (6,676,474)	\$ (6,870,092)	\$ (7,069,324)	\$ (7,274,336)	\$ (7,485,290)	\$ (7,702,364)	\$ (7,925,732)	\$ (8,155,578)	\$ (8,392,090)
3	Total Avoided Costs	\$ (163,263,177)	\$ (6,127,750)	\$ (6,305,455)	\$ (6,488,313)	\$ (6,676,474)	\$ (6,870,092)	\$ (7,069,324)	\$ (7,274,336)	\$ (7,485,290)	\$ (7,702,364)	\$ (7,925,732)	\$ (8,155,578)	\$ (8,392,090)
4	Annual O&M Cost	\$ 15,283,747	\$ 1,790,591	\$ 1,842,519	\$ 1,895,952	\$ 1,950,934	\$ 2,007,511	\$ 2,065,729	\$ 2,125,635	\$ 2,187,279	\$ 2,250,710	\$ 2,315,980	\$ 2,383,144	\$ 2,452,255
5	Total O&M Costs	\$ 15,283,747	\$ 1,790,591	\$ 1,842,519	\$ 1,895,952	\$ 1,950,934	\$ 2,007,511	\$ 2,065,729	\$ 2,125,635	\$ 2,187,279	\$ 2,250,710	\$ 2,315,980	\$ 2,383,144	\$ 2,452,255
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ (34,683,589)	\$ (34,389,413)
2	MCS O&M and Emissions Cost	\$ (62,977,694)	\$ (6,127,750)	\$ (6,305,455)	\$ (6,488,313)	\$ (6,676,474)	\$ (6,870,092)	\$ (7,069,324)	\$ (7,274,336)	\$ (7,485,290)	\$ (7,702,364)	\$ (7,925,732)	\$ (8,155,578)	\$ (8,392,090)
3	Total Avoided Costs	\$ (163,263,177)	\$ (6,127,750)	\$ (6,305,455)	\$ (6,488,313)	\$ (6,676,474)	\$ (6,870,092)	\$ (7,069,324)	\$ (7,274,336)	\$ (7,485,290)	\$ (7,702,364)	\$ (7,925,732)	\$ (8,155,578)	\$ (8,392,090)
4	Annual O&M Cost	\$ 15,283,747	\$ 1,790,591	\$ 1,842,519	\$ 1,895,952	\$ 1,950,934	\$ 2,007,511	\$ 2,065,729	\$ 2,125,635	\$ 2,187,279	\$ 2,250,710	\$ 2,315,980	\$ 2,383,144	\$ 2,452,255
5	Total O&M Costs	\$ 15,283,747	\$ 1,790,591	\$ 1,842,519	\$ 1,895,952	\$ 1,950,934	\$ 2,007,511	\$ 2,065,729	\$ 2,125,635	\$ 2,187,279	\$ 2,250,710	\$ 2,315,980	\$ 2,383,144	\$ 2,452,255
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ (34,683,589)	\$ (34,389,413)
2	MCS O&M and Emissions Cost	\$ (62,977,694)	\$ (6,127,750)	\$ (6,305,455)	\$ (6,488,313)	\$ (6,676,474)	\$ (6,870,092)	\$ (7,069,324)	\$ (7,274,336)	\$ (7,485,290)	\$ (7,702,364)	\$ (7,925,732)	\$ (8,155,578)	\$ (8,392,090)
3	Total Avoided Costs	\$ (163,263,177)	\$ (6,127,750)	\$ (6,305,455)	\$ (6,488,313)	\$ (6,676,474)	\$ (6,870,092)	\$ (7,069,324)	\$ (7,274,336)	\$ (7,485,290)	\$ (7,702,364)	\$ (7,925,732)	\$ (8,155,578)	\$ (8,392,090)
4	Annual O&M Cost	\$ 4,544,076	\$ (600,944)	\$ 710,982	\$ 731,600	\$ 752,817	\$ 774,648	\$ 797,113	\$ 820,229	\$ 844,016	\$ 868,493	\$ 893,679	\$ 919,596	\$ 946,264
5	Paging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE
6	TIMP Cost	\$ 595,634	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 937,796	\$ -	\$ -	\$ -	\$ -	\$ -
7	Total O&M Costs	\$ 5,139,710	\$ (600,944)	\$ 710,982	\$ 731,600	\$ 752,817	\$ 774,648	\$ 797,113	\$ 820,229	\$ 1,781,812	\$ 868,493	\$ 893,679	\$ 919,596	\$ 946,264
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ (34,683,589)	\$ (34,389,413)
2	MCS O&M and Emissions Cost	\$ (62,977,694)	\$ (6,127,750)	\$ (6,305,455)	\$ (6,488,313)	\$ (6,676,474)	\$ (6,870,092)	\$ (7,069,324)	\$ (7,274,336)	\$ (7,485,290)	\$ (7,702,364)	\$ (7,925,732)	\$ (8,155,578)	\$ (8,392,090)
3	Total Avoided Costs	\$ (163,263,177)	\$ (6,127,750)	\$ (6,305,455)	\$ (6,488,313)	\$ (6,676,474)	\$ (6,870,092)	\$ (7,069,324)	\$ (7,274,336)	\$ (7,485,290)	\$ (7,702,364)	\$ (7,925,732)	\$ (8,155,578)	\$ (8,392,090)
4	Annual O&M Cost	\$ 14,495,118	\$ 1,698,198	\$ 1,747,446	\$ 1,798,122	\$ 1,850,268	\$ 1,903,925	\$ 1,959,139	\$ 2,015,954	\$ 2,074,417	\$ 2,134,575	\$ 2,196,478	\$ 2,260,176	\$ 2,325,721
5	Paging to Occur	N/A	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE
6	TIMP Cost	\$ 2,458,604	\$ -	\$ -	\$ -	\$ 2,438,688	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 2,978,930	\$ -
7	Total O&M Costs	\$ 16,953,722	\$ 1,698,198	\$ 1,747,446	\$ 1,798,122	\$ 4,298,956	\$ 1,903,925	\$ 1,959,139	\$ 2,015,954	\$ 2,074,417	\$ 2,134,575	\$ 2,196,478	\$ 5,239,105	\$ 2,325,721

WORK PAPER TABLE - AVOIDED COST MODEL - COSTS OVER 00 YEARS (AC 1.2)
ANNUAL COSTS BY PROJECT ALTERNATE, FOR AVOIDED COSTS AND O&M COSTS
A.15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 21)

Line No.	PV (X years after operation)	27	28	29	30	31	32	33	34	35	36	37	38	39
1	100													
C6 Alternative Diameter Pipeline (30')														
	PV	2042	2043	2044	2045	2046	2047	2048	2049	2050	2051	2052	2053	2054
100	\$	(100,285,483)	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-
101	\$	(62,977,694)	\$	(8,885,889)	\$	(9,143,580)	\$	(9,408,744)	\$	(9,681,597)	\$	(9,962,364)	\$	(10,251,272)
102	\$	(100,285,483)	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-
103	\$	(163,263,177)	\$	(8,885,889)	\$	(9,143,580)	\$	(9,408,744)	\$	(9,681,597)	\$	(9,962,364)	\$	(10,251,272)
104	\$													
105	\$	3,680,546	\$	519,310	\$	534,370	\$	549,866	\$	565,812	\$	582,221	\$	599,105
106	N/A		TRUE		FALSE		FALSE		FALSE		FALSE		TRUE	
107	\$	904,581	\$	1,081,895	\$	1,312,578	\$	1,600,274	\$	1,959,935	\$	2,403,468	\$	2,959,718
108	\$	4,585,126	\$	1,601,205	\$	534,370	\$	549,866	\$	565,812	\$	582,221	\$	599,105
109	\$													
110														
111														
112														
113														
114	1	Future L1600 Replacement Cost	\$	(100,285,483)	\$	-	\$	-	\$	-	\$	-	\$	-
115	2	MCS O&M and Emissions Cost	\$	(62,977,694)	\$	(8,885,889)	\$	(9,143,580)	\$	(9,408,744)	\$	(9,681,597)	\$	(9,962,364)
116	3	Total Avoided Costs	\$	(163,263,177)	\$	(8,885,889)	\$	(9,143,580)	\$	(9,408,744)	\$	(9,681,597)	\$	(9,962,364)
117														
118	4	Annual O&M Cost	\$	3,680,546	\$	519,310	\$	534,370	\$	549,866	\$	565,812	\$	582,221
119	5	Pigging to Occur	N/A		TRUE		FALSE		FALSE		FALSE		TRUE	
120	6	TIWP Cost	\$	904,581	\$	1,081,895	\$	1,312,578	\$	1,600,274	\$	1,959,935	\$	2,403,468
121	7	Total O&M Costs	\$	4,585,126	\$	1,601,205	\$	534,370	\$	549,866	\$	565,812	\$	582,221
122														
123														
124														
125														
126														
127	1	Future L1600 Replacement Cost	\$	(100,285,483)	\$	-	\$	-	\$	-	\$	-	\$	-
128	2	MCS O&M and Emissions Cost	\$	(62,977,694)	\$	(8,885,889)	\$	(9,143,580)	\$	(9,408,744)	\$	(9,681,597)	\$	(9,962,364)
129	3	Total Avoided Costs	\$	(163,263,177)	\$	(8,885,889)	\$	(9,143,580)	\$	(9,408,744)	\$	(9,681,597)	\$	(9,962,364)
130														
131														
132	4	Annual O&M Cost	\$	3,680,546	\$	519,310	\$	534,370	\$	549,866	\$	565,812	\$	582,221
133	5	Pigging to Occur	N/A		TRUE		FALSE		FALSE		FALSE		TRUE	
134	6	TIWP Cost	\$	904,581	\$	1,081,895	\$	1,312,578	\$	1,600,274	\$	1,959,935	\$	2,403,468
135	7	Total O&M Costs	\$	4,585,126	\$	1,601,205	\$	534,370	\$	549,866	\$	565,812	\$	582,221
136														
137														
138														
139														
140														
141														
142														
143														
144														
145														
146														
147														
148														
149														
150														
151														
152														
153														
154														
155														
156														
157														
158														
159														
160														
161														
162														
163														
164														
165														
166														
167														
168														
169														
170														
171														
172														
173														
174														
175														
176														
177														
178														
179														
180														
181														
182														
183														
184														
185														
186														
187														
188														
189														
190														
191														
192														
193														
194														
195														
196														
197														
198														
199														
200														
201														
202														
203														
204														
205														
206														
207														

WORK PAPER TABLE - AVOIDED COST MODEL - COSTS OVER 00 YEARS (AC 1.2)
ANNUAL COSTS BY PROJECT ALTERNATE, FOR AVOIDED COSTS AND O&M COSTS
 A.15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2)

Line No.	PV (X years after operation)	40	41	42	43	44	45	46	47	48	49	50	51	52
100	100													
	PV	2055	2056	2057	2058	2059	2060	2061	2062	2063	2064	2065	2066	2067
101	100,285,483	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
102	12,885,485	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE
103	183,263,177	\$ (12,885,485)	\$ (13,259,164)	\$ (13,643,680)	\$ (14,039,346)	\$ (14,446,487)	\$ (14,865,436)	\$ (15,296,533)	\$ (15,740,133)	\$ (16,196,597)	\$ (16,666,298)	\$ (17,149,621)	\$ (17,646,960)	\$ (18,158,721)
104	Total Avoided Costs	\$ (183,263,177)	\$ (18,407,836)	\$ (18,941,663)	\$ (19,490,971)	\$ (20,056,209)	\$ (20,637,839)	\$ (21,236,337)	\$ (21,852,190)	\$ (22,485,904)	\$ (23,137,995)	\$ (23,808,997)	\$ (24,499,458)	\$ (25,209,942)
105	Annual O&M Cost	3,680,546	753,054	774,893	797,365	820,488	844,282	868,767	893,961	919,886	946,562	974,013	1,002,259	1,031,325
106	Pigging to Occur	N/A	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE
107	TI MP Cost	904,581	1,614,360	-	-	-	-	-	-	1,972,005	-	-	-	-
108	Total O&M Costs	4,585,126	753,054	2,389,253	797,365	820,488	844,282	868,767	893,961	919,886	2,918,567	974,013	1,002,259	1,031,325
109	Total O&M Costs	\$ 4,585,126	\$ 753,054	\$ 2,389,253	\$ 797,365	\$ 820,488	\$ 844,282	\$ 868,767	\$ 893,961	\$ 919,886	\$ 2,918,567	\$ 974,013	\$ 1,002,259	\$ 1,031,325
110	110													
111	110													
112	110													
113	110													
114	110													
115	110													
116	110													
117	110													
118	110													
119	110													
120	110													
121	110													
122	110													
123	110													
124	110													
125	110													
126	110													
127	110													
128	110													
129	110													
130	110													
131	110													
132	110													
133	110													
134	110													
135	110													
136	110													
137	110													
138	110													
139	110													
140	110													
141	110													
142	110													
143	110													
144	110													
145	110													
146	110													
147	110													
148	110													
149	110													
150	110													
151	110													
152	110													
153	110													
154	110													
155	110													
156	110													
157	110													
158	110													
159	110													
160	110													
161	110													
162	110													
163	110													
164	110													
165	110													
166	110													
167	110													
168	110													
169	110													
170	110													
171	110													
172	110													
173	110													
174	110													
175	110													
176	110													
177	110													
178	110													
179	110													
180	110													
181	110													
182	110													
183	110													
184	110													
185	110													
186	110													
187	110													
188	110													
189	110													
190	110													
191	110													
192	110													
193	110													
194	110													
195	110													
196	110													
197	110													
198	110													
199	110													
200	110													
201	110													
202	110													
203	110													
204	110													
205	110													
206	110													
207	110													

WORK PAPER TABLE - AVOIDED COST MODEL - COSTS OVER 00 YEARS (AC 1.2)
ANNUAL COSTS BY PROJECT ALTERNATE, FOR AVOIDED COSTS AND O&M COSTS
A.15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2)

Line No.	PV (X years after operation)	53	54	55	56	57	58	59	60	61	62	63	64	65
C6 Alternative Diameter Pipeline (30")														
PV														
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ (62,977,694)	\$ (18,685,324)	\$ (19,227,199)	\$ (19,784,787)	\$ (20,358,546)	\$ (20,948,944)	\$ (21,556,463)	\$ (22,181,601)	\$ (22,824,867)	\$ (23,486,788)	\$ (24,167,905)	\$ (24,868,775)	\$ (25,589,969)
3	Total Avoided Costs	\$ (163,263,177)	\$ (18,685,324)	\$ (19,227,199)	\$ (19,784,787)	\$ (20,358,546)	\$ (20,948,944)	\$ (21,556,463)	\$ (22,181,601)	\$ (22,824,867)	\$ (23,486,788)	\$ (24,167,905)	\$ (24,868,775)	\$ (25,589,969)
PV														
4	Annual O&M Cost	\$ 3,680,546	\$ 1,092,009	\$ 1,123,677	\$ 1,156,264	\$ 1,189,795	\$ 1,224,299	\$ 1,259,804	\$ 1,296,338	\$ 1,333,932	\$ 1,372,616	\$ 1,412,422	\$ 1,453,382	\$ 1,495,530
5	Pigging to Occur	N/A	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE
6	TIHP Cost	\$ 904,581	\$ -	\$ -	\$ 2,408,882	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 2,942,546	\$ -	\$ -
7	Total O&M Costs	\$ 4,585,126	\$ 1,092,009	\$ 1,123,677	\$ 3,565,146	\$ 1,189,795	\$ 1,224,299	\$ 1,259,804	\$ 1,296,338	\$ 1,333,932	\$ 1,372,616	\$ 4,354,968	\$ 1,453,382	\$ 1,495,530
C7 Alternative Diameter Pipeline (42")														
PV														
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ (69,588,134)	\$ (26,693,320)	\$ (27,467,427)	\$ (28,263,982)	\$ (29,083,638)	\$ (29,927,063)	\$ (30,794,948)	\$ (31,688,001)	\$ (32,606,953)	\$ (33,552,555)	\$ (34,525,579)	\$ (35,526,821)	\$ (36,557,099)
3	Total Avoided Costs	\$ (169,873,617)	\$ (26,693,320)	\$ (27,467,427)	\$ (28,263,982)	\$ (29,083,638)	\$ (29,927,063)	\$ (30,794,948)	\$ (31,688,001)	\$ (32,606,953)	\$ (33,552,555)	\$ (34,525,579)	\$ (35,526,821)	\$ (36,557,099)
PV														
4	Annual O&M Cost	\$ 3,680,546	\$ 1,092,009	\$ 1,123,677	\$ 1,156,264	\$ 1,189,795	\$ 1,224,299	\$ 1,259,804	\$ 1,296,338	\$ 1,333,932	\$ 1,372,616	\$ 1,412,422	\$ 1,453,382	\$ 1,495,530
5	Pigging to Occur	N/A	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE
6	TIHP Cost	\$ 904,581	\$ -	\$ -	\$ 2,408,882	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 2,942,546	\$ -	\$ -
7	Total O&M Costs	\$ 4,585,126	\$ 1,092,009	\$ 1,123,677	\$ 3,565,146	\$ 1,189,795	\$ 1,224,299	\$ 1,259,804	\$ 1,296,338	\$ 1,333,932	\$ 1,372,616	\$ 4,354,968	\$ 1,453,382	\$ 1,495,530
D Replace Line 1600 In-Place														
PV														
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
3	Total Avoided Costs	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
PV														
4	Annual O&M Cost	\$ 3,647,596	\$ 1,365,011	\$ 1,404,596	\$ 1,445,329	\$ 1,487,244	\$ 1,530,374	\$ 1,574,755	\$ 1,620,423	\$ 1,667,415	\$ 1,715,770	\$ 1,765,528	\$ 1,816,728	\$ 1,869,413
5	Pigging to Occur	N/A	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE
6	TIHP Cost	\$ 717,186	\$ 2,275,018	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 2,779,025	\$ -	\$ -	\$ -	\$ -
7	Total O&M Costs	\$ 4,364,782	\$ 3,640,029	\$ 1,404,596	\$ 1,445,329	\$ 1,487,244	\$ 1,530,374	\$ 1,574,755	\$ 1,620,423	\$ 4,446,440	\$ 1,715,770	\$ 1,765,528	\$ 1,816,728	\$ 1,869,413
EF Olay Mesa Alternative														
PV														
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
3	Total Avoided Costs	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
PV														
4	Annual O&M Cost	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
5	Total O&M Costs	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
G LNG Storage (Peak-Shaver)														
PV														
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
3	Total Avoided Costs	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
PV														
4	Annual O&M Cost	\$ 15,283,747	\$ 5,460,044	\$ 5,618,385	\$ 5,781,318	\$ 5,948,976	\$ 6,121,497	\$ 6,299,020	\$ 6,481,692	\$ 6,669,661	\$ 6,863,081	\$ 7,062,110	\$ 7,266,911	\$ 7,477,652
5	Total O&M Costs	\$ 15,283,747	\$ 5,460,044	\$ 5,618,385	\$ 5,781,318	\$ 5,948,976	\$ 6,121,497	\$ 6,299,020	\$ 6,481,692	\$ 6,669,661	\$ 6,863,081	\$ 7,062,110	\$ 7,266,911	\$ 7,477,652
H1 Alternative Energy (Grid-Scale Battery)														
PV														
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
3	Total Avoided Costs	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
PV														
4	Annual O&M Cost	\$ 15,283,747	\$ 5,460,044	\$ 5,618,385	\$ 5,781,318	\$ 5,948,976	\$ 6,121,497	\$ 6,299,020	\$ 6,481,692	\$ 6,669,661	\$ 6,863,081	\$ 7,062,110	\$ 7,266,911	\$ 7,477,652
5	Total O&M Costs	\$ 15,283,747	\$ 5,460,044	\$ 5,618,385	\$ 5,781,318	\$ 5,948,976	\$ 6,121,497	\$ 6,299,020	\$ 6,481,692	\$ 6,669,661	\$ 6,863,081	\$ 7,062,110	\$ 7,266,911	\$ 7,477,652
H2 Alternative Energy (Smaller-Scale Battery)														
PV														
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
3	Total Avoided Costs	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
PV														
4	Annual O&M Cost	\$ 15,283,747	\$ 5,460,044	\$ 5,618,385	\$ 5,781,318	\$ 5,948,976	\$ 6,121,497	\$ 6,299,020	\$ 6,481,692	\$ 6,669,661	\$ 6,863,081	\$ 7,062,110	\$ 7,266,911	\$ 7,477,652
5	Total O&M Costs	\$ 15,283,747	\$ 5,460,044	\$ 5,618,385	\$ 5,781,318	\$ 5,948,976	\$ 6,121,497	\$ 6,299,020	\$ 6,481,692	\$ 6,669,661	\$ 6,863,081	\$ 7,062,110	\$ 7,266,911	\$ 7,477,652
I Off-shore Route														
PV														
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ (69,588,134)	\$ (26,693,320)	\$ (27,467,427)	\$ (28,263,982)	\$ (29,083,638)	\$ (29,927,063)	\$ (30,794,948)	\$ (31,688,001)	\$ (32,606,953)	\$ (33,552,555)	\$ (34,525,579)	\$ (35,526,821)	\$ (36,557,099)
3	Total Avoided Costs	\$ (169,873,617)	\$ (26,693,320)	\$ (27,467,427)	\$ (28,263,982)	\$ (29,083,638)	\$ (29,927,063)	\$ (30,794,948)	\$ (31,688,001)	\$ (32,606,953)	\$ (33,552,555)	\$ (34,525,579)	\$ (35,526,821)	\$ (36,557,099)
PV														
4	Annual O&M Cost	\$ 4,544,076	\$ 2,047,516	\$ 2,106,894	\$ 2,167,994	\$ 2,230,866	\$ 2,295,561	\$ 2,362,132	\$ 2,430,634	\$ 2,501,123	\$ 2,573,655	\$ 2,648,291	\$ 2,725,092	\$ 2,804,119
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE
6	TIHP Cost	\$ 595,634	\$ -	\$ -	\$ 2,560,634	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 3,115,088
7	Total O&M Costs	\$ 5,139,710	\$ 2,047,516	\$ 2,106,894	\$ 2,167,994	\$ 2,230,866	\$ 4,846,165	\$ 2,362,132	\$ 2,430,634	\$ 2,501,123	\$ 2,573,655	\$ 2,648,291	\$ 2,725,092	\$ 5,919,008
J1 Blythe to Santee Alternative 1														
PV														
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ (74,719,007)	\$ (26,693,320)	\$ (27,467,427)	\$ (28,263,982)	\$ (29,083,638)	\$ (29,927,063)	\$ (30,794,948)	\$ (31,688,001)	\$ (32,606,953)	\$ (33,552,555)	\$ (34,525,579)	\$ (35,526,821)	\$ (36,557,099)
3	Total Avoided Costs	\$ (175,004,490)	\$ (26,693,320)	\$ (27,467,427)	\$ (28,263,982)	\$ (29,083,638)	\$ (29,927,063)	\$ (30,794,948)	\$ (31,688,001)	\$ (32,606,953)	\$ (33,552,555)	\$ (34,525,579)	\$ (35,526,821)	\$ (36,557,099)
PV														
4	Annual O&M Cost	\$ 14,495,118	\$ 5,178,310	\$ 5,328,481	\$ 5,483,007	\$ 5,642,014	\$ 5,805,632	\$ 5,973,996	\$ 6,147,242	\$ 6,325,512	\$ 6,508,951	\$ 6,697,711	\$ 6,891,945	\$ 7,091,811
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE
6	TIHP Cost	\$ 2,253,804	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 8,102,114	\$ -	\$ -	\$ -	\$ -	\$ -
7	Total O&M Costs	\$ 16,748,922	\$ 5,178,310	\$ 5,328,481	\$ 5,483,007	\$ 5,642,014	\$ 5,805,632	\$ 5,973,996	\$ 14,249,356	\$ 6,325,512	\$ 6,508,951	\$ 6,697,711	\$ 6,891,945	\$ 7,091,811
J2 Blythe to Santee Alternative 2														

WORK PAPER TABLE - AVOIDED COST MODEL - COSTS OVER 00 YEARS (AC 1.2)

ANNUAL COSTS BY PROJECT ALTERNATE, FOR AVOIDED COSTS AND O&M COSTS

A.15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2)

Line No.	PV (X years after operation)	66	67	68	69	70	71	72	73	74	75	76	77	78
	100													
	PV	2081	2082	2083	2084	2085	2086	2087	2088	2089	2090	2091	2092	2093
C6 Alternative Diameter Pipeline (30")														
1	Future L1600 Replacement Cost	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$
2	MCS O&M and Emissions Cost	\$	(62,977,694)	(27,095,708)	(27,881,484)	(28,690,047)	(29,522,058)	(30,378,198)	(31,259,166)	(32,165,882)	(33,098,486)	(34,058,343)	(35,046,034)	(36,062,369)
3	Total Avoided Costs	\$	(163,263,177)	(27,095,708)	(27,881,484)	(28,690,047)	(29,522,058)	(30,378,198)	(31,259,166)	(32,165,882)	(33,098,486)	(34,058,343)	(35,046,034)	(36,062,369)
4	Annual O&M Cost	\$	3,680,546	1,583,529	1,629,451	1,676,705	1,725,330	1,775,364	1,826,850	1,879,828	1,934,344	1,990,439	2,048,162	2,107,559
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE
6	TIMP Cost	\$	904,581	-	-	-	3,594,437	-	-	-	-	4,300,748	-	-
7	Total O&M Costs	\$	4,585,126	1,583,529	1,629,451	1,676,705	5,319,767	1,775,364	1,826,850	1,879,828	1,934,344	1,990,439	2,048,162	6,498,307
C7 Alternative Diameter Pipeline (42")														
1	Future L1600 Replacement Cost	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$
2	MCS O&M and Emissions Cost	\$	(89,988,134)	(38,708,155)	(39,830,691)	(40,985,781)	(42,174,369)	(43,397,426)	(44,655,951)	(45,950,974)	(47,283,552)	(48,654,775)	(50,065,764)	(51,517,671)
3	Total Avoided Costs	\$	(190,253,617)	(38,708,155)	(39,830,691)	(40,985,781)	(42,174,369)	(43,397,426)	(44,655,951)	(45,950,974)	(47,283,552)	(48,654,775)	(50,065,764)	(51,517,671)
4	Annual O&M Cost	\$	3,680,546	1,583,529	1,629,451	1,676,705	1,725,330	1,775,364	1,826,850	1,879,828	1,934,344	1,990,439	2,048,162	2,107,559
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE
6	TIMP Cost	\$	904,581	-	-	-	3,594,437	-	-	-	-	4,300,748	-	-
7	Total O&M Costs	\$	4,585,126	1,583,529	1,629,451	1,676,705	5,319,767	1,775,364	1,826,850	1,879,828	1,934,344	1,990,439	2,048,162	6,498,307
D Replace Line 1600 In-Place														
1	Future L1600 Replacement Cost	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$
2	MCS O&M and Emissions Cost	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-
3	Total Avoided Costs	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-
4	Annual O&M Cost	\$	3,647,596	1,879,411	2,036,814	2,095,882	2,156,662	2,219,205	2,283,562	2,349,786	2,417,929	2,488,049	2,560,203	2,634,449
5	Pigging to Occur	N/A	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE
6	TIMP Cost	\$	717,196	-	3,384,691	-	-	-	-	-	4,146,748	-	-	-
7	Total O&M Costs	\$	4,364,792	1,879,411	5,431,504	2,095,882	2,156,662	2,219,205	2,283,562	2,349,786	2,417,929	6,634,796	2,560,203	2,634,449
EF Olay Mesa Alternative														
1	Future L1600 Replacement Cost	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$
2	MCS O&M and Emissions Cost	\$	-	-	-	-	-	-	-	-	-	-	-	-
3	Total Avoided Costs	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-
4	Annual O&M Cost	\$	-	-	-	-	-	-	-	-	-	-	-	-
5	Total O&M Costs	\$	-	-	-	-	-	-	-	-	-	-	-	-
G LNG Storage (Peak-Shaver)														
1	Future L1600 Replacement Cost	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$
2	MCS O&M and Emissions Cost	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-
3	Total Avoided Costs	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-
4	Annual O&M Cost	\$	15,283,747	7,917,644	8,147,256	8,383,526	8,626,649	8,876,821	9,134,249	9,399,142	9,671,718	9,952,197	10,240,811	10,537,795
5	Total O&M Costs	\$	15,283,747	7,917,644	8,147,256	8,383,526	8,626,649	8,876,821	9,134,249	9,399,142	9,671,718	9,952,197	10,240,811	10,537,795
H1 Alternative Energy (Grid-Scale Battery)														
1	Future L1600 Replacement Cost	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$
2	MCS O&M and Emissions Cost	\$	-	-	-	-	-	-	-	-	-	-	-	-
3	Total Avoided Costs	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-
4	Annual O&M Cost	\$	15,283,747	7,917,644	8,147,256	8,383,526	8,626,649	8,876,821	9,134,249	9,399,142	9,671,718	9,952,197	10,240,811	10,537,795
5	Total O&M Costs	\$	15,283,747	7,917,644	8,147,256	8,383,526	8,626,649	8,876,821	9,134,249	9,399,142	9,671,718	9,952,197	10,240,811	10,537,795
H2 Alternative Energy (Smaller-Scale Battery)														
1	Future L1600 Replacement Cost	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$
2	MCS O&M and Emissions Cost	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-
3	Total Avoided Costs	\$	(100,285,483)	-	-	-	-	-	-	-	-	-	-	-
4	Annual O&M Cost	\$	15,283,747	7,917,644	8,147,256	8,383,526	8,626,649	8,876,821	9,134,249	9,399,142	9,671,718	9,952,197	10,240,811	10,537,795
5	Total O&M Costs	\$	15,283,747	7,917,644	8,147,256	8,383,526	8,626,649	8,876,821	9,134,249	9,399,142	9,671,718	9,952,197	10,240,811	10,537,795
J1 Blythe to Santee Alternative 1														
1	Future L1600 Replacement Cost	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$
2	MCS O&M and Emissions Cost	\$	(174,719,007)	(38,708,155)	(39,830,691)	(40,985,781)	(42,174,369)	(43,397,426)	(44,655,951)	(45,950,974)	(47,283,552)	(48,654,775)	(50,065,764)	(51,517,671)
3	Total Avoided Costs	\$	(175,005,390)	(38,708,155)	(39,830,691)	(40,985,781)	(42,174,369)	(43,397,426)	(44,655,951)	(45,950,974)	(47,283,552)	(48,654,775)	(50,065,764)	(51,517,671)
4	Annual O&M Cost	\$	14,495,118	7,509,100	7,726,864	7,950,943	8,181,521	8,418,785	8,662,930	8,914,154	9,172,665	9,438,672	9,712,394	9,994,053
5	Pigging to Occur	N/A	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	TRUE
6	TIMP Cost	\$	2,253,834	9,887,095	-	-	-	-	-	-	3,805,937	-	-	4,640,104
7	Total O&M Costs	\$	17,446,922	17,406,195	7,726,864	7,950,943	8,181,521	8,418,785	8,662,930	8,914,154	21,262,312	9,438,672	9,712,394	9,994,053
J2 Blythe to Santee Alternative 2														
1	Future L1600 Replacement Cost	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$
2	MCS O&M and Emissions Cost	\$	(174,719,007)	(38,708,155)	(39,830,691)	(40,985,781)	(42,174,369)	(43,397,426)	(44,655,951)	(45,950,974)	(47,283,552)	(48,654,775)	(50,065,764)	(51,517,671)
3	Total Avoided Costs	\$	(175,005,390)	(38,708,155)	(39,830,691)	(40,985,781)	(42,174,369)	(43,397,426)	(44,655,951)	(45,950,974)	(47,283,552)	(48,654,775)	(50,065,764)	(51,517,671)
4	Annual O&M Cost	\$	14,495,118	7,509,100	7,726,864	7,950,943	8,181,521	8,418,785	8,662,930	8,914,154	9,172,665	9,438,672	9,712,394	9,994,053
5	Pigging to Occur	N/A	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	TRUE
6	TIMP Cost	\$	2,253,834	9,887,095	-	-	-	-	-	-	3,805,937	-	-	4,640,104
7	Total O&M Costs	\$	17,446,922	17,406,195	7,726,864	7,950,943	8,181,521	8,418,785	8,662,930	8,914,154	21,262,312	9,438,672	9,712,394	9,994,053

WORK PAPER TABLE - AVOIDED COST MODEL - COSTS OVER 00 YEARS (AC 1.2)
ANNUAL COSTS BY PROJECT ALTERNATE, FOR AVOIDED COSTS AND O&M COSTS
A.15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 20

Line No.	PV (X years after operation)	79	80	81	82	83	84	85	86	87	88	89	90	91
1	100													
2	100													
3	100													
4	100													
5	100													
6	100													
7	100													
8	100													
9	100													
10	100													
11	100													
12	100													
13	100													
14	100													
15	100													
16	100													
17	100													
18	100													
19	100													
20	100													
21	100													
22	100													
23	100													
24	100													
25	100													
26	100													
27	100													
28	100													
29	100													
30	100													
31	100													
32	100													
33	100													
34	100													
35	100													
36	100													
37	100													
38	100													
39	100													
40	100													
41	100													
42	100													
43	100													
44	100													
45	100													
46	100													
47	100													
48	100													
49	100													
50	100													
51	100													
52	100													
53	100													
54	100													
55	100													
56	100													
57	100													
58	100													
59	100													
60	100													
61	100													
62	100													
63	100													
64	100													
65	100													
66	100													
67	100													
68	100													
69	100													
70	100													
71	100													
72	100													
73	100													
74	100													
75	100													
76	100													
77	100													
78	100													
79	100													
80	100													
81	100													
82	100													
83	100													
84	100													
85	100													
86	100													
87	100													
88	100													
89	100													
90	100													
91	100													
92	100													
93	100													
94	100													
95	100													
96	100													
97	100													
98	100													
99	100													
100	100													

WORK PAPER TABLE - AVOIDED COST MODEL - COSTS OVER 00 YEARS (AC 1.2)
ANNUAL COSTS BY PROJECT ALTERNATE, FOR AVOIDED COSTS AND O&M COSTS
A.15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.	PV (X years after operational)	0	1	2	3	4	5	6	7	8	9	10	11	12	13
100	PV	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
209												Operational Year			
210	1 Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
211	2 MCS O&M and Emissions Cost	\$ (74,719,907)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ (7,808,030)	\$ (8,034,463)	\$ (8,267,462)	\$ (8,507,219)
212	3 Total Avoided Costs	\$ (175,005,390)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ (7,808,030)	\$ (8,034,463)	\$ (8,267,462)	\$ (8,507,219)
213															
214															
215	4 Annual O&M Cost	\$ 14,508,148	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 1,516,063	\$ 1,560,028	\$ 1,605,269	\$ 1,651,822
216	5 Pipping to Occur	N/A	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE
217	6 TIMP Cost	\$ 2,253,804	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
218	7 Total O&M Costs	\$ 16,761,952	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 1,516,063	\$ 1,560,028	\$ 1,605,269	\$ 1,651,822
220	J3 Cactus City to San Diego Alternative														
221															
222															
223	1 Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
224	2 MCS O&M and Emissions Cost	\$ (74,719,907)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ (7,808,030)	\$ (8,034,463)	\$ (8,267,462)	\$ (8,507,219)
225	3 Total Avoided Costs	\$ (175,005,390)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ (7,808,030)	\$ (8,034,463)	\$ (8,267,462)	\$ (8,507,219)
226															
227															
228	4 Annual O&M Cost	\$ 10,434,660	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 1,090,394	\$ 1,122,016	\$ 1,154,554	\$ 1,188,036
229	5 Pipping to Occur	N/A	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE
230	6 TIMP Cost	\$ 2,253,804	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
231	7 Total O&M Costs	\$ 12,688,464	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 1,090,394	\$ 1,122,016	\$ 1,154,554	\$ 1,188,036
232															
233	K Second Pipeline Along Line 3010														
234															
235															
236	1 Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
237	2 MCS O&M and Emissions Cost	\$ (71,330,165)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ (8,034,463)	\$ (8,267,462)	\$ (8,507,219)
238	3 Total Avoided Costs	\$ (171,615,648)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ (8,034,463)	\$ (8,267,462)	\$ (8,507,219)
239															
240															
241	4 Annual O&M Cost	\$ 2,799,858	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 315,369	\$ 324,515	\$ 333,926
242	5 Pipping to Occur	N/A	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE
243	6 TIMP Cost	\$ 717,186	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
244	7 Total O&M Costs	\$ 3,517,044	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 315,369	\$ 324,515	\$ 333,926

WORK PAPER TABLE - AVOIDED COST MODEL - COSTS OVER 00 YEARS (AC 1.2)
ANNUAL COSTS BY PROJECT ALTERNATE, FOR AVOIDED COSTS AND O&M COSTS
A.15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2)

Line No.	PV (X years after operation)	14	15	16	17	18	19	20	21	22	23	24	25	26
208	100													
209	PV	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041
210	1 Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
211	2 MCS O&M and Emissions Cost	\$ (74,719,907)	\$ (8,753,928)	\$ (9,007,792)	\$ (9,269,018)	\$ (9,537,820)	\$ (9,814,416)	\$ (10,099,035)	\$ (10,391,907)	\$ (10,693,272)	\$ (11,003,377)	\$ (11,322,475)	\$ (11,650,826)	\$ (11,988,700)
212	3 Total Avoided Costs	\$ (175,005,390)	\$ (8,753,928)	\$ (9,007,792)	\$ (9,269,018)	\$ (9,537,820)	\$ (9,814,416)	\$ (10,099,035)	\$ (10,391,907)	\$ (10,693,272)	\$ (11,003,377)	\$ (11,322,475)	\$ (11,650,826)	\$ (11,988,700)
213														
214	4 Annual O&M Cost	\$ 14,508,148	\$ 1,699,725	\$ 1,749,017	\$ 1,799,738	\$ 1,851,931	\$ 1,905,637	\$ 1,960,900	\$ 2,017,766	\$ 2,076,282	\$ 2,136,494	\$ 2,198,452	\$ 2,262,207	\$ 2,327,811
215	5 Pipping to Occur	N/A	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE
216	6 TIMP Cost	\$ 2,253,804	\$ -	\$ -	\$ -	\$ 2,438,668	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 2,978,930
217	7 Total O&M Costs	\$ 16,761,952	\$ 1,699,725	\$ 1,749,017	\$ 1,799,738	\$ 4,290,599	\$ 1,905,637	\$ 1,960,900	\$ 2,017,766	\$ 2,076,282	\$ 2,136,494	\$ 2,198,452	\$ 5,241,137	\$ 2,327,811
218														
219	J3 Cactus City to San Diego Alternative													
220	PV	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041
221	1 Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
222	2 MCS O&M and Emissions Cost	\$ (74,719,907)	\$ (8,753,928)	\$ (9,007,792)	\$ (9,269,018)	\$ (9,537,820)	\$ (9,814,416)	\$ (10,099,035)	\$ (10,391,907)	\$ (10,693,272)	\$ (11,003,377)	\$ (11,322,475)	\$ (11,650,826)	\$ (11,988,700)
223	3 Total Avoided Costs	\$ (175,005,390)	\$ (8,753,928)	\$ (9,007,792)	\$ (9,269,018)	\$ (9,537,820)	\$ (9,814,416)	\$ (10,099,035)	\$ (10,391,907)	\$ (10,693,272)	\$ (11,003,377)	\$ (11,322,475)	\$ (11,650,826)	\$ (11,988,700)
224														
225	4 Annual O&M Cost	\$ 10,434,660	\$ 1,222,489	\$ 1,257,941	\$ 1,294,421	\$ 1,331,960	\$ 1,370,586	\$ 1,410,334	\$ 1,451,233	\$ 1,493,319	\$ 1,536,626	\$ 1,581,187	\$ 1,627,042	\$ 1,674,226
226	5 Pipping to Occur	N/A	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE
227	6 TIMP Cost	\$ 2,253,804	\$ -	\$ -	\$ -	\$ 2,438,668	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 2,978,930
228	7 Total O&M Costs	\$ 12,688,464	\$ 1,222,489	\$ 1,257,941	\$ 1,294,421	\$ 3,770,627	\$ 1,370,586	\$ 1,410,334	\$ 1,451,233	\$ 1,493,319	\$ 1,536,626	\$ 1,581,187	\$ 4,605,971	\$ 1,674,226
229														
230	K Second Pipeline Along Line 3010													
231	PV	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	2039	2040	2041
232	1 Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
233	2 MCS O&M and Emissions Cost	\$ (71,330,165)	\$ (8,753,928)	\$ (9,007,792)	\$ (9,269,018)	\$ (9,537,820)	\$ (9,814,416)	\$ (10,099,035)	\$ (10,391,907)	\$ (10,693,272)	\$ (11,003,377)	\$ (11,322,475)	\$ (11,650,826)	\$ (11,988,700)
234	3 Total Avoided Costs	\$ (171,615,648)	\$ (8,753,928)	\$ (9,007,792)	\$ (9,269,018)	\$ (9,537,820)	\$ (9,814,416)	\$ (10,099,035)	\$ (10,391,907)	\$ (10,693,272)	\$ (11,003,377)	\$ (11,322,475)	\$ (11,650,826)	\$ (11,988,700)
235														
236	4 Annual O&M Cost	\$ 2,799,858	\$ 343,610	\$ 353,575	\$ 363,828	\$ 374,379	\$ 385,236	\$ 396,408	\$ 407,904	\$ 419,733	\$ 431,906	\$ 444,431	\$ 457,319	\$ 470,592
237	5 Pipping to Occur	N/A	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE
238	6 TIMP Cost	\$ 717,186	\$ -	\$ -	\$ -	\$ -	\$ 836,463	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 1,021,773
239	7 Total O&M Costs	\$ 3,517,044	\$ 343,610	\$ 353,575	\$ 363,828	\$ 374,379	\$ 1,221,699	\$ 396,408	\$ 407,904	\$ 419,733	\$ 431,906	\$ 444,431	\$ 457,319	\$ 1,492,364
240														
241														
242														
243														
244														

WORK PAPER TABLE - AVOIDED COST MODEL - COSTS OVER 00 YEARS (AC 1.2)
ANNUAL COSTS BY PROJECT ALTERNATE, FOR AVOIDED COSTS AND O&M COSTS
A.15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 21)

Line No.	PV (X years after operation)	27	28	29	30	31	32	33	34	35	36	37	38	39
100	PV	2042	2043	2044	2045	2046	2047	2048	2049	2050	2051	2052	2053	2054
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ (74,719,907)	\$ (12,694,127)	\$ (13,062,257)	\$ (13,441,063)	\$ (13,830,853)	\$ (14,231,948)	\$ (14,644,675)	\$ (15,069,370)	\$ (15,506,382)	\$ (15,956,067)	\$ (16,418,793)	\$ (16,894,938)	\$ (17,384,891)
3	Total Avoided Costs	\$ (175,005,390)	\$ (12,694,127)	\$ (13,062,257)	\$ (13,441,063)	\$ (13,830,853)	\$ (14,231,948)	\$ (14,644,675)	\$ (15,069,370)	\$ (15,506,382)	\$ (15,956,067)	\$ (16,418,793)	\$ (16,894,938)	\$ (17,384,891)
4	Annual O&M Cost	\$ 14,508,148	\$ 2,464,782	\$ 2,536,261	\$ 2,609,812	\$ 2,685,497	\$ 2,763,376	\$ 2,843,514	\$ 2,925,976	\$ 3,010,829	\$ 3,098,143	\$ 3,187,989	\$ 3,280,441	\$ 3,375,574
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE
6	TIMP Cost	\$ 2,253,804	\$ -	\$ -	\$ -	\$ -	\$ 3,638,881	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 4,445,038
7	Total O&M Costs	\$ 16,761,952	\$ 2,464,782	\$ 2,536,261	\$ 2,609,812	\$ 2,685,497	\$ 6,402,257	\$ 2,843,514	\$ 2,925,976	\$ 3,010,829	\$ 3,098,143	\$ 3,187,989	\$ 3,280,441	\$ 7,820,612
J3	Cactus City to San Diego Alternative													
100	PV	2042	2043	2044	2045	2046	2047	2048	2049	2050	2051	2052	2053	2054
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ (74,719,907)	\$ (12,694,127)	\$ (13,062,257)	\$ (13,441,063)	\$ (13,830,853)	\$ (14,231,948)	\$ (14,644,675)	\$ (15,069,370)	\$ (15,506,382)	\$ (15,956,067)	\$ (16,418,793)	\$ (16,894,938)	\$ (17,384,891)
3	Total Avoided Costs	\$ (175,005,390)	\$ (12,694,127)	\$ (13,062,257)	\$ (13,441,063)	\$ (13,830,853)	\$ (14,231,948)	\$ (14,644,675)	\$ (15,069,370)	\$ (15,506,382)	\$ (15,956,067)	\$ (16,418,793)	\$ (16,894,938)	\$ (17,384,891)
4	Annual O&M Cost	\$ 10,434,660	\$ 1,772,739	\$ 1,824,149	\$ 1,877,049	\$ 1,931,483	\$ 1,987,496	\$ 2,045,134	\$ 2,104,443	\$ 2,165,471	\$ 2,228,270	\$ 2,292,890	\$ 2,359,384	\$ 2,427,806
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE
6	TIMP Cost	\$ 2,253,804	\$ -	\$ -	\$ -	\$ -	\$ 3,638,881	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 4,445,038
7	Total O&M Costs	\$ 12,688,464	\$ 1,772,739	\$ 1,824,149	\$ 1,877,049	\$ 1,931,483	\$ 5,626,377	\$ 2,045,134	\$ 2,104,443	\$ 2,165,471	\$ 2,228,270	\$ 2,292,890	\$ 2,359,384	\$ 6,872,844
K	Second Pipeline Along Line 3010													
100	PV	2042	2043	2044	2045	2046	2047	2048	2049	2050	2051	2052	2053	2054
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ (71,330,165)	\$ (12,694,127)	\$ (13,062,257)	\$ (13,441,063)	\$ (13,830,853)	\$ (14,231,948)	\$ (14,644,675)	\$ (15,069,370)	\$ (15,506,382)	\$ (15,956,067)	\$ (16,418,793)	\$ (16,894,938)	\$ (17,384,891)
3	Total Avoided Costs	\$ (171,615,648)	\$ (12,694,127)	\$ (13,062,257)	\$ (13,441,063)	\$ (13,830,853)	\$ (14,231,948)	\$ (14,644,675)	\$ (15,069,370)	\$ (15,506,382)	\$ (15,956,067)	\$ (16,418,793)	\$ (16,894,938)	\$ (17,384,891)
4	Annual O&M Cost	\$ 2,799,858	\$ 498,271	\$ 512,721	\$ 527,590	\$ 542,890	\$ 558,634	\$ 574,834	\$ 591,504	\$ 608,658	\$ 626,309	\$ 644,472	\$ 663,162	\$ 682,393
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE
6	TIMP Cost	\$ 717,186	\$ -	\$ -	\$ -	\$ -	\$ 1,248,136	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 1,624,648
7	Total O&M Costs	\$ 3,517,044	\$ 498,271	\$ 512,721	\$ 527,590	\$ 542,890	\$ 558,634	\$ 1,822,970	\$ 591,504	\$ 608,658	\$ 626,309	\$ 644,472	\$ 663,162	\$ 2,226,831

WORK PAPER TABLE - AVOIDED COST MODEL - COSTS OVER 00 YEARS (AC 1.2)
ANNUAL COSTS BY PROJECT ALTERNATE, FOR AVOIDED COSTS AND O&M COSTS
A.15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2)

Line No.	PV (X years after operation)	40	41	42	43	44	45	46	47	48	49	50	51	52
100	PV	2055	2056	2057	2058	2059	2060	2061	2062	2063	2064	2065	2066	2067
208														
209														
210	1 Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
211	2 MCS O&M and Emissions Cost	\$ (74,719,907)	\$ (18,407,836)	\$ (18,941,663)	\$ (19,490,971)	\$ (20,056,209)	\$ (20,637,839)	\$ (21,236,337)	\$ (21,852,190)	\$ (22,485,904)	\$ (23,137,995)	\$ (23,808,997)	\$ (24,499,458)	\$ (25,209,942)
212	3 Total Avoided Costs	\$ (175,005,390)	\$ (18,407,836)	\$ (18,941,663)	\$ (19,490,971)	\$ (20,056,209)	\$ (20,637,839)	\$ (21,236,337)	\$ (21,852,190)	\$ (22,485,904)	\$ (23,137,995)	\$ (23,808,997)	\$ (24,499,458)	\$ (25,209,942)
213														
214														
215	4 Annual O&M Cost	\$ 14,508,148	\$ 3,574,196	\$ 3,677,848	\$ 3,784,505	\$ 3,894,256	\$ 4,007,189	\$ 4,123,398	\$ 4,242,976	\$ 4,366,023	\$ 4,492,637	\$ 4,622,924	\$ 4,756,989	\$ 4,894,941
216	5 Pipping to Occur	N/A	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE
217	6 TIMP Cost	\$ 2,253,804	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 5,429,791	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
218	7 Total O&M Costs	\$ 16,761,952	\$ 3,574,196	\$ 3,677,848	\$ 3,784,505	\$ 3,894,256	\$ 4,007,189	\$ 9,553,189	\$ 4,242,976	\$ 4,366,023	\$ 4,492,637	\$ 4,622,924	\$ 4,756,989	\$ 4,894,941
219														
220														
221	J3 Cactus City to San Diego Alternative													
222														
223	1 Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
224	2 MCS O&M and Emissions Cost	\$ (74,719,907)	\$ (18,407,836)	\$ (18,941,663)	\$ (19,490,971)	\$ (20,056,209)	\$ (20,637,839)	\$ (21,236,337)	\$ (21,852,190)	\$ (22,485,904)	\$ (23,137,995)	\$ (23,808,997)	\$ (24,499,458)	\$ (25,209,942)
225	3 Total Avoided Costs	\$ (175,005,390)	\$ (18,407,836)	\$ (18,941,663)	\$ (19,490,971)	\$ (20,056,209)	\$ (20,637,839)	\$ (21,236,337)	\$ (21,852,190)	\$ (22,485,904)	\$ (23,137,995)	\$ (23,808,997)	\$ (24,499,458)	\$ (25,209,942)
226														
227														
228	4 Annual O&M Cost	\$ 10,434,660	\$ 2,570,660	\$ 2,645,209	\$ 2,721,921	\$ 2,800,856	\$ 2,882,081	\$ 2,965,661	\$ 3,051,666	\$ 3,140,164	\$ 3,231,229	\$ 3,324,934	\$ 3,421,357	\$ 3,520,577
229	5 Pipping to Occur	N/A	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE
230	6 TIMP Cost	\$ 2,253,804	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 5,429,791	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
231	7 Total O&M Costs	\$ 12,688,464	\$ 2,570,660	\$ 2,645,209	\$ 2,721,921	\$ 2,800,856	\$ 2,882,081	\$ 8,395,453	\$ 3,051,666	\$ 3,140,164	\$ 3,231,229	\$ 3,324,934	\$ 3,421,357	\$ 3,520,577
232														
233	K Second Pipeline Along Line 3010													
234														
235														
236	1 Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
237	2 MCS O&M and Emissions Cost	\$ (71,330,165)	\$ (18,407,836)	\$ (18,941,663)	\$ (19,490,971)	\$ (20,056,209)	\$ (20,637,839)	\$ (21,236,337)	\$ (21,852,190)	\$ (22,485,904)	\$ (23,137,995)	\$ (23,808,997)	\$ (24,499,458)	\$ (25,209,942)
238	3 Total Avoided Costs	\$ (171,615,648)	\$ (18,407,836)	\$ (18,941,663)	\$ (19,490,971)	\$ (20,056,209)	\$ (20,637,839)	\$ (21,236,337)	\$ (21,852,190)	\$ (22,485,904)	\$ (23,137,995)	\$ (23,808,997)	\$ (24,499,458)	\$ (25,209,942)
239														
240														
241	4 Annual O&M Cost	\$ 2,799,858	\$ 722,546	\$ 743,500	\$ 765,061	\$ 787,248	\$ 810,078	\$ 833,571	\$ 857,744	\$ 882,619	\$ 908,215	\$ 934,553	\$ 961,655	\$ 989,543
242	5 Pipping to Occur	N/A	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE
243	6 TIMP Cost	\$ 717,186	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 1,862,418	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
244	7 Total O&M Costs	\$ 3,517,044	\$ 722,546	\$ 743,500	\$ 765,061	\$ 787,248	\$ 810,078	\$ 833,571	\$ 2,720,163	\$ 882,619	\$ 908,215	\$ 934,553	\$ 961,655	\$ 989,543

WORK PAPER TABLE - AVOIDED COST MODEL - COSTS OVER 00 YEARS (AC 1.2)
ANNUAL COSTS BY PROJECT ALTERNATE, FOR AVOIDED COSTS AND O&M COSTS
A.15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2)

Line No.	PV (X years after operation)	53	54	55	56	57	58	59	60	61	62	63	64	65
100		2068	2069	2070	2071	2072	2073	2074	2075	2076	2077	2078	2079	2080
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ (74,719,907)	\$ (26,693,320)	\$ (27,467,427)	\$ (28,263,982)	\$ (29,083,638)	\$ (29,927,063)	\$ (30,794,948)	\$ (31,688,001)	\$ (32,606,953)	\$ (33,552,555)	\$ (34,525,579)	\$ (35,526,821)	\$ (36,557,099)
3	Total Avoided Costs	\$ (175,005,390)	\$ (26,693,320)	\$ (27,467,427)	\$ (28,263,982)	\$ (29,083,638)	\$ (29,927,063)	\$ (30,794,948)	\$ (31,688,001)	\$ (32,606,953)	\$ (33,552,555)	\$ (34,525,579)	\$ (35,526,821)	\$ (36,557,099)
4	Annual O&M Cost	\$ 14,508,148	\$ 5,182,965	\$ 5,333,271	\$ 5,487,935	\$ 5,647,086	\$ 5,810,851	\$ 5,979,366	\$ 6,152,767	\$ 6,331,198	\$ 6,514,802	\$ 6,703,732	\$ 6,898,140	\$ 7,098,186
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE
6	TIMP Cost	\$ 2,253,804	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 8,102,114	\$ -	\$ -	\$ -	\$ -	\$ -
7	Total O&M Costs	\$ 16,761,952	\$ 5,182,965	\$ 5,333,271	\$ 5,487,935	\$ 5,647,086	\$ 5,810,851	\$ 5,979,366	\$ 14,254,882	\$ 6,331,198	\$ 6,514,802	\$ 6,703,732	\$ 6,898,140	\$ 7,098,186
J3	Cactus City to San Diego Alternative													
100		2068	2069	2070	2071	2072	2073	2074	2075	2076	2077	2078	2079	2080
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ (74,719,907)	\$ (26,693,320)	\$ (27,467,427)	\$ (28,263,982)	\$ (29,083,638)	\$ (29,927,063)	\$ (30,794,948)	\$ (31,688,001)	\$ (32,606,953)	\$ (33,552,555)	\$ (34,525,579)	\$ (35,526,821)	\$ (36,557,099)
3	Total Avoided Costs	\$ (175,005,390)	\$ (26,693,320)	\$ (27,467,427)	\$ (28,263,982)	\$ (29,083,638)	\$ (29,927,063)	\$ (30,794,948)	\$ (31,688,001)	\$ (32,606,953)	\$ (33,552,555)	\$ (34,525,579)	\$ (35,526,821)	\$ (36,557,099)
4	Annual O&M Cost	\$ 10,434,660	\$ 3,727,731	\$ 3,835,835	\$ 3,947,074	\$ 4,061,540	\$ 4,179,324	\$ 4,300,525	\$ 4,425,240	\$ 4,553,572	\$ 4,685,625	\$ 4,821,509	\$ 4,961,332	\$ 5,105,211
5	Pigging to Occur	N/A	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE
6	TIMP Cost	\$ 2,253,804	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 8,102,114	\$ -	\$ -	\$ -	\$ -	\$ -
7	Total O&M Costs	\$ 12,688,464	\$ 3,727,731	\$ 3,835,835	\$ 3,947,074	\$ 4,061,540	\$ 4,179,324	\$ 4,300,525	\$ 12,527,354	\$ 4,553,572	\$ 4,685,625	\$ 4,821,509	\$ 4,961,332	\$ 5,105,211
K	Second Pipeline Along Line 3010													
100		2068	2069	2070	2071	2072	2073	2074	2075	2076	2077	2078	2079	2080
1	Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
2	MCS O&M and Emissions Cost	\$ (71,330,165)	\$ (26,693,320)	\$ (27,467,427)	\$ (28,263,982)	\$ (29,083,638)	\$ (29,927,063)	\$ (30,794,948)	\$ (31,688,001)	\$ (32,606,953)	\$ (33,552,555)	\$ (34,525,579)	\$ (35,526,821)	\$ (36,557,099)
3	Total Avoided Costs	\$ (171,615,648)	\$ (26,693,320)	\$ (27,467,427)	\$ (28,263,982)	\$ (29,083,638)	\$ (29,927,063)	\$ (30,794,948)	\$ (31,688,001)	\$ (32,606,953)	\$ (33,552,555)	\$ (34,525,579)	\$ (35,526,821)	\$ (36,557,099)
4	Annual O&M Cost	\$ 2,799,858	\$ 1,047,769	\$ 1,076,154	\$ 1,109,420	\$ 1,141,594	\$ 1,174,700	\$ 1,208,766	\$ 1,243,820	\$ 1,279,891	\$ 1,317,008	\$ 1,355,201	\$ 1,394,502	\$ 1,434,943
5	Pigging to Occur	N/A	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE
6	TIMP Cost	\$ 717,186	\$ 2,275,018	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 2,779,025	\$ -	\$ -	\$ -	\$ -
7	Total O&M Costs	\$ 3,517,044	\$ 3,322,787	\$ 1,076,154	\$ 1,109,420	\$ 1,141,594	\$ 1,174,700	\$ 1,208,766	\$ 1,243,820	\$ 4,058,916	\$ 1,317,008	\$ 1,355,201	\$ 1,394,502	\$ 1,434,943

WORK PAPER TABLE - AVOIDED COST MODEL - COSTS OVER 00 YEARS (AC 1.2)
ANNUAL COSTS BY PROJECT ALTERNATE, FOR AVOIDED COSTS AND O&M COSTS
A.15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2)

Line No.	PV (X years after operation)	66	67	68	69	70	71	72	73	74	75	76	77	78
208	100													
209	PV	2081	2082	2083	2084	2085	2086	2087	2088	2089	2090	2091	2092	2093
210	1 Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
211	2 MCS O&M and Emissions Cost	\$ (74,719,907)	\$ (38,708,155)	\$ (39,830,691)	\$ (40,985,781)	\$ (42,174,369)	\$ (43,397,426)	\$ (44,655,951)	\$ (45,950,974)	\$ (47,283,552)	\$ (48,654,775)	\$ (50,065,764)	\$ (51,517,671)	\$ (53,011,683)
212	3 Total Avoided Costs	\$ (175,005,390)	\$ (38,708,155)	\$ (39,830,691)	\$ (40,985,781)	\$ (42,174,369)	\$ (43,397,426)	\$ (44,655,951)	\$ (45,950,974)	\$ (47,283,552)	\$ (48,654,775)	\$ (50,065,764)	\$ (51,517,671)	\$ (53,011,683)
213														
214														
215	4 Annual O&M Cost	\$ 14,508,148	\$ 7,515,850	\$ 7,733,810	\$ 7,958,090	\$ 8,188,875	\$ 8,426,352	\$ 8,670,716	\$ 8,922,167	\$ 9,180,910	\$ 9,447,156	\$ 9,721,124	\$ 10,003,037	\$ 10,293,125
216	5 Pipping to Occur	N/A	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE
217	6 TIMP Cost	\$ 2,253,804	\$ 9,897,056	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 12,089,647	\$ -	\$ -	\$ -	\$ -
218	7 Total O&M Costs	\$ 16,761,952	\$ 17,412,906	\$ 7,733,810	\$ 7,958,090	\$ 8,188,875	\$ 8,426,352	\$ 8,670,716	\$ 8,922,167	\$ 21,270,557	\$ 9,447,156	\$ 9,721,124	\$ 10,003,037	\$ 10,293,125
219														
220	J3 Cactus City to San Diego Alternative													
221	PV	2081	2082	2083	2084	2085	2086	2087	2088	2089	2090	2091	2092	2093
222														
223	1 Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
224	2 MCS O&M and Emissions Cost	\$ (74,719,907)	\$ (38,708,155)	\$ (39,830,691)	\$ (40,985,781)	\$ (42,174,369)	\$ (43,397,426)	\$ (44,655,951)	\$ (45,950,974)	\$ (47,283,552)	\$ (48,654,775)	\$ (50,065,764)	\$ (51,517,671)	\$ (53,011,683)
225	3 Total Avoided Costs	\$ (175,005,390)	\$ (38,708,155)	\$ (39,830,691)	\$ (40,985,781)	\$ (42,174,369)	\$ (43,397,426)	\$ (44,655,951)	\$ (45,950,974)	\$ (47,283,552)	\$ (48,654,775)	\$ (50,065,764)	\$ (51,517,671)	\$ (53,011,683)
226														
227														
228	4 Annual O&M Cost	\$ 10,434,660	\$ 5,405,607	\$ 5,562,369	\$ 5,723,678	\$ 5,889,665	\$ 6,060,465	\$ 6,236,218	\$ 6,417,069	\$ 6,603,164	\$ 6,794,655	\$ 6,991,700	\$ 7,194,460	\$ 7,403,099
229	5 Pipping to Occur	N/A	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE
230	6 TIMP Cost	\$ 2,253,804	\$ 9,897,056	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 12,089,647	\$ -	\$ -	\$ -	\$ -
231	7 Total O&M Costs	\$ 12,688,464	\$ 15,302,662	\$ 5,562,369	\$ 5,723,678	\$ 5,889,665	\$ 6,060,465	\$ 6,236,218	\$ 6,417,069	\$ 18,692,811	\$ 6,794,655	\$ 6,991,700	\$ 7,194,460	\$ 7,403,099
232														
233	K Second Pipeline Along Line 3010													
234	PV	2081	2082	2083	2084	2085	2086	2087	2088	2089	2090	2091	2092	2093
235														
236	1 Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
237	2 MCS O&M and Emissions Cost	\$ (71,330,165)	\$ (38,708,155)	\$ (39,830,691)	\$ (40,985,781)	\$ (42,174,369)	\$ (43,397,426)	\$ (44,655,951)	\$ (45,950,974)	\$ (47,283,552)	\$ (48,654,775)	\$ (50,065,764)	\$ (51,517,671)	\$ (53,011,683)
238	3 Total Avoided Costs	\$ (171,615,648)	\$ (38,708,155)	\$ (39,830,691)	\$ (40,985,781)	\$ (42,174,369)	\$ (43,397,426)	\$ (44,655,951)	\$ (45,950,974)	\$ (47,283,552)	\$ (48,654,775)	\$ (50,065,764)	\$ (51,517,671)	\$ (53,011,683)
239														
240														
241	4 Annual O&M Cost	\$ 2,799,858	\$ 1,519,376	\$ 1,563,438	\$ 1,608,778	\$ 1,655,432	\$ 1,703,440	\$ 1,752,840	\$ 1,803,672	\$ 1,855,978	\$ 1,909,802	\$ 1,965,186	\$ 2,022,176	\$ 2,080,820
242	5 Pipping to Occur	N/A	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE
243	6 TIMP Cost	\$ 717,186	\$ -	\$ 3,394,690	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 4,146,749	\$ -	\$ -	\$ -
244	7 Total O&M Costs	\$ 3,517,044	\$ 1,519,376	\$ 4,958,128	\$ 1,608,778	\$ 1,655,432	\$ 1,703,440	\$ 1,752,840	\$ 1,803,672	\$ 1,855,978	\$ 6,056,551	\$ 1,965,186	\$ 2,022,176	\$ 2,080,820

WORK PAPER TABLE - AVOIDED COST MODEL - COSTS OVER 00 YEARS (AC 1.2)
ANNUAL COSTS BY PROJECT ALTERNATE, FOR AVOIDED COSTS AND O&M COSTS
A.15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2)

Line No.	PV (X years after operation)	79	80	81	82	83	84	85	86	87	88	89	90	91
1	100													
208	PV	2094	2095	2096	2097	2098	2099	2100	2101	2102	2103	2104	2105	2106
209														
210	1 Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
211	2 MCS O&M and Emissions Cost	\$ (74,719,907)	\$ (66,130,944)	\$ (57,758,741)	\$ (59,433,744)	\$ (61,157,323)	\$ (62,930,885)	\$ (64,755,881)	\$ (66,633,802)	\$ (68,566,182)	\$ (70,554,601)	\$ (72,600,685)	\$ (74,706,104)	\$ (76,872,581)
212	3 Total Avoided Costs	\$ (175,005,390)	\$ (66,130,944)	\$ (57,758,741)	\$ (59,433,744)	\$ (61,157,323)	\$ (62,930,885)	\$ (64,755,881)	\$ (66,633,802)	\$ (68,566,182)	\$ (70,554,601)	\$ (72,600,685)	\$ (74,706,104)	\$ (76,872,581)
213														
214	4 Annual O&M Cost	\$ 14,508,148	\$ 10,898,782	\$ 11,214,847	\$ 11,540,078	\$ 11,874,740	\$ 12,219,107	\$ 12,573,462	\$ 12,938,092	\$ 13,313,297	\$ 13,699,382	\$ 14,096,664	\$ 14,505,468	\$ 14,926,126
215	5 Pipping to Occur	N/A	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE
216	6 TIMP Cost	\$ 2,253,804	\$ -	\$ 14,767,985	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 18,039,681	\$ -	\$ -	\$ -
217	7 Total O&M Costs	\$ 16,761,952	\$ 10,898,782	\$ 25,982,832	\$ 11,540,078	\$ 11,874,740	\$ 12,219,107	\$ 12,573,462	\$ 12,938,092	\$ 13,313,297	\$ 31,739,064	\$ 14,096,664	\$ 14,505,468	\$ 14,926,126
218														
219	J3 Cactus City to San Diego Alternative													
220														
221	PV	2094	2095	2096	2097	2098	2099	2100	2101	2102	2103	2104	2105	2106
222														
223	1 Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
224	2 MCS O&M and Emissions Cost	\$ (74,719,907)	\$ (66,130,944)	\$ (57,758,741)	\$ (59,433,744)	\$ (61,157,323)	\$ (62,930,885)	\$ (64,755,881)	\$ (66,633,802)	\$ (68,566,182)	\$ (70,554,601)	\$ (72,600,685)	\$ (74,706,104)	\$ (76,872,581)
225	3 Total Avoided Costs	\$ (175,005,390)	\$ (66,130,944)	\$ (57,758,741)	\$ (59,433,744)	\$ (61,157,323)	\$ (62,930,885)	\$ (64,755,881)	\$ (66,633,802)	\$ (68,566,182)	\$ (70,554,601)	\$ (72,600,685)	\$ (74,706,104)	\$ (76,872,581)
226														
227	4 Annual O&M Cost	\$ 10,434,660	\$ 7,838,705	\$ 8,066,027	\$ 8,299,942	\$ 8,540,640	\$ 8,788,319	\$ 9,043,180	\$ 9,305,432	\$ 9,575,290	\$ 9,852,973	\$ 10,138,710	\$ 10,432,732	\$ 10,735,281
228	5 Pipping to Occur	N/A	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE
229	6 TIMP Cost	\$ 2,253,804	\$ -	\$ 14,767,985	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 18,039,681	\$ -	\$ -	\$ -
230	7 Total O&M Costs	\$ 12,688,464	\$ 7,838,705	\$ 22,834,012	\$ 8,299,942	\$ 8,540,640	\$ 8,788,319	\$ 9,043,180	\$ 9,305,432	\$ 9,575,290	\$ 27,892,655	\$ 10,138,710	\$ 10,432,732	\$ 10,735,281
231														
232	K Second Pipeline Along Line 3010													
233														
234	PV	2094	2095	2096	2097	2098	2099	2100	2101	2102	2103	2104	2105	2106
235														
236	1 Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
237	2 MCS O&M and Emissions Cost	\$ (71,330,165)	\$ (66,130,944)	\$ (57,758,741)	\$ (59,433,744)	\$ (61,157,323)	\$ (62,930,885)	\$ (64,755,881)	\$ (66,633,802)	\$ (68,566,182)	\$ (70,554,601)	\$ (72,600,685)	\$ (74,706,104)	\$ (76,872,581)
238	3 Total Avoided Costs	\$ (171,615,648)	\$ (66,130,944)	\$ (57,758,741)	\$ (59,433,744)	\$ (61,157,323)	\$ (62,930,885)	\$ (64,755,881)	\$ (66,633,802)	\$ (68,566,182)	\$ (70,554,601)	\$ (72,600,685)	\$ (74,706,104)	\$ (76,872,581)
239														
240	4 Annual O&M Cost	\$ 2,799,858	\$ 2,203,257	\$ 2,267,152	\$ 2,332,899	\$ 2,400,553	\$ 2,470,169	\$ 2,541,804	\$ 2,615,516	\$ 2,691,366	\$ 2,769,416	\$ 2,849,729	\$ 2,932,371	\$ 3,017,410
241	5 Pipping to Occur	N/A	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE
242	6 TIMP Cost	\$ 717,186	\$ -	\$ -	\$ 5,065,419	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 6,187,611	\$ -	\$ -
243	7 Total O&M Costs	\$ 3,517,044	\$ 2,203,257	\$ 2,267,152	\$ 7,398,318	\$ 2,400,553	\$ 2,470,169	\$ 2,541,804	\$ 2,615,516	\$ 2,691,366	\$ 2,769,416	\$ 9,037,340	\$ 2,932,371	\$ 3,017,410
244														

WORK PAPER TABLE - AVOIDED COST MODEL - COSTS OVER 00 YEARS (AC 1.2)
ANNUAL COSTS BY PROJECT ALTERNATE, FOR AVOIDED COSTS AND O&M COSTS
A.15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2)

Line No.	PV (X years after operation)	92	93	94	95	96	97	98	99	100	101	102	103	104
208	100													
209	PV	2107	2108	2109	2110	2111	2112	2113	2114	2115	2116	2117	2118	2119
210	1 Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
211	2 MCS O&M and Emissions Cost	\$ (74,719,907)	\$ (81,395,841)	\$ (83,756,320)	\$ (86,185,254)	\$ (88,684,626)	\$ (91,256,480)	\$ (93,902,818)	\$ (96,626,103)	\$ (99,428,260)	\$ (102,311,679)	\$ (105,278,718)	\$ (108,331,801)	\$ (111,473,423)
212	3 Total Avoided Costs	\$ (175,005,390)	\$ (81,395,841)	\$ (83,756,320)	\$ (86,185,254)	\$ (88,684,626)	\$ (91,256,480)	\$ (93,902,818)	\$ (96,626,103)	\$ (99,428,260)	\$ (102,311,679)	\$ (105,278,718)	\$ (108,331,801)	\$ (111,473,423)
213														
214														
215	4 Annual O&M Cost	\$ 14,508,148	\$ 15,804,394	\$ 16,262,722	\$ 16,734,341	\$ 17,219,636	\$ 17,719,006	\$ 18,232,857	\$ 18,761,610	\$ 19,305,697	\$ 19,865,562	\$ 20,441,663	\$ 21,034,471	\$ 21,644,471
216	5 Pipping to Occur	N/A	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE
217	6 TIMP Cost	\$ 2,253,804	\$ -	\$ -	\$ 22,036,189	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 26,918,082	\$ -	\$ -
218	7 Total O&M Costs	\$ 16,761,952	\$ 15,804,394	\$ 16,262,722	\$ 38,770,530	\$ 17,219,636	\$ 17,719,006	\$ 18,232,857	\$ 18,761,610	\$ 19,305,697	\$ 19,865,562	\$ 47,359,745	\$ 21,034,471	\$ 21,644,471
219														
220	J3 Cactus City to San Diego Alternative													
221														
222														
223	PV	2107	2108	2109	2110	2111	2112	2113	2114	2115	2116	2117	2118	2119
224	1 Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
225	2 MCS O&M and Emissions Cost	\$ (74,719,907)	\$ (81,395,841)	\$ (83,756,320)	\$ (86,185,254)	\$ (88,684,626)	\$ (91,256,480)	\$ (93,902,818)	\$ (96,626,103)	\$ (99,428,260)	\$ (102,311,679)	\$ (105,278,718)	\$ (108,331,801)	\$ (111,473,423)
226	3 Total Avoided Costs	\$ (175,005,390)	\$ (81,395,841)	\$ (83,756,320)	\$ (86,185,254)	\$ (88,684,626)	\$ (91,256,480)	\$ (93,902,818)	\$ (96,626,103)	\$ (99,428,260)	\$ (102,311,679)	\$ (105,278,718)	\$ (108,331,801)	\$ (111,473,423)
227														
228	4 Annual O&M Cost	\$ 10,434,660	\$ 11,366,956	\$ 11,696,598	\$ 12,035,799	\$ 12,384,837	\$ 12,743,998	\$ 13,113,573	\$ 13,493,867	\$ 13,885,189	\$ 14,287,860	\$ 14,702,208	\$ 15,128,572	\$ 15,567,300
229	5 Pipping to Occur	N/A	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE
230	6 TIMP Cost	\$ 2,253,804	\$ -	\$ -	\$ 22,036,189	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 26,918,082	\$ -	\$ -
231	7 Total O&M Costs	\$ 12,688,464	\$ 11,366,956	\$ 11,696,598	\$ 34,071,988	\$ 12,384,837	\$ 12,743,998	\$ 13,113,573	\$ 13,493,867	\$ 13,885,189	\$ 14,287,860	\$ 41,620,290	\$ 15,128,572	\$ 15,567,300
232														
233	K Second Pipeline Along Line 3010													
234														
235														
236	PV	2107	2108	2109	2110	2111	2112	2113	2114	2115	2116	2117	2118	2119
237	1 Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
238	2 MCS O&M and Emissions Cost	\$ (71,330,165)	\$ (81,395,841)	\$ (83,756,320)	\$ (86,185,254)	\$ (88,684,626)	\$ (91,256,480)	\$ (93,902,818)	\$ (96,626,103)	\$ (99,428,260)	\$ (102,311,679)	\$ (105,278,718)	\$ (108,331,801)	\$ (111,473,423)
239	3 Total Avoided Costs	\$ (171,615,648)	\$ (81,395,841)	\$ (83,756,320)	\$ (86,185,254)	\$ (88,684,626)	\$ (91,256,480)	\$ (93,902,818)	\$ (96,626,103)	\$ (99,428,260)	\$ (102,311,679)	\$ (105,278,718)	\$ (108,331,801)	\$ (111,473,423)
240														
241	4 Annual O&M Cost	\$ 2,799,858	\$ 3,194,957	\$ 3,287,611	\$ 3,382,952	\$ 3,481,057	\$ 3,582,008	\$ 3,685,886	\$ 3,792,777	\$ 3,902,767	\$ 4,015,948	\$ 4,132,410	\$ 4,252,250	\$ 4,375,565
242	5 Pipping to Occur	N/A	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE
243	6 TIMP Cost	\$ 717,186	\$ -	\$ -	\$ -	\$ 7,558,413	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 9,232,902	\$ -	\$ -
244	7 Total O&M Costs	\$ 3,517,044	\$ 3,194,957	\$ 3,287,611	\$ 3,382,952	\$ 11,039,470	\$ 3,582,008	\$ 3,685,886	\$ 3,792,777	\$ 3,902,767	\$ 4,015,948	\$ 4,132,410	\$ 13,485,152	\$ 4,375,565

WORK PAPER TABLE - AVOIDED COST MODEL - COSTS OVER 00 YEARS (AC 1.2)
ANNUAL COSTS BY PROJECT ALTERNATE, FOR AVOIDED COSTS AND O&M COSTS
A.15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 21)

Line No.	PV (X years after operation)	105	106	107	108	109	110	111	112	113	114	115	116
208	100												
209	PV	2120	2121	2122	2123	2124	2125	2126	2127	2128	2129	2130	2131
210	1 Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
211	2 MCS O&M and Emissions Cost	\$ (74,719,907)	\$ (118,032,631)	\$ (121,455,577)	\$ (124,977,789)	\$ (128,602,145)	\$ (132,331,607)	\$ (136,169,223)	\$ (140,118,131)	\$ (144,181,557)	\$ (148,362,822)	\$ (152,665,344)	\$ (157,092,638)
212	3 Total Avoided Costs	\$ (175,005,390)	\$ (118,032,631)	\$ (121,455,577)	\$ (124,977,789)	\$ (128,602,145)	\$ (132,331,607)	\$ (136,169,223)	\$ (140,118,131)	\$ (144,181,557)	\$ (148,362,822)	\$ (152,665,344)	\$ (157,092,638)
213													
214													
215	4 Annual O&M Cost	\$ 14,508,148	\$ 22,918,053	\$ 23,582,677	\$ 24,266,575	\$ 24,970,305	\$ 25,694,444	\$ 26,439,583	\$ 27,206,331	\$ 27,995,314	\$ 28,807,179	\$ 29,642,587	\$ 30,502,222
216	5 Pipping to Occur	N/A	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE
217	6 TIMP Cost	\$ 2,253,804	\$ -	\$ -	\$ -	\$ 32,881,509	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
218	7 Total O&M Costs	\$ 16,761,952	\$ 22,918,053	\$ 23,582,677	\$ 24,266,575	\$ 57,851,814	\$ 25,694,444	\$ 26,439,583	\$ 27,206,331	\$ 27,995,314	\$ 28,807,179	\$ 29,642,587	\$ 30,502,222
219													
220													
221	J3 Cactus City to San Diego Alternative												
222													
223	1 Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
224	2 MCS O&M and Emissions Cost	\$ (74,719,907)	\$ (118,032,631)	\$ (121,455,577)	\$ (124,977,789)	\$ (128,602,145)	\$ (132,331,607)	\$ (136,169,223)	\$ (140,118,131)	\$ (144,181,557)	\$ (148,362,822)	\$ (152,665,344)	\$ (157,092,638)
225	3 Total Avoided Costs	\$ (175,005,390)	\$ (118,032,631)	\$ (121,455,577)	\$ (124,977,789)	\$ (128,602,145)	\$ (132,331,607)	\$ (136,169,223)	\$ (140,118,131)	\$ (144,181,557)	\$ (148,362,822)	\$ (152,665,344)	\$ (157,092,638)
226													
227													
228	4 Annual O&M Cost	\$ 10,434,660	\$ 16,483,296	\$ 16,961,311	\$ 17,453,189	\$ 17,959,332	\$ 18,480,153	\$ 19,016,077	\$ 19,567,543	\$ 20,136,002	\$ 20,718,917	\$ 21,319,766	\$ 21,938,039
229	5 Pipping to Occur	N/A	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE
230	6 TIMP Cost	\$ 2,253,804	\$ -	\$ -	\$ -	\$ 32,881,509	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
231	7 Total O&M Costs	\$ 12,688,464	\$ 16,483,296	\$ 16,961,311	\$ 17,453,189	\$ 50,840,840	\$ 18,480,153	\$ 19,016,077	\$ 19,567,543	\$ 20,135,002	\$ 20,718,917	\$ 21,319,766	\$ 21,938,039
232													
233	K Second Pipeline Along Line 3010												
234													
235													
236	1 Future L1600 Replacement Cost	\$ (100,285,483)	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
237	2 MCS O&M and Emissions Cost	\$ (71,330,165)	\$ (118,032,631)	\$ (121,455,577)	\$ (124,977,789)	\$ (128,602,145)	\$ (132,331,607)	\$ (136,169,223)	\$ (140,118,131)	\$ (144,181,557)	\$ (148,362,822)	\$ (152,665,344)	\$ (157,092,638)
238	3 Total Avoided Costs	\$ (171,615,648)	\$ (118,032,631)	\$ (121,455,577)	\$ (124,977,789)	\$ (128,602,145)	\$ (132,331,607)	\$ (136,169,223)	\$ (140,118,131)	\$ (144,181,557)	\$ (148,362,822)	\$ (152,665,344)	\$ (157,092,638)
239													
240													
241	4 Annual O&M Cost	\$ 2,799,858	\$ 4,633,028	\$ 4,767,386	\$ 4,905,640	\$ 5,047,903	\$ 5,194,293	\$ 5,344,927	\$ 5,499,930	\$ 5,659,428	\$ 5,823,551	\$ 5,992,434	\$ 6,166,215
242	5 Pipping to Occur	N/A	FALSE	FALSE	FALSE	FALSE	TRUE	FALSE	FALSE	FALSE	FALSE	FALSE	FALSE
243	6 TIMP Cost	\$ 717,186	\$ -	\$ -	\$ -	\$ -	\$ 11,278,367	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
244	7 Total O&M Costs	\$ 3,517,044	\$ 4,633,028	\$ 4,767,386	\$ 4,905,640	\$ 5,047,903	\$ 16,472,650	\$ 5,344,927	\$ 5,499,930	\$ 5,659,428	\$ 5,823,551	\$ 5,992,434	\$ 6,166,215

WORK PAPER TABLE - AVOIDED COST MODEL OUTPUTS (AC 1.3)
 TOTAL O&M COSTS, TOTAL AVOIDED COSTS, AND NET COSTS BY PROJECT ALTERNATE **OVER 100 YRS**
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

		A		B		C		D		E = (B+C+D)		F		G		H = (F+G)		I = (A+E+H)	
Alt. No.	Project Name	Fixed Cost	Total O&M			Avoided Cost			Net Cost	Fixed Cost (\$M) ¹	Total O&M (\$M)			Avoided Cost (\$M)			Total Avoided Cost (\$M)	Net Cost (\$M)	
			Gas Import	O&M	TIMP	L1600 Replacement	MCS O&M and Emissions	Gas Import			O&M	TIMP	L1600 Replacement	MCS O&M and Emissions					
5	A Proposed Project (Line 3602	\$441.9 M	\$ 0 M	\$3.7 M	\$ 9 M	-\$100.3 M	-\$90.0 M	\$256.2 M	\$441.9 M	\$0.0	\$3.7	\$0.9	\$4.6	(\$100.3)	(\$90.0)	(\$190.3)	\$256.2		
6	B Hydrotest Alternative (Line 1600	\$112.9 M	\$ 0 M	\$4.2 M	\$1.6 M	\$ 0 M	\$ 0 M	\$118.7 M	\$112.9 M	\$0.0	\$4.2	\$1.6	\$5.8	\$0.0	\$0.0	\$0.0	\$118.7		
7	C1 All Diameter Pipeline 10	\$297.6 M	\$100.8 M	\$3.7 M	\$ 9 M	-\$100.3 M	\$ 0 M	\$302.7 M	\$297.6 M	\$100.8	\$3.7	\$0.9	\$105.3	(\$100.3)	\$0.0	(\$100.3)	\$302.7		
8	C2 All Diameter Pipeline 12	\$320.1 M	\$67.2 M	\$3.7 M	\$ 9 M	-\$100.3 M	\$ 0 M	\$291.6 M	\$320.1 M	\$67.2	\$3.7	\$0.9	\$71.8	(\$100.3)	\$0.0	(\$100.3)	\$291.6		
9	C3 All Diameter Pipeline 16	\$337.1 M	\$ 0 M	\$3.7 M	\$ 9 M	-\$100.3 M	\$ 0 M	\$241.4 M	\$337.1 M	\$0.0	\$3.7	\$0.9	\$4.6	(\$100.3)	\$0.0	(\$100.3)	\$241.4		
10	C4 All Diameter Pipeline 20	\$352.9 M	\$ 0 M	\$3.7 M	\$ 9 M	-\$100.3 M	-\$18.0 M	\$239.2 M	\$352.9 M	\$0.0	\$3.7	\$0.9	\$4.6	(\$100.3)	(\$18.0)	(\$118.3)	\$239.2		
11	C5 All Diameter Pipeline 24	\$361.2 M	\$ 0 M	\$3.7 M	\$ 9 M	-\$100.3 M	-\$36.0 M	\$229.6 M	\$361.2 M	\$0.0	\$3.7	\$0.9	\$4.6	(\$100.3)	(\$36.0)	(\$136.3)	\$229.6		
12	C6 All Diameter Pipeline 30	\$392.2 M	\$ 0 M	\$3.7 M	\$ 9 M	-\$100.3 M	-\$63.0 M	\$233.5 M	\$392.2 M	\$0.0	\$3.7	\$0.9	\$4.6	(\$100.3)	(\$63.0)	(\$163.3)	\$233.5		
13	C7 All Diameter Pipeline 42	\$527.5 M	\$ 0 M	\$3.7 M	\$ 9 M	-\$100.3 M	-\$90.0 M	\$341.9 M	\$527.5 M	\$0.0	\$3.7	\$0.9	\$4.6	(\$100.3)	(\$90.0)	(\$190.3)	\$341.9		
14	D Replace Line 1600 In-Place	\$556.1 M	\$ 0 M	\$3.6 M	\$ 7 M	-\$100.3 M	\$ 0 M	\$460.1 M	\$556.1 M	\$0.0	\$3.6	\$0.7	\$4.4	(\$100.3)	\$0.0	(\$100.3)	\$460.1		
15	E/F Otay Mesa Alternative	\$977.1 M	\$ 0 M	\$ 0 M	\$ 0 M	-\$100.3 M	\$ 0 M	\$876.8 M	\$977.1 M	\$0.0	\$0.0	\$0.0	\$0.0	(\$100.3)	\$0.0	(\$100.3)	\$876.8		
16	G LNG Storage (Peak-Shaver) Alternative	\$2669.7 M	\$ 0 M	\$15.3 M	\$ 0 M	-\$100.3 M	\$ 0 M	\$2584.7 M	\$2669.7 M	\$0.0	\$15.3	\$0.0	\$15.3	(\$100.3)	\$0.0	(\$100.3)	\$2,584.7		
17	H1 Alternate Energy Alternative: Grid-Scale Batterie	\$8415.1 M	\$ 0 M	\$15.3 M	\$ 0 M	-\$100.3 M	\$ 0 M	\$8330.1 M	\$8415.1 M	\$0.0	\$15.3	\$0.0	\$15.3	(\$100.3)	\$0.0	(\$100.3)	\$8,330.1		
18	H2 Alternate Energy Alternative: Small-Scale Batterie	\$10095.1 M	\$ 0 M	\$15.3 M	\$ 0 M	-\$100.3 M	\$ 0 M	\$10010.1 M	\$10095.1 M	\$0.0	\$15.3	\$0.0	\$15.3	(\$100.3)	\$0.0	(\$100.3)	\$10,010.1		
19	I Offshore Route Alternative	\$1449.9 M	\$ 0 M	\$4.5 M	\$ 6 M	-\$100.3 M	-\$59.2 M	\$1295.5 M	\$1,449.9 M	\$0.0	\$4.5	\$0.6	\$5.1	(\$100.3)	(\$59.2)	(\$159.5)	\$1,295.5		
20	J1 Blythe to Santee Alternative	\$1377.5 M	\$ 0 M	\$14.5 M	\$2.3 M	-\$100.3 M	-\$74.7 M	\$1219.3 M	\$1,377.5 M	\$0.0	\$14.5	\$2.3	\$16.7	(\$100.3)	(\$74.7)	(\$175.0)	\$1,219.3		
21	J2 Blythe to Santee Alternative	\$1315.5 M	\$ 0 M	\$14.5 M	\$2.3 M	-\$100.3 M	-\$74.7 M	\$1157.3 M	\$1,315.5 M	\$0.0	\$14.5	\$2.3	\$16.8	(\$100.3)	(\$74.7)	(\$175.0)	\$1,157.3		
22	J3 Cactus City to San Diego Alternative	\$1143.4 M	\$ 0 M	\$10.4 M	\$2.3 M	-\$100.3 M	-\$74.7 M	\$981.1 M	\$1,143.4 M	\$0.0	\$10.4	\$2.3	\$12.7	(\$100.3)	(\$74.7)	(\$175.0)	\$981.1		
23	K Second Pipeline Along Line 3010 Alternative	\$595.2 M	\$ 0 M	\$2.8 M	\$ 7 M	-\$100.3 M	-\$71.3 M	\$427.1 M	\$595.2 M	\$0.0	\$2.8	\$0.7	\$3.5	(\$100.3)	(\$71.3)	(\$171.6)	\$427.1		

Footnotes

1. See Prepared Direct Testimony of Neil Navin (March 21, 2016), page 31, workpaper Estimated Fixed and Operating Costs for Proposed Project and Alternates

A.15-09-013 Cost-Effectiveness Analysis
Workpaper - Scenario Analysis
corrected February 2017

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1)
 EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
 CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

		1. Example Summer Low- EG Day MMcfd	2. Example Summer High EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	D	E	F	G	H

Model Inputs

Natural Gas Demand (MMcfd)							
Core Demand		100	100	310	350	170	180
Electric Generation (EG) Demand		100	300	165	165	220	270
Non-Core, Non-EG Demand		75	75	62	62	75	75
Total Demand		275	475	537	577	465	525

Natural Gas Supply Combinations (MMcfd)							
Project Alternatives Capacity (MMcfd)							
Line 1600 (Pre/Post Hydrotesting)		150	150	150	150	150	150
Line 1600 (During Hydrotesting)		0	0	0	0	0	0
Line 3602 (Proposed Project)		680	680	680	680	680	680
Alternate Diameter Pipeline 10"		50	50	50	50	50	50
Alternate Diameter Pipeline 12"		70	70	70	70	70	70
Alternate Diameter Pipeline 16"		160	160	160	160	160	160
Alternate Diameter Pipeline 20"		250	250	250	250	250	250
Alternate Diameter Pipeline 24"		400	400	400	400	400	400
Alternate Diameter Pipeline 30"		600	600	600	600	600	600
Alternate Diameter Pipeline 42"		710	710	710	710	710	710
L1600 In-Kind Replacement		160	160	160	160	160	160
Otay Mesa Alternate		0	0	0	0	0	0
LNG Storage Alternate		0	0	0	0	0	0
Alt Energy Alternate (Grid-Scale)		0	0	0	0	0	0
Alt Energy Alternate (Smaller-Scale)		0	0	0	0	0	0
Offshore Route		680	680	680	680	680	680
Blythe to Santee Alternate 1		680	680	680	680	680	680
Blythe to Santee Alternate 2		680	680	680	680	680	680
Cactus City to San Diego Alternate		680	680	680	680	680	680
Second Pipeline Along L3010 Alternate		680	680	680	680	680	680
Line 3010 Parameters (MMcfd)							
Line 3010 Complete Outage		0	0	0	0	0	0
Line 3010 at 80% Supply		380	380	380	380	380	380
Otay Mesa Supply Variables (MMcfd)							
Otay Mesa Full Supply		295	86	313	313	329	324
Otay Mesa Medium Supply		156	60	230	230	244	247
Otay Mesa Low Supply		33	33	148	148	130	168
Otay Mesa No Supply		0	0	0	0	0	0

Notes:

1. Conversion rate from MMcfd NG to MWh Electric (consistent with LNG Storage Facility Alternative Cost Analysis prepared by SDG&E/SoCalGas):
 Using approx. 7,600 btu/kWh and 1,025,000 btu per 1,000 cubic feet of natural gas, 1 MW = 7,415 cf of natural gas per hour
 Heat rate of approx. 7,600 btu/kWh is based on data obtained from the U.S. Energy Information Administration website
 (<https://www.eia.gov/tools/faqs/faq.cfm?id=667&t=6>).

MMcfd	1	CF	7,415	1,000,000
MMBTU	1025	BTU	7,600,375	1,025,000,000
MWh	135	MWh	1.00	134.87

2. Count of Total SDG&E Gas Core Customers (source: SDG&E Gas Engineering Department)
 Count (#) 868,838

3. NG demand provided by customer class, and pipeline capacities provided for operation during outage on L3010 (source: SoCalGas / SDG&E Gas Transmission Planning Department)

4. Otay Mesa supply provided over various seasonal conditions (source: SoCalGas / SDG&E Gas Transmission Planning Department)

5. Curtailment sequences are based on SDG&E's Rule 14, as defined in the Prepare Direct Testimony of Ms. Gwen Marelli (March 21, 2016), page 2
 First to be curtailed: Non-Core, Non-EG (Referenced as Customer Class Non-Core in SDG&E Rule 14, 2007)

Second to be curtailed: Electric Generation (EG) (Referenced as Customer Class P2-A in SDG&E Rule 14, 2007)

Last to be curtailed: Core Customers (Referenced as Customer Class P1 in SDG&E Rule 14, 2007)

6. Line 25

The Otay Mesa Alternate strives to achieve a firm supply of 400 MMcfd, but for the purposes of this analysis, the supply is assumed to be variable as is consistent with the Prepared Direct Testimony of Ms. Gwen Marelli (March 21, 2016)

7. Line 26

LNG Storage Alternate supply is zero (0) as it will provide gas supply to electric generation sites only and not into the gas network

8. Line 27

Alt Energy Alternate (Grid-Scale) supply is zero (0) as will not provide additional supply to the gas network

9. Line 28

Alt Energy Alternate (Small-Scale) supply is zero (0) as will not provide additional supply to the gas network

10. Line 38 - Column D

Otay Mesa Full Supply determined as Summer minimum OAC on Gasoducto Rosarito + 1 Standard Deviation of data set

11. Line 40 - Column D

Otay Mesa Low Supply determined as Summer minimum OAC on Gasoducto Rosarito

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

		1. Example Summer Low- EG Day MMcfd	2. Example Summer High EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	D	E	F	G	H

Dynamic Model Outputs (For Use in Working Model Only)

Select Parameters Below

77	Line 1600 (Pre/Post Hydrotesting)	150	150	150	150	150	150
78	Line 3010 Complete Outage	0	0	0	0	0	0
79	Otay Mesa Full Supply	295	86	313	313	329	324
80	Total Supply	445	236	463	463	479	474
81	Total MMcfd Shortfall	0	239	74	114	0	51
82	Immediate Curtailment to EG Stations?	No	Yes	Yes	Yes	No	No
83	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%
84		Gas EG [%]	0%	55%	7%	32%	0%
85		Gas Non-Core Non-EG [%]	0%	100%	100%	100%	0%
86	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0
87		Gas EG [MWh/d]	0	22,091	1,647	7,042	0
88		Gas EG [MW]	0	920	69	293	0
89		Gas Non-Core Non-EG [MMcfd]	0	75	62	62	51
90	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0
91		Gas EG [# Affected]	0	N/A	N/A	N/A	0
92		Gas Non-Core Non-EG [# Affected]	0	N/A	N/A	N/A	0

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

		1. Example Summer Low- EG Day MMcfd	2. Example Summer High- EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	D	E	F	G	H

Line 1600 (Pre/Post Hydrotesting)

L1600 / Otay Full / L3010 80%		1.1.1.1	1.1.1.2	1.1.1.3	1.1.1.4	1.1.1.5	1.1.1.6
Line 1600 (Pre/Post Hydrotesting)		150	150	150	150	150	150
Line 3010 at 80% Supply		380	380	380	380	380	380
Otay Mesa Full Supply		295	86	313	313	329	324
Total Supply		825	616	843	843	859	854
Total MMcfd Shortfall		0	0	0	0	0	0
Immediate Curtailment to EG Stations?		No	No	No	No	No	No
Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
	Gas EG [%]	0%	0%	0%	0%	0%	0%
	Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
	Gas EG [MWh/d]	0	0	0	0	0	0
	Gas EG [MW]	0	0	0	0	0	0
Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
	Gas Core [# Affected]	0	0	0	0	0	0
	Gas EG [# Affected]	0	0	0	0	0	0
	Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0

L1600 / Otay Full / L3010 Out		1.2.1.1	1.2.1.2	1.2.1.3	1.2.1.4	1.2.1.5	1.2.1.6
Line 1600 (Pre/Post Hydrotesting)		150	150	150	150	150	150
Line 3010 Complete Outage		0	0	0	0	0	0
Otay Mesa Full Supply		295	86	313	313	329	324
Total Supply		445	236	463	463	479	474
Total MMcfd Shortfall		0	239	74	114	0	51
Immediate Curtailment to EG Stations?		No	Yes	Yes	Yes	No	No
Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
	Gas EG [%]	0%	55%	7%	32%	0%	0%
	Gas Non-Core Non-EG [%]	0%	100%	100%	100%	0%	68%
Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
	Gas EG [MWh/d]	0	22,091	1,647	7,042	0	0
	Gas EG [MW]	0	920	69	293	0	0
Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	75	62	62	0	51
	Gas Core [# Affected]	0	0	0	0	0	0
	Gas EG [# Affected]	0	N/A	N/A	N/A	0	0
	Gas Non-Core Non-EG [# Affected]	0	N/A	N/A	N/A	0	N/A

L1600 / Otay Medium / L3010 80%		1.1.2.1	1.1.2.2	1.1.2.3	1.1.2.4	1.1.2.5	1.1.2.6
Line 1600 (Pre/Post Hydrotesting)		150	150	150	150	150	150
Line 3010 at 80% Supply		380	380	380	380	380	380
Otay Mesa Medium Supply		156	60	230	230	244	247
Total Supply		686	590	760	760	774	777
Total MMcfd Shortfall		0	0	0	0	0	0
Immediate Curtailment to EG Stations?		No	No	No	No	No	No
Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
	Gas EG [%]	0%	0%	0%	0%	0%	0%
	Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
	Gas EG [MWh/d]	0	0	0	0	0	0
	Gas EG [MW]	0	0	0	0	0	0
Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
	Gas Core [# Affected]	0	0	0	0	0	0
	Gas EG [# Affected]	0	0	0	0	0	0
	Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0

L1600 / Otay Medium / L3010 Out		1.2.2.1	1.2.2.2	1.2.2.3	1.2.2.4	1.2.2.5	1.2.2.6
Line 1600 (Pre/Post Hydrotesting)		150	150	150	150	150	150
Line 3010 Complete Outage		0	0	0	0	0	0
Otay Mesa Medium Supply		156	60	230	230	244	247
Total Supply		306	210	380	380	394	397
Total MMcfd Shortfall		0	265	157	197	71	128
Immediate Curtailment to EG Stations?		No	Yes	Yes	Yes	No	Yes
Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
	Gas EG [%]	0%	63%	58%	82%	0%	20%
	Gas Non-Core Non-EG [%]	0%	100%	100%	100%	94%	100%
Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
	Gas EG [MWh/d]	0	25,658	12,824	18,219	0	7,125
	Gas EG [MW]	0	1,069	534	759	0	297
Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	75	62	62	71	75
	Gas Core [# Affected]	0	0	0	0	0	0
	Gas EG [# Affected]	0	N/A	N/A	N/A	0	N/A
	Gas Non-Core Non-EG [# Affected]	0	N/A	N/A	N/A	N/A	N/A

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low- EG Day MMcfd	2. Example Summer High EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	E	F	G	H
1							
2							
167							
168	L1600 / Otay Low / L3010 80%						
169		1.1.3.1	1.1.3.2	1.1.3.3	1.1.3.4	1.1.3.5	1.1.3.6
170	Line 1600 (Pre/Post Hydrotesting)	150	150	150	150	150	150
171	Line 3010 at 80% Supply	380	380	380	380	380	380
172	Otay Mesa Low Supply	33	33	148	148	130	168
173	Total Supply	563	563	678	678	660	698
174	Total MMcfd Shortfall	0	0	0	0	0	0
175	Immediate Curtailment to EG Stations?	No	No	No	No	No	No
176	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%
177		Gas EG [%]	0%	0%	0%	0%	0%
178		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%
179	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0
180		Gas EG [MWh/d]	0	0	0	0	0
181		Gas EG [MW]	0	0	0	0	0
182	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0
183		Gas Core [# Affected]	0	0	0	0	0
184		Gas EG [# Affected]	0	0	0	0	0
185	Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
186							
187	L1600 / Otay Low / L3010 Out						
188		1.2.3.1	1.2.3.2	1.2.3.3	1.2.3.4	1.2.3.5	1.2.3.6
189	Line 1600 (Pre/Post Hydrotesting)	150	150	150	150	150	150
190	Line 3010 Complete Outage	0	0	0	0	0	0
191	Otay Mesa Low Supply	33	33	148	148	130	168
192	Total Supply	183	183	298	298	280	318
193	Total MMcfd Shortfall	92	292	239	279	185	207
194	Immediate Curtailment to EG Stations?	Yes	Yes	Yes	Yes	Yes	Yes
195	Curtailment (%)	Gas Core [%]	0%	0%	4%	15%	0%
196		Gas EG [%]	17%	72%	100%	100%	50%
197		Gas Non-Core Non-EG [%]	100%	100%	100%	100%	100%
198	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	12	52	0
199		Gas EG [MWh/d]	2,251	29,225	22,253	22,253	14,822
200		Gas EG [MW]	94	1,218	927	927	618
201	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	75	75	62	62	75
202		Gas Core [# Affected]	0	0	33,352	128,836	0
203		Gas EG [# Affected]	N/A	N/A	N/A	N/A	N/A
204	Gas Non-Core Non-EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A
205							
206	L1600 / Otay Out / L3010 80%						
207		1.1.4.1	1.1.4.2	1.1.4.3	1.1.4.4	1.1.4.5	1.1.4.6
208	Line 1600 (Pre/Post Hydrotesting)	150	150	150	150	150	150
209	Line 3010 at 80% Supply	380	380	380	380	380	380
210	Otay Mesa No Supply	0	0	0	0	0	0
211	Total Supply	530	530	530	530	530	530
212	Total MMcfd Shortfall	0	0	7	47	0	0
213	Immediate Curtailment to EG Stations?	No	No	No	No	No	No
214	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%
215		Gas EG [%]	0%	0%	0%	0%	0%
216		Gas Non-Core Non-EG [%]	0%	0%	11%	76%	0%
217	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0
218		Gas EG [MWh/d]	0	0	0	0	0
219		Gas EG [MW]	0	0	0	0	0
220	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	7	47	0
221		Gas Core [# Affected]	0	0	0	0	0
222		Gas EG [# Affected]	0	0	0	0	0
223	Gas Non-Core Non-EG [# Affected]	0	0	N/A	N/A	0	0
224							
225	L1600 / Otay Out / L3010 Out						
226		1.2.4.1	1.2.4.2	1.2.4.3	1.2.4.4	1.2.4.5	1.2.4.6
227	Line 1600 (Pre/Post Hydrotesting)	150	150	150	150	150	150
228	Line 3010 Complete Outage	0	0	0	0	0	0
229	Otay Mesa No Supply	0	0	0	0	0	0
230	Total Supply	150	150	150	150	150	150
231	Total MMcfd Shortfall	125	325	387	427	315	375
232	Immediate Curtailment to EG Stations?	Yes	Yes	Yes	Yes	Yes	Yes
233	Curtailment (%)	Gas Core [%]	0%	0%	52%	57%	12%
234		Gas EG [%]	50%	83%	100%	100%	100%
235		Gas Non-Core Non-EG [%]	100%	100%	100%	100%	100%
236	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	160	200	20
237		Gas EG [MWh/d]	6,743	33,717	22,253	22,253	29,671
238		Gas EG [MW]	281	1,405	927	927	1,236
239	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	75	75	62	62	75
240		Gas Core [# Affected]	0	0	448,433	496,479	102,216
241		Gas EG [# Affected]	N/A	N/A	N/A	N/A	N/A
242	Gas Non-Core Non-EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1)
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

		1. Example Summer Low-EG Day MMcfd	2. Example Summer High-EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1-in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	D	E	F	G	H

1

2

239

Line 3602 (Proposed Project)

240

241

L3602 / Otay Full / L3010 80%		2.1.1.1	2.1.1.2	2.1.1.3	2.1.1.4	2.1.1.5	2.1.1.6
242	Line 3602 (Proposed Project)	680	680	680	680	680	680
243	Line 3010 at 80% Supply	380	380	380	380	380	380
244	Otay Mesa Full Supply	295	86	313	313	329	324
245	Total Supply	1355	1146	1373	1373	1389	1384
246	Total MMcfd Shortfall	0	0	0	0	0	0
247	Immediate Curtailment to EG Stations?	No	No	No	No	No	No
248	Curtailment (%)	0%	0%	0%	0%	0%	0%
249	Gas Core [%]	0%	0%	0%	0%	0%	0%
250	Gas EG [%]	0%	0%	0%	0%	0%	0%
251	Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
252	Curtailment (Capacity)	0	0	0	0	0	0
253	Gas Core [MMcfd]	0	0	0	0	0	0
254	Gas EG [MWh/d]	0	0	0	0	0	0
255	Gas EG [MW]	0	0	0	0	0	0
256	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
257	Number of Customers Affected	0	0	0	0	0	0
258	Gas Core [# Affected]	0	0	0	0	0	0
259	Gas EG [# Affected]	0	0	0	0	0	0
260	Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0

259

L3602 / Otay Full / L3010 Out		2.2.1.1	2.2.1.2	2.2.1.3	2.2.1.4	2.2.1.5	2.2.1.6
260	Line 3602 (Proposed Project)	680	680	680	680	680	680
261	Line 3010 Complete Outage	0	0	0	0	0	0
262	Otay Mesa Full Supply	295	86	313	313	329	324
263	Total Supply	975	766	993	993	1009	1004
264	Total MMcfd Shortfall	0	0	0	0	0	0
265	Immediate Curtailment to EG Stations?	No	No	No	No	No	No
266	Curtailment (%)	0%	0%	0%	0%	0%	0%
267	Gas Core [%]	0%	0%	0%	0%	0%	0%
268	Gas EG [%]	0%	0%	0%	0%	0%	0%
269	Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
270	Curtailment (Capacity)	0	0	0	0	0	0
271	Gas Core [MMcfd]	0	0	0	0	0	0
272	Gas EG [MWh/d]	0	0	0	0	0	0
273	Gas EG [MW]	0	0	0	0	0	0
274	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
275	Number of Customers Affected	0	0	0	0	0	0
276	Gas Core [# Affected]	0	0	0	0	0	0
277	Gas EG [# Affected]	0	0	0	0	0	0
278	Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0

277

L3602 / Otay Medium / L3010 80%		2.1.2.1	2.1.2.2	2.1.2.3	2.1.2.4	2.1.2.5	2.1.2.6
278	Line 3602 (Proposed Project)	680	680	680	680	680	680
279	Line 3010 at 80% Supply	380	380	380	380	380	380
280	Otay Mesa Medium Supply	156	60	230	230	244	247
281	Total Supply	1216	1120	1290	1290	1304	1307
282	Total MMcfd Shortfall	0	0	0	0	0	0
283	Immediate Curtailment to EG Stations?	No	No	No	No	No	No
284	Curtailment (%)	0%	0%	0%	0%	0%	0%
285	Gas Core [%]	0%	0%	0%	0%	0%	0%
286	Gas EG [%]	0%	0%	0%	0%	0%	0%
287	Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
288	Curtailment (Capacity)	0	0	0	0	0	0
289	Gas Core [MMcfd]	0	0	0	0	0	0
290	Gas EG [MWh/d]	0	0	0	0	0	0
291	Gas EG [MW]	0	0	0	0	0	0
292	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
293	Number of Customers Affected	0	0	0	0	0	0
294	Gas Core [# Affected]	0	0	0	0	0	0
295	Gas EG [# Affected]	0	0	0	0	0	0
296	Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0

295

L3602 / Otay Medium / L3010 Out		2.2.2.1	2.2.2.2	2.2.2.3	2.2.2.4	2.2.2.5	2.2.2.6
296	Line 3602 (Proposed Project)	680	680	680	680	680	680
297	Line 3010 Complete Outage	0	0	0	0	0	0
298	Otay Mesa Medium Supply	156	60	230	230	244	247
299	Total Supply	836	740	910	910	924	927
300	Total MMcfd Shortfall	0	0	0	0	0	0
301	Immediate Curtailment to EG Stations?	No	No	No	No	No	No
302	Curtailment (%)	0%	0%	0%	0%	0%	0%
303	Gas Core [%]	0%	0%	0%	0%	0%	0%
304	Gas EG [%]	0%	0%	0%	0%	0%	0%
305	Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
306	Curtailment (Capacity)	0	0	0	0	0	0
307	Gas Core [MMcfd]	0	0	0	0	0	0
308	Gas EG [MWh/d]	0	0	0	0	0	0
309	Gas EG [MW]	0	0	0	0	0	0
310	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
311	Number of Customers Affected	0	0	0	0	0	0
312	Gas Core [# Affected]	0	0	0	0	0	0
	Gas EG [# Affected]	0	0	0	0	0	0
	Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.		1. Example Summer Low- EG Day MMcfd	2. Example Summer High EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	D	E	F	G	H
1								
2								
313								
314	L3602 / Otay Low / L3010 80%		2.1.3.1	2.1.3.2	2.1.3.3	2.1.3.4	2.1.3.5	2.1.3.6
315	Line 3602 (Proposed Project)		680	680	680	680	680	680
316	Line 3010 at 80% Supply		380	380	380	380	380	380
317	Otay Mesa Low Supply		33	33	148	148	130	168
318	Total Supply		1093	1093	1208	1208	1190	1228
319	Total MMcfd Shortfall		0	0	0	0	0	0
320	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
321	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
322		Gas EG [%]	0%	0%	0%	0%	0%	0%
323		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
324	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
325		Gas EG [MWh/d]	0	0	0	0	0	0
326		Gas EG [MW]	0	0	0	0	0	0
327		Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
328	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	0
329		Gas EG [# Affected]	0	0	0	0	0	0
330		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
331								
332	L3602 / Otay Low / L3010 Out		2.2.3.1	2.2.3.2	2.2.3.3	2.2.3.4	2.2.3.5	2.2.3.6
333	Line 3602 (Proposed Project)		680	680	680	680	680	680
334	Line 3010 Complete Outage		0	0	0	0	0	0
335	Otay Mesa Low Supply		33	33	148	148	130	168
336	Total Supply		713	713	828	828	810	848
337	Total MMcfd Shortfall		0	0	0	0	0	0
338	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
339	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
340		Gas EG [%]	0%	0%	0%	0%	0%	0%
341		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
342	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
343		Gas EG [MWh/d]	0	0	0	0	0	0
344		Gas EG [MW]	0	0	0	0	0	0
345		Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
346	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	0
347		Gas EG [# Affected]	0	0	0	0	0	0
348		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
349								
350	L3602 / Otay Out / L3010 80%		2.1.4.1	2.1.4.2	2.1.4.3	2.1.4.4	2.1.4.5	2.1.4.6
351	Line 3602 (Proposed Project)		680	680	680	680	680	680
352	Line 3010 at 80% Supply		380	380	380	380	380	380
353	Otay Mesa No Supply		0	0	0	0	0	0
354	Total Supply		1060	1060	1060	1060	1060	1060
355	Total MMcfd Shortfall		0	0	0	0	0	0
356	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
357	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
358		Gas EG [%]	0%	0%	0%	0%	0%	0%
359		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
360	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
361		Gas EG [MWh/d]	0	0	0	0	0	0
362		Gas EG [MW]	0	0	0	0	0	0
363		Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
364	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	0
365		Gas EG [# Affected]	0	0	0	0	0	0
366		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
367								
368	L3602 / Otay Out / L3010 Out		2.2.4.1	2.2.4.2	2.2.4.3	2.2.4.4	2.2.4.5	2.2.4.6
369	Line 3602 (Proposed Project)		680	680	680	680	680	680
370	Line 3010 Complete Outage		0	0	0	0	0	0
371	Otay Mesa No Supply		0	0	0	0	0	0
372	Total Supply		680	680	680	680	680	680
373	Total MMcfd Shortfall		0	0	0	0	0	0
374	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
375	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
376		Gas EG [%]	0%	0%	0%	0%	0%	0%
377		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
378	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
379		Gas EG [MWh/d]	0	0	0	0	0	0
380		Gas EG [MW]	0	0	0	0	0	0
381		Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
382	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	0
383		Gas EG [# Affected]	0	0	0	0	0	0
384		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low- EG Day MMcfd	2. Example Summer High EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd		
	A	B	C	D	E	F	G	H

1

2

385

386

387

Line 1600 (During Hydrotesting)

388

Hydrotesting / Otay Full / L3010 80%		3.1.1.1	3.1.1.2	3.1.1.3	3.1.1.4	3.1.1.5	3.1.1.6
Line 1600 (During Hydrotesting)		0	0	0	0	0	0
Line 3010 at 80% Supply		380	380	380	380	380	380
Otay Mesa Full Supply		295	86	313	313	329	324
Total Supply		675	466	693	693	709	704
Total MMcfd Shortfall		0	9	0	0	0	0
Immediate Curtailment to EG Stations?		No	No	No	No	No	No
Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
	Gas EG [%]	0%	0%	0%	0%	0%	0%
	Gas Non-Core Non-EG [%]	0%	12%	0%	0%	0%	0%
Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
	Gas EG [MWh/d]	0	0	0	0	0	0
	Gas EG [MW]	0	0	0	0	0	0
	Gas Non-Core Non-EG [MMcfd]	0	9	0	0	0	0
Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	0
	Gas EG [# Affected]	0	0	0	0	0	0
	Gas Non-Core Non-EG [# Affected]	0	N/A	0	0	0	0

405

406

Hydrotesting / Otay Full / L3010 Out		3.2.1.1	3.2.1.2	3.2.1.3	3.2.1.4	3.2.1.5	3.2.1.6
Line 1600 (During Hydrotesting)		0	0	0	0	0	0
Line 3010 Complete Outage		0	0	0	0	0	0
Otay Mesa Full Supply		295	86	313	313	329	324
Total Supply		295	86	313	313	329	324
Total MMcfd Shortfall		0	389	224	264	136	201
Immediate Curtailment to EG Stations?		No	Yes	Yes	Yes	Yes	Yes
Curtailment (%)	Gas Core [%]	0%	14%	0%	11%	0%	0%
	Gas EG [%]	0%	100%	98%	100%	28%	47%
	Gas Non-Core Non-EG [%]	0%	100%	100%	100%	100%	100%
Curtailment (Capacity)	Gas Core [MMcfd]	0	14	0	37	0	0
	Gas EG [MWh/d]	0	40,461	21,877	22,253	8,240	17,039
	Gas EG [MW]	0	1,686	912	927	343	710
	Gas Non-Core Non-EG [MMcfd]	0	75	62	62	75	75
Number of Customers Affected	Gas Core [# Affected]	0	119,839	0	92,375	0	0
	Gas EG [# Affected]	0	N/A	N/A	N/A	N/A	N/A
	Gas Non-Core Non-EG [# Affected]	0	N/A	N/A	N/A	N/A	N/A

423

424

Hydrotesting / Otay Medium / L3010 80%		3.1.2.1	3.1.2.2	3.1.2.3	3.1.2.4	3.1.2.5	3.1.2.6
Line 1600 (During Hydrotesting)		0	0	0	0	0	0
Line 3010 at 80% Supply		380	380	380	380	380	380
Otay Mesa Medium Supply		156	60	230	230	244	247
Total Supply		536	440	610	610	624	627
Total MMcfd Shortfall		0	35	0	0	0	0
Immediate Curtailment to EG Stations?		No	No	No	No	No	No
Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
	Gas EG [%]	0%	0%	0%	0%	0%	0%
	Gas Non-Core Non-EG [%]	0%	47%	0%	0%	0%	0%
Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
	Gas EG [MWh/d]	0	0	0	0	0	0
	Gas EG [MW]	0	0	0	0	0	0
	Gas Non-Core Non-EG [MMcfd]	0	35	0	0	0	0
Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	0
	Gas EG [# Affected]	0	0	0	0	0	0
	Gas Non-Core Non-EG [# Affected]	0	N/A	0	0	0	0

441

442

Hydrotesting / Otay Medium / L3010 Out		3.2.2.1	3.2.2.2	3.2.2.3	3.2.2.4	3.2.2.5	3.2.2.6
Line 1600 (During Hydrotesting)		0	0	0	0	0	0
Line 3010 Complete Outage		0	0	0	0	0	0
Otay Mesa Medium Supply		156	60	230	230	244	247
Total Supply		156	60	230	230	244	247
Total MMcfd Shortfall		119	415	307	347	221	278
Immediate Curtailment to EG Stations?		Yes	Yes	Yes	Yes	Yes	Yes
Curtailment (%)	Gas Core [%]	0%	40%	26%	34%	0%	0%
	Gas EG [%]	44%	100%	100%	100%	66%	75%
	Gas Non-Core Non-EG [%]	100%	100%	100%	100%	100%	100%
Curtailment (Capacity)	Gas Core [MMcfd]	0	40	80	120	0	0
	Gas EG [MWh/d]	5,978	40,461	22,253	22,253	19,672	27,355
	Gas EG [MW]	249	1,686	927	927	820	1,140
	Gas Non-Core Non-EG [MMcfd]	75	75	62	62	75	75
Number of Customers Affected	Gas Core [# Affected]	0	349,638	224,454	298,098	0	0
	Gas EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A
	Gas Non-Core Non-EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A

458

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low- EG Day MMcfd	2. Example Summer High EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd		
	A	B	C	E	F	G	H	
1								
2								
459								
460	Hydrotesting / Otay Low / L3010 80%		3.1.3.1	3.1.3.2	3.1.3.3	3.1.3.4	3.1.3.5	3.1.3.6
461	Line 1600 (During Hydrotesting)	0	0	0	0	0	0	
462	Line 3010 at 80% Supply	380	380	380	380	380	380	
463	Otay Mesa Low Supply	33	33	148	148	130	168	
464	Total Supply	413	413	528	528	510	548	
465	Total MMcfd Shortfall	0	62	9	49	0	0	
466	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	
467	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	
468		Gas EG [%]	0%	0%	0%	0%	0%	
469		Gas Non-Core Non-EG [%]	0%	82%	14%	79%	0%	0%
470	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	
471		Gas EG [MWh/d]	0	0	0	0	0	
472		Gas EG [MW]	0	0	0	0	0	
473	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	62	9	49	0	
474		Gas Core [# Affected]	0	0	0	0	0	
475		Gas EG [# Affected]	0	0	0	0	0	
476	Gas Non-Core Non-EG [# Affected]	0	N/A	N/A	N/A	0	0	
477								
478	Hydrotesting / Otay Low / L3010 Out		3.2.3.1	3.2.3.2	3.2.3.3	3.2.3.4	3.2.3.5	3.2.3.6
479	Line 1600 (During Hydrotesting)	0	0	0	0	0	0	
480	Line 3010 Complete Outage	0	0	0	0	0	0	
481	Otay Mesa Low Supply	33	33	148	148	130	168	
482	Total Supply	33	33	148	148	130	168	
483	Total MMcfd Shortfall	242	442	389	429	335	357	
484	Immediate Curtailment to EG Stations?	Yes	Yes	Yes	Yes	Yes	Yes	
485	Curtailment (%)	Gas Core [%]	67%	67%	52%	58%	23%	7%
486		Gas EG [%]	100%	100%	100%	100%	100%	100%
487		Gas Non-Core Non-EG [%]	100%	100%	100%	100%	100%	100%
488	Curtailment (Capacity)	Gas Core [MMcfd]	67	67	162	202	40	12
489		Gas EG [MWh/d]	13,487	40,461	22,253	22,253	29,671	36,414
490		Gas EG [MW]	562	1,686	927	927	1,236	1,517
491	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	75	75	62	62	75	75
492		Gas Core [# Affected]	579,437	579,437	453,758	501,195	203,921	60,119
493		Gas EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A
494	Gas Non-Core Non-EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A	
495								
496	Hydrotesting / Otay Out / L3010 80%		3.1.4.1	3.1.4.2	3.1.4.3	3.1.4.4	3.1.4.5	3.1.4.6
497	Line 1600 (During Hydrotesting)	0	0	0	0	0	0	
498	Line 3010 at 80% Supply	380	380	380	380	380	380	
499	Otay Mesa No Supply	0	0	0	0	0	0	
500	Total Supply	380	380	380	380	380	380	
501	Total MMcfd Shortfall	0	95	157	197	85	145	
502	Immediate Curtailment to EG Stations?	No	Yes	Yes	Yes	Yes	Yes	
503	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	
504		Gas EG [%]	0%	7%	58%	82%	5%	26%
505		Gas Non-Core Non-EG [%]	0%	100%	100%	100%	100%	100%
506	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	
507		Gas EG [MWh/d]	0	2,697	12,813	18,207	1,349	9,441
508		Gas EG [MW]	0	112	534	759	56	393
509	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	75	62	62	75	75
510		Gas Core [# Affected]	0	0	0	0	0	0
511		Gas EG [# Affected]	0	N/A	N/A	N/A	N/A	N/A
512	Gas Non-Core Non-EG [# Affected]	0	N/A	N/A	N/A	N/A	N/A	
513								
514	Hydrotesting / Otay Out / L3010 Out		3.2.4.1	3.2.4.2	3.2.4.3	3.2.4.4	3.2.4.5	3.2.4.6
515	Line 1600 (During Hydrotesting)	0	0	0	0	0	0	
516	Line 3010 Complete Outage	0	0	0	0	0	0	
517	Otay Mesa No Supply	0	0	0	0	0	0	
518	Total Supply	0	0	0	0	0	0	
519	Total MMcfd Shortfall	275	475	537	577	465	525	
520	Immediate Curtailment to EG Stations?	Yes	Yes	Yes	Yes	Yes	Yes	
521	Curtailment (%)	Gas Core [%]	100%	100%	100%	100%	100%	
522		Gas EG [%]	100%	100%	100%	100%	100%	
523		Gas Non-Core Non-EG [%]	100%	100%	100%	100%	100%	
524	Curtailment (Capacity)	Gas Core [MMcfd]	100	100	310	350	170	180
525		Gas EG [MWh/d]	13,487	40,461	22,253	22,253	29,671	36,414
526		Gas EG [MW]	562	1,686	927	927	1,236	1,517
527	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	75	75	62	62	75	75
528		Gas Core [# Affected]	868,838	868,838	868,838	868,838	868,838	868,838
529		Gas EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A
530	Gas Non-Core Non-EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A	

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low- EG Day MMcfd	2. Example Summer High- EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd		
	A	B	C	D	E	F	G	H

531

Alternate Diameter Pipeline 10"

532

533

Alt Diameter 10" / Otay Full / L3010 80%		4.1.1.1	4.1.1.2	4.1.1.3	4.1.1.4	4.1.1.5	4.1.1.6
Alternate Diameter Pipeline 10"		50	50	50	50	50	50
Line 3010 at 80% Supply		380	380	380	380	380	380
Otay Mesa Full Supply		295	86	313	313	329	324
Total Supply		725	516	743	743	759	754
Total MMcfd Shortfall		0	0	0	0	0	0
Immediate Curtailment to EG Stations?		No	No	No	No	No	No
Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
	Gas EG [%]	0%	0%	0%	0%	0%	0%
	Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
	Gas EG [MWh/d]	0	0	0	0	0	0
	Gas EG [MW]	0	0	0	0	0	0
Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
	Gas Core [# Affected]	0	0	0	0	0	0
	Gas EG [# Affected]	0	0	0	0	0	0
Affected		0	0	0	0	0	0

551

Alt Diameter 10" / Otay Full / L3010 Out		4.2.1.1	4.2.1.2	4.2.1.3	4.2.1.4	4.2.1.5	4.2.1.6
Alternate Diameter Pipeline 10"		50	50	50	50	50	50
Line 3010 Complete Outage		0	0	0	0	0	0
Otay Mesa Full Supply		295	86	313	313	329	324
Total Supply		345	136	363	363	379	374
Total MMcfd Shortfall		0	339	174	214	86	151
Immediate Curtailment to EG Stations?		No	Yes	Yes	Yes	Yes	Yes
Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
	Gas EG [%]	0%	88%	68%	92%	5%	28%
	Gas Non-Core Non-EG [%]	0%	100%	100%	100%	100%	100%
Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
	Gas EG [MWh/d]	0	35,577	15,134	20,529	1,497	10,296
	Gas EG [MW]	0	1,482	631	855	62	429
Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	75	62	62	75	75
	Gas Core [# Affected]	0	0	0	0	0	0
	Gas EG [# Affected]	0	N/A	N/A	N/A	N/A	N/A
Affected		0	N/A	N/A	N/A	N/A	N/A

569

Alt Diameter 10" / Otay Medium / L3010 80%		4.1.2.1	4.1.2.2	4.1.2.3	4.1.2.4	4.1.2.5	4.1.2.6
Alternate Diameter Pipeline 10"		50	50	50	50	50	50
Line 3010 at 80% Supply		380	380	380	380	380	380
Otay Mesa Medium Supply		156	60	230	230	244	247
Total Supply		586	490	660	660	674	677
Total MMcfd Shortfall		0	0	0	0	0	0
Immediate Curtailment to EG Stations?		No	No	No	No	No	No
Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
	Gas EG [%]	0%	0%	0%	0%	0%	0%
	Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
	Gas EG [MWh/d]	0	0	0	0	0	0
	Gas EG [MW]	0	0	0	0	0	0
Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
	Gas Core [# Affected]	0	0	0	0	0	0
	Gas EG [# Affected]	0	0	0	0	0	0
Affected		0	0	0	0	0	0

587

Alt Diameter 10" / Otay Medium / L3010 Out		4.2.2.1	4.2.2.2	4.2.2.3	4.2.2.4	4.2.2.5	4.2.2.6
Alternate Diameter Pipeline 10"		50	50	50	50	50	50
Line 3010 Complete Outage		0	0	0	0	0	0
Otay Mesa Medium Supply		156	60	230	230	244	247
Total Supply		206	110	280	280	294	297
Total MMcfd Shortfall		69	365	257	297	171	228
Immediate Curtailment to EG Stations?		No	Yes	Yes	Yes	Yes	Yes
Curtailment (%)	Gas Core [%]	0%	0%	10%	20%	0%	0%
	Gas EG [%]	0%	97%	100%	100%	44%	57%
	Gas Non-Core Non-EG [%]	92%	100%	100%	100%	100%	100%
Curtailment (Capacity)	Gas Core [MMcfd]	0	0	30	70	0	0
	Gas EG [MWh/d]	0	39,144	22,253	22,253	12,928	20,612
	Gas EG [MW]	0	1,631	927	927	539	859
Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	69	75	62	62	75	75
	Gas Core [# Affected]	0	0	84,319	173,979	0	0
	Gas EG [# Affected]	0	N/A	N/A	N/A	N/A	N/A
Affected		N/A	N/A	N/A	N/A	N/A	N/A

604

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1)
 EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
 CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low- EG Day MMcfd	2. Example Summer High- EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	E	F	G	H
1							
2							
605							
606	Alt Diameter 10" / Otay Low / L3010 80%		4.1.3.1	4.1.3.2	4.1.3.3	4.1.3.4	4.1.3.5
607	Alternate Diameter Pipeline 10"		50	50	50	50	50
608	Line 3010 at 80% Supply		380	380	380	380	380
609	Otay Mesa Low Supply		33	33	148	148	168
610	Total Supply		463	463	578	578	598
611	Total MMcfd Shortfall		0	12	0	0	0
612	Immediate Curtailment to EG Stations?		No	No	No	No	No
613	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%
614		Gas EG [%]	0%	0%	0%	0%	0%
615		Gas Non-Core Non-EG [%]	0%	16%	0%	0%	0%
616	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0
617		Gas EG [MWh/d]	0	0	0	0	0
618		Gas EG [MW]	0	0	0	0	0
619	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	12	0	0	0
620		Gas Core [# Affected]	0	0	0	0	0
621		Gas EG [# Affected]	0	0	0	0	0
622	Gas Non-Core Non-EG [# Affected]		0	N/A	0	0	0
623							
624	Alt Diameter 10" / Otay Low / L3010 Out		4.2.3.1	4.2.3.2	4.2.3.3	4.2.3.4	4.2.3.5
625	Alternate Diameter Pipeline 10"		50	50	50	50	50
626	Line 3010 Complete Outage		0	0	0	0	0
627	Otay Mesa Low Supply		33	33	148	148	168
628	Total Supply		83	83	198	198	218
629	Total MMcfd Shortfall		192	392	339	379	307
630	Immediate Curtailment to EG Stations?		Yes	Yes	Yes	Yes	Yes
631	Curtailment (%)	Gas Core [%]	17%	17%	36%	43%	0%
632		Gas EG [%]	100%	100%	100%	100%	95%
633		Gas Non-Core Non-EG [%]	100%	100%	100%	100%	100%
634	Curtailment (Capacity)	Gas Core [MMcfd]	17	17	112	152	0
635		Gas EG [MWh/d]	13,487	40,461	22,253	22,253	28,309
636		Gas EG [MW]	562	1,686	927	927	1,180
637	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	75	75	62	62	75
638		Gas Core [# Affected]	145,018	145,018	313,622	377,076	0
639		Gas EG [# Affected]	N/A	N/A	N/A	N/A	N/A
640	Gas Non-Core Non-EG [# Affected]		N/A	N/A	N/A	N/A	N/A
641							
642	Alt Diameter 10" / Otay Out / L3010 80%		4.1.4.1	4.1.4.2	4.1.4.3	4.1.4.4	4.1.4.5
643	Alternate Diameter Pipeline 10"		50	50	50	50	50
644	Line 3010 at 80% Supply		380	380	380	380	380
645	Otay Mesa No Supply		0	0	0	0	0
646	Total Supply		430	430	430	430	430
647	Total MMcfd Shortfall		0	45	107	147	95
648	Immediate Curtailment to EG Stations?		No	No	Yes	No	Yes
649	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%
650		Gas EG [%]	0%	0%	27%	52%	7%
651		Gas Non-Core Non-EG [%]	0%	60%	100%	100%	47%
652	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0
653		Gas EG [MWh/d]	0	0	6,069	11,464	0
654		Gas EG [MW]	0	0	253	478	0
655	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	45	62	62	35
656		Gas Core [# Affected]	0	0	0	0	0
657		Gas EG [# Affected]	0	0	N/A	N/A	0
658	Gas Non-Core Non-EG [# Affected]		0	N/A	N/A	N/A	N/A
659							
660	Alt Diameter 10" / Otay Out / L3010 Out		4.2.4.1	4.2.4.2	4.2.4.3	4.2.4.4	4.2.4.5
661	Alternate Diameter Pipeline 10"		50	50	50	50	50
662	Line 3010 Complete Outage		0	0	0	0	0
663	Otay Mesa No Supply		0	0	0	0	0
664	Total Supply		50	50	50	50	50
665	Total MMcfd Shortfall		225	425	487	527	475
666	Immediate Curtailment to EG Stations?		Yes	Yes	Yes	Yes	Yes
667	Curtailment (%)	Gas Core [%]	50%	50%	84%	86%	71%
668		Gas EG [%]	100%	100%	100%	100%	100%
669		Gas Non-Core Non-EG [%]	100%	100%	100%	100%	100%
670	Curtailment (Capacity)	Gas Core [MMcfd]	50	50	260	300	120
671		Gas EG [MWh/d]	13,487	40,461	22,253	22,253	29,671
672		Gas EG [MW]	562	1,686	927	927	1,236
673	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	75	75	62	62	75
674		Gas Core [# Affected]	434,419	434,419	728,703	744,718	613,297
675		Gas EG [# Affected]	N/A	N/A	N/A	N/A	N/A
676	Gas Non-Core Non-EG [# Affected]		N/A	N/A	N/A	N/A	N/A

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low- EG Day MMcfd	2. Example Summer High- EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd		
	A	B	C	D	E	F	G	H

677
678
679
680
681
682
683
684
685
686
687
688
689
690
691
692
693
694
695
696
697
698
699
700
701
702
703
704
705
706
707
708
709
710
711
712
713
714
715
716
717
718
719
720
721
722
723
724
725
726
727
728
729
730
731
732
733
734
735
736
737
738
739
740
741
742
743
744
745
746
747
748
749
750

Alternat Diameter Pipeline 12"		5.1.1.1	5.1.1.2	5.1.1.3	5.1.1.4	5.1.1.5	5.1.1.6
Alternat Diameter Pipeline 12"		70	70	70	70	70	70
Line 3010 at 80% Supply		380	380	380	380	380	380
Otay Mesa Full Supply		295	86	313	313	329	324
Total Supply		745	536	763	763	779	774
Total MMcfd Shortfall		0	0	0	0	0	0
Immediate Curtailment to EG Stations?		No	No	No	No	No	No
Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
	Gas EG [%]	0%	0%	0%	0%	0%	0%
	Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
	Gas EG [MWh/d]	0	0	0	0	0	0
	Gas EG [MW]	0	0	0	0	0	0
Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	0
	Gas EG [# Affected]	0	0	0	0	0	0
	Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
Alt Diameter 12" / Otay Full / L3010 Out		5.2.1.1	5.2.1.2	5.2.1.3	5.2.1.4	5.2.1.5	5.2.1.6
Alternat Diameter Pipeline 12"		70	70	70	70	70	70
Line 3010 Complete Outage		0	0	0	0	0	0
Otay Mesa Full Supply		295	86	313	313	329	324
Total Supply		365	156	383	383	399	394
Total MMcfd Shortfall		0	319	154	194	66	131
Immediate Curtailment to EG Stations?		No	Yes	Yes	Yes	No	Yes
Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
	Gas EG [%]	0%	81%	56%	80%	0%	21%
	Gas Non-Core Non-EG [%]	0%	100%	100%	100%	88%	100%
Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
	Gas EG [MWh/d]	0	32,880	12,436	17,831	0	7,599
	Gas EG [MW]	0	1,370	518	743	0	317
Number of Customers Affected	Gas Core [# Affected]	0	75	62	62	66	75
	Gas EG [# Affected]	0	N/A	N/A	N/A	0	N/A
	Gas Non-Core Non-EG [# Affected]	0	N/A	N/A	N/A	N/A	N/A
Alt Diameter 12" / Otay Medium / L3010 80%		5.1.2.1	5.1.2.2	5.1.2.3	5.1.2.4	5.1.2.5	5.1.2.6
Alternat Diameter Pipeline 12"		70	70	70	70	70	70
Line 3010 at 80% Supply		380	380	380	380	380	380
Otay Mesa Medium Supply		156	60	230	230	244	247
Total Supply		606	510	680	680	694	697
Total MMcfd Shortfall		0	0	0	0	0	0
Immediate Curtailment to EG Stations?		No	No	No	No	No	No
Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
	Gas EG [%]	0%	0%	0%	0%	0%	0%
	Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
	Gas EG [MWh/d]	0	0	0	0	0	0
	Gas EG [MW]	0	0	0	0	0	0
Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	0
	Gas EG [# Affected]	0	0	0	0	0	0
	Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
Alt Diameter 12" / Otay Medium / L3010 Out		5.2.2.1	5.2.2.2	5.2.2.3	5.2.2.4	5.2.2.5	5.2.2.6
Alternat Diameter Pipeline 12"		70	70	70	70	70	70
Line 3010 Complete Outage		0	0	0	0	0	0
Otay Mesa Medium Supply		156	60	230	230	244	247
Total Supply		226	130	300	300	314	317
Total MMcfd Shortfall		49	345	237	277	151	208
Immediate Curtailment to EG Stations?		No	Yes	Yes	Yes	Yes	Yes
Curtailment (%)	Gas Core [%]	0%	0%	3%	14%	0%	0%
	Gas EG [%]	0%	90%	100%	100%	34%	49%
	Gas Non-Core Non-EG [%]	66%	100%	100%	100%	100%	100%
Curtailment (Capacity)	Gas Core [MMcfd]	0	0	10	50	0	0
	Gas EG [MWh/d]	0	36,447	22,253	22,253	10,231	17,915
	Gas EG [MW]	0	1,519	927	927	426	746
Number of Customers Affected	Gas Core [# Affected]	0	75	62	62	75	75
	Gas EG [# Affected]	0	0	28,265	124,331	0	0
	Gas Non-Core Non-EG [# Affected]	0	N/A	N/A	N/A	N/A	N/A

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

Line No.		1. Example Summer Low-EG Day MMcfd	2. Example Summer High-EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1-in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	D	E	F	G	H
751								
752								
753								
754								
755								
756								
757								
758								
759								
760								
761								
762								
763								
764								
765								
766								
767								
768								
769								
770								
771								
772								
773								
774								
775								
776								
777								
778								
779								
780								
781								
782								
783								
784								
785								
786								
787								
788								
789								
790								
791								
792								
793								
794								
795								
796								
797								
798								
799								
800								
801								
802								
803								
804								
805								
806								
807								
808								
809								
810								
811								
812								
813								
814								
815								
816								
817								
818								
819								
820								
821								
822								

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

1		1. Example Summer Low-EG Day MMcf	2. Example Summer High-EG Day MMcf	3. Example Winter Day MMcf	4. Winter 1-in-10 Year Day MMcf	5. Example Spring Day MMcf	6. Example Fall Day MMcf	
2	A	B	C	D	E	F	G	H

Alternate Diameter Pipeline 16"

826	Alt Diameter 16" / Otay Full / L3010 80%		6.1.1.1	6.1.1.2	6.1.1.3	6.1.1.4	6.1.1.5	6.1.1.6
827	Alternate Diameter Pipeline 16"		160	160	160	160	160	160
828	Line 3010 at 80% Supply		380	380	380	380	380	380
829	Otay Mesa Full Supply		295	86	313	313	329	324
830	Total Supply		835	626	853	853	869	864
831	Total MMcf Shortfall		0	0	0	0	0	0
832	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
833	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
834		Gas EG [%]	0%	0%	0%	0%	0%	0%
835		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
836	Curtailment (Capacity)	Gas Core [MMcf]	0	0	0	0	0	0
837		Gas EG [MWh/d]	0	0	0	0	0	0
838		Gas EG [MW]	0	0	0	0	0	0
839		Gas Non-Core Non-EG [MMcf]	0	0	0	0	0	0
840	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	0
841		Gas EG [# Affected]	0	0	0	0	0	0
842		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0

844	Alt Diameter 16" / Otay Full / L3010 Out		6.2.1.1	6.2.1.2	6.2.1.3	6.2.1.4	6.2.1.5	6.2.1.6
845	Alternate Diameter Pipeline 16"		160	160	160	160	160	160
846	Line 3010 Complete Outage		0	0	0	0	0	0
847	Otay Mesa Full Supply		295	86	313	313	329	324
848	Total Supply		455	246	473	473	489	484
849	Total MMcf Shortfall		0	229	64	104	0	41
850	Immediate Curtailment to EG Stations?		No	Yes	Yes	Yes	No	No
851	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
852		Gas EG [%]	0%	51%	1%	26%	0%	0%
853		Gas Non-Core Non-EG [%]	0%	100%	100%	100%	0%	55%
854	Curtailment (Capacity)	Gas Core [MMcf]	0	0	0	0	0	0
855		Gas EG [MWh/d]	0	20,742	298	5,693	0	0
856		Gas EG [MW]	0	864	12	237	0	0
857		Gas Non-Core Non-EG [MMcf]	0	75	62	62	0	41
858	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	0
859		Gas EG [# Affected]	0	N/A	N/A	N/A	0	0
860		Gas Non-Core Non-EG [# Affected]	0	N/A	N/A	N/A	0	N/A

862	Alt Diameter 16" / Otay Medium / L3010 80%		6.1.2.1	6.1.2.2	6.1.2.3	6.1.2.4	6.1.2.5	6.1.2.6
863	Alternate Diameter Pipeline 16"		160	160	160	160	160	160
864	Line 3010 at 80% Supply		380	380	380	380	380	380
865	Otay Mesa Medium Supply		156	60	230	230	244	247
866	Total Supply		696	600	770	770	784	787
867	Total MMcf Shortfall		0	0	0	0	0	0
868	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
869	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
870		Gas EG [%]	0%	0%	0%	0%	0%	0%
871		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
872	Curtailment (Capacity)	Gas Core [MMcf]	0	0	0	0	0	0
873		Gas EG [MWh/d]	0	0	0	0	0	0
874		Gas EG [MW]	0	0	0	0	0	0
875		Gas Non-Core Non-EG [MMcf]	0	0	0	0	0	0
876	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	0
877		Gas EG [# Affected]	0	0	0	0	0	0
878		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0

880	Alt Diameter 16" / Otay Medium / L3010 Out		6.2.2.1	6.2.2.2	6.2.2.3	6.2.2.4	6.2.2.5	6.2.2.6
881	Alternate Diameter Pipeline 16"		160	160	160	160	160	160
882	Line 3010 Complete Outage		0	0	0	0	0	0
883	Otay Mesa Medium Supply		156	60	230	230	244	247
884	Total Supply		316	220	390	390	404	407
885	Total MMcf Shortfall		0	255	147	187	61	118
886	Immediate Curtailment to EG Stations?		No	Yes	Yes	Yes	No	Yes
887	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
888		Gas EG [%]	0%	60%	52%	76%	0%	16%
889		Gas Non-Core Non-EG [%]	0%	100%	100%	100%	81%	100%
890	Curtailment (Capacity)	Gas Core [MMcf]	0	0	0	0	0	0
891		Gas EG [MWh/d]	0	24,309	11,475	16,870	0	5,777
892		Gas EG [MW]	0	1,013	478	703	0	241
893		Gas Non-Core Non-EG [MMcf]	0	75	62	62	61	75
894	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	0
895		Gas EG [# Affected]	0	N/A	N/A	N/A	0	N/A
896		Gas Non-Core Non-EG [# Affected]	0	N/A	N/A	N/A	N/A	N/A

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

1		1. Example Summer Low-EG Day MMcfd	2. Example Summer High-EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1-in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
2	A	B	C	D	E	F	G	H
897								
898	Alt Diameter 16" / Otay Low / L3010 80%		6.1.3.1	6.1.3.2	6.1.3.3	6.1.3.4	6.1.3.5	6.1.3.6
899	Alternate Diameter Pipeline 16"		160	160	160	160	160	160
900	Line 3010 at 80% Supply		380	380	380	380	380	380
901	Otay Mesa Low Supply		33	33	148	148	130	168
902	Total Supply		573	573	688	688	670	708
903	Total MMcfd Shortfall		0	0	0	0	0	0
904	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
905	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
906		Gas EG [%]	0%	0%	0%	0%	0%	0%
907		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
908	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
909		Gas EG [MWh/d]	0	0	0	0	0	0
910		Gas EG [MW]	0	0	0	0	0	0
911	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
912		Gas Core [# Affected]	0	0	0	0	0	0
913		Gas EG [# Affected]	0	0	0	0	0	0
914		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
915								
916	Alt Diameter 16" / Otay Low / L3010 Out		6.2.3.1	6.2.3.2	6.2.3.3	6.2.3.4	6.2.3.5	6.2.3.6
917	Alternate Diameter Pipeline 16"		160	160	160	160	160	160
918	Line 3010 Complete Outage		0	0	0	0	0	0
919	Otay Mesa Low Supply		33	33	148	148	130	168
920	Total Supply		193	193	308	308	290	328
921	Total MMcfd Shortfall		82	282	229	269	175	197
922	Immediate Curtailment to EG Stations?		Yes	Yes	Yes	Yes	Yes	Yes
923	Curtailment (%)	Gas Core [%]	0%	0%	1%	12%	0%	0%
924		Gas EG [%]	7%	69%	100%	100%	45%	45%
925		Gas Non-Core Non-EG [%]	100%	100%	100%	100%	100%	100%
926	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	2	42	0	0
927		Gas EG [MWh/d]	902	27,876	22,253	22,253	13,473	16,515
928		Gas EG [MW]	38	1,162	927	927	561	688
929	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	75	75	62	62	75	75
930		Gas Core [# Affected]	0	0	5,325	104,012	0	0
931		Gas EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A
932		Gas Non-Core Non-EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A
933								
934	Alt Diameter 16" / Otay Out / L3010 80%		6.1.4.1	6.1.4.2	6.1.4.3	6.1.4.4	6.1.4.5	6.1.4.6
935	Alternate Diameter Pipeline 16"		160	160	160	160	160	160
936	Line 3010 at 80% Supply		380	380	380	380	380	380
937	Otay Mesa No Supply		0	0	0	0	0	0
938	Total Supply		540	540	540	540	540	540
939	Total MMcfd Shortfall		0	0	0	37	0	0
940	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
941	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
942		Gas EG [%]	0%	0%	0%	0%	0%	0%
943		Gas Non-Core Non-EG [%]	0%	0%	0%	60%	0%	0%
944	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
945		Gas EG [MWh/d]	0	0	0	0	0	0
946		Gas EG [MW]	0	0	0	0	0	0
947	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	37	0	0
948		Gas Core [# Affected]	0	0	0	0	0	0
949		Gas EG [# Affected]	0	0	0	0	0	0
950		Gas Non-Core Non-EG [# Affected]	0	0	0	N/A	0	0
951								
952	Alt Diameter 16" / Otay Out / L3010 Out		6.2.4.1	6.2.4.2	6.2.4.3	6.2.4.4	6.2.4.5	6.2.4.6
953	Alternate Diameter Pipeline 16"		160	160	160	160	160	160
954	Line 3010 Complete Outage		0	0	0	0	0	0
955	Otay Mesa No Supply		0	0	0	0	0	0
956	Total Supply		160	160	160	160	160	160
957	Total MMcfd Shortfall		115	315	377	417	305	365
958	Immediate Curtailment to EG Stations?		Yes	Yes	Yes	Yes	Yes	Yes
959	Curtailment (%)	Gas Core [%]	0%	0%	48%	54%	6%	11%
960		Gas EG [%]	40%	80%	100%	100%	100%	100%
961		Gas Non-Core Non-EG [%]	100%	100%	100%	100%	100%	100%
962	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	150	190	10	20
963		Gas EG [MWh/d]	5,395	32,368	22,253	22,253	29,671	36,414
964		Gas EG [MW]	225	1,349	927	927	1,236	1,517
965	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	75	75	62	62	75	75
966		Gas Core [# Affected]	0	0	420,405	471,655	51,108	96,538
967		Gas EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A
968		Gas Non-Core Non-EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1)
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

		1. Example Summer Low- EG Day MMcfd	2. Example Summer High- EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	D	E	F	G	H
1								
2								
969								
970	<u>Alternate Diameter Pipeline 20"</u>							
971								
972	<u>Alt Diameter 20" / Otay Full / L3010 80%</u>							
973		20.1.1.1	20.1.1.2	20.1.1.3	20.1.1.4	20.1.1.5	20.1.1.6	
974	Alternate Diameter Pipeline 20"	250	250	250	250	250	250	250
975	Line 3010 at 80% Supply	380	380	380	380	380	380	380
976	Otay Mesa Full Supply	295	86	313	313	329	324	
977	Total Supply	925	716	943	943	959	954	
978	Total MMcfd Shortfall	0	0	0	0	0	0	
979	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	
980	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
981		Gas EG [%]	0%	0%	0%	0%	0%	0%
982		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
983	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
984		Gas EG [MWh/d]	0	0	0	0	0	0
985		Gas EG [MW]	0	0	0	0	0	0
986	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
987		Gas Core [# Affected]	0	0	0	0	0	0
988		Gas EG [# Affected]	0	0	0	0	0	0
989								
990	<u>Alt Diameter 20" / Otay Full / L3010 Out</u>							
991		20.2.1.1	20.2.1.2	20.2.1.3	20.2.1.4	20.2.1.5	20.2.1.6	
992	Alternate Diameter Pipeline 20"	250	250	250	250	250	250	
993	Line 3010 Complete Outage	0	0	0	0	0	0	
994	Otay Mesa Full Supply	295	86	313	313	329	324	
995	Total Supply	545	336	563	563	579	574	
996	Total MMcfd Shortfall	0	139	0	14	0	0	
997	Immediate Curtailment to EG Stations?	No	Yes	No	No	No	No	
998	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
999		Gas EG [%]	0%	21%	0%	0%	0%	0%
1000		Gas Non-Core Non-EG [%]	0%	100%	0%	23%	0%	0%
1001	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1002		Gas EG [MWh/d]	0	8,604	0	0	0	0
1003		Gas EG [MW]	0	358	0	0	0	0
1004	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	75	0	14	0	0
1005		Gas Core [# Affected]	0	0	0	0	0	0
1006		Gas EG [# Affected]	0	N/A	0	0	0	0
1007								
1008	<u>Alt Diameter 20" / Otay Medium / L3010 80%</u>							
1009		20.1.2.1	20.1.2.2	20.1.2.3	20.1.2.4	20.1.2.5	20.1.2.6	
1010	Alternate Diameter Pipeline 20"	250	250	250	250	250	250	
1011	Line 3010 at 80% Supply	380	380	380	380	380	380	
1012	Otay Mesa Medium Supply	156	60	230	230	244	247	
1013	Total Supply	786	690	860	860	874	877	
1014	Total MMcfd Shortfall	0	0	0	0	0	0	
1015	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	
1016	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1017		Gas EG [%]	0%	0%	0%	0%	0%	0%
1018		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
1019	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1020		Gas EG [MWh/d]	0	0	0	0	0	0
1021		Gas EG [MW]	0	0	0	0	0	0
1022	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
1023		Gas Core [# Affected]	0	0	0	0	0	0
1024		Gas EG [# Affected]	0	0	0	0	0	0
1025								
1026	<u>Alt Diameter 20" / Otay Medium / L3010 Out</u>							
1027		20.2.2.1	20.2.2.2	20.2.2.3	20.2.2.4	20.2.2.5	20.2.2.6	
1028	Alternate Diameter Pipeline 20"	250	250	250	250	250	250	
1029	Line 3010 Complete Outage	0	0	0	0	0	0	
1030	Otay Mesa Medium Supply	156	60	230	230	244	247	
1031	Total Supply	406	310	480	480	494	497	
1032	Total MMcfd Shortfall	0	165	57	97	0	28	
1033	Immediate Curtailment to EG Stations?	No	Yes	No	Yes	No	No	
1034	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1035		Gas EG [%]	0%	30%	0%	21%	0%	0%
1036		Gas Non-Core Non-EG [%]	0%	100%	92%	100%	0%	37%
1037	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1038		Gas EG [MWh/d]	0	12,171	0	4,732	0	0
1039		Gas EG [MW]	0	507	0	197	0	0
1040	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	75	57	62	0	28
1041		Gas Core [# Affected]	0	0	0	0	0	0
1042		Gas EG [# Affected]	0	N/A	0	N/A	0	0
1043								

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1)
 EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
 CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.		1. Example Summer Low- EG Day MMcfd	2. Example Summer High EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	D	E	F	G	H
1043								
1044	Alt Diameter 20" / Otay Low / L3010 80%							
1045	Alternate Diameter Pipeline 20"	250	250	250	250	250	250	250
1046	Line 3010 at 80% Supply	380	380	380	380	380	380	380
1047	Otay Mesa Low Supply	33	33	148	148	130	168	168
1048	Total Supply	663	663	778	778	760	798	798
1049	Total MMcfd Shortfall	0	0	0	0	0	0	0
1050	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	No
1051	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1052		Gas EG [%]	0%	0%	0%	0%	0%	0%
1053		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
1054	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1055		Gas EG [MWh/d]	0	0	0	0	0	0
1056		Gas EG [MW]	0	0	0	0	0	0
1057	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
1058		Gas Core [# Affected]	0	0	0	0	0	0
1059		Gas EG [# Affected]	0	0	0	0	0	0
1060		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
1061								
1062	Alt Diameter 20" / Otay Low / L3010 Out							
1063	Alternate Diameter Pipeline 20"	250	250	250	250	250	250	250
1064	Line 3010 Complete Outage	0	0	0	0	0	0	0
1065	Otay Mesa Low Supply	33	33	148	148	130	168	168
1066	Total Supply	283	283	398	398	380	418	418
1067	Total MMcfd Shortfall	0	192	139	179	85	107	107
1068	Immediate Curtailment to EG Stations?	No	Yes	Yes	Yes	Yes	Yes	Yes
1069	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1070		Gas EG [%]	0%	39%	47%	71%	4%	12%
1071		Gas Non-Core Non-EG [%]	0%	100%	100%	100%	100%	100%
1072	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1073		Gas EG [MWh/d]	0	15,738	10,371	15,766	1,335	4,377
1074		Gas EG [MW]	0	656	432	657	56	182
1075	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	75	62	62	75	75
1076		Gas Core [# Affected]	0	0	0	0	0	0
1077		Gas EG [# Affected]	0	N/A	N/A	N/A	N/A	N/A
1078		Gas Non-Core Non-EG [# Affected]	0	N/A	N/A	N/A	N/A	N/A
1079								
1080	Alt Diameter 20" / Otay Out / L3010 80%							
1081	Alternate Diameter Pipeline 20"	250	250	250	250	250	250	250
1082	Line 3010 at 80% Supply	380	380	380	380	380	380	380
1083	Otay Mesa No Supply	0	0	0	0	0	0	0
1084	Total Supply	630	630	630	630	630	630	630
1085	Total MMcfd Shortfall	0	0	0	0	0	0	0
1086	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	No
1087	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1088		Gas EG [%]	0%	0%	0%	0%	0%	0%
1089		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
1090	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1091		Gas EG [MWh/d]	0	0	0	0	0	0
1092		Gas EG [MW]	0	0	0	0	0	0
1093	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
1094		Gas Core [# Affected]	0	0	0	0	0	0
1095		Gas EG [# Affected]	0	0	0	0	0	0
1096		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
1097								
1098	Alt Diameter 20" / Otay Out / L3010 Out							
1099	Alternate Diameter Pipeline 20"	250	250	250	250	250	250	250
1100	Line 3010 Complete Outage	0	0	0	0	0	0	0
1101	Otay Mesa No Supply	0	0	0	0	0	0	0
1102	Total Supply	250	250	250	250	250	250	250
1103	Total MMcfd Shortfall	25	225	287	327	215	275	275
1104	Immediate Curtailment to EG Stations?	No	Yes	Yes	Yes	Yes	Yes	Yes
1105	Curtailment (%)	Gas Core [%]	0%	0%	19%	29%	0%	0%
1106		Gas EG [%]	0%	50%	100%	100%	64%	74%
1107		Gas Non-Core Non-EG [%]	33%	100%	100%	100%	100%	100%
1108	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	60	100	0	0
1109		Gas EG [MWh/d]	0	20,230	22,253	22,253	18,882	26,974
1110		Gas EG [MW]	0	843	927	927	787	1,124
1111	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	25	75	62	62	75	75
1112		Gas Core [# Affected]	0	0	168,162	248,239	0	0
1113		Gas EG [# Affected]	0	N/A	N/A	N/A	N/A	N/A
1114		Gas Non-Core Non-EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

Line No.		1. Example Summer Low-EG Day MMcfd	2. Example Summer High-EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1-in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
1		C	D	E	F	G	H	
2	A	B	C	D	E	F	G	H
1115	Alternate Diameter Pipeline 24"							
1116	Alt Diameter 24" / Otay Full / L3010 80%							
1117		7.1.1.1	7.1.1.2	7.1.1.3	7.1.1.4	7.1.1.5	7.1.1.6	
1118	Alternate Diameter Pipeline 24"	400	400	400	400	400	400	
1119	Line 3010 at 80% Supply	380	380	380	380	380	380	
1120	Otay Mesa Full Supply	295	86	313	313	329	324	
1121	Total Supply	1075	866	1093	1093	1109	1104	
1122	Total MMcfd Shortfall	0	0	0	0	0	0	
1123	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	
1124	Curtailment (%)	0%	0%	0%	0%	0%	0%	
1125	Gas Core [%]	0%	0%	0%	0%	0%	0%	
1126	Gas EG [%]	0%	0%	0%	0%	0%	0%	
1127	Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%	
1128	Curtailment (Capacity)	0	0	0	0	0	0	
1129	Gas Core [MMcfd]	0	0	0	0	0	0	
1130	Gas EG [MWh/d]	0	0	0	0	0	0	
1131	Gas EG [MW]	0	0	0	0	0	0	
1132	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0	
1133	Number of Customers Affected	0	0	0	0	0	0	
1134	Gas Core [# Affected]	0	0	0	0	0	0	
1135	Gas EG [# Affected]	0	0	0	0	0	0	
1136	Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0	
1137	Alt Diameter 24" / Otay Full / L3010 Out							
1138		7.2.1.1	7.2.1.2	7.2.1.3	7.2.1.4	7.2.1.5	7.2.1.6	
1139	Alternate Diameter Pipeline 24"	400	400	400	400	400	400	
1140	Line 3010 Complete Outage	0	0	0	0	0	0	
1141	Otay Mesa Full Supply	295	86	313	313	329	324	
1142	Total Supply	695	486	713	713	729	724	
1143	Total MMcfd Shortfall	0	0	0	0	0	0	
1144	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	
1145	Curtailment (%)	0%	0%	0%	0%	0%	0%	
1146	Gas Core [%]	0%	0%	0%	0%	0%	0%	
1147	Gas EG [%]	0%	0%	0%	0%	0%	0%	
1148	Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%	
1149	Curtailment (Capacity)	0	0	0	0	0	0	
1150	Gas Core [MMcfd]	0	0	0	0	0	0	
1151	Gas EG [MWh/d]	0	0	0	0	0	0	
1152	Gas EG [MW]	0	0	0	0	0	0	
1153	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0	
1154	Number of Customers Affected	0	0	0	0	0	0	
1155	Gas Core [# Affected]	0	0	0	0	0	0	
1156	Gas EG [# Affected]	0	0	0	0	0	0	
1157	Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0	
1158	Alt Diameter 24" / Otay Medium / L3010 80%							
1159		7.1.2.1	7.1.2.2	7.1.2.3	7.1.2.4	7.1.2.5	7.1.2.6	
1160	Alternate Diameter Pipeline 24"	400	400	400	400	400	400	
1161	Line 3010 at 80% Supply	380	380	380	380	380	380	
1162	Otay Mesa Medium Supply	156	60	230	230	244	247	
1163	Total Supply	936	840	1010	1010	1024	1027	
1164	Total MMcfd Shortfall	0	0	0	0	0	0	
1165	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	
1166	Curtailment (%)	0%	0%	0%	0%	0%	0%	
1167	Gas Core [%]	0%	0%	0%	0%	0%	0%	
1168	Gas EG [%]	0%	0%	0%	0%	0%	0%	
1169	Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%	
1170	Curtailment (Capacity)	0	0	0	0	0	0	
1171	Gas Core [MMcfd]	0	0	0	0	0	0	
1172	Gas EG [MWh/d]	0	0	0	0	0	0	
1173	Gas EG [MW]	0	0	0	0	0	0	
1174	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0	
1175	Number of Customers Affected	0	0	0	0	0	0	
1176	Gas Core [# Affected]	0	0	0	0	0	0	
1177	Gas EG [# Affected]	0	0	0	0	0	0	
1178	Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0	
1179	Alt Diameter 24" / Otay Medium / L3010 Out							
1180		7.2.2.1	7.2.2.2	7.2.2.3	7.2.2.4	7.2.2.5	7.2.2.6	
1181	Alternate Diameter Pipeline 24"	400	400	400	400	400	400	
1182	Line 3010 Complete Outage	0	0	0	0	0	0	
1183	Otay Mesa Medium Supply	156	60	230	230	244	247	
1184	Total Supply	556	460	630	630	644	647	
1185	Total MMcfd Shortfall	0	15	0	0	0	0	
1186	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	
1187	Curtailment (%)	0%	0%	0%	0%	0%	0%	
1188	Gas Core [%]	0%	0%	0%	0%	0%	0%	
1189	Gas EG [%]	0%	0%	0%	0%	0%	0%	
1190	Gas Non-Core Non-EG [%]	0%	20%	0%	0%	0%	0%	
1191	Curtailment (Capacity)	0	15	0	0	0	0	
1192	Gas Core [MMcfd]	0	0	0	0	0	0	
1193	Gas EG [MWh/d]	0	0	0	0	0	0	
1194	Gas EG [MW]	0	0	0	0	0	0	
1195	Gas Non-Core Non-EG [MMcfd]	0	15	0	0	0	0	
1196	Number of Customers Affected	0	0	0	0	0	0	
1197	Gas Core [# Affected]	0	0	0	0	0	0	
1198	Gas EG [# Affected]	0	0	0	0	0	0	
1199	Gas Non-Core Non-EG [# Affected]	0	N/A	0	0	0	0	

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.		1. Example Summer Low- EG Day MMcfd	2. Example Summer High EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	D	E	F	G	H
1189								
1190	Alt Diameter 24" / Otay Low / L3010 80%		7.1.3.1	7.1.3.2	7.1.3.3	7.1.3.4	7.1.3.5	7.1.3.6
1191	Alternate Diameter Pipeline 24"		400	400	400	400	400	400
1192	Line 3010 at 80% Supply		380	380	380	380	380	380
1193	Otay Mesa Low Supply		33	33	148	148	130	168
1194	Total Supply		813	813	928	928	910	948
1195	Total MMcfd Shortfall		0	0	0	0	0	0
1196	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
1197	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1198		Gas EG [%]	0%	0%	0%	0%	0%	0%
1199		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
1200	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1201		Gas EG [MWh/d]	0	0	0	0	0	0
1202		Gas EG [MW]	0	0	0	0	0	0
1203	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
1204		Gas Core [# Affected]	0	0	0	0	0	0
1205		Gas EG [# Affected]	0	0	0	0	0	0
1206		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
1207								
1208	Alt Diameter 24" / Otay Low / L3010 Out		7.2.3.1	7.2.3.2	7.2.3.3	7.2.3.4	7.2.3.5	7.2.3.6
1209	Alternate Diameter Pipeline 24"		400	400	400	400	400	400
1210	Line 3010 Complete Outage		0	0	0	0	0	0
1211	Otay Mesa Low Supply		33	33	148	148	130	168
1212	Total Supply		433	433	548	548	530	568
1213	Total MMcfd Shortfall		0	42	0	29	0	0
1214	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
1215	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1216		Gas EG [%]	0%	0%	0%	0%	0%	0%
1217		Gas Non-Core Non-EG [%]	0%	56%	0%	47%	0%	0%
1218	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1219		Gas EG [MWh/d]	0	0	0	0	0	0
1220		Gas EG [MW]	0	0	0	0	0	0
1221	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	42	0	29	0	0
1222		Gas Core [# Affected]	0	0	0	0	0	0
1223		Gas EG [# Affected]	0	0	0	0	0	0
1224		Gas Non-Core Non-EG [# Affected]	0	N/A	0	N/A	0	0
1225								
1226	Alt Diameter 24" / Otay Out / L3010 80%		7.1.4.1	7.1.4.2	7.1.4.3	7.1.4.4	7.1.4.5	7.1.4.6
1227	Alternate Diameter Pipeline 24"		400	400	400	400	400	400
1228	Line 3010 at 80% Supply		380	380	380	380	380	380
1229	Otay Mesa No Supply		0	0	0	0	0	0
1230	Total Supply		780	780	780	780	780	780
1231	Total MMcfd Shortfall		0	0	0	0	0	0
1232	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
1233	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1234		Gas EG [%]	0%	0%	0%	0%	0%	0%
1235		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
1236	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1237		Gas EG [MWh/d]	0	0	0	0	0	0
1238		Gas EG [MW]	0	0	0	0	0	0
1239	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
1240		Gas Core [# Affected]	0	0	0	0	0	0
1241		Gas EG [# Affected]	0	0	0	0	0	0
1242		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
1243								
1244	Alt Diameter 24" / Otay Out / L3010 Out		7.2.4.1	7.2.4.2	7.2.4.3	7.2.4.4	7.2.4.5	7.2.4.6
1245	Alternate Diameter Pipeline 24"		400	400	400	400	400	400
1246	Line 3010 Complete Outage		0	0	0	0	0	0
1247	Otay Mesa No Supply		0	0	0	0	0	0
1248	Total Supply		400	400	400	400	400	400
1249	Total MMcfd Shortfall		0	75	137	177	65	125
1250	Immediate Curtailment to EG Stations?		No	Yes	Yes	Yes	No	Yes
1251	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1252		Gas EG [%]	0%	0%	45%	70%	0%	19%
1253		Gas Non-Core Non-EG [%]	0%	100%	100%	100%	87%	100%
1254	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1255		Gas EG [MWh/d]	0	0	10,115	15,510	0	6,743
1256		Gas EG [MW]	0	0	421	646	0	281
1257	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	75	62	62	65	75
1258		Gas Core [# Affected]	0	0	0	0	0	0
1259		Gas EG [# Affected]	0	0	N/A	N/A	0	N/A
1260		Gas Non-Core Non-EG [# Affected]	0	N/A	N/A	N/A	N/A	N/A

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

Line No.		1. Example Summer Low- EG Day MMcfd	2. Example Summer High EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	D	E	F	G	H
1								
2								
1261								
1262								
1263								
1264								
1265								
1266								
1267								
1268								
1269								
1270								
1271								
1272								
1273								
1274								
1275								
1276								
1277								
1278								
1279								
1280								
1281								
1282								
1283								
1284								
1285								
1286								
1287								
1288								
1289								
1290								
1291								
1292								
1293								
1294								
1295								
1296								
1297								
1298								
1299								
1300								
1301								
1302								
1303								
1304								
1305								
1306								
1307								
1308								
1309								
1310								
1311								
1312								
1313								
1314								
1315								
1316								
1317								
1318								
1319								
1320								
1321								
1322								
1323								
1324								
1325								
1326								
1327								
1328								
1329								
1330								
1331								
1332								
1333								
1334								

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.		1. Example Summer Low- EG Day MMcfd	2. Example Summer High- EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	D	E	F	G	H
1335								
1336	Alt Diameter 30" / Otay Low / L3010 80%		8.1.3.1	8.1.3.2	8.1.3.3	8.1.3.4	8.1.3.5	8.1.3.6
1337	Alternate Diameter Pipeline 30"		600	600	600	600	600	600
1338	Line 3010 at 80% Supply		380	380	380	380	380	380
1339	Otay Mesa Low Supply		33	33	148	148	130	168
1340	Total Supply		1013	1013	1128	1128	1110	1148
1341	Total MMcfd Shortfall		0	0	0	0	0	0
1342	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
1343	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1344		Gas EG [%]	0%	0%	0%	0%	0%	0%
1345		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
1346	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1347		Gas EG [MWh/d]	0	0	0	0	0	0
1348		Gas EG [MW]	0	0	0	0	0	0
1349	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
1350		Gas Core [# Affected]	0	0	0	0	0	0
1351		Gas EG [# Affected]	0	0	0	0	0	0
1352		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
1353								
1354	Alt Diameter 30" / Otay Low / L3010 Out		8.2.3.1	8.2.3.2	8.2.3.3	8.2.3.4	8.2.3.5	8.2.3.6
1355	Alternate Diameter Pipeline 30"		600	600	600	600	600	600
1356	Line 3010 Complete Outage		0	0	0	0	0	0
1357	Otay Mesa Low Supply		33	33	148	148	130	168
1358	Total Supply		633	633	748	748	730	768
1359	Total MMcfd Shortfall		0	0	0	0	0	0
1360	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
1361	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1362		Gas EG [%]	0%	0%	0%	0%	0%	0%
1363		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
1364	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1365		Gas EG [MWh/d]	0	0	0	0	0	0
1366		Gas EG [MW]	0	0	0	0	0	0
1367	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
1368		Gas Core [# Affected]	0	0	0	0	0	0
1369		Gas EG [# Affected]	0	0	0	0	0	0
1370		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
1371								
1372	Alt Diameter 30" / Otay Out / L3010 80%		8.1.4.1	8.1.4.2	8.1.4.3	8.1.4.4	8.1.4.5	8.1.4.6
1373	Alternate Diameter Pipeline 30"		600	600	600	600	600	600
1374	Line 3010 at 80% Supply		380	380	380	380	380	380
1375	Otay Mesa No Supply		0	0	0	0	0	0
1376	Total Supply		980	980	980	980	980	980
1377	Total MMcfd Shortfall		0	0	0	0	0	0
1378	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
1379	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1380		Gas EG [%]	0%	0%	0%	0%	0%	0%
1381		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
1382	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1383		Gas EG [MWh/d]	0	0	0	0	0	0
1384		Gas EG [MW]	0	0	0	0	0	0
1385	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
1386		Gas Core [# Affected]	0	0	0	0	0	0
1387		Gas EG [# Affected]	0	0	0	0	0	0
1388		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
1389								
1390	Alt Diameter 30" / Otay Out / L3010 Out		8.2.4.1	8.2.4.2	8.2.4.3	8.2.4.4	8.2.4.5	8.2.4.6
1391	Alternate Diameter Pipeline 30"		600	600	600	600	600	600
1392	Line 3010 Complete Outage		0	0	0	0	0	0
1393	Otay Mesa No Supply		0	0	0	0	0	0
1394	Total Supply		600	600	600	600	600	600
1395	Total MMcfd Shortfall		0	0	0	0	0	0
1396	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
1397	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1398		Gas EG [%]	0%	0%	0%	0%	0%	0%
1399		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
1400	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1401		Gas EG [MWh/d]	0	0	0	0	0	0
1402		Gas EG [MW]	0	0	0	0	0	0
1403	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
1404		Gas Core [# Affected]	0	0	0	0	0	0
1405		Gas EG [# Affected]	0	0	0	0	0	0
1406		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

		1. Example Summer Low- EG Day MMcfd	2. Example Summer High- EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	D	E	F	G	H
1								
2								
1407								
1408	<u>Alternate Diameter Pipeline 42"</u>							
1409								
1410	Alt Diameter 42" / Otay Full / L3010 80%		9.1.1.1	9.1.1.2	9.1.1.3	9.1.1.4	9.1.1.5	9.1.1.6
1411	Alternate Diameter Pipeline 42"		710	710	710	710	710	710
1412	Line 3010 at 80% Supply		380	380	380	380	380	380
1413	Otay Mesa Full Supply		295	86	313	313	329	324
1414	Total Supply		1385	1176	1403	1403	1419	1414
1415	Total MMcfd Shortfall		0	0	0	0	0	0
1416	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
1417	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1418		Gas EG [%]	0%	0%	0%	0%	0%	0%
1419		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
1420	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1421		Gas EG [MWh/d]	0	0	0	0	0	0
1422		Gas EG [MW]	0	0	0	0	0	0
1423		Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
1424	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	0
1425		Gas EG [# Affected]	0	0	0	0	0	0
1426		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
1427								
1428	Alt Diameter 42" / Otay Full / L3010 Out		9.2.1.1	9.2.1.2	9.2.1.3	9.2.1.4	9.2.1.5	9.2.1.6
1429	Alternate Diameter Pipeline 42"		710	710	710	710	710	710
1430	Line 3010 Complete Outage		0	0	0	0	0	0
1431	Otay Mesa Full Supply		295	86	313	313	329	324
1432	Total Supply		1005	796	1023	1023	1039	1034
1433	Total MMcfd Shortfall		0	0	0	0	0	0
1434	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
1435	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1436		Gas EG [%]	0%	0%	0%	0%	0%	0%
1437		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
1438	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1439		Gas EG [MWh/d]	0	0	0	0	0	0
1440		Gas EG [MW]	0	0	0	0	0	0
1441		Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
1442	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	0
1443		Gas EG [# Affected]	0	0	0	0	0	0
1444		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
1445								
1446	Alt Diameter 42" / Otay Medium / L3010 80%		9.1.2.1	9.1.2.2	9.1.2.3	9.1.2.4	9.1.2.5	9.1.2.6
1447	Alternate Diameter Pipeline 42"		710	710	710	710	710	710
1448	Line 3010 at 80% Supply		380	380	380	380	380	380
1449	Otay Mesa Medium Supply		156	60	230	230	244	247
1450	Total Supply		1246	1150	1320	1320	1334	1337
1451	Total MMcfd Shortfall		0	0	0	0	0	0
1452	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
1453	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1454		Gas EG [%]	0%	0%	0%	0%	0%	0%
1455		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
1456	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1457		Gas EG [MWh/d]	0	0	0	0	0	0
1458		Gas EG [MW]	0	0	0	0	0	0
1459		Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
1460	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	0
1461		Gas EG [# Affected]	0	0	0	0	0	0
1462		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
1463								
1464	Alt Diameter 42" / Otay Medium / L3010 Out		9.2.2.1	9.2.2.2	9.2.2.3	9.2.2.4	9.2.2.5	9.2.2.6
1465	Alternate Diameter Pipeline 42"		710	710	710	710	710	710
1466	Line 3010 Complete Outage		0	0	0	0	0	0
1467	Otay Mesa Medium Supply		156	60	230	230	244	247
1468	Total Supply		866	770	940	940	954	957
1469	Total MMcfd Shortfall		0	0	0	0	0	0
1470	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
1471	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1472		Gas EG [%]	0%	0%	0%	0%	0%	0%
1473		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
1474	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1475		Gas EG [MWh/d]	0	0	0	0	0	0
1476		Gas EG [MW]	0	0	0	0	0	0
1477		Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
1478	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	0
1479		Gas EG [# Affected]	0	0	0	0	0	0
1480		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.		1. Example Summer Low- EG Day MMcfd	2. Example Summer High EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	D	E	F	G	H
1								
2								
1481								
1482	Alt Diameter 42" / Otay Low / L3010 80%		9.1.3.1	9.1.3.2	9.1.3.3	9.1.3.4	9.1.3.5	9.1.3.6
1483	Alternate Diameter Pipeline 42"		710	710	710	710	710	710
1484	Line 3010 at 80% Supply		380	380	380	380	380	380
1485	Otay Mesa Low Supply		33	33	148	148	130	168
1486	Total Supply		1123	1123	1238	1238	1220	1258
1487	Total MMcfd Shortfall		0	0	0	0	0	0
1488	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
1489	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1490		Gas EG [%]	0%	0%	0%	0%	0%	0%
1491		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
1492	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1493		Gas EG [MWh/d]	0	0	0	0	0	0
1494		Gas EG [MW]	0	0	0	0	0	0
1495	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
1496		Gas Core [# Affected]	0	0	0	0	0	0
1497		Gas EG [# Affected]	0	0	0	0	0	0
1498		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
1499								
1500	Alt Diameter 42" / Otay Low / L3010 Out		9.2.3.1	9.2.3.2	9.2.3.3	9.2.3.4	9.2.3.5	9.2.3.6
1501	Alternate Diameter Pipeline 42"		710	710	710	710	710	710
1502	Line 3010 Complete Outage		0	0	0	0	0	0
1503	Otay Mesa Low Supply		33	33	148	148	130	168
1504	Total Supply		743	743	858	858	840	878
1505	Total MMcfd Shortfall		0	0	0	0	0	0
1506	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
1507	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1508		Gas EG [%]	0%	0%	0%	0%	0%	0%
1509		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
1510	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1511		Gas EG [MWh/d]	0	0	0	0	0	0
1512		Gas EG [MW]	0	0	0	0	0	0
1513	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
1514		Gas Core [# Affected]	0	0	0	0	0	0
1515		Gas EG [# Affected]	0	0	0	0	0	0
1516		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
1517								
1518	Alt Diameter 42" / Otay Out / L3010 80%		9.1.4.1	9.1.4.2	9.1.4.3	9.1.4.4	9.1.4.5	9.1.4.6
1519	Alternate Diameter Pipeline 42"		710	710	710	710	710	710
1520	Line 3010 at 80% Supply		380	380	380	380	380	380
1521	Otay Mesa No Supply		0	0	0	0	0	0
1522	Total Supply		1090	1090	1090	1090	1090	1090
1523	Total MMcfd Shortfall		0	0	0	0	0	0
1524	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
1525	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1526		Gas EG [%]	0%	0%	0%	0%	0%	0%
1527		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
1528	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1529		Gas EG [MWh/d]	0	0	0	0	0	0
1530		Gas EG [MW]	0	0	0	0	0	0
1531	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
1532		Gas Core [# Affected]	0	0	0	0	0	0
1533		Gas EG [# Affected]	0	0	0	0	0	0
1534		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
1535								
1536	Alt Diameter 42" / Otay Out / L3010 Out		9.2.4.1	9.2.4.2	9.2.4.3	9.2.4.4	9.2.4.5	9.2.4.6
1537	Alternate Diameter Pipeline 42"		710	710	710	710	710	710
1538	Line 3010 Complete Outage		0	0	0	0	0	0
1539	Otay Mesa No Supply		0	0	0	0	0	0
1540	Total Supply		710	710	710	710	710	710
1541	Total MMcfd Shortfall		0	0	0	0	0	0
1542	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
1543	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1544		Gas EG [%]	0%	0%	0%	0%	0%	0%
1545		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
1546	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1547		Gas EG [MWh/d]	0	0	0	0	0	0
1548		Gas EG [MW]	0	0	0	0	0	0
1549	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
1550		Gas Core [# Affected]	0	0	0	0	0	0
1551		Gas EG [# Affected]	0	0	0	0	0	0
1552		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1)
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low-EG Day MMcf/d	2. Example Summer High-EG Day MMcf/d	3. Example Winter Day MMcf/d	4. Winter 1-in-10 Year Day MMcf/d	5. Example Spring Day MMcf/d	6. Example Fall Day MMcf/d		
	A	B	C	D	E	F	G	H

1

2

1553

L1600 In-Kind Replacement

1554

1555

1556

1557

1558

1559

1560

1561

1562

1563

1564

1565

1566

1567

1568

1569

1570

1571

1572

1573

L1600 In-Kind / Otay Full / L3010 80%		10.1.1.1	10.1.1.2	10.1.1.3	10.1.1.4	10.1.1.5	10.1.1.6
L1600 In-Kind Replacement		160	160	160	160	160	160
Line 3010 at 80% Supply		380	380	380	380	380	380
Otay Mesa Full Supply		295	86	313	313	329	324
Total Supply		835	626	853	853	869	864
Total MMcf/d Shortfall		0	0	0	0	0	0
Immediate Curtailment to EG Stations?		No	No	No	No	No	No
Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
	Gas EG [%]	0%	0%	0%	0%	0%	0%
	Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
Curtailment (Capacity)	Gas Core [MMcf/d]	0	0	0	0	0	0
	Gas EG [MWh/d]	0	0	0	0	0	0
	Gas EG [MW]	0	0	0	0	0	0
Number of Customers Affected	Gas Non-Core Non-EG [MMcf/d]	0	0	0	0	0	0
	Gas Core [# Affected]	0	0	0	0	0	0
	Gas EG [# Affected]	0	0	0	0	0	0
Affected		0	0	0	0	0	0

1574

1575

1576

1577

1578

1579

1580

1581

1582

1583

1584

1585

1586

1587

1588

1589

1590

1591

L1600 In-Kind / Otay Full / L3010 Out		10.2.1.1	10.2.1.2	10.2.1.3	10.2.1.4	10.2.1.5	10.2.1.6
L1600 In-Kind Replacement		160	160	160	160	160	160
Line 3010 Complete Outage		0	0	0	0	0	0
Otay Mesa Full Supply		295	86	313	313	329	324
Total Supply		455	246	473	473	489	484
Total MMcf/d Shortfall		0	229	64	104	0	41
Immediate Curtailment to EG Stations?		No	Yes	Yes	Yes	No	No
Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
	Gas EG [%]	0%	51%	1%	26%	0%	0%
	Gas Non-Core Non-EG [%]	0%	100%	100%	100%	0%	55%
Curtailment (Capacity)	Gas Core [MMcf/d]	0	0	0	0	0	0
	Gas EG [MWh/d]	0	20,742	298	5,693	0	0
	Gas EG [MW]	0	864	12	237	0	0
Number of Customers Affected	Gas Non-Core Non-EG [MMcf/d]	0	75	62	62	0	41
	Gas Core [# Affected]	0	0	0	0	0	0
	Gas EG [# Affected]	0	N/A	N/A	N/A	0	0
Affected		0	N/A	N/A	N/A	0	N/A

1592

1593

1594

1595

1596

1597

1598

1599

1600

1601

1602

1603

1604

1605

1606

1607

1608

1609

L1600 In-Kind / Otay Medium / L3010 80%		10.1.2.1	10.1.2.2	10.1.2.3	10.1.2.4	10.1.2.5	10.1.2.6
L1600 In-Kind Replacement		160	160	160	160	160	160
Line 3010 at 80% Supply		380	380	380	380	380	380
Otay Mesa Medium Supply		156	60	230	230	244	247
Total Supply		696	600	770	770	784	787
Total MMcf/d Shortfall		0	0	0	0	0	0
Immediate Curtailment to EG Stations?		No	No	No	No	No	No
Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
	Gas EG [%]	0%	0%	0%	0%	0%	0%
	Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
Curtailment (Capacity)	Gas Core [MMcf/d]	0	0	0	0	0	0
	Gas EG [MWh/d]	0	0	0	0	0	0
	Gas EG [MW]	0	0	0	0	0	0
Number of Customers Affected	Gas Non-Core Non-EG [MMcf/d]	0	0	0	0	0	0
	Gas Core [# Affected]	0	0	0	0	0	0
	Gas EG [# Affected]	0	0	0	0	0	0
Affected		0	0	0	0	0	0

1610

1611

1612

1613

1614

1615

1616

1617

1618

1619

1620

1621

1622

1623

1624

1625

1626

L1600 In-Kind / Otay Medium / L3010 Out		10.2.2.1	10.2.2.2	10.2.2.3	10.2.2.4	10.2.2.5	10.2.2.6
L1600 In-Kind Replacement		160	160	160	160	160	160
Line 3010 Complete Outage		0	0	0	0	0	0
Otay Mesa Medium Supply		156	60	230	230	244	247
Total Supply		316	220	390	390	404	407
Total MMcf/d Shortfall		0	255	147	187	61	118
Immediate Curtailment to EG Stations?		No	Yes	Yes	Yes	No	Yes
Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
	Gas EG [%]	0%	60%	52%	76%	0%	16%
	Gas Non-Core Non-EG [%]	0%	100%	100%	100%	81%	100%
Curtailment (Capacity)	Gas Core [MMcf/d]	0	0	0	0	0	0
	Gas EG [MWh/d]	0	24,309	11,475	16,870	0	5,777
	Gas EG [MW]	0	1,013	478	703	0	241
Number of Customers Affected	Gas Non-Core Non-EG [MMcf/d]	0	75	62	62	61	75
	Gas Core [# Affected]	0	0	0	0	0	0
	Gas EG [# Affected]	0	N/A	N/A	N/A	0	N/A
Affected		0	N/A	N/A	N/A	N/A	N/A

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.		1. Example Summer Low-EG Day MMcfd	2. Example Summer High-EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1-in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	D	E	F	G	H
1627	L1600 In-Kind / Otay Low / L3010 80%							
1628	L1600 In-Kind Replacement		10.1.3.1	10.1.3.2	10.1.3.3	10.1.3.4	10.1.3.5	10.1.3.6
1629	L1600 In-Kind Replacement		160	160	160	160	160	160
1630	Line 3010 at 80% Supply		380	380	380	380	380	380
1631	Otay Mesa Low Supply		33	33	148	148	130	168
1632	Total Supply		573	573	688	688	670	708
1633	Total MMcfd Shortfall		0	0	0	0	0	0
1634	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
1635	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1636		Gas EG [%]	0%	0%	0%	0%	0%	0%
1637		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
1638	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1639		Gas EG [MWh/d]	0	0	0	0	0	0
1640		Gas EG [MW]	0	0	0	0	0	0
1641	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
1642		Gas Core [# Affected]	0	0	0	0	0	0
1643		Gas EG [# Affected]	0	0	0	0	0	0
1644	Gas Non-Core Non-EG [# Affected]		0	0	0	0	0	0
1645	L1600 In-Kind / Otay Low / L3010 Out							
1646	L1600 In-Kind Replacement		10.2.3.1	10.2.3.2	10.2.3.3	10.2.3.4	10.2.3.5	10.2.3.6
1647	L1600 In-Kind Replacement		160	160	160	160	160	160
1648	Line 3010 Complete Outage		0	0	0	0	0	0
1649	Otay Mesa Low Supply		33	33	148	148	130	168
1650	Total Supply		193	193	308	308	290	328
1651	Total MMcfd Shortfall		82	282	229	269	175	197
1652	Immediate Curtailment to EG Stations?		Yes	Yes	Yes	Yes	Yes	Yes
1653	Curtailment (%)	Gas Core [%]	0%	0%	1%	12%	0%	0%
1654		Gas EG [%]	7%	69%	100%	100%	45%	45%
1655		Gas Non-Core Non-EG [%]	100%	100%	100%	100%	100%	100%
1656	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	2	42	0	0
1657		Gas EG [MWh/d]	902	27,876	22,253	22,253	13,473	16,515
1658		Gas EG [MW]	38	1,162	927	927	561	688
1659	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	75	75	62	62	75	75
1660		Gas Core [# Affected]	0	0	5,325	104,012	0	0
1661		Gas EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A
1662	Gas Non-Core Non-EG [# Affected]		N/A	N/A	N/A	N/A	N/A	N/A
1663	L1600 In-Kind / Otay Out / L3010 80%							
1664	L1600 In-Kind Replacement		10.1.4.1	10.1.4.2	10.1.4.3	10.1.4.4	10.1.4.5	10.1.4.6
1665	L1600 In-Kind Replacement		160	160	160	160	160	160
1666	Line 3010 at 80% Supply		380	380	380	380	380	380
1667	Otay Mesa No Supply		0	0	0	0	0	0
1668	Total Supply		540	540	540	540	540	540
1669	Total MMcfd Shortfall		0	0	0	37	0	0
1670	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
1671	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1672		Gas EG [%]	0%	0%	0%	0%	0%	0%
1673		Gas Non-Core Non-EG [%]	0%	0%	0%	60%	0%	0%
1674	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1675		Gas EG [MWh/d]	0	0	0	0	0	0
1676		Gas EG [MW]	0	0	0	0	0	0
1677	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	37	0	0
1678		Gas Core [# Affected]	0	0	0	0	0	0
1679		Gas EG [# Affected]	0	0	0	0	0	0
1680	Gas Non-Core Non-EG [# Affected]		0	0	0	N/A	0	0
1681	L1600 In-Kind / Otay Out / L3010 Out							
1682	L1600 In-Kind Replacement		10.2.4.1	10.2.4.2	10.2.4.3	10.2.4.4	10.2.4.5	10.2.4.6
1683	L1600 In-Kind Replacement		160	160	160	160	160	160
1684	Line 3010 Complete Outage		0	0	0	0	0	0
1685	Otay Mesa No Supply		0	0	0	0	0	0
1686	Total Supply		160	160	160	160	160	160
1687	Total MMcfd Shortfall		115	315	377	417	305	365
1688	Immediate Curtailment to EG Stations?		Yes	Yes	Yes	Yes	Yes	Yes
1689	Curtailment (%)	Gas Core [%]	0%	0%	48%	54%	6%	11%
1690		Gas EG [%]	40%	80%	100%	100%	100%	100%
1691		Gas Non-Core Non-EG [%]	100%	100%	100%	100%	100%	100%
1692	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	150	190	10	20
1693		Gas EG [MWh/d]	5,395	32,368	22,253	22,253	29,671	36,414
1694		Gas EG [MW]	225	1,349	927	927	1,236	1,517
1695	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	75	75	62	62	75	75
1696		Gas Core [# Affected]	0	0	420,405	471,655	51,108	96,538
1697		Gas EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A
1698	Gas Non-Core Non-EG [# Affected]		N/A	N/A	N/A	N/A	N/A	N/A

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low- EG Day MMcfd	2. Example Summer High EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd		
1	A	B	C	D	E	F	G	H
1699	Otay Mesa Alternate							
1700	Otay Mesa Alternate / Otay Full / L3010 80%							
1701	0	0	0	0	0	0	0	
1702	380	380	380	380	380	380	380	
1703	295	86	313	313	329	324		
1704	675	466	693	693	709	704		
1705	0	9	0	0	0	0		
1706	No	No	No	No	No	No		
1707	0%	0%	0%	0%	0%	0%		
1708	0%	0%	0%	0%	0%	0%		
1709	0%	12%	0%	0%	0%	0%		
1710	0	0	0	0	0	0		
1711	0	0	0	0	0	0		
1712	0	0	0	0	0	0		
1713	0	0	0	0	0	0		
1714	0	0	0	0	0	0		
1715	0	9	0	0	0	0		
1716	0	0	0	0	0	0		
1717	0	0	0	0	0	0		
1718	0	N/A	0	0	0	0		
1719	Otay Mesa Alternate / Otay Full / L3010 Out							
1720	0	0	0	0	0	0		
1721	0	0	0	0	0	0		
1722	295	86	313	313	329	324		
1723	295	86	313	313	329	324		
1724	0	389	224	264	136	201		
1725	No	Yes	Yes	Yes	Yes	Yes		
1726	0%	14%	0%	11%	0%	0%		
1727	0%	100%	98%	100%	28%	47%		
1728	0%	100%	100%	100%	100%	100%		
1729	0	14	0	37	0	0		
1730	0	40,461	21,877	22,253	8,240	17,039		
1731	0	1,686	912	927	343	710		
1732	0	75	62	62	75	75		
1733	0	119,839	0	92,375	0	0		
1734	0	N/A	N/A	N/A	N/A	N/A		
1735	0	N/A	N/A	N/A	N/A	N/A		
1736	0	N/A	N/A	N/A	N/A	N/A		
1737	Otay Mesa Alternate / Otay Medium / L3010 80%							
1738	0	0	0	0	0	0		
1739	380	380	380	380	380	380		
1740	156	60	230	230	244	247		
1741	536	440	610	610	624	627		
1742	0	35	0	0	0	0		
1743	No	No	No	No	No	No		
1744	0%	0%	0%	0%	0%	0%		
1745	0%	0%	0%	0%	0%	0%		
1746	0%	47%	0%	0%	0%	0%		
1747	0	0	0	0	0	0		
1748	0	0	0	0	0	0		
1749	0	0	0	0	0	0		
1750	0	0	0	0	0	0		
1751	0	35	0	0	0	0		
1752	0	0	0	0	0	0		
1753	0	0	0	0	0	0		
1754	0	N/A	0	0	0	0		
1755	Otay Mesa Alternate / Otay Medium / L3010 Out							
1756	0	0	0	0	0	0		
1757	0	0	0	0	0	0		
1758	156	60	230	230	244	247		
1759	156	60	230	230	244	247		
1760	119	415	307	347	221	278		
1761	Yes	Yes	Yes	Yes	Yes	Yes		
1762	0%	40%	26%	34%	0%	0%		
1763	44%	100%	100%	100%	66%	75%		
1764	100%	100%	100%	100%	100%	100%		
1765	0	40	80	120	0	0		
1766	5,978	40,461	22,253	22,253	19,672	27,355		
1767	249	1,686	927	927	820	1,140		
1768	75	75	62	62	75	75		
1769	0	349,638	224,454	298,098	0	0		
1770	N/A	N/A	N/A	N/A	N/A	N/A		
1771	N/A	N/A	N/A	N/A	N/A	N/A		
1772	N/A	N/A	N/A	N/A	N/A	N/A		

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.		1. Example Summer Low-EG Day MMcfd	2. Example Summer High-EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1-in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	D	E	F	G	H
1773								
1774	Otay Mesa Alternate / Otay Low / L3010 80%		11.1.3.1	11.1.3.2	11.1.3.3	11.1.3.4	11.1.3.5	11.1.3.6
1775	Otay Mesa Alternate		0	0	0	0	0	0
1776	Line 3010 at 80% Supply		380	380	380	380	380	380
1777	Otay Mesa Low Supply		33	33	148	148	130	168
1778	Total Supply		413	413	528	528	510	548
1779	Total MMcfd Shortfall		0	62	9	49	0	0
1780	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
1781	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1782		Gas EG [%]	0%	0%	0%	0%	0%	0%
1783		Gas Non-Core Non-EG [%]	0%	82%	14%	79%	0%	0%
1784	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1785		Gas EG [MWh/d]	0	0	0	0	0	0
1786		Gas EG [MW]	0	0	0	0	0	0
1787	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	62	9	49	0	0
1788		Gas Core [# Affected]	0	0	0	0	0	0
1789		Gas EG [# Affected]	0	0	0	0	0	0
1790	Gas Non-Core Non-EG [# Affected]	0	N/A	N/A	N/A	0	0	
1791								
1792	Otay Mesa Alternate / Otay Low / L3010 Out		11.2.3.1	11.2.3.2	11.2.3.3	11.2.3.4	11.2.3.5	11.2.3.6
1793	Otay Mesa Alternate		0	0	0	0	0	0
1794	Line 3010 Complete Outage		0	0	0	0	0	0
1795	Otay Mesa Low Supply		33	33	148	148	130	168
1796	Total Supply		33	33	148	148	130	168
1797	Total MMcfd Shortfall		242	442	389	429	335	357
1798	Immediate Curtailment to EG Stations?		Yes	Yes	Yes	Yes	Yes	Yes
1799	Curtailment (%)	Gas Core [%]	67%	67%	52%	58%	23%	7%
1800		Gas EG [%]	100%	100%	100%	100%	100%	100%
1801		Gas Non-Core Non-EG [%]	100%	100%	100%	100%	100%	100%
1802	Curtailment (Capacity)	Gas Core [MMcfd]	67	67	162	202	40	12
1803		Gas EG [MWh/d]	13,487	40,461	22,253	22,253	29,671	36,414
1804		Gas EG [MW]	562	1,686	927	927	1,236	1,517
1805	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	75	75	62	62	75	75
1806		Gas Core [# Affected]	579,437	579,437	453,758	501,195	203,921	60,119
1807		Gas EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A
1808	Gas Non-Core Non-EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A	
1809								
1810	Otay Mesa Alternate / Otay Out / L3010 80%		11.1.4.1	11.1.4.2	11.1.4.3	11.1.4.4	11.1.4.5	11.1.4.6
1811	Otay Mesa Alternate		0	0	0	0	0	0
1812	Line 3010 at 80% Supply		380	380	380	380	380	380
1813	Otay Mesa No Supply		0	0	0	0	0	0
1814	Total Supply		380	380	380	380	380	380
1815	Total MMcfd Shortfall		0	95	157	197	85	145
1816	Immediate Curtailment to EG Stations?		No	Yes	Yes	Yes	Yes	Yes
1817	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1818		Gas EG [%]	0%	7%	58%	82%	5%	26%
1819		Gas Non-Core Non-EG [%]	0%	100%	100%	100%	100%	100%
1820	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1821		Gas EG [MWh/d]	0	2,697	12,813	18,207	1,349	9,441
1822		Gas EG [MW]	0	112	534	759	56	393
1823	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	75	62	62	75	75
1824		Gas Core [# Affected]	0	0	0	0	0	0
1825		Gas EG [# Affected]	0	N/A	N/A	N/A	N/A	N/A
1826	Gas Non-Core Non-EG [# Affected]	0	N/A	N/A	N/A	N/A	N/A	
1827								
1828	Otay Mesa Alternate / Otay Out / L3010 Out		11.2.4.1	11.2.4.2	11.2.4.3	11.2.4.4	11.2.4.5	11.2.4.6
1829	Otay Mesa Alternate		0	0	0	0	0	0
1830	Line 3010 Complete Outage		0	0	0	0	0	0
1831	Otay Mesa No Supply		0	0	0	0	0	0
1832	Total Supply		0	0	0	0	0	0
1833	Total MMcfd Shortfall		275	475	537	577	465	525
1834	Immediate Curtailment to EG Stations?		Yes	Yes	Yes	Yes	Yes	Yes
1835	Curtailment (%)	Gas Core [%]	100%	100%	100%	100%	100%	100%
1836		Gas EG [%]	100%	100%	100%	100%	100%	100%
1837		Gas Non-Core Non-EG [%]	100%	100%	100%	100%	100%	100%
1838	Curtailment (Capacity)	Gas Core [MMcfd]	100	100	310	350	170	180
1839		Gas EG [MWh/d]	13,487	40,461	22,253	22,253	29,671	36,414
1840		Gas EG [MW]	562	1,686	927	927	1,236	1,517
1841	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	75	75	62	62	75	75
1842		Gas Core [# Affected]	868,838	868,838	868,838	868,838	868,838	868,838
1843		Gas EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A
1844	Gas Non-Core Non-EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A	

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

Line No.		1. Example Summer Low- EG Day MMcfd	2. Example Summer High- EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	D	E	F	G	H
1845	LNG Storage Alternate							
1846	LNG Storage / Otay Full / L3010 80%							
1847	LNG Storage Alternate	0	0	0	0	0	0	0
1848	Line 3010 at 80% Supply	380	380	380	380	380	380	380
1849	Otay Mesa Full Supply	295	86	313	313	329	324	324
1850	Total Supply	675	466	693	693	709	704	704
1851	Total MMcfd Shortfall	0	9	0	0	0	0	0
1852	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	No
1853	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1854		Gas EG [%]	0%	0%	0%	0%	0%	0%
1855		Gas Non-Core Non-EG [%]	0%	12%	0%	0%	0%	0%
1856	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1857		Gas EG [MWh/d]	0	0	0	0	0	0
1858		Gas EG [MW]	0	0	0	0	0	0
1859		Gas Non-Core Non-EG [MMcfd]	0	9	0	0	0	0
1860	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	0
1861		Gas EG [# Affected]	0	0	0	0	0	0
1862		Gas Non-Core Non-EG [# Affected]	0	N/A	0	0	0	0
1863	LNG Storage / Otay Full / L3010 Out							
1864	LNG Storage Alternate	0	0	0	0	0	0	0
1865	Line 3010 Complete Outage	0	0	0	0	0	0	0
1866	Otay Mesa Full Supply	295	86	313	313	329	324	324
1867	Total Supply	295	86	313	313	329	324	324
1868	Total MMcfd Shortfall	0	389	224	264	136	201	201
1869	Immediate Curtailment to EG Stations?	No	Yes	Yes	Yes	Yes	Yes	Yes
1870	Curtailment (%)	Gas Core [%]	0%	14%	0%	11%	0%	0%
1871		Gas EG [%]	0%	100%	98%	100%	28%	47%
1872		Gas Non-Core Non-EG [%]	0%	100%	100%	100%	100%	100%
1873	Curtailment (Capacity)	Gas Core [MMcfd]	0	14	0	37	0	0
1874		Gas EG [MWh/d]	0	40,461	21,877	22,253	8,240	17,039
1875		Gas EG [MW]	0	1,686	912	927	343	710
1876		Gas Non-Core Non-EG [MMcfd]	0	75	62	62	75	75
1877	Number of Customers Affected	Gas Core [# Affected]	0	119,839	0	92,375	0	0
1878		Gas EG [# Affected]	0	N/A	N/A	N/A	N/A	N/A
1879		Gas Non-Core Non-EG [# Affected]	0	N/A	N/A	N/A	N/A	N/A
1880	LNG Storage / Otay Medium / L3010 80%							
1881	LNG Storage Alternate	0	0	0	0	0	0	0
1882	Line 3010 at 80% Supply	380	380	380	380	380	380	380
1883	Otay Mesa Medium Supply	156	60	230	230	244	247	247
1884	Total Supply	536	440	610	610	624	627	627
1885	Total MMcfd Shortfall	0	35	0	0	0	0	0
1886	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	No
1887	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1888		Gas EG [%]	0%	0%	0%	0%	0%	0%
1889		Gas Non-Core Non-EG [%]	0%	47%	0%	0%	0%	0%
1890	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1891		Gas EG [MWh/d]	0	0	0	0	0	0
1892		Gas EG [MW]	0	0	0	0	0	0
1893		Gas Non-Core Non-EG [MMcfd]	0	35	0	0	0	0
1894	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	0
1895		Gas EG [# Affected]	0	0	0	0	0	0
1896		Gas Non-Core Non-EG [# Affected]	0	N/A	0	0	0	0
1900	LNG Storage / Otay Medium / L3010 Out							
1901	LNG Storage Alternate	0	0	0	0	0	0	0
1902	Line 3010 Complete Outage	0	0	0	0	0	0	0
1903	Otay Mesa Medium Supply	156	60	230	230	244	247	247
1904	Total Supply	156	60	230	230	244	247	247
1905	Total MMcfd Shortfall	119	415	307	347	221	278	278
1906	Immediate Curtailment to EG Stations?	Yes	Yes	Yes	Yes	Yes	Yes	Yes
1907	Curtailment (%)	Gas Core [%]	0%	40%	26%	34%	0%	0%
1908		Gas EG [%]	44%	100%	100%	100%	66%	75%
1909		Gas Non-Core Non-EG [%]	100%	100%	100%	100%	100%	100%
1910	Curtailment (Capacity)	Gas Core [MMcfd]	0	40	80	120	0	0
1911		Gas EG [MWh/d]	5,978	40,461	22,253	22,253	19,672	27,355
1912		Gas EG [MW]	249	1,686	927	927	820	1,140
1913		Gas Non-Core Non-EG [MMcfd]	75	75	62	62	75	75
1914	Number of Customers Affected	Gas Core [# Affected]	0	349,638	224,454	298,098	0	0
1915		Gas EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A
1916		Gas Non-Core Non-EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

Line No.		1. Example Summer Low-EG Day MMcfd	2. Example Summer High-EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1-in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	D	E	F	G	H
1919								
1920	LNG Storage / Otay Low / L3010 80%		13.1.3.1	13.1.3.2	13.1.3.3	13.1.3.4	13.1.3.5	13.1.3.6
1921	LNG Storage Alternate		0	0	0	0	0	0
1922	Line 3010 at 80% Supply		380	380	380	380	380	380
1923	Otay Mesa Low Supply		33	33	148	148	130	168
1924	Total Supply		413	413	528	528	510	548
1925	Total MMcfd Shortfall		0	62	9	49	0	0
1926	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
1927	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1928		Gas EG [%]	0%	0%	0%	0%	0%	0%
1929		Gas Non-Core Non-EG [%]	0%	82%	14%	79%	0%	0%
1930	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1931		Gas EG [MWh/d]	0	0	0	0	0	0
1932		Gas EG [MW]	0	0	0	0	0	0
1933	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	62	9	49	0	0
1934		Gas Core [# Affected]	0	0	0	0	0	0
1935		Gas EG [# Affected]	0	0	0	0	0	0
1936		Gas Non-Core Non-EG [# Affected]	0	N/A	N/A	N/A	0	0
1937								
1938	LNG Storage / Otay Low / L3010 Out		13.2.3.1	13.2.3.2	13.2.3.3	13.2.3.4	13.2.3.5	13.2.3.6
1939	LNG Storage Alternate		0	0	0	0	0	0
1940	Line 3010 Complete Outage		0	0	0	0	0	0
1941	Otay Mesa Low Supply		33	33	148	148	130	168
1942	Total Supply		33	33	148	148	130	168
1943	Total MMcfd Shortfall		242	442	389	429	335	357
1944	Immediate Curtailment to EG Stations?		Yes	Yes	Yes	Yes	Yes	Yes
1945	Curtailment (%)	Gas Core [%]	67%	67%	52%	58%	23%	7%
1946		Gas EG [%]	100%	100%	100%	100%	100%	100%
1947		Gas Non-Core Non-EG [%]	100%	100%	100%	100%	100%	100%
1948	Curtailment (Capacity)	Gas Core [MMcfd]	67	67	162	202	40	12
1949		Gas EG [MWh/d]	13,487	40,461	22,253	22,253	29,671	36,414
1950		Gas EG [MW]	562	1,686	927	927	1,236	1,517
1951	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	75	75	62	62	75	75
1952		Gas Core [# Affected]	579,437	579,437	453,758	501,195	203,921	60,119
1953		Gas EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A
1954		Gas Non-Core Non-EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A
1955								
1956	LNG Storage / Otay Out / L3010 80%		13.1.4.1	13.1.4.2	13.1.4.3	13.1.4.4	13.1.4.5	13.1.4.6
1957	LNG Storage Alternate		0	0	0	0	0	0
1958	Line 3010 at 80% Supply		380	380	380	380	380	380
1959	Otay Mesa No Supply		0	0	0	0	0	0
1960	Total Supply		380	380	380	380	380	380
1961	Total MMcfd Shortfall		0	95	157	197	85	145
1962	Immediate Curtailment to EG Stations?		No	Yes	Yes	Yes	Yes	Yes
1963	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
1964		Gas EG [%]	0%	7%	58%	82%	5%	26%
1965		Gas Non-Core Non-EG [%]	0%	100%	100%	100%	100%	100%
1966	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
1967		Gas EG [MWh/d]	0	2,697	12,813	18,207	1,349	9,441
1968		Gas EG [MW]	0	112	534	759	56	393
1969	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	75	62	62	75	75
1970		Gas Core [# Affected]	0	0	0	0	0	0
1971		Gas EG [# Affected]	0	N/A	N/A	N/A	N/A	N/A
1972		Gas Non-Core Non-EG [# Affected]	0	N/A	N/A	N/A	N/A	N/A
1973								
1974	LNG Storage / Otay Out / L3010 Out		13.2.4.1	13.2.4.2	13.2.4.3	13.2.4.4	13.2.4.5	13.2.4.6
1975	LNG Storage Alternate		0	0	0	0	0	0
1976	Line 3010 Complete Outage		0	0	0	0	0	0
1977	Otay Mesa No Supply		0	0	0	0	0	0
1978	Total Supply		0	0	0	0	0	0
1979	Total MMcfd Shortfall		275	475	537	577	465	525
1980	Immediate Curtailment to EG Stations?		Yes	Yes	Yes	Yes	Yes	Yes
1981	Curtailment (%)	Gas Core [%]	100%	100%	100%	100%	100%	100%
1982		Gas EG [%]	100%	100%	100%	100%	100%	100%
1983		Gas Non-Core Non-EG [%]	100%	100%	100%	100%	100%	100%
1984	Curtailment (Capacity)	Gas Core [MMcfd]	100	100	310	350	170	180
1985		Gas EG [MWh/d]	13,487	40,461	22,253	22,253	29,671	36,414
1986		Gas EG [MW]	562	1,686	927	927	1,236	1,517
1987	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	75	75	62	62	75	75
1988		Gas Core [# Affected]	868,838	868,838	868,838	868,838	868,838	868,838
1989		Gas EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A
1990		Gas Non-Core Non-EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

		1. Example Summer Low- EG Day MMcfd	2. Example Summer High- EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	D	E	F	G	H
1								
2								
1991	Alt Energy Alternate (Grid-Scale)							
1992								
1993								
1994	Alt Energy (Grid) / Otay Full / L3010 80%							
1995			14.1.1.1	14.1.1.2	14.1.1.3	14.1.1.4	14.1.1.5	14.1.1.6
1996	Alt Energy Alternate (Grid-Scale)	0	0	0	0	0	0	0
1997	Line 3010 at 80% Supply	380	380	380	380	380	380	380
1998	Otay Mesa Full Supply	295	86	313	313	329	324	
1999	Total Supply	675	466	693	693	709	704	
2000	Total MMcfd Shortfall	0	9	0	0	0	0	
2001	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	
2002	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
2003		Gas EG [%]	0%	0%	0%	0%	0%	0%
2004		Gas Non-Core Non-EG [%]	0%	12%	0%	0%	0%	0%
2005	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
2006		Gas EG [MWh/d]	0	0	0	0	0	0
2007		Gas EG [MW]	0	0	0	0	0	0
2008	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	9	0	0	0	0
2009		Gas Core [# Affected]	0	0	0	0	0	0
2010		Gas EG [# Affected]	0	0	0	0	0	0
2011								
2012	Alt Energy (Grid) / Otay Full / L3010 Out							
2013			14.2.1.1	14.2.1.2	14.2.1.3	14.2.1.4	14.2.1.5	14.2.1.6
2014	Alt Energy Alternate (Grid-Scale)	0	0	0	0	0	0	0
2015	Line 3010 Complete Outage	0	0	0	0	0	0	0
2016	Otay Mesa Full Supply	295	86	313	313	329	324	
2017	Total Supply	295	86	313	313	329	324	
2018	Total MMcfd Shortfall	0	389	224	264	136	201	
2019	Immediate Curtailment to EG Stations?	No	Yes	Yes	Yes	Yes	Yes	
2020	Curtailment (%)	Gas Core [%]	0%	14%	0%	11%	0%	0%
2021		Gas EG [%]	0%	100%	98%	100%	28%	47%
2022		Gas Non-Core Non-EG [%]	0%	100%	100%	100%	100%	100%
2023	Curtailment (Capacity)	Gas Core [MMcfd]	0	14	0	37	0	0
2024		Gas EG [MWh/d]	0	40,461	21,877	22,253	8,240	17,039
2025		Gas EG [MW]	0	1,686	912	927	343	710
2026	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	75	62	62	75	75
2027		Gas Core [# Affected]	0	119,839	0	92,375	0	0
2028		Gas EG [# Affected]	0	N/A	N/A	N/A	N/A	N/A
2029								
2030	Alt Energy (Grid) / Otay Medium / L3010 80%							
2031			14.1.2.1	14.1.2.2	14.1.2.3	14.1.2.4	14.1.2.5	14.1.2.6
2032	Alt Energy Alternate (Grid-Scale)	0	0	0	0	0	0	0
2033	Line 3010 at 80% Supply	380	380	380	380	380	380	380
2034	Otay Mesa Medium Supply	156	60	230	230	244	247	
2035	Total Supply	536	440	610	610	624	627	
2036	Total MMcfd Shortfall	0	35	0	0	0	0	
2037	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	
2038	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
2039		Gas EG [%]	0%	0%	0%	0%	0%	0%
2040		Gas Non-Core Non-EG [%]	0%	47%	0%	0%	0%	0%
2041	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
2042		Gas EG [MWh/d]	0	0	0	0	0	0
2043		Gas EG [MW]	0	0	0	0	0	0
2044	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	35	0	0	0	0
2045		Gas Core [# Affected]	0	0	0	0	0	0
2046		Gas EG [# Affected]	0	0	0	0	0	0
2047								
2048	Alt Energy (Grid) / Otay Medium / L3010 Out							
2049			14.2.2.1	14.2.2.2	14.2.2.3	14.2.2.4	14.2.2.5	14.2.2.6
2050	Alt Energy Alternate (Grid-Scale)	0	0	0	0	0	0	0
2051	Line 3010 Complete Outage	0	0	0	0	0	0	0
2052	Otay Mesa Medium Supply	156	60	230	230	244	247	
2053	Total Supply	156	60	230	230	244	247	
2054	Total MMcfd Shortfall	119	415	307	347	221	278	
2055	Immediate Curtailment to EG Stations?	Yes	Yes	Yes	Yes	Yes	Yes	
2056	Curtailment (%)	Gas Core [%]	0%	40%	26%	34%	0%	0%
2057		Gas EG [%]	44%	100%	100%	100%	66%	75%
2058		Gas Non-Core Non-EG [%]	100%	100%	100%	100%	100%	100%
2059	Curtailment (Capacity)	Gas Core [MMcfd]	0	40	80	120	0	0
2060		Gas EG [MWh/d]	5,978	40,461	22,253	22,253	19,672	27,355
2061		Gas EG [MW]	249	1,686	927	927	820	1,140
2062	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	75	75	62	62	75	75
2063		Gas Core [# Affected]	0	349,638	224,454	298,098	0	0
2064		Gas EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A
2064								

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1)
 EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
 CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.		1. Example Summer Low- EG Day MMcfd	2. Example Summer High- EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	D	E	F	G	H
2065								
2066	Alt Energy (Grid) / Otay Low / L3010 80%	14.1.3.1	14.1.3.2	14.1.3.3	14.1.3.4	14.1.3.5	14.1.3.6	
2067	Alt Energy Alternate (Grid-Scale)	0	0	0	0	0	0	0
2068	Line 3010 at 80% Supply	380	380	380	380	380	380	380
2069	Otay Mesa Low Supply	33	33	148	148	130	168	
2070	Total Supply	413	413	528	528	510	548	
2071	Total MMcfd Shortfall	0	62	9	49	0	0	
2072	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	
2073	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
2074		Gas EG [%]	0%	0%	0%	0%	0%	0%
2075		Gas Non-Core Non-EG [%]	0%	82%	14%	79%	0%	0%
2076	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
2077		Gas EG [MWh/d]	0	0	0	0	0	0
2078		Gas EG [MW]	0	0	0	0	0	0
2079		Gas Non-Core Non-EG [MMcfd]	0	62	9	49	0	0
2080	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	0
2081		Gas EG [# Affected]	0	0	0	0	0	0
2082		Gas Non-Core Non-EG [# Affected]	0	N/A	N/A	N/A	0	0
2083								
2084	Alt Energy (Grid) / Otay Low / L3010 Out	14.2.3.1	14.2.3.2	14.2.3.3	14.2.3.4	14.2.3.5	14.2.3.6	
2085	Alt Energy Alternate (Grid-Scale)	0	0	0	0	0	0	0
2086	Line 3010 Complete Outage	0	0	0	0	0	0	0
2087	Otay Mesa Low Supply	33	33	148	148	130	168	
2088	Total Supply	33	33	148	148	130	168	
2089	Total MMcfd Shortfall	242	442	389	429	335	357	
2090	Immediate Curtailment to EG Stations?	Yes	Yes	Yes	Yes	Yes	Yes	
2091	Curtailment (%)	Gas Core [%]	67%	67%	52%	58%	23%	7%
2092		Gas EG [%]	100%	100%	100%	100%	100%	100%
2093		Gas Non-Core Non-EG [%]	100%	100%	100%	100%	100%	100%
2094	Curtailment (Capacity)	Gas Core [MMcfd]	67	67	162	202	40	12
2095		Gas EG [MWh/d]	13,487	40,461	22,253	22,253	29,671	36,414
2096		Gas EG [MW]	562	1,686	927	927	1,236	1,517
2097		Gas Non-Core Non-EG [MMcfd]	75	75	62	62	75	75
2098	Number of Customers Affected	Gas Core [# Affected]	579,437	579,437	453,758	501,195	203,921	60,119
2099		Gas EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A
2100		Gas Non-Core Non-EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A
2101								
2102	Alt Energy (Grid) / Otay Out / L3010 80%	14.1.4.1	14.1.4.2	14.1.4.3	14.1.4.4	14.1.4.5	14.1.4.6	
2103	Alt Energy Alternate (Grid-Scale)	0	0	0	0	0	0	0
2104	Line 3010 at 80% Supply	380	380	380	380	380	380	380
2105	Otay Mesa No Supply	0	0	0	0	0	0	0
2106	Total Supply	380	380	380	380	380	380	
2107	Total MMcfd Shortfall	0	95	157	197	85	145	
2108	Immediate Curtailment to EG Stations?	No	Yes	Yes	Yes	Yes	Yes	
2109	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
2110		Gas EG [%]	0%	7%	58%	82%	5%	26%
2111		Gas Non-Core Non-EG [%]	0%	100%	100%	100%	100%	100%
2112	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
2113		Gas EG [MWh/d]	0	2,697	12,813	18,207	1,349	9,441
2114		Gas EG [MW]	0	112	534	759	56	393
2115		Gas Non-Core Non-EG [MMcfd]	0	75	62	62	75	75
2116	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	0
2117		Gas EG [# Affected]	0	N/A	N/A	N/A	N/A	N/A
2118		Gas Non-Core Non-EG [# Affected]	0	N/A	N/A	N/A	N/A	N/A
2119								
2120	Alt Energy (Grid) / Otay Out / L3010 Out	14.2.4.1	14.2.4.2	14.2.4.3	14.2.4.4	14.2.4.5	14.2.4.6	
2121	Alt Energy Alternate (Grid-Scale)	0	0	0	0	0	0	0
2122	Line 3010 Complete Outage	0	0	0	0	0	0	0
2123	Otay Mesa No Supply	0	0	0	0	0	0	0
2124	Total Supply	0	0	0	0	0	0	
2125	Total MMcfd Shortfall	275	475	537	577	465	525	
2126	Immediate Curtailment to EG Stations?	Yes	Yes	Yes	Yes	Yes	Yes	
2127	Curtailment (%)	Gas Core [%]	100%	100%	100%	100%	100%	100%
2128		Gas EG [%]	100%	100%	100%	100%	100%	100%
2129		Gas Non-Core Non-EG [%]	100%	100%	100%	100%	100%	100%
2130	Curtailment (Capacity)	Gas Core [MMcfd]	100	100	310	350	170	180
2131		Gas EG [MWh/d]	13,487	40,461	22,253	22,253	29,671	36,414
2132		Gas EG [MW]	562	1,686	927	927	1,236	1,517
2133		Gas Non-Core Non-EG [MMcfd]	75	75	62	62	75	75
2134	Number of Customers Affected	Gas Core [# Affected]	868,838	868,838	868,838	868,838	868,838	868,838
2135		Gas EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A
2136		Gas Non-Core Non-EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1)
 EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
 CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low- EG Day MMcfd	2. Example Summer High- EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	E	F	G	H
1							
2							
2137	Alt Energy Alternate (Smaller-Scale)						
2138	Alt Energy (Small) / Otay Full / L3010 80%						
2139	Alt Energy Alternate (Smaller-Scale)	0	0	0	0	0	0
2140	Line 3010 at 80% Supply	380	380	380	380	380	380
2141	Otay Mesa Full Supply	295	86	313	313	329	324
2142	Total Supply	675	466	693	693	709	704
2143	Total MMcfd Shortfall	0	9	0	0	0	0
2144	Immediate Curtailment to EG Stations?	No	No	No	No	No	No
2145	Curtailment (%)	0%	0%	0%	0%	0%	0%
2146	Gas Core [%]	0%	0%	0%	0%	0%	0%
2147	Gas EG [%]	0%	0%	0%	0%	0%	0%
2148	Gas Non-Core Non-EG [%]	0%	12%	0%	0%	0%	0%
2149	Gas Core [MMcfd]	0	0	0	0	0	0
2150	Gas EG [MWh/d]	0	0	0	0	0	0
2151	Gas EG [MW]	0	0	0	0	0	0
2152	Gas Non-Core Non-EG [MMcfd]	0	9	0	0	0	0
2153	Number of Customers	0	0	0	0	0	0
2154	Gas Core [# Affected]	0	0	0	0	0	0
2155	Gas EG [# Affected]	0	0	0	0	0	0
2156	Gas Non-Core Non-EG [# Affected]	0	N/A	0	0	0	0
2157							
2158	Alt Energy (Small) / Otay Full / L3010 Out						
2159	Alt Energy Alternate (Smaller-Scale)	0	0	0	0	0	0
2160	Line 3010 Complete Outage	0	0	0	0	0	0
2161	Otay Mesa Full Supply	295	86	313	313	329	324
2162	Total Supply	295	86	313	313	329	324
2163	Total MMcfd Shortfall	0	389	224	264	136	201
2164	Immediate Curtailment to EG Stations?	No	Yes	Yes	Yes	Yes	Yes
2165	Curtailment (%)	0%	14%	0%	11%	0%	0%
2166	Gas Core [%]	0%	14%	0%	11%	0%	0%
2167	Gas EG [%]	0%	100%	98%	100%	28%	47%
2168	Gas Non-Core Non-EG [%]	0%	100%	100%	100%	100%	100%
2169	Gas Core [MMcfd]	0	14	0	37	0	0
2170	Gas EG [MWh/d]	0	40,461	21,877	22,253	8,240	17,039
2171	Gas EG [MW]	0	1,686	912	927	343	710
2172	Gas Non-Core Non-EG [MMcfd]	0	75	62	62	75	75
2173	Number of Customers	0	119,839	0	92,375	0	0
2174	Gas Core [# Affected]	0	119,839	0	92,375	0	0
2175	Gas EG [# Affected]	0	N/A	N/A	N/A	N/A	N/A
2176	Gas Non-Core Non-EG [# Affected]	0	N/A	N/A	N/A	N/A	N/A
2177							
2178	Alt Energy (Small) / Otay Medium / L3010 80%						
2179	Alt Energy Alternate (Smaller-Scale)	0	0	0	0	0	0
2180	Line 3010 at 80% Supply	380	380	380	380	380	380
2181	Otay Mesa Medium Supply	156	60	230	230	244	247
2182	Total Supply	536	440	610	610	624	627
2183	Total MMcfd Shortfall	0	35	0	0	0	0
2184	Immediate Curtailment to EG Stations?	No	No	No	No	No	No
2185	Curtailment (%)	0%	0%	0%	0%	0%	0%
2186	Gas Core [%]	0%	0%	0%	0%	0%	0%
2187	Gas EG [%]	0%	0%	0%	0%	0%	0%
2188	Gas Non-Core Non-EG [%]	0%	47%	0%	0%	0%	0%
2189	Gas Core [MMcfd]	0	0	0	0	0	0
2190	Gas EG [MWh/d]	0	0	0	0	0	0
2191	Gas EG [MW]	0	0	0	0	0	0
2192	Gas Non-Core Non-EG [MMcfd]	0	35	0	0	0	0
2193	Number of Customers	0	0	0	0	0	0
2194	Gas Core [# Affected]	0	0	0	0	0	0
2195	Gas EG [# Affected]	0	0	0	0	0	0
2196	Gas Non-Core Non-EG [# Affected]	0	N/A	0	0	0	0
2197							
2198	Alt Energy (Small) / Otay Medium / L3010 Out						
2199	Alt Energy Alternate (Smaller-Scale)	0	0	0	0	0	0
2200	Line 3010 Complete Outage	0	0	0	0	0	0
2201	Otay Mesa Medium Supply	156	60	230	230	244	247
2202	Total Supply	156	60	230	230	244	247
2203	Total MMcfd Shortfall	119	415	307	347	221	278
2204	Immediate Curtailment to EG Stations?	Yes	Yes	Yes	Yes	Yes	Yes
2205	Curtailment (%)	0%	40%	26%	34%	0%	0%
2206	Gas Core [%]	0%	40%	26%	34%	0%	0%
2207	Gas EG [%]	44%	100%	100%	100%	66%	75%
2208	Gas Non-Core Non-EG [%]	100%	100%	100%	100%	100%	100%
2209	Gas Core [MMcfd]	0	40	80	120	0	0
2210	Gas EG [MWh/d]	5,978	40,461	22,253	22,253	19,672	27,355
2211	Gas EG [MW]	249	1,686	927	927	820	1,140
2212	Gas Non-Core Non-EG [MMcfd]	75	75	62	62	75	75
2213	Number of Customers	0	349,638	224,454	298,098	0	0
2214	Gas Core [# Affected]	0	349,638	224,454	298,098	0	0
2215	Gas EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A
2216	Gas Non-Core Non-EG [# Affected]	N/A	N/A	N/A	N/A	N/A	N/A

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

Line No.		1. Example Summer Low-EG Day MMcfd	2. Example Summer High-EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1-in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	D	E	F	G	H
1								
2								
2211								
2212								
2213								
2214								
2215								
2216								
2217								
2218								
2219								
2220								
2221								
2222								
2223								
2224								
2225								
2226								
2227								
2228								
2229								
2230								
2231								
2232								
2233								
2234								
2235								
2236								
2237								
2238								
2239								
2240								
2241								
2242								
2243								
2244								
2245								
2246								
2247								
2248								
2249								
2250								
2251								
2252								
2253								
2254								
2255								
2256								
2257								
2258								
2259								
2260								
2261								
2262								
2263								
2264								
2265								
2266								
2267								
2268								
2269								
2270								
2271								
2272								
2273								
2274								
2275								
2276								
2277								
2278								
2279								
2280								
2281								
2282								

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low- EG Day MMcfd	2. Example Summer High EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	E	F	G	H
1							
2							
2283	Offshore Route						
2284	Offshore / Otay Full / L3010 80%						
2285							
2286	15.1.1.1	15.1.1.2	15.1.1.3	15.1.1.4	15.1.1.5	15.1.1.6	
2287	Offshore Route	680	680	680	680	680	680
2288	Line 3010 at 80% Supply	380	380	380	380	380	380
2289	Otay Mesa Full Supply	295	86	313	313	329	324
2290	Total Supply	1355	1146	1373	1373	1389	1384
2291	Total MMcfd Shortfall	0	0	0	0	0	0
2292	Immediate Curtailment to EG Stations?	No	No	No	No	No	No
2293	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%
2294		Gas EG [%]	0%	0%	0%	0%	0%
2295		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%
2296	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0
2297		Gas EG [MWh/d]	0	0	0	0	0
2298		Gas EG [MW]	0	0	0	0	0
2299		Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0
2300	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0
2301		Gas EG [# Affected]	0	0	0	0	0
2302		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0
2303							
2304	Offshore / Otay Full / L3010 Out						
2305							
2306	15.2.1.1	15.2.1.2	15.2.1.3	15.2.1.4	15.2.1.5	15.2.1.6	
2307	Offshore Route	680	680	680	680	680	680
2308	Line 3010 Complete Outage	0	0	0	0	0	0
2309	Otay Mesa Full Supply	295	86	313	313	329	324
2310	Total Supply	975	766	993	993	1009	1004
2311	Total MMcfd Shortfall	0	0	0	0	0	0
2312	Immediate Curtailment to EG Stations?	No	No	No	No	No	No
2313	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%
2314		Gas EG [%]	0%	0%	0%	0%	0%
2315		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%
2316	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0
2317		Gas EG [MWh/d]	0	0	0	0	0
2318		Gas EG [MW]	0	0	0	0	0
2319		Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0
2320	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0
2321		Gas EG [# Affected]	0	0	0	0	0
2322		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0
2323							
2324	Offshore / Otay Medium / L3010 80%						
2325							
2326	15.1.2.1	15.1.2.2	15.1.2.3	15.1.2.4	15.1.2.5	15.1.2.6	
2327	Offshore Route	680	680	680	680	680	680
2328	Line 3010 at 80% Supply	380	380	380	380	380	380
2329	Otay Mesa Medium Supply	156	60	230	230	244	247
2330	Total Supply	1216	1120	1290	1290	1304	1307
2331	Total MMcfd Shortfall	0	0	0	0	0	0
2332	Immediate Curtailment to EG Stations?	No	No	No	No	No	No
2333	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%
2334		Gas EG [%]	0%	0%	0%	0%	0%
2335		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%
2336	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0
2337		Gas EG [MWh/d]	0	0	0	0	0
2338		Gas EG [MW]	0	0	0	0	0
2339		Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0
2340	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0
2341		Gas EG [# Affected]	0	0	0	0	0
2342		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0
2343							
2344	Offshore / Otay Medium / L3010 Out						
2345							
2346	15.2.2.1	15.2.2.2	15.2.2.3	15.2.2.4	15.2.2.5	15.2.2.6	
2347	Offshore Route	680	680	680	680	680	680
2348	Line 3010 Complete Outage	0	0	0	0	0	0
2349	Otay Mesa Medium Supply	156	60	230	230	244	247
2350	Total Supply	836	740	910	910	924	927
2351	Total MMcfd Shortfall	0	0	0	0	0	0
2352	Immediate Curtailment to EG Stations?	No	No	No	No	No	No
2353	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%
2354		Gas EG [%]	0%	0%	0%	0%	0%
2355		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%
2356	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0
2357		Gas EG [MWh/d]	0	0	0	0	0
2358		Gas EG [MW]	0	0	0	0	0
2359		Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0
2360	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0
2361		Gas EG [# Affected]	0	0	0	0	0
2362		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

1		1. Example Summer Low-EG Day MMcf/d	2. Example Summer High-EG Day MMcf/d	3. Example Winter Day MMcf/d	4. Winter 1-in-10 Year Day MMcf/d	5. Example Spring Day MMcf/d	6. Example Fall Day MMcf/d	
2	A	B	C	D	E	F	G	H
2357								
2358	Offshore / Otay Low / L3010 80%		15.1.3.1	15.1.3.2	15.1.3.3	15.1.3.4	15.1.3.5	15.1.3.6
2359	Offshore Route		680	680	680	680	680	680
2360	Line 3010 at 80% Supply		380	380	380	380	380	380
2361	Otay Mesa Low Supply		33	33	148	148	130	168
2362	Total Supply		1093	1093	1208	1208	1190	1228
2363	Total MMcf/d Shortfall		0	0	0	0	0	0
2364	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
2365	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
2366		Gas EG [%]	0%	0%	0%	0%	0%	0%
2367		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
2368	Curtailment (Capacity)	Gas Core [MMcf/d]	0	0	0	0	0	0
2369		Gas EG [MWh/d]	0	0	0	0	0	0
2370		Gas EG [MW]	0	0	0	0	0	0
2371	Number of Customers Affected	Gas Non-Core Non-EG [MMcf/d]	0	0	0	0	0	0
2372		Gas Core [# Affected]	0	0	0	0	0	0
2373		Gas EG [# Affected]	0	0	0	0	0	0
2374		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
2375								
2376	Offshore / Otay Low / L3010 Out		15.2.3.1	15.2.3.2	15.2.3.3	15.2.3.4	15.2.3.5	15.2.3.6
2377	Offshore Route		680	680	680	680	680	680
2378	Line 3010 Complete Outage		0	0	0	0	0	0
2379	Otay Mesa Low Supply		33	33	148	148	130	168
2380	Total Supply		713	713	828	828	810	848
2381	Total MMcf/d Shortfall		0	0	0	0	0	0
2382	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
2383	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
2384		Gas EG [%]	0%	0%	0%	0%	0%	0%
2385		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
2386	Curtailment (Capacity)	Gas Core [MMcf/d]	0	0	0	0	0	0
2387		Gas EG [MWh/d]	0	0	0	0	0	0
2388		Gas EG [MW]	0	0	0	0	0	0
2389	Number of Customers Affected	Gas Non-Core Non-EG [MMcf/d]	0	0	0	0	0	0
2390		Gas Core [# Affected]	0	0	0	0	0	0
2391		Gas EG [# Affected]	0	0	0	0	0	0
2392		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
2393								
2394	Offshore / Otay Out / L3010 80%		15.1.4.1	15.1.4.2	15.1.4.3	15.1.4.4	15.1.4.5	15.1.4.6
2395	Offshore Route		680	680	680	680	680	680
2396	Line 3010 at 80% Supply		380	380	380	380	380	380
2397	Otay Mesa No Supply		0	0	0	0	0	0
2398	Total Supply		1060	1060	1060	1060	1060	1060
2399	Total MMcf/d Shortfall		0	0	0	0	0	0
2400	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
2401	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
2402		Gas EG [%]	0%	0%	0%	0%	0%	0%
2403		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
2404	Curtailment (Capacity)	Gas Core [MMcf/d]	0	0	0	0	0	0
2405		Gas EG [MWh/d]	0	0	0	0	0	0
2406		Gas EG [MW]	0	0	0	0	0	0
2407	Number of Customers Affected	Gas Non-Core Non-EG [MMcf/d]	0	0	0	0	0	0
2408		Gas Core [# Affected]	0	0	0	0	0	0
2409		Gas EG [# Affected]	0	0	0	0	0	0
2410		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
2411								
2412	Offshore / Otay Out / L3010 Out		15.2.4.1	15.2.4.2	15.2.4.3	15.2.4.4	15.2.4.5	15.2.4.6
2413	Offshore Route		680	680	680	680	680	680
2414	Line 3010 Complete Outage		0	0	0	0	0	0
2415	Otay Mesa No Supply		0	0	0	0	0	0
2416	Total Supply		680	680	680	680	680	680
2417	Total MMcf/d Shortfall		0	0	0	0	0	0
2418	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
2419	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
2420		Gas EG [%]	0%	0%	0%	0%	0%	0%
2421		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
2422	Curtailment (Capacity)	Gas Core [MMcf/d]	0	0	0	0	0	0
2423		Gas EG [MWh/d]	0	0	0	0	0	0
2424		Gas EG [MW]	0	0	0	0	0	0
2425	Number of Customers Affected	Gas Non-Core Non-EG [MMcf/d]	0	0	0	0	0	0
2426		Gas Core [# Affected]	0	0	0	0	0	0
2427		Gas EG [# Affected]	0	0	0	0	0	0
2428		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1)
 EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
 CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low- EG Day MMcfd	2. Example Summer High EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd		
	A	B	C	D	E	F	G	H
1								
2								
2429	<i>Blythe to Santee Alternate 1</i>							
2430	<i>Blythe to Santee 1 / Otay Full / L3010 80%</i>							
2431								
2432								
2433								
2434								
2435								
2436								
2437								
2438								
2439								
2440								
2441								
2442								
2443								
2444								
2445								
2446								
2447								
2448								
2449								
2450	<i>Blythe to Santee 1 / Otay Full / L3010 Out</i>							
2451								
2452								
2453								
2454								
2455								
2456								
2457								
2458								
2459								
2460								
2461								
2462								
2463								
2464								
2465								
2466								
2467								
2468	<i>Blythe to Santee 1 / Otay Medium / L3010 80%</i>							
2469								
2470								
2471								
2472								
2473								
2474								
2475								
2476								
2477								
2478								
2479								
2480								
2481								
2482								
2483								
2484								
2485								
2486	<i>Blythe to Santee 1 / Otay Medium / L3010 Out</i>							
2487								
2488								
2489								
2490								
2491								
2492								
2493								
2494								
2495								
2496								
2497								
2498								
2499								
2500								
2501								
2502								

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.		1. Example Summer Low-EG Day MMcfd	2. Example Summer High-EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1-in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	D	E	F	G	H
2503								
2504	Blythe to Santee 1 / Otay Low / L3010 80%							
2505	Blythe to Santee Alternate 1		680	680	680	680	680	680
2506	Line 3010 at 80% Supply		380	380	380	380	380	380
2507	Otay Mesa Low Supply		33	33	148	148	130	168
2508	Total Supply		1093	1093	1208	1208	1190	1228
2509	Total MMcfd Shortfall		0	0	0	0	0	0
2510	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
2511	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
2512		Gas EG [%]	0%	0%	0%	0%	0%	0%
2513		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
2514	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
2515		Gas EG [MWh/d]	0	0	0	0	0	0
2516		Gas EG [MW]	0	0	0	0	0	0
2517	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
2518		Gas Core [# Affected]	0	0	0	0	0	0
2519		Gas EG [# Affected]	0	0	0	0	0	0
2520		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
2521								
2522	Blythe to Santee 1 / Otay Low / L3010 Out							
2523	Blythe to Santee Alternate 1		680	680	680	680	680	680
2524	Line 3010 Complete Outage		0	0	0	0	0	0
2525	Otay Mesa Low Supply		33	33	148	148	130	168
2526	Total Supply		713	713	828	828	810	848
2527	Total MMcfd Shortfall		0	0	0	0	0	0
2528	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
2529	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
2530		Gas EG [%]	0%	0%	0%	0%	0%	0%
2531		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
2532	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
2533		Gas EG [MWh/d]	0	0	0	0	0	0
2534		Gas EG [MW]	0	0	0	0	0	0
2535	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
2536		Gas Core [# Affected]	0	0	0	0	0	0
2537		Gas EG [# Affected]	0	0	0	0	0	0
2538		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
2539								
2540	Blythe to Santee 1 / Otay Out / L3010 80%							
2541	Blythe to Santee Alternate 1		680	680	680	680	680	680
2542	Line 3010 at 80% Supply		380	380	380	380	380	380
2543	Otay Mesa No Supply		0	0	0	0	0	0
2544	Total Supply		1060	1060	1060	1060	1060	1060
2545	Total MMcfd Shortfall		0	0	0	0	0	0
2546	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
2547	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
2548		Gas EG [%]	0%	0%	0%	0%	0%	0%
2549		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
2550	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
2551		Gas EG [MWh/d]	0	0	0	0	0	0
2552		Gas EG [MW]	0	0	0	0	0	0
2553	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
2554		Gas Core [# Affected]	0	0	0	0	0	0
2555		Gas EG [# Affected]	0	0	0	0	0	0
2556		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
2557								
2558	Blythe to Santee 1 / Otay Out / L3010 Out							
2559	Blythe to Santee Alternate 1		680	680	680	680	680	680
2560	Line 3010 Complete Outage		0	0	0	0	0	0
2561	Otay Mesa No Supply		0	0	0	0	0	0
2562	Total Supply		680	680	680	680	680	680
2563	Total MMcfd Shortfall		0	0	0	0	0	0
2564	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
2565	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
2566		Gas EG [%]	0%	0%	0%	0%	0%	0%
2567		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
2568	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
2569		Gas EG [MWh/d]	0	0	0	0	0	0
2570		Gas EG [MW]	0	0	0	0	0	0
2571	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
2572		Gas Core [# Affected]	0	0	0	0	0	0
2573		Gas EG [# Affected]	0	0	0	0	0	0
2574		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1)
 EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
 CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low- EG Day MMcfd	2. Example Summer High EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd		
	A	B	C	D	E	F	G	H
1								
2								
2575								
2576	<i>Blythe to Santee Alternate 2</i>							
2577								
2578	<i>Blythe to Santee 2 / Otay Full / L3010 80%</i>							
2579		680	680	680	680	680	680	680
2580	Line 3010 at 80% Supply	380	380	380	380	380	380	380
2581	Otay Mesa Full Supply	295	86	313	313	329	324	
2582	Total Supply	1355	1146	1373	1373	1389	1384	
2583	Total MMcfd Shortfall	0	0	0	0	0	0	
2584	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	
2585	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
2586		Gas EG [%]	0%	0%	0%	0%	0%	0%
2587		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
2588	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
2589		Gas EG [MWh/d]	0	0	0	0	0	0
2590		Gas EG [MW]	0	0	0	0	0	0
2591		Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
2592	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	0
2593		Gas EG [# Affected]	0	0	0	0	0	0
2594		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
2595								
2596	<i>Blythe to Santee 2 / Otay Full / L3010 Out</i>							
2597		680	680	680	680	680	680	
2598	Line 3010 Complete Outage	0	0	0	0	0	0	
2599	Otay Mesa Full Supply	295	86	313	313	329	324	
2600	Total Supply	975	766	993	993	1009	1004	
2601	Total MMcfd Shortfall	0	0	0	0	0	0	
2602	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	
2603	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
2604		Gas EG [%]	0%	0%	0%	0%	0%	0%
2605		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
2606	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
2607		Gas EG [MWh/d]	0	0	0	0	0	0
2608		Gas EG [MW]	0	0	0	0	0	0
2609		Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
2610	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	0
2611		Gas EG [# Affected]	0	0	0	0	0	0
2612		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
2613								
2614	<i>Blythe to Santee 2 / Otay Medium / L3010 80%</i>							
2615		680	680	680	680	680	680	
2616	Line 3010 at 80% Supply	380	380	380	380	380	380	
2617	Otay Mesa Medium Supply	156	60	230	230	244	247	
2618	Total Supply	1216	1120	1290	1290	1304	1307	
2619	Total MMcfd Shortfall	0	0	0	0	0	0	
2620	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	
2621	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
2622		Gas EG [%]	0%	0%	0%	0%	0%	0%
2623		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
2624	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
2625		Gas EG [MWh/d]	0	0	0	0	0	0
2626		Gas EG [MW]	0	0	0	0	0	0
2627		Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
2628	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	0
2629		Gas EG [# Affected]	0	0	0	0	0	0
2630		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
2631								
2632	<i>Blythe to Santee 2 / Otay Medium / L3010 Out</i>							
2633		680	680	680	680	680	680	
2634	Line 3010 Complete Outage	0	0	0	0	0	0	
2635	Otay Mesa Medium Supply	156	60	230	230	244	247	
2636	Total Supply	836	740	910	910	924	927	
2637	Total MMcfd Shortfall	0	0	0	0	0	0	
2638	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	
2639	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
2640		Gas EG [%]	0%	0%	0%	0%	0%	0%
2641		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
2642	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
2643		Gas EG [MWh/d]	0	0	0	0	0	0
2644		Gas EG [MW]	0	0	0	0	0	0
2645		Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
2646	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	0
2647		Gas EG [# Affected]	0	0	0	0	0	0
2648		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

Line No.		1. Example Summer Low-EG Day MMcfd	2. Example Summer High-EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1-in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	D	E	F	G	H
2649								
2650	Blythe to Santee 2 / Otay Low / L3010 80%							
2651	Blythe to Santee Alternate 2		680	680	680	680	680	680
2652	Line 3010 at 80% Supply		380	380	380	380	380	380
2653	Otay Mesa Low Supply		33	33	148	148	130	168
2654	Total Supply		1093	1093	1208	1208	1190	1228
2655	Total MMcfd Shortfall		0	0	0	0	0	0
2656	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
2657	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
2658		Gas EG [%]	0%	0%	0%	0%	0%	0%
2659		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
2660	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
2661		Gas EG [MWh/d]	0	0	0	0	0	0
2662		Gas EG [MW]	0	0	0	0	0	0
2663	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
2664		Gas Core [# Affected]	0	0	0	0	0	0
2665		Gas EG [# Affected]	0	0	0	0	0	0
2666		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
2667								
2668	Blythe to Santee 2 / Otay Low / L3010 Out							
2669	Blythe to Santee Alternate 2		680	680	680	680	680	680
2670	Line 3010 Complete Outage		0	0	0	0	0	0
2671	Otay Mesa Low Supply		33	33	148	148	130	168
2672	Total Supply		713	713	828	828	810	848
2673	Total MMcfd Shortfall		0	0	0	0	0	0
2674	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
2675	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
2676		Gas EG [%]	0%	0%	0%	0%	0%	0%
2677		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
2678	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
2679		Gas EG [MWh/d]	0	0	0	0	0	0
2680		Gas EG [MW]	0	0	0	0	0	0
2681	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
2682		Gas Core [# Affected]	0	0	0	0	0	0
2683		Gas EG [# Affected]	0	0	0	0	0	0
2684		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
2685								
2686	Blythe to Santee 2 / Otay Out / L3010 80%							
2687	Blythe to Santee Alternate 2		680	680	680	680	680	680
2688	Line 3010 at 80% Supply		380	380	380	380	380	380
2689	Otay Mesa No Supply		0	0	0	0	0	0
2690	Total Supply		1060	1060	1060	1060	1060	1060
2691	Total MMcfd Shortfall		0	0	0	0	0	0
2692	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
2693	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
2694		Gas EG [%]	0%	0%	0%	0%	0%	0%
2695		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
2696	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
2697		Gas EG [MWh/d]	0	0	0	0	0	0
2698		Gas EG [MW]	0	0	0	0	0	0
2699	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
2700		Gas Core [# Affected]	0	0	0	0	0	0
2701		Gas EG [# Affected]	0	0	0	0	0	0
2702		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
2703								
2704	Blythe to Santee 2 / Otay Out / L3010 Out							
2705	Blythe to Santee Alternate 2		680	680	680	680	680	680
2706	Line 3010 Complete Outage		0	0	0	0	0	0
2707	Otay Mesa No Supply		0	0	0	0	0	0
2708	Total Supply		680	680	680	680	680	680
2709	Total MMcfd Shortfall		0	0	0	0	0	0
2710	Immediate Curtailment to EG Stations?		No	No	No	No	No	No
2711	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
2712		Gas EG [%]	0%	0%	0%	0%	0%	0%
2713		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
2714	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
2715		Gas EG [MWh/d]	0	0	0	0	0	0
2716		Gas EG [MW]	0	0	0	0	0	0
2717	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
2718		Gas Core [# Affected]	0	0	0	0	0	0
2719		Gas EG [# Affected]	0	0	0	0	0	0
2720		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1)
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

		1. Example Summer Low- EG Day MMcfd	2. Example Summer High- EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
1								
2	A	B	C	D	E	F	G	H
2721	Cactus City to San Diego Alternate							
2722								
2723								
2724	Cactus City to SD / Otay Full / L3010 80%	18.1.1.1	18.1.1.2	18.1.1.3	18.1.1.4	18.1.1.5	18.1.1.6	
2725	Cactus City to San Diego Alternate	680	680	680	680	680	680	
2726	Line 3010 at 80% Supply	380	380	380	380	380	380	
2727	Otay Mesa Full Supply	295	86	313	313	329	324	
2728	Total Supply	1355	1146	1373	1373	1389	1384	
2729	Total MMcfd Shortfall	0	0	0	0	0	0	
2730	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	
2731	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	
2732		Gas EG [%]	0%	0%	0%	0%	0%	
2733		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	
2734	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	
2735		Gas EG [MWh/d]	0	0	0	0	0	
2736		Gas EG [MW]	0	0	0	0	0	
2737		Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	
2738	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	
2739		Gas EG [# Affected]	0	0	0	0	0	
2740		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	
2741								
2742	Cactus City to SD / Otay Full / L3010 Out	18.2.1.1	18.2.1.2	18.2.1.3	18.2.1.4	18.2.1.5	18.2.1.6	
2743	Cactus City to San Diego Alternate	680	680	680	680	680	680	
2744	Line 3010 Complete Outage	0	0	0	0	0	0	
2745	Otay Mesa Full Supply	295	86	313	313	329	324	
2746	Total Supply	975	766	993	993	1009	1004	
2747	Total MMcfd Shortfall	0	0	0	0	0	0	
2748	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	
2749	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	
2750		Gas EG [%]	0%	0%	0%	0%	0%	
2751		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	
2752	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	
2753		Gas EG [MWh/d]	0	0	0	0	0	
2754		Gas EG [MW]	0	0	0	0	0	
2755		Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	
2756	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	
2757		Gas EG [# Affected]	0	0	0	0	0	
2758		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	
2759								
2760	Cactus City to SD / Otay Medium / L3010 80%	18.1.2.1	18.1.2.2	18.1.2.3	18.1.2.4	18.1.2.5	18.1.2.6	
2761	Cactus City to San Diego Alternate	680	680	680	680	680	680	
2762	Line 3010 at 80% Supply	380	380	380	380	380	380	
2763	Otay Mesa Medium Supply	156	60	230	230	244	247	
2764	Total Supply	1216	1120	1290	1290	1304	1307	
2765	Total MMcfd Shortfall	0	0	0	0	0	0	
2766	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	
2767	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	
2768		Gas EG [%]	0%	0%	0%	0%	0%	
2769		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	
2770	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	
2771		Gas EG [MWh/d]	0	0	0	0	0	
2772		Gas EG [MW]	0	0	0	0	0	
2773		Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	
2774	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	
2775		Gas EG [# Affected]	0	0	0	0	0	
2776		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	
2777								
2778	Cactus City to SD / Otay Medium / L3010 Out	18.2.2.1	18.2.2.2	18.2.2.3	18.2.2.4	18.2.2.5	18.2.2.6	
2779	Cactus City to San Diego Alternate	680	680	680	680	680	680	
2780	Line 3010 Complete Outage	0	0	0	0	0	0	
2781	Otay Mesa Medium Supply	156	60	230	230	244	247	
2782	Total Supply	836	740	910	910	924	927	
2783	Total MMcfd Shortfall	0	0	0	0	0	0	
2784	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	
2785	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	
2786		Gas EG [%]	0%	0%	0%	0%	0%	
2787		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	
2788	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	
2789		Gas EG [MWh/d]	0	0	0	0	0	
2790		Gas EG [MW]	0	0	0	0	0	
2791		Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	
2792	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	
2793		Gas EG [# Affected]	0	0	0	0	0	
2794		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.		1. Example Summer Low-EG Day MMcfd	2. Example Summer High-EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1-in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	D	E	F	G	H
2795								
2796								
2797								
2798								
2799								
2800								
2801								
2802								
2803								
2804								
2805								
2806								
2807								
2808								
2809								
2810								
2811								
2812								
2813								
2814								
2815								
2816								
2817								
2818								
2819								
2820								
2821								
2822								
2823								
2824								
2825								
2826								
2827								
2828								
2829								
2830								
2831								
2832								
2833								
2834								
2835								
2836								
2837								
2838								
2839								
2840								
2841								
2842								
2843								
2844								
2845								
2846								
2847								
2848								
2849								
2850								
2851								
2852								
2853								
2854								
2855								
2856								
2857								
2858								
2859								
2860								
2861								
2862								
2863								
2864								
2865								
2866								

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1)
 EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
 CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

Line No.		1. Example Summer Low- EG Day MMcfd	2. Example Summer High- EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1- in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	D	E	F	G	H
1								
2								
2867	Second Pipeline Along L3010 Alternate							
2868	Second Pipeline Along L3010 / Otay Full / L3010 80%							
2869		19.1.1.1	19.1.1.2	19.1.1.3	19.1.1.4	19.1.1.5	19.1.1.6	
2870	Second Pipeline Along L3010 Alternate	680	680	680	680	680	680	680
2871	Line 3010 at 80% Supply	380	380	380	380	380	380	380
2872	Otay Mesa Full Supply	295	86	313	313	329	324	
2873	Total Supply	1355	1146	1373	1373	1389	1384	
2874	Total MMcfd Shortfall	0	0	0	0	0	0	
2875	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	
2876	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
2877		Gas EG [%]	0%	0%	0%	0%	0%	0%
2878		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
2879	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
2880		Gas EG [MWh/d]	0	0	0	0	0	0
2881		Gas EG [MW]	0	0	0	0	0	0
2882	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
2883		Gas Core [# Affected]	0	0	0	0	0	0
2884		Gas EG [# Affected]	0	0	0	0	0	0
2885		0	0	0	0	0	0	
2886		0	0	0	0	0	0	
2887	Second Pipeline Along L3010 / Otay Full / L3010 Out							
2888		19.2.1.1	19.2.1.2	19.2.1.3	19.2.1.4	19.2.1.5	19.2.1.6	
2889	Second Pipeline Along L3010 Alternate	680	680	680	680	680	680	680
2890	Line 3010 Complete Outage	0	0	0	0	0	0	0
2891	Otay Mesa Full Supply	295	86	313	313	329	324	
2892	Total Supply	975	766	993	993	1009	1004	
2893	Total MMcfd Shortfall	0	0	0	0	0	0	
2894	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	
2895	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
2896		Gas EG [%]	0%	0%	0%	0%	0%	0%
2897		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
2898	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
2899		Gas EG [MWh/d]	0	0	0	0	0	0
2900		Gas EG [MW]	0	0	0	0	0	0
2901	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
2902		Gas Core [# Affected]	0	0	0	0	0	0
2903		Gas EG [# Affected]	0	0	0	0	0	0
2904		0	0	0	0	0	0	
2905	Second Pipeline Along L3010 / Otay Medium / L3010 80%							
2906		19.1.2.1	19.1.2.2	19.1.2.3	19.1.2.4	19.1.2.5	19.1.2.6	
2907	Second Pipeline Along L3010 Alternate	680	680	680	680	680	680	680
2908	Line 3010 at 80% Supply	380	380	380	380	380	380	380
2909	Otay Mesa Medium Supply	156	60	230	230	244	247	
2910	Total Supply	1216	1120	1290	1290	1304	1307	
2911	Total MMcfd Shortfall	0	0	0	0	0	0	
2912	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	
2913	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
2914		Gas EG [%]	0%	0%	0%	0%	0%	0%
2915		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
2916	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
2917		Gas EG [MWh/d]	0	0	0	0	0	0
2918		Gas EG [MW]	0	0	0	0	0	0
2919	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
2920		Gas Core [# Affected]	0	0	0	0	0	0
2921		Gas EG [# Affected]	0	0	0	0	0	0
2922		0	0	0	0	0	0	
2923	Second Pipeline Along L3010 / Otay Medium / L3010 Out							
2924		19.2.2.1	19.2.2.2	19.2.2.3	19.2.2.4	19.2.2.5	19.2.2.6	
2925	Second Pipeline Along L3010 Alternate	680	680	680	680	680	680	680
2926	Line 3010 Complete Outage	0	0	0	0	0	0	0
2927	Otay Mesa Medium Supply	156	60	230	230	244	247	
2928	Total Supply	836	740	910	910	924	927	
2929	Total MMcfd Shortfall	0	0	0	0	0	0	
2930	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	
2931	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
2932		Gas EG [%]	0%	0%	0%	0%	0%	0%
2933		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
2934	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
2935		Gas EG [MWh/d]	0	0	0	0	0	0
2936		Gas EG [MW]	0	0	0	0	0	0
2937	Number of Customers Affected	Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
2938		Gas Core [# Affected]	0	0	0	0	0	0
2939		Gas EG [# Affected]	0	0	0	0	0	0
2940		0	0	0	0	0	0	

WORK PAPER TABLE - SCENARIO ANALYSIS GAS DEMAND AND SUPPLY (SA 1.1
EXAMPLE DAY OF GAS DEMAND AND SUPPLY FOR CUSTOMER CLASSES DURING SEASONAL VARIATIONS FOR ANALYSIS OF
CURTAILMENT AND CUSTOMERS AFFECTED FOR EACH PROJECT ALTERNATE
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.		1. Example Summer Low-EG Day MMcfd	2. Example Summer High-EG Day MMcfd	3. Example Winter Day MMcfd	4. Winter 1-in-10 Year Day MMcfd	5. Example Spring Day MMcfd	6. Example Fall Day MMcfd	
	A	B	C	D	E	F	G	H
2941								
2942	Second Pipeline Along L3010 / Otay Low / L3010 80%							
2943	Second Pipeline Along L3010 Alternate	680	680	680	680	680	680	680
2944	Line 3010 at 80% Supply	380	380	380	380	380	380	380
2945	Otay Mesa Low Supply	33	33	148	148	130	168	168
2946	Total Supply	1093	1093	1208	1208	1190	1228	1228
2947	Total MMcfd Shortfall	0	0	0	0	0	0	0
2948	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	No
2949	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
2950		Gas EG [%]	0%	0%	0%	0%	0%	0%
2951		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
2952	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
2953		Gas EG [MWh/d]	0	0	0	0	0	0
2954		Gas EG [MW]	0	0	0	0	0	0
2955		Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
2956	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	0
2957		Gas EG [# Affected]	0	0	0	0	0	0
2958		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
2959								
2960	Second Pipeline Along L3010 / Otay Low / L3010 Out							
2961	Second Pipeline Along L3010 Alternate	680	680	680	680	680	680	680
2962	Line 3010 Complete Outage	0	0	0	0	0	0	0
2963	Otay Mesa Low Supply	33	33	148	148	130	168	168
2964	Total Supply	713	713	828	828	810	848	848
2965	Total MMcfd Shortfall	0	0	0	0	0	0	0
2966	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	No
2967	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
2968		Gas EG [%]	0%	0%	0%	0%	0%	0%
2969		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
2970	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
2971		Gas EG [MWh/d]	0	0	0	0	0	0
2972		Gas EG [MW]	0	0	0	0	0	0
2973		Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
2974	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	0
2975		Gas EG [# Affected]	0	0	0	0	0	0
2976		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
2977								
2978	Second Pipeline Along L3010 / Otay Out / L3010 80%							
2979	Second Pipeline Along L3010 Alternate	680	680	680	680	680	680	680
2980	Line 3010 at 80% Supply	380	380	380	380	380	380	380
2981	Otay Mesa No Supply	0	0	0	0	0	0	0
2982	Total Supply	1060	1060	1060	1060	1060	1060	1060
2983	Total MMcfd Shortfall	0	0	0	0	0	0	0
2984	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	No
2985	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
2986		Gas EG [%]	0%	0%	0%	0%	0%	0%
2987		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
2988	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
2989		Gas EG [MWh/d]	0	0	0	0	0	0
2990		Gas EG [MW]	0	0	0	0	0	0
2991		Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
2992	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	0
2993		Gas EG [# Affected]	0	0	0	0	0	0
2994		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
2995								
2996	Second Pipeline Along L3010 / Otay Out / L3010 Out							
2997	Second Pipeline Along L3010 Alternate	680	680	680	680	680	680	680
2998	Line 3010 Complete Outage	0	0	0	0	0	0	0
2999	Otay Mesa No Supply	0	0	0	0	0	0	0
3000	Total Supply	680	680	680	680	680	680	680
3001	Total MMcfd Shortfall	0	0	0	0	0	0	0
3002	Immediate Curtailment to EG Stations?	No	No	No	No	No	No	No
3003	Curtailment (%)	Gas Core [%]	0%	0%	0%	0%	0%	0%
3004		Gas EG [%]	0%	0%	0%	0%	0%	0%
3005		Gas Non-Core Non-EG [%]	0%	0%	0%	0%	0%	0%
3006	Curtailment (Capacity)	Gas Core [MMcfd]	0	0	0	0	0	0
3007		Gas EG [MWh/d]	0	0	0	0	0	0
3008		Gas EG [MW]	0	0	0	0	0	0
3009		Gas Non-Core Non-EG [MMcfd]	0	0	0	0	0	0
3010	Number of Customers Affected	Gas Core [# Affected]	0	0	0	0	0	0
3011		Gas EG [# Affected]	0	0	0	0	0	0
3012		Gas Non-Core Non-EG [# Affected]	0	0	0	0	0	0
3013								

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND SUPPLY (SA 1.2)
 EXAMPLE DAY OF ELECTRIC DEMAND AND SUPPLY DURING SEASONAL VARIATIONS FOR ANALYSIS OF CURTAILMENT AND METERS AFFECTED FOR EACH
 PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW	
A	B	C	D	E	F	G	H

Model Inputs

Date Ranges						
Date Ranges for Seasonal Demand Conditions	8/2/2015	8/8/2015	1/2/2015	1/14/2013	5/9/2015	11/23/2015

Electric Demand (MW)						
Peak Electric Demand	3062	3723	2969	3328	2693	3019

Electric Supply (MW)						
NG-Fired Electric Gen	562	1,686	927	927	1,236	1,517
Other In-Basin Electric Gen	70	70	70	70	70	70
Electric Import Capacity	2500	2500	2500	2500	2500	2500

Notes:						
1. SDG&E electric peak demand data and renewable data (source: SDG&E Grid Operations Services Department)						
2. Current state estimate of electric import capacity provided by SDG&E Grid Operations. Capacity expected to increase by completion date of the proposed project or alternates.						
3. For the Alt Energy Alternative, it was assumed that the capacity would be designed as a full backup to the EG stations (equivalent to max EG demand for gas)						
	Capacity (MW)	1,686				
4. For the LNG Storage Alternative, it was assumed that the storage capacity would be designed to meet a full NG outage to the electric generation sites. (Source: SDG&E / SoCalGas LNG Storage Facility Alternative Cost Analysis)						
5. Count of Total SDG&E Electric meters (source: SDG&E website, http://www.sdge.com/aboutus ;						
	Count (#)	1,400,000				

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND SUPPLY (SA 1.2)
 EXAMPLE DAY OF ELECTRIC DEMAND AND SUPPLY DURING SEASONAL VARIATIONS FOR ANALYSIS OF CURTAILMENT AND METERS AFFECTED FOR EACH
 PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW	
A	B	C	D	E	F	G	H
Line 1600 (Pre/Post Hydrotesting)							
L1600 / Otay Full / L3010 80%							
1		1.1.1.1	1.1.1.2	1.1.1.3	1.1.1.4	1.1.1.5	1.1.1.6
2							
26							
27							
28							
29							
30							
31							
32							
33							
34							
35							
36							
37							
38							
39							
40							
41							
42							
43							
44							
45							
46							
47							
48							
49							
50							
51							
52							
53							
54							
55							
56							
57							
58							
59							
60							
61							
62							
63							
64							
65							
66							
67							
68							
69							
70							
71							
72							
73							
74							
75							
76							
77							
78							
79							
80							
81							

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND SUPPLY (SA 1.2)
 EXAMPLE DAY OF ELECTRIC DEMAND AND SUPPLY DURING SEASONAL VARIATIONS FOR ANALYSIS OF CURTAILMENT AND METERS AFFECTED FOR EACH
 PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

1			1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW
2	A	B	C	D	E	F	G	H
82								
83	L1600 / Otay Out / L3010 80%		1.1.4.1	1.1.4.2	1.1.4.3	1.1.4.4	1.1.4.5	1.1.4.6
84	Curtailed NG-Fired Electric Gen (MW)		0	0	0	0	0	0
85	Total Supply		3132	4256	3497	3497	3806	4087
86	Elec Curtailment (MWh)		0	0	0	0	0	0
87	Elec Curtailment Duration (h)		0	0	0	0	0	0
88	Avg Elec Curtailment (MW)		0	0	0	0	0	0
89	Elec Curtailment (%)		0%	0%	0%	0%	0%	0%
90	Elec Curtailment (# of Customers)		0	0	0	0	0	0
91								
92	L1600 / Otay Out / L3010 Out		1.2.4.1	1.2.4.2	1.2.4.3	1.2.4.4	1.2.4.5	1.2.4.6
93	Curtailed NG-Fired Electric Gen (MW)		281	1405	927	927	1236	1517
94	Total Supply		2851	2851	2570	2570	2570	2570
95	Elec Curtailment (MWh)		720	7,881	1,450	5,152	150	1,636
96	Elec Curtailment Duration (h)		6	15	5	17	2	8
97	Avg Elec Curtailment (MW)		120	534	276	308	86	204
98	Elec Curtailment (%)		4%	14%	9%	9%	3%	7%
99	Elec Curtailment (# of Customers)		54,877	200,930	130,224	129,384	44,549	94,833

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND SUPPLY (SA 1.2)
 EXAMPLE DAY OF ELECTRIC DEMAND AND SUPPLY DURING SEASONAL VARIATIONS FOR ANALYSIS OF CURTAILMENT AND METERS AFFECTED FOR EACH
 PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW		
	A	B	C	D	E	F	G	H
1								
2								
100								
101								
102	Line 3602 (Proposed Project)							
103	L3602 / Otay Full / L3010 80%							
104	2.1.1.1	2.1.1.2	2.1.1.3	2.1.1.4	2.1.1.5	2.1.1.6		
105	0	0	0	0	0	0	0	0
106	3132	4256	3497	3497	3806	4087		
107	0	0	0	0	0	0		
108	0	0	0	0	0	0		
109	0%	0%	0%	0%	0%	0%		
110	0	0	0	0	0	0		
111								
112	L3602 / Otay Full / L3010 Out							
113	2.2.1.1	2.2.1.2	2.2.1.3	2.2.1.4	2.2.1.5	2.2.1.6		
114	0	0	0	0	0	0		
115	3132	4256	3497	3497	3806	4087		
116	0	0	0	0	0	0		
117	0	0	0	0	0	0		
118	0%	0%	0%	0%	0%	0%		
119	0	0	0	0	0	0		
120								
121	L3602 / Otay Medium / L3010 80%							
122	2.1.2.1	2.1.2.2	2.1.2.3	2.1.2.4	2.1.2.5	2.1.2.6		
123	0	0	0	0	0	0		
124	3132	4256	3497	3497	3806	4087		
125	0	0	0	0	0	0		
126	0	0	0	0	0	0		
127	0%	0%	0%	0%	0%	0%		
128	0	0	0	0	0	0		
129								
130	L3602 / Otay Medium / L3010 Out							
131	2.2.2.1	2.2.2.2	2.2.2.3	2.2.2.4	2.2.2.5	2.2.2.6		
132	0	0	0	0	0	0		
133	3132	4256	3497	3497	3806	4087		
134	0	0	0	0	0	0		
135	0	0	0	0	0	0		
136	0%	0%	0%	0%	0%	0%		
137	0	0	0	0	0	0		
138								
139	L3602 / Otay Low / L3010 80%							
140	2.1.3.1	2.1.3.2	2.1.3.3	2.1.3.4	2.1.3.5	2.1.3.6		
141	0	0	0	0	0	0		
142	3132	4256	3497	3497	3806	4087		
143	0	0	0	0	0	0		
144	0	0	0	0	0	0		
145	0%	0%	0%	0%	0%	0%		
146	0	0	0	0	0	0		
147								
148	L3602 / Otay Low / L3010 Out							
149	2.2.3.1	2.2.3.2	2.2.3.3	2.2.3.4	2.2.3.5	2.2.3.6		
150	0	0	0	0	0	0		
151	3132	4256	3497	3497	3806	4087		
152	0	0	0	0	0	0		
153	0	0	0	0	0	0		
154	0%	0%	0%	0%	0%	0%		
155	0	0	0	0	0	0		
156								
157	L3602 / Otay Out / L3010 80%							
158	2.1.4.1	2.1.4.2	2.1.4.3	2.1.4.4	2.1.4.5	2.1.4.6		
159	0	0	0	0	0	0		
160	3132	4256	3497	3497	3806	4087		
161	0	0	0	0	0	0		
162	0	0	0	0	0	0		
163	0%	0%	0%	0%	0%	0%		
164	0	0	0	0	0	0		
165								
166	L3602 / Otay Out / L3010 Out							
167	2.2.4.1	2.2.4.2	2.2.4.3	2.2.4.4	2.2.4.5	2.2.4.6		
168	0	0	0	0	0	0		
169	3132	4256	3497	3497	3806	4087		
170	0	0	0	0	0	0		
171	0	0	0	0	0	0		
172	0%	0%	0%	0.0%	0%	0%		
173	0	0	0	0	0	0		

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND SUPPLY (SA 1.2)
 EXAMPLE DAY OF ELECTRIC DEMAND AND SUPPLY DURING SEASONAL VARIATIONS FOR ANALYSIS OF CURTAILMENT AND METERS AFFECTED FOR EACH
 PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW		
	A	B	C	D	E	F	G	H
1								
2								
174								
175	Line 1600 (During Hydrotesting)							
176								
177	Hydrotesting / Otay Full / L3010 80%							
178	3.1.1.1	3.1.1.2	3.1.1.3	3.1.1.4	3.1.1.5	3.1.1.6		
178	0	0	0	0	0	0	0	0
179	3132	4256	3497	3497	3806	4087		
180	0	0	0	0	0	0		
181	0	0	0	0	0	0		
182	0	0	0	0	0	0		
183	0%	0%	0%	0%	0%	0%		
184	0	0	0	0	0	0		
185								
186	Hydrotesting / Otay Full / L3010 Out							
187	3.2.1.1	3.2.1.2	3.2.1.3	3.2.1.4	3.2.1.5	3.2.1.6		
187	0	1686	912	927	343	710		
188	3132	2570	2586	2570	3463	3377		
189	0	12,380	1,368	5,152	0	0		
190	0	18	5	17	0	0		
191	0	697	261	308	0	0		
192	0%	19%	9%	9%	0%	0%		
193	0	262,272	122,837	129,384	0	0		
194								
195	Hydrotesting / Otay Medium / L3010 80%							
196	3.1.2.1	3.1.2.2	3.1.2.3	3.1.2.4	3.1.2.5	3.1.2.6		
196	0	0	0	0	0	0		
197	3132	4256	3497	3497	3806	4087		
198	0	0	0	0	0	0		
199	0	0	0	0	0	0		
200	0	0	0	0	0	0		
201	0%	0%	0%	0%	0%	0%		
202	0	0	0	0	0	0		
203								
204	Hydrotesting / Otay Medium / L3010 Out							
205	3.2.2.1	3.2.2.2	3.2.2.3	3.2.2.4	3.2.2.5	3.2.2.6		
205	249	1686	927	927	820	1140		
206	2883	2570	2570	2570	2987	2947		
207	542	12,380	1,450	5,152	0	70		
208	5	18	5	17	0	2		
209	103	697	276	308	0	46		
210	3%	19%	9%	9%	0%	2%		
211	47,219	262,272	130,224	129,384	0	21,550		
212								
213	Hydrotesting / Otay Low / L3010 80%							
214	3.1.3.1	3.1.3.2	3.1.3.3	3.1.3.4	3.1.3.5	3.1.3.6		
214	0	0	0	0	0	0		
215	3132	4256	3497	3497	3806	4087		
216	0	0	0	0	0	0		
217	0	0	0	0	0	0		
218	0	0	0	0	0	0		
219	0%	0%	0%	0%	0%	0%		
220	0	0	0	0	0	0		
221								
222	Hydrotesting / Otay Low / L3010 Out							
223	3.2.3.1	3.2.3.2	3.2.3.3	3.2.3.4	3.2.3.5	3.2.3.6		
223	562	1686	927	927	1236	1517		
224	2570	2570	2570	2570	2570	2570		
225	2,873	12,380	1,450	5,152	150	1,636		
226	9	18	5	17	2	8		
227	311	697	276	308	86	204		
228	10%	19%	9%	9%	3%	7%		
229	142,040	262,272	130,224	129,384	44,549	94,833		
230								
231	Hydrotesting / Otay Out / L3010 80%							
232	3.1.4.1	3.1.4.2	3.1.4.3	3.1.4.4	3.1.4.5	3.1.4.6		
232	0	112	534	759	56	393		
233	3132	4143	2963	2739	3750	3694		
234	0	0	1	2,881	0	0		
235	0	0	0	11	0	0		
236	0	0	5	268	0	0		
237	0%	0%	0%	8%	0%	0%		
238	0	0	2,440	112,734	0	0		
239								
240	Hydrotesting / Otay Out / L3010 Out							
241	3.2.4.1	3.2.4.2	3.2.4.3	3.2.4.4	3.2.4.5	3.2.4.6		
241	562	1686	927	927	1236	1517		
242	2570	2570	2570	2570	2570	2570		
243	2,873	12,380	1,450	5,152	150	1,636		
244	9	18	5	17	2	8		
245	311	697	276	308	86	204		
246	10%	19%	9%	9%	3%	7%		
247	142,040	262,272	130,224	129,384	44,549	94,833		

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND SUPPLY (SA 1.2)
 EXAMPLE DAY OF ELECTRIC DEMAND AND SUPPLY DURING SEASONAL VARIATIONS FOR ANALYSIS OF CURTAILMENT AND METERS AFFECTED FOR EACH
 PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW	
A	B	C	D	E	F	G	H
1							
2							
248							
249							
250							
251	Alternate Diameter Pipeline 10"						
252	Alt Diameter 10" / Otay Full / L3010 80%						
253	4.1.1.1	4.1.1.2	4.1.1.3	4.1.1.4	4.1.1.5	4.1.1.6	
254	0	0	0	0	0	0	0
255	3132	4256	3497	3497	3806	4087	
256	0	0	0	0	0	0	0
257	0	0	0	0	0	0	0
258	0%	0%	0%	0%	0%	0%	0%
259	0	0	0	0	0	0	0
260	Alt Diameter 10" / Otay Full / L3010 Out						
261	4.2.1.1	4.2.1.2	4.2.1.3	4.2.1.4	4.2.1.5	4.2.1.6	
262	0	1482	631	855	62	429	
263	3132	2773	2867	2642	3744	3658	
264	0	9,051	172	4,053	0	0	
265	0	16	3	14	0	0	
266	0	584	62	300	0	0	
267	0%	16%	2%	9%	0%	0%	
268	0	219,576	29,432	126,283	0	0	
269	Alt Diameter 10" / Otay Medium / L3010 80%						
270	4.1.2.1	4.1.2.2	4.1.2.3	4.1.2.4	4.1.2.5	4.1.2.6	
271	0	0	0	0	0	0	
272	3132	4256	3497	3497	3806	4087	
273	0	0	0	0	0	0	
274	0	0	0	0	0	0	
275	0%	0%	0%	0%	0%	0%	
276	0	0	0	0	0	0	
277	Alt Diameter 10" / Otay Medium / L3010 Out						
278	4.2.2.1	4.2.2.2	4.2.2.3	4.2.2.4	4.2.2.5	4.2.2.6	
279	0	1631	927	927	539	859	
280	3132	2625	2570	2570	3268	3228	
281	0	11,438	1,450	5,152	0	0	
282	0	17	5	17	0	0	
283	0	683	276	308	0	0	
284	0%	18%	9%	9%	0%	0%	
285	0	256,793	130,224	129,384	0	0	
286	Alt Diameter 10" / Otay Low / L3010 80%						
287	4.1.3.1	4.1.3.2	4.1.3.3	4.1.3.4	4.1.3.5	4.1.3.6	
288	0	0	0	0	0	0	
289	3132	4256	3497	3497	3806	4087	
290	0	0	0	0	0	0	
291	0	0	0	0	0	0	
292	0	0	0	0	0	0	
293	0%	0%	0%	0%	0%	0%	
294	0	0	0	0	0	0	
295	Alt Diameter 10" / Otay Low / L3010 Out						
296	4.2.3.1	4.2.3.2	4.2.3.3	4.2.3.4	4.2.3.5	4.2.3.6	
297	562	1686	927	927	1180	1306	
298	2570	2570	2570	2570	2627	2781	
299	2,873	12,380	1,450	5,152	58	473	
300	9	18	5	17	2	3	
301	311	697	276	308	38	146	
302	10%	19%	9%	9%	1%	5%	
303	142,040	262,272	130,224	129,384	19,934	67,529	
304	Alt Diameter 10" / Otay Out / L3010 80%						
305	4.1.4.1	4.1.4.2	4.1.4.3	4.1.4.4	4.1.4.5	4.1.4.6	
306	0	0	253	478	0	112	
307	3132	4256	3244	3020	3806	3975	
308	0	0	0	912	0	0	
309	0	0	0	4	0	0	
310	0	0	0	215	0	0	
311	0%	0%	0%	6%	0%	0%	
312	0	0	0	90,313	0	0	
313	Alt Diameter 10" / Otay Out / L3010 Out						
314	4.2.4.1	4.2.4.2	4.2.4.3	4.2.4.4	4.2.4.5	4.2.4.6	
315	562	1686	927	927	1236	1517	
316	2570	2570	2570	2570	2570	2570	
317	2,873	12,380	1,450	5,152	150	1,636	
318	9	18	5	17	2	8	
319	311	697	276	308	86	204	
320	10%	19%	9%	9%	3%	7%	
321	142,040	262,272	130,224	129,384	44,549	94,833	

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND SUPPLY (SA 1.2)
 EXAMPLE DAY OF ELECTRIC DEMAND AND SUPPLY DURING SEASONAL VARIATIONS FOR ANALYSIS OF CURTAILMENT AND METERS AFFECTED FOR EACH
 PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW		
	A	B	C	D	E	F	G	H
1								
2								
322								
323								
324								
325	Alternate Diameter Pipeline 12"							
326	Alt Diameter 12" / Otay Full / L3010 80%							
327	5.1.1.1	5.1.1.2	5.1.1.3	5.1.1.4	5.1.1.5	5.1.1.6		
328	0	0	0	0	0	0	0	0
329	3132	4256	3497	3497	3806	4087		
330	0	0	0	0	0	0	0	0
331	0	0	0	0	0	0	0	0
332	0%	0%	0%	0%	0%	0%	0%	0%
333	0	0	0	0	0	0	0	0
334	Alt Diameter 12" / Otay Full / L3010 Out							
335	5.2.1.1	5.2.1.2	5.2.1.3	5.2.1.4	5.2.1.5	5.2.1.6		
336	0	1370	518	743	0	317		
337	3132	2886	2979	2754	3806	3771		
338	0	7,374	0	2,716	0	0		
339	0	15	0	11	0	0		
340	0	509	0	259	0	0		
341	0%	14%	0%	8%	0%	0%		
342	0	191,226	0	108,815	0	0		
343	Alt Diameter 12" / Otay Medium / L3010 80%							
344	5.1.2.1	5.1.2.2	5.1.2.3	5.1.2.4	5.1.2.5	5.1.2.6		
345	0	0	0	0	0	0		
346	3132	4256	3497	3497	3806	4087		
347	0	0	0	0	0	0		
348	0	0	0	0	0	0		
349	0	0	0	0	0	0		
350	0%	0%	0%	0%	0%	0%		
351	0	0	0	0	0	0		
352	Alt Diameter 12" / Otay Medium / L3010 Out							
353	5.2.2.1	5.2.2.2	5.2.2.3	5.2.2.4	5.2.2.5	5.2.2.6		
354	0	1519	927	927	426	746		
355	3132	2737	2570	2570	3380	3341		
356	0	9,618	1,450	5,152	0	0		
357	0	16	5	17	0	0		
358	0	601	276	308	0	0		
359	0%	16%	9%	9%	0%	0%		
360	0	226,051	130,224	129,384	0	0		
361	Alt Diameter 12" / Otay Low / L3010 80%							
362	5.1.3.1	5.1.3.2	5.1.3.3	5.1.3.4	5.1.3.5	5.1.3.6		
363	0	0	0	0	0	0		
364	3132	4256	3497	3497	3806	4087		
365	0	0	0	0	0	0		
366	0	0	0	0	0	0		
367	0	0	0	0	0	0		
368	0%	0%	0%	0%	0%	0%		
369	0	0	0	0	0	0		
370	Alt Diameter 12" / Otay Low / L3010 Out							
371	5.2.3.1	5.2.3.2	5.2.3.3	5.2.3.4	5.2.3.5	5.2.3.6		
372	543	1667	927	927	1067	1194		
373	2589	2589	2570	2570	2739	2893		
374	2,701	12,054	1,450	5,152	0	170		
375	9	18	5	17	0	2		
376	292	689	276	308	0	76		
377	10%	19%	9%	9%	0%	3%		
378	133,537	259,014	130,224	129,384	0	35,092		
379	Alt Diameter 12" / Otay Out / L3010 80%							
380	5.1.4.1	5.1.4.2	5.1.4.3	5.1.4.4	5.1.4.5	5.1.4.6		
381	0	0	140	365	0	0		
382	3132	4256	3357	3132	3806	4087		
383	0	0	0	486	0	0		
384	0	0	0	4	0	0		
385	0	0	0	139	0	0		
386	0%	0%	0%	4%	0%	0%		
387	0	0	0	58,403	0	0		
388	Alt Diameter 12" / Otay Out / L3010 Out							
389	5.2.4.1	5.2.4.2	5.2.4.3	5.2.4.4	5.2.4.5	5.2.4.6		
390	562	1686	927	927	1236	1517		
391	2570	2570	2570	2570	2570	2570		
392	2,873	12,380	1,450	5,152	150	1,636		
393	9	18	5	17	2	8		
394	311	697	276	308	86	204		
395	10%	19%	9%	9%	3%	7%		
	142,040	262,272	130,224	129,384	44,549	94,833		

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND SUPPLY (SA 1.2)
 EXAMPLE DAY OF ELECTRIC DEMAND AND SUPPLY DURING SEASONAL VARIATIONS FOR ANALYSIS OF CURTAILMENT AND METERS AFFECTED FOR EACH
 PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW		
	A	B	C	D	E	F	G	H
1								
2								
396								
397								
398								
399	Alternate Diameter Pipeline 16"							
400	Alt Diameter 16" / Otay Full / L3010 80%							
401	6.1.1.1	6.1.1.2	6.1.1.3	6.1.1.4	6.1.1.5	6.1.1.6		
402	0	0	0	0	0	0	0	0
403	3132	4256	3497	3497	3806	4087		
404	0	0	0	0	0	0	0	0
405	0	0	0	0	0	0	0	0
406	0%	0%	0%	0%	0%	0%	0%	0%
407	0	0	0	0	0	0	0	0
408	Alt Diameter 16" / Otay Full / L3010 Out							
409	6.2.1.1	6.2.1.2	6.2.1.3	6.2.1.4	6.2.1.5	6.2.1.6		
410	0	864	12	237	0	0	0	0
411	3132	3392	3485	3260	3806	4087		
412	0	1,539	0	105	0	0	0	0
413	0	9	0	2	0	0	0	0
414	0	181	0	47	0	0	0	0
415	0%	5%	0%	1%	0%	0%	0%	0%
416	0	68,106	0	19,607	0	0	0	0
417	Alt Diameter 16" / Otay Medium / L3010 80%							
418	6.1.2.1	6.1.2.2	6.1.2.3	6.1.2.4	6.1.2.5	6.1.2.6		
419	0	0	0	0	0	0	0	0
420	3132	4256	3497	3497	3806	4087		
421	0	0	0	0	0	0	0	0
422	0	0	0	0	0	0	0	0
423	0%	0%	0%	0%	0%	0%	0%	0%
424	0	0	0	0	0	0	0	0
425	Alt Diameter 16" / Otay Medium / L3010 Out							
426	6.2.2.1	6.2.2.2	6.2.2.3	6.2.2.4	6.2.2.5	6.2.2.6		
427	0	1013	478	703	0	241	0	0
428	3132	3243	3019	2794	3806	3847		
429	0	2,953	0	2,315	0	0	0	0
430	0	11	0	9	0	0	0	0
431	0	281	0	250	0	0	0	0
432	0%	8%	0%	8%	0%	0%	0%	0%
433	0	105,754	0	105,273	0	0	0	0
434	Alt Diameter 16" / Otay Low / L3010 80%							
435	6.1.3.1	6.1.3.2	6.1.3.3	6.1.3.4	6.1.3.5	6.1.3.6		
436	0	0	0	0	0	0	0	0
437	3132	4256	3497	3497	3806	4087		
438	0	0	0	0	0	0	0	0
439	0	0	0	0	0	0	0	0
440	0	0	0	0	0	0	0	0
441	0%	0%	0%	0%	0%	0%	0%	0%
442	0	0	0	0	0	0	0	0
443	Alt Diameter 16" / Otay Low / L3010 Out							
444	6.2.3.1	6.2.3.2	6.2.3.3	6.2.3.4	6.2.3.5	6.2.3.6		
445	38	1162	927	927	561	688	0	0
446	3094	3094	2570	2570	3245	3399		
447	0	4,618	1,450	5,152	0	0	0	0
448	0	12	5	17	0	0	0	0
449	0	385	276	308	0	0	0	0
450	0%	10%	9%	9%	0%	0%	0%	0%
451	0	144,719	130,224	129,384	0	0	0	0
452	Alt Diameter 16" / Otay Out / L3010 80%							
453	6.1.4.1	6.1.4.2	6.1.4.3	6.1.4.4	6.1.4.5	6.1.4.6		
454	0	0	0	0	0	0	0	0
455	3132	4256	3497	3497	3806	4087		
456	0	0	0	0	0	0	0	0
457	0	0	0	0	0	0	0	0
458	0	0	0	0	0	0	0	0
459	0%	0%	0%	0%	0%	0%	0%	0%
460	0	0	0	0	0	0	0	0
461	Alt Diameter 16" / Otay Out / L3010 Out							
462	6.2.4.1	6.2.4.2	6.2.4.3	6.2.4.4	6.2.4.5	6.2.4.6		
463	225	1349	927	927	1236	1517	0	0
464	2907	2907	2570	2570	2570	2570		
465	417	7,065	1,450	5,152	150	1,636	0	0
466	5	15	5	17	2	8	0	0
467	83	487	276	308	86	204	0	0
468	3%	13%	9%	9%	3%	7%	0	0
469	38,177	183,210	130,224	129,384	44,549	94,833	0	0

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND SUPPLY (SA 1.2)
 EXAMPLE DAY OF ELECTRIC DEMAND AND SUPPLY DURING SEASONAL VARIATIONS FOR ANALYSIS OF CURTAILMENT AND METERS AFFECTED FOR EACH
 PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW	
A	B	C	D	E	F	G	H
1							
2							
470							
471							
472	Alternate Diameter Pipeline 20"						
473	Alt Diameter 20" / Otay Full / L3010 80%						
474	20.1.1.1	20.1.1.2	20.1.1.3	20.1.1.4	20.1.1.5	20.1.1.6	
475	0	0	0	0	0	0	0
476	3132	4256	3497	3497	3806	4087	
477	0	0	0	0	0	0	0
478	0	0	0	0	0	0	0
479	0	0	0	0	0	0	0
480	0%	0%	0%	0%	0%	0%	0%
481	0	0	0	0	0	0	0
482	Alt Diameter 20" / Otay Full / L3010 Out						
483	20.2.1.1	20.2.1.2	20.2.1.3	20.2.1.4	20.2.1.5	20.2.1.6	
484	0	358	0	0	0	0	0
485	3132	3897	3497	3497	3806	4087	
486	0	0	0	0	0	0	0
487	0	0	0	0	0	0	0
488	0	0	0	0	0	0	0
489	0%	0%	0%	0%	0%	0%	0%
490	0	0	0	0	0	0	0
491	Alt Diameter 20" / Otay Medium / L3010 80%						
492	20.1.2.1	20.1.2.2	20.1.2.3	20.1.2.4	20.1.2.5	20.1.2.6	
493	0	0	0	0	0	0	0
494	3132	4256	3497	3497	3806	4087	
495	0	0	0	0	0	0	0
496	0	0	0	0	0	0	0
497	0	0	0	0	0	0	0
498	0%	0%	0%	0%	0%	0%	0%
499	0	0	0	0	0	0	0
500	Alt Diameter 20" / Otay Medium / L3010 Out						
501	20.2.2.1	20.2.2.2	20.2.2.3	20.2.2.4	20.2.2.5	20.2.2.6	
502	0	507	0	197	0	0	0
503	3132	3749	3497	3300	3806	4087	
504	0	0	0	28	0	0	0
505	0	0	0	1	0	0	0
506	0	0	0	23	0	0	0
507	0%	0%	0%	1%	0%	0%	0%
508	0	0	0	9,493	0	0	0
509	Alt Diameter 20" / Otay Low / L3010 80%						
510	20.1.3.1	20.1.3.2	20.1.3.3	20.1.3.4	20.1.3.5	20.1.3.6	
511	0	0	0	0	0	0	0
512	3132	4256	3497	3497	3806	4087	
513	0	0	0	0	0	0	0
514	0	0	0	0	0	0	0
515	0	0	0	0	0	0	0
516	0%	0%	0%	0%	0%	0%	0%
517	0	0	0	0	0	0	0
518	Alt Diameter 20" / Otay Low / L3010 Out						
519	20.2.3.1	20.2.3.2	20.2.3.3	20.2.3.4	20.2.3.5	20.2.3.6	
520	0	656	432	657	56	182	
521	3132	3600	3065	2840	3751	3905	
522	0	297	0	1,906	0	0	0
523	0	4	0	8	0	0	0
524	0	85	0	231	0	0	0
525	0%	2%	0%	7%	0%	0%	0%
526	0	31,857	0	97,165	0	0	0
527	Alt Diameter 20" / Otay Out / L3010 80%						
528	20.1.4.1	20.1.4.2	20.1.4.3	20.1.4.4	20.1.4.5	20.1.4.6	
529	0	0	0	0	0	0	0
530	3132	4256	3497	3497	3806	4087	
531	0	0	0	0	0	0	0
532	0	0	0	0	0	0	0
533	0	0	0	0	0	0	0
534	0%	0%	0%	0%	0%	0%	0%
535	0	0	0	0	0	0	0
536	Alt Diameter 20" / Otay Out / L3010 Out						
537	20.2.4.1	20.2.4.2	20.2.4.3	20.2.4.4	20.2.4.5	20.2.4.6	
538	0	843	927	927	787	1124	
539	3132	3413	2570	2570	3020	2963	
540	0	1,363	1,450	5,152	0	49	
541	0	8	5	17	0	1	
542	0	165	276	308	0	39	
543	0%	4%	9%	9%	0%	1%	
544	0	62,123	130,224	129,384	0	18,018	

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND SUPPLY (SA 1.2)
 EXAMPLE DAY OF ELECTRIC DEMAND AND SUPPLY DURING SEASONAL VARIATIONS FOR ANALYSIS OF CURTAILMENT AND METERS AFFECTED FOR EACH
 PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW	
A	B	C	D	E	F	G	H
1							
2							
544							
545							
546							
547	Alternate Diameter Pipeline 24"						
548	Alt Diameter 24" / Otay Full / L3010 80%						
549	Curtailed NG-Fired Electric Gen (MW)	0	0	0	0	0	0
550	Total Supply	3132	4256	3497	3497	3806	4087
551	Elec Curtailment (MWh)	0	0	0	0	0	0
552	Elec Curtailment Duration (h)	0	0	0	0	0	0
553	Avg Elec Curtailment (MW)	0	0	0	0	0	0
554	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%
555	Elec Curtailment (# of Customers)	0	0	0	0	0	0
556	Alt Diameter 24" / Otay Full / L3010 Out						
557	Curtailed NG-Fired Electric Gen (MW)	0	0	0	0	0	0
558	Total Supply	3132	4256	3497	3497	3806	4087
559	Elec Curtailment (MWh)	0	0	0	0	0	0
560	Elec Curtailment Duration (h)	0	0	0	0	0	0
561	Avg Elec Curtailment (MW)	0	0	0	0	0	0
562	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%
563	Elec Curtailment (# of Customers)	0	0	0	0	0	0
564	Alt Diameter 24" / Otay Medium / L3010 80%						
565	Curtailed NG-Fired Electric Gen (MW)	0	0	0	0	0	0
566	Total Supply	3132	4256	3497	3497	3806	4087
567	Elec Curtailment (MWh)	0	0	0	0	0	0
568	Elec Curtailment Duration (h)	0	0	0	0	0	0
569	Avg Elec Curtailment (MW)	0	0	0	0	0	0
570	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%
571	Elec Curtailment (# of Customers)	0	0	0	0	0	0
572	Alt Diameter 24" / Otay Medium / L3010 Out						
573	Curtailed NG-Fired Electric Gen (MW)	0	0	0	0	0	0
574	Total Supply	3132	4256	3497	3497	3806	4087
575	Elec Curtailment (MWh)	0	0	0	0	0	0
576	Elec Curtailment Duration (h)	0	0	0	0	0	0
577	Avg Elec Curtailment (MW)	0	0	0	0	0	0
578	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%
579	Elec Curtailment (# of Customers)	0	0	0	0	0	0
580	Alt Diameter 24" / Otay Low / L3010 80%						
581	Curtailed NG-Fired Electric Gen (MW)	0	0	0	0	0	0
582	Total Supply	3132	4256	3497	3497	3806	4087
583	Elec Curtailment (MWh)	0	0	0	0	0	0
584	Elec Curtailment Duration (h)	0	0	0	0	0	0
585	Avg Elec Curtailment (MW)	0	0	0	0	0	0
586	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%
587	Elec Curtailment (# of Customers)	0	0	0	0	0	0
588	Alt Diameter 24" / Otay Low / L3010 Out						
589	Curtailed NG-Fired Electric Gen (MW)	0	0	0	0	0	0
590	Total Supply	3132	4256	3497	3497	3806	4087
591	Elec Curtailment (MWh)	0	0	0	0	0	0
592	Elec Curtailment Duration (h)	0	0	0	0	0	0
593	Avg Elec Curtailment (MW)	0	0	0	0	0	0
594	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%
595	Elec Curtailment (# of Customers)	0	0	0	0	0	0
596	Alt Diameter 24" / Otay Out / L3010 80%						
597	Curtailed NG-Fired Electric Gen (MW)	0	0	0	0	0	0
598	Total Supply	3132	4256	3497	3497	3806	4087
599	Elec Curtailment (MWh)	0	0	0	0	0	0
600	Elec Curtailment Duration (h)	0	0	0	0	0	0
601	Avg Elec Curtailment (MW)	0	0	0	0	0	0
602	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%
603	Elec Curtailment (# of Customers)	0	0	0	0	0	0
604	Alt Diameter 24" / Otay Out / L3010 Out						
605	Curtailed NG-Fired Electric Gen (MW)	0	0	421	646	0	281
606	Total Supply	3132	4256	3076	2851	3806	3806
607	Elec Curtailment (MWh)	0	0	0	1,819	0	0
608	Elec Curtailment Duration (h)	0	0	0	8	0	0
609	Avg Elec Curtailment (MW)	0	0	0	227	0	0
610	Elec Curtailment (%)	0%	0%	0%	7%	0%	0%
611	Elec Curtailment (# of Customers)	0	0	0	95,660	0	0

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND SUPPLY (SA 1.2)
 EXAMPLE DAY OF ELECTRIC DEMAND AND SUPPLY DURING SEASONAL VARIATIONS FOR ANALYSIS OF CURTAILMENT AND METERS AFFECTED FOR EACH
 PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW	
A	B	C	D	E	F	G	H
1							
2							
618	Alternate Diameter Pipeline 30"						
619	Alt Diameter 30" / Otay Full / L3010 80%						
620							
621	8.1.1.1	8.1.1.2	8.1.1.3	8.1.1.4	8.1.1.5	8.1.1.6	
622	0	0	0	0	0	0	
623	3132	4256	3497	3497	3806	4087	
624	0	0	0	0	0	0	
625	0	0	0	0	0	0	
626	0	0	0	0	0	0	
627	0%	0%	0%	0%	0%	0%	
628	0	0	0	0	0	0	
629	Alt Diameter 30" / Otay Full / L3010 Out						
630	8.2.1.1	8.2.1.2	8.2.1.3	8.2.1.4	8.2.1.5	8.2.1.6	
631	0	0	0	0	0	0	
632	3132	4256	3497	3497	3806	4087	
633	0	0	0	0	0	0	
634	0	0	0	0	0	0	
635	0	0	0	0	0	0	
636	0%	0%	0%	0%	0%	0%	
637	0	0	0	0	0	0	
638	Alt Diameter 30" / Otay Medium / L3010 80%						
639	8.1.2.1	8.1.2.2	8.1.2.3	8.1.2.4	8.1.2.5	8.1.2.6	
640	0	0	0	0	0	0	
641	3132	4256	3497	3497	3806	4087	
642	0	0	0	0	0	0	
643	0	0	0	0	0	0	
644	0	0	0	0	0	0	
645	0%	0%	0%	0%	0%	0%	
646	0	0	0	0	0	0	
647	Alt Diameter 30" / Otay Medium / L3010 Out						
648	8.2.2.1	8.2.2.2	8.2.2.3	8.2.2.4	8.2.2.5	8.2.2.6	
649	0	0	0	0	0	0	
650	3132	4256	3497	3497	3806	4087	
651	0	0	0	0	0	0	
652	0	0	0	0	0	0	
653	0	0	0	0	0	0	
654	0%	0%	0%	0%	0%	0%	
655	0	0	0	0	0	0	
656	Alt Diameter 30" / Otay Low / L3010 80%						
657	8.1.3.1	8.1.3.2	8.1.3.3	8.1.3.4	8.1.3.5	8.1.3.6	
658	0	0	0	0	0	0	
659	3132	4256	3497	3497	3806	4087	
660	0	0	0	0	0	0	
661	0	0	0	0	0	0	
662	0	0	0	0	0	0	
663	0%	0%	0%	0%	0%	0%	
664	0	0	0	0	0	0	
665	Alt Diameter 30" / Otay Low / L3010 Out						
666	8.2.3.1	8.2.3.2	8.2.3.3	8.2.3.4	8.2.3.5	8.2.3.6	
667	0	0	0	0	0	0	
668	3132	4256	3497	3497	3806	4087	
669	0	0	0	0	0	0	
670	0	0	0	0	0	0	
671	0	0	0	0	0	0	
672	0%	0%	0%	0%	0%	0%	
673	0	0	0	0	0	0	
674	Alt Diameter 30" / Otay Out / L3010 80%						
675	8.1.4.1	8.1.4.2	8.1.4.3	8.1.4.4	8.1.4.5	8.1.4.6	
676	0	0	0	0	0	0	
677	3132	4256	3497	3497	3806	4087	
678	0	0	0	0	0	0	
679	0	0	0	0	0	0	
680	0	0	0	0	0	0	
681	0%	0%	0%	0%	0%	0%	
682	0	0	0	0	0	0	
683	Alt Diameter 30" / Otay Out / L3010 Out						
684	8.2.4.1	8.2.4.2	8.2.4.3	8.2.4.4	8.2.4.5	8.2.4.6	
685	0	0	0	0	0	0	
686	3132	4256	3497	3497	3806	4087	
687	0	0	0	0	0	0	
688	0	0	0	0	0	0	
689	0	0	0	0	0	0	
690	0%	0%	0%	0%	0%	0%	
691	0	0	0	0	0	0	

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND SUPPLY (SA 1.2)
 EXAMPLE DAY OF ELECTRIC DEMAND AND SUPPLY DURING SEASONAL VARIATIONS FOR ANALYSIS OF CURTAILMENT AND METERS AFFECTED FOR EACH
 PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW		
	A	B	C	D	E	F	G	H
1								
2								
692								
693								
694								
695	Alternate Diameter Pipeline 42"							
695	Alt Diameter 42" / Otay Full / L3010 80%							
696	9.1.1.1	9.1.1.2	9.1.1.3	9.1.1.4	9.1.1.5	9.1.1.6		
696	Curtailed NG-Fired Electric Gen (MW)	0	0	0	0	0	0	
697	Total Supply	3132	4256	3497	3497	3806	4087	
698	Elec Curtailment (MWh)	0	0	0	0	0	0	
699	Elec Curtailment Duration (h)	0	0	0	0	0	0	
700	Avg Elec Curtailment (MW)	0	0	0	0	0	0	
701	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%	
702	Elec Curtailment (# of Customers)	0	0	0	0	0	0	
703								
704	Alt Diameter 42" / Otay Full / L3010 Out							
704	9.2.1.1	9.2.1.2	9.2.1.3	9.2.1.4	9.2.1.5	9.2.1.6		
705	Curtailed NG-Fired Electric Gen (MW)	0	0	0	0	0	0	
706	Total Supply	3132	4256	3497	3497	3806	4087	
707	Elec Curtailment (MWh)	0	0	0	0	0	0	
708	Elec Curtailment Duration (h)	0	0	0	0	0	0	
709	Avg Elec Curtailment (MW)	0	0	0	0	0	0	
710	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%	
711	Elec Curtailment (# of Customers)	0	0	0	0	0	0	
712								
713	Alt Diameter 42" / Otay Medium / L3010 80%							
713	9.1.2.1	9.1.2.2	9.1.2.3	9.1.2.4	9.1.2.5	9.1.2.6		
714	Curtailed NG-Fired Electric Gen (MW)	0	0	0	0	0	0	
715	Total Supply	3132	4256	3497	3497	3806	4087	
716	Elec Curtailment (MWh)	0	0	0	0	0	0	
717	Elec Curtailment Duration (h)	0	0	0	0	0	0	
718	Avg Elec Curtailment (MW)	0	0	0	0	0	0	
719	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%	
720	Elec Curtailment (# of Customers)	0	0	0	0	0	0	
721								
722	Alt Diameter 42" / Otay Medium / L3010 Out							
722	9.2.2.1	9.2.2.2	9.2.2.3	9.2.2.4	9.2.2.5	9.2.2.6		
723	Curtailed NG-Fired Electric Gen (MW)	0	0	0	0	0	0	
724	Total Supply	3132	4256	3497	3497	3806	4087	
725	Elec Curtailment (MWh)	0	0	0	0	0	0	
726	Elec Curtailment Duration (h)	0	0	0	0	0	0	
727	Avg Elec Curtailment (MW)	0	0	0	0	0	0	
728	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%	
729	Elec Curtailment (# of Customers)	0	0	0	0	0	0	
730								
731	Alt Diameter 42" / Otay Low / L3010 80%							
731	9.1.3.1	9.1.3.2	9.1.3.3	9.1.3.4	9.1.3.5	9.1.3.6		
732	Curtailed NG-Fired Electric Gen (MW)	0	0	0	0	0	0	
733	Total Supply	3132	4256	3497	3497	3806	4087	
734	Elec Curtailment (MWh)	0	0	0	0	0	0	
735	Elec Curtailment Duration (h)	0	0	0	0	0	0	
736	Avg Elec Curtailment (MW)	0	0	0	0	0	0	
737	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%	
738	Elec Curtailment (# of Customers)	0	0	0	0	0	0	
739								
740	Alt Diameter 42" / Otay Low / L3010 Out							
740	9.2.3.1	9.2.3.2	9.2.3.3	9.2.3.4	9.2.3.5	9.2.3.6		
741	Curtailed NG-Fired Electric Gen (MW)	0	0	0	0	0	0	
742	Total Supply	3132	4256	3497	3497	3806	4087	
743	Elec Curtailment (MWh)	0	0	0	0	0	0	
744	Elec Curtailment Duration (h)	0	0	0	0	0	0	
745	Avg Elec Curtailment (MW)	0	0	0	0	0	0	
746	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%	
747	Elec Curtailment (# of Customers)	0	0	0	0	0	0	
748								
749	Alt Diameter 42" / Otay Out / L3010 80%							
749	9.1.4.1	9.1.4.2	9.1.4.3	9.1.4.4	9.1.4.5	9.1.4.6		
750	Curtailed NG-Fired Electric Gen (MW)	0	0	0	0	0	0	
751	Total Supply	3132	4256	3497	3497	3806	4087	
752	Elec Curtailment (MWh)	0	0	0	0	0	0	
753	Elec Curtailment Duration (h)	0	0	0	0	0	0	
754	Avg Elec Curtailment (MW)	0	0	0	0	0	0	
755	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%	
756	Elec Curtailment (# of Customers)	0	0	0	0	0	0	
757								
758	Alt Diameter 42" / Otay Out / L3010 Out							
758	9.2.4.1	9.2.4.2	9.2.4.3	9.2.4.4	9.2.4.5	9.2.4.6		
759	Curtailed NG-Fired Electric Gen (MW)	0	0	0	0	0	0	
760	Total Supply	3132	4256	3497	3497	3806	4087	
761	Elec Curtailment (MWh)	0	0	0	0	0	0	
762	Elec Curtailment Duration (h)	0	0	0	0	0	0	
763	Avg Elec Curtailment (MW)	0	0	0	0	0	0	
764	Elec Curtailment (%)	0%	0%	0%	0.0%	0%	0%	
765	Elec Curtailment (# of Customers)	0	0	0	0	0	0	

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND SUPPLY (SA 1.2)
 EXAMPLE DAY OF ELECTRIC DEMAND AND SUPPLY DURING SEASONAL VARIATIONS FOR ANALYSIS OF CURTAILMENT AND METERS AFFECTED FOR EACH
 PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW		
	A	B	C	D	E	F	G	H
1								
2								
766								
767								
768								
769	L1600 In-Kind Replacement							
770								
771								
772								
773								
774								
775								
776								
777								
778								
779								
780								
781								
782								
783								
784								
785								
786								
787								
788								
789								
790								
791								
792								
793								
794								
795								
796								
797								
798								
799								
800								
801								
802								
803								
804								
805								
806								
807								
808								
809								
810								
811								
812								
813								
814								
815								
816								
817								
818								
819								
820								
821								
822								
823								
824								
825								
826								
827								
828								
829								
830								
831								
832								
833								
834								
835								
836								
837								
838								
839								

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND SUPPLY (SA 1.2)
 EXAMPLE DAY OF ELECTRIC DEMAND AND SUPPLY DURING SEASONAL VARIATIONS FOR ANALYSIS OF CURTAILMENT AND METERS AFFECTED FOR EACH
 PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW		
	A	B	C	D	E	F	G	H
1								
2								
840								
841	Otay Mesa Alternate							
842								
843	Otay Mesa Alternate / Otay Full / L3010 80%							
844	11.1.1.1	11.1.1.2	11.1.1.3	11.1.1.4	11.1.1.5	11.1.1.6		
845	0	0	0	0	0	0	0	0
846	3132	4256	3497	3497	3806	4087		
847	0	0	0	0	0	0	0	0
848	0	0	0	0	0	0	0	0
849	0%	0%	0%	0%	0%	0%	0%	0%
850	0	0	0	0	0	0	0	0
851								
852	Otay Mesa Alternate / Otay Full / L3010 Out							
853	11.2.1.1	11.2.1.2	11.2.1.3	11.2.1.4	11.2.1.5	11.2.1.6		
854	0	1686	912	927	343	710		
855	3132	2570	2586	2570	3463	3377		
856	0	12,380	1,368	5,152	0	0		
857	0	18	5	17	0	0		
858	0	697	261	308	0	0		
859	0%	19%	9%	9%	0%	0%		
860	0	262,272	122,837	129,384	0	0		
861								
862	Otay Mesa Alternate / Otay Medium / L3010 80%							
863	11.1.2.1	11.1.2.2	11.1.2.3	11.1.2.4	11.1.2.5	11.1.2.6		
864	0	0	0	0	0	0		
865	3132	4256	3497	3497	3806	4087		
866	0	0	0	0	0	0		
867	0	0	0	0	0	0		
868	0%	0%	0%	0%	0%	0%		
869	0	0	0	0	0	0		
870								
871	Otay Mesa Alternate / Otay Medium / L3010 Out							
872	11.2.2.1	11.2.2.2	11.2.2.3	11.2.2.4	11.2.2.5	11.2.2.6		
873	249	1686	927	927	820	1140		
874	2883	2570	2570	2570	2987	2947		
875	542	12,380	1,450	5,152	0	70		
876	5	18	5	17	0	2		
877	103	697	276	308	0	46		
878	3%	19%	9%	9%	0%	2%		
879	47,219	262,272	130,224	129,384	0	21,550		
880								
881	Otay Mesa Alternate / Otay Low / L3010 80%							
882	11.1.3.1	11.1.3.2	11.1.3.3	11.1.3.4	11.1.3.5	11.1.3.6		
883	0	0	0	0	0	0		
884	3132	4256	3497	3497	3806	4087		
885	0	0	0	0	0	0		
886	0	0	0	0	0	0		
887	0%	0%	0%	0%	0%	0%		
888	0	0	0	0	0	0		
889								
890	Otay Mesa Alternate / Otay Low / L3010 Out							
891	11.2.3.1	11.2.3.2	11.2.3.3	11.2.3.4	11.2.3.5	11.2.3.6		
892	562	1686	927	927	1236	1517		
893	2570	2570	2570	2570	2570	2570		
894	2,873	12,380	1,450	5,152	150	1,636		
895	9	18	5	17	2	8		
896	311	697	276	308	86	204		
897	10%	19%	9%	9%	3%	7%		
898	142,040	262,272	130,224	129,384	44,549	94,833		
899								
900	Otay Mesa Alternate / Otay Out / L3010 80%							
901	11.1.4.1	11.1.4.2	11.1.4.3	11.1.4.4	11.1.4.5	11.1.4.6		
902	0	112	534	759	56	393		
903	3132	4143	2963	2739	3750	3694		
904	0	0	1	2,881	0	0		
905	0	0	0	11	0	0		
906	0	0	5	268	0	0		
907	0%	0%	0%	8%	0%	0%		
908	0	0	2,440	112,734	0	0		
909								
910	Otay Mesa Alternate / Otay Out / L3010 Out							
911	11.2.4.1	11.2.4.2	11.2.4.3	11.2.4.4	11.2.4.5	11.2.4.6		
912	562	1686	927	927	1236	1517		
913	2570	2570	2570	2570	2570	2570		
	2,873	12,380	1,450	5,152	150	1,636		
	9	18	5	17	2	8		
	311	697	276	308	86	204		
	10%	19%	9%	9%	3%	7%		
	142,040	262,272	130,224	129,384	44,549	94,833		

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND SUPPLY (SA 1.2)
 EXAMPLE DAY OF ELECTRIC DEMAND AND SUPPLY DURING SEASONAL VARIATIONS FOR ANALYSIS OF CURTAILMENT AND METERS AFFECTED FOR EACH
 PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW	
A	B	C	D	E	F	G	H
1							
2							
914	LNG Storage Alternate						
916							
917	LNG Storage / Otay Full / L3010 80%						
918	13.1.1.1	13.1.1.2	13.1.1.3	13.1.1.4	13.1.1.5	13.1.1.6	
919	0	0	0	0	0	0	0
920	3132	4256	3497	3497	3806	4087	
921	0	0	0	0	0	0	0
922	0	0	0	0	0	0	0
923	0%	0%	0%	0%	0%	0%	0%
924	0	0	0	0	0	0	0
925							
926	LNG Storage / Otay Full / L3010 Out						
927	13.2.1.1	13.2.1.2	13.2.1.3	13.2.1.4	13.2.1.5	13.2.1.6	
928	0	0	0	0	0	0	0
929	3132	4256	3497	3497	3806	4087	
930	0	0	0	0	0	0	0
931	0	0	0	0	0	0	0
932	0%	0%	0%	0%	0%	0%	0%
933	0	0	0	0	0	0	0
934							
935	LNG Storage / Otay Medium / L3010 80%						
936	13.1.2.1	13.1.2.2	13.1.2.3	13.1.2.4	13.1.2.5	13.1.2.6	
937	0	0	0	0	0	0	0
938	3132	4256	3497	3497	3806	4087	
939	0	0	0	0	0	0	0
940	0	0	0	0	0	0	0
941	0%	0%	0%	0%	0%	0%	0%
942	0	0	0	0	0	0	0
943							
944	LNG Storage / Otay Medium / L3010 Out						
945	13.2.2.1	13.2.2.2	13.2.2.3	13.2.2.4	13.2.2.5	13.2.2.6	
946	0	0	0	0	0	0	0
947	3132	4256	3497	3497	3806	4087	
948	0	0	0	0	0	0	0
949	0	0	0	0	0	0	0
950	0%	0%	0%	0%	0%	0%	0%
951	0	0	0	0	0	0	0
952							
953	LNG Storage / Otay Low / L3010 80%						
954	13.1.3.1	13.1.3.2	13.1.3.3	13.1.3.4	13.1.3.5	13.1.3.6	
955	0	0	0	0	0	0	0
956	3132	4256	3497	3497	3806	4087	
957	0	0	0	0	0	0	0
958	0	0	0	0	0	0	0
959	0%	0%	0%	0%	0%	0%	0%
960	0	0	0	0	0	0	0
961							
962	LNG Storage / Otay Low / L3010 Out						
963	13.2.3.1	13.2.3.2	13.2.3.3	13.2.3.4	13.2.3.5	13.2.3.6	
964	0	0	0	0	0	0	0
965	3132	4256	3497	3497	3806	4087	
966	0	0	0	0	0	0	0
967	0	0	0	0	0	0	0
968	0%	0%	0%	0%	0%	0%	0%
969	0	0	0	0	0	0	0
970							
971	LNG Storage / Otay Out / L3010 80%						
972	13.1.4.1	13.1.4.2	13.1.4.3	13.1.4.4	13.1.4.5	13.1.4.6	
973	0	0	0	0	0	0	0
974	3132	4256	3497	3497	3806	4087	
975	0	0	0	0	0	0	0
976	0	0	0	0	0	0	0
977	0%	0%	0%	0%	0%	0%	0%
978	0	0	0	0	0	0	0
979							
980	LNG Storage / Otay Out / L3010 Out						
981	13.2.4.1	13.2.4.2	13.2.4.3	13.2.4.4	13.2.4.5	13.2.4.6	
982	0	0	0	0	0	0	0
983	3132	4256	3497	3497	3806	4087	
984	0	0	0	0	0	0	0
985	0	0	0	0	0	0	0
986	0%	0%	0%	0%	0%	0%	0%
987	0	0	0	0	0	0	0

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND SUPPLY (SA 1.2)
 EXAMPLE DAY OF ELECTRIC DEMAND AND SUPPLY DURING SEASONAL VARIATIONS FOR ANALYSIS OF CURTAILMENT AND METERS AFFECTED FOR EACH
 PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW		
	A	B	C	D	E	F	G	H
1								
2								
988	Alt Energy Alternate (Grid-Scale)							
989								
990								
991	Alt Energy (Grid) / Otay Full / L3010 80%							
992	14.1.1.1	14.1.1.2	14.1.1.3	14.1.1.4	14.1.1.5	14.1.1.6		
993	0	0	0	0	0	0	0	0
994	4818	5942	5183	5183	5492	5773		
995	0	0	0	0	0	0	0	0
996	0	0	0	0	0	0	0	0
997	0	0	0	0	0	0	0	0
998	0%	0%	0%	0%	0%	0%	0%	0%
999	0	0	0	0	0	0	0	0
1000	Alt Energy (Grid) / Otay Full / L3010 Out							
1001	14.2.1.1	14.2.1.2	14.2.1.3	14.2.1.4	14.2.1.5	14.2.1.6		
1002	0	1686	912	927	343	710		
1003	4818	4256	4272	4256	5149	5063		
1004	0	0	0	0	0	0	0	0
1005	0	0	0	0	0	0	0	0
1006	0	0	0	0	0	0	0	0
1007	0%	0%	0%	0%	0%	0%	0%	0%
1008	0	0	0	0	0	0	0	0
1009	Alt Energy (Grid) / Otay Medium / L3010 80%							
1010	14.1.2.1	14.1.2.2	14.1.2.3	14.1.2.4	14.1.2.5	14.1.2.6		
1011	0	0	0	0	0	0	0	0
1012	4818	5942	5183	5183	5492	5773		
1013	0	0	0	0	0	0	0	0
1014	0	0	0	0	0	0	0	0
1015	0	0	0	0	0	0	0	0
1016	0%	0%	0%	0%	0%	0%	0%	0%
1017	0	0	0	0	0	0	0	0
1018	Alt Energy (Grid) / Otay Medium / L3010 Out							
1019	14.2.2.1	14.2.2.2	14.2.2.3	14.2.2.4	14.2.2.5	14.2.2.6		
1020	249	1686	927	927	820	1140		
1021	4569	4256	4256	4256	4672	4633		
1022	0	0	0	0	0	0	0	0
1023	0	0	0	0	0	0	0	0
1024	0	0	0	0	0	0	0	0
1025	0%	0%	0%	0%	0%	0%	0%	0%
1026	0	0	0	0	0	0	0	0
1027	Alt Energy (Grid) / Otay Low / L3010 80%							
1028	14.1.3.1	14.1.3.2	14.1.3.3	14.1.3.4	14.1.3.5	14.1.3.6		
1029	0	0	0	0	0	0	0	0
1030	4818	5942	5183	5183	5492	5773		
1031	0	0	0	0	0	0	0	0
1032	0	0	0	0	0	0	0	0
1033	0	0	0	0	0	0	0	0
1034	0%	0%	0%	0%	0%	0%	0%	0%
1035	0	0	0	0	0	0	0	0
1036	Alt Energy (Grid) / Otay Low / L3010 Out							
1037	14.2.3.1	14.2.3.2	14.2.3.3	14.2.3.4	14.2.3.5	14.2.3.6		
1038	562	1686	927	927	1236	1517		
1039	4256	4256	4256	4256	4256	4256		
1040	0	0	0	0	0	0	0	0
1041	0	0	0	0	0	0	0	0
1042	0	0	0	0	0	0	0	0
1043	0%	0%	0%	0%	0%	0%	0%	0%
1044	0	0	0	0	0	0	0	0
1045	Alt Energy (Grid) / Otay Out / L3010 80%							
1046	14.1.4.1	14.1.4.2	14.1.4.3	14.1.4.4	14.1.4.5	14.1.4.6		
1047	0	112	534	759	56	393		
1048	4818	5829	4649	4424	5436	5380		
1049	0	0	0	0	0	0	0	0
1050	0	0	0	0	0	0	0	0
1051	0	0	0	0	0	0	0	0
1052	0%	0%	0%	0%	0%	0%	0%	0%
1053	0	0	0	0	0	0	0	0
1054	Alt Energy (Grid) / Otay Out / L3010 Out							
1055	14.2.4.1	14.2.4.2	14.2.4.3	14.2.4.4	14.2.4.5	14.2.4.6		
1056	562	1686	927	927	1236	1517		
1057	4256	4256	4256	4256	4256	4256		
1058	0	0	0	0	0	0	0	0
1059	0	0	0	0	0	0	0	0
1060	0%	0%	0%	0%	0%	0%	0%	0%
1061	0	0	0	0	0	0	0	0

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND SUPPLY (SA 1.2)
 EXAMPLE DAY OF ELECTRIC DEMAND AND SUPPLY DURING SEASONAL VARIATIONS FOR ANALYSIS OF CURTAILMENT AND METERS AFFECTED FOR EACH
 PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW		
	A	B	C	D	E	F	G	H
1								
2								
1062								
1063	Alt Energy Alternate (Smaller-Scale)							
1064								
1065	Alt Energy (Small) / Otay Full / L3010 80%							
1066	21.1.1.1	21.1.1.2	21.1.1.3	21.1.1.4	21.1.1.5	21.1.1.6		
1066	Curtailed NG-Fired Electric Gen (MW)	0	0	0	0	0	0	0
1067	Total Supply	4818	5942	5183	5183	5492	5773	
1068	Elec Curtailment (MWh)	0	0	0	0	0	0	
1069	Elec Curtailment Duration (h)	0	0	0	0	0	0	
1070	Avg Elec Curtailment (MW)	0	0	0	0	0	0	
1071	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%	
1072	Elec Curtailment (# of Customers)	0	0	0	0	0	0	
1073								
1074	Alt Energy (Small) / Otay Full / L3010 Out							
1075	21.2.1.1	21.2.1.2	21.2.1.3	21.2.1.4	21.2.1.5	21.2.1.6		
1075	Curtailed NG-Fired Electric Gen (MW)	0	1686	912	927	343	710	
1076	Total Supply	4818	4256	4272	4256	5149	5063	
1077	Elec Curtailment (MWh)	0	0	0	0	0	0	
1078	Elec Curtailment Duration (h)	0	0	0	0	0	0	
1079	Avg Elec Curtailment (MW)	0	0	0	0	0	0	
1080	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%	
1081	Elec Curtailment (# of Customers)	0	0	0	0	0	0	
1082								
1083	Alt Energy (Small) / Otay Medium / L3010 80%							
1084	21.1.2.1	21.1.2.2	21.1.2.3	21.1.2.4	21.1.2.5	21.1.2.6		
1084	Curtailed NG-Fired Electric Gen (MW)	0	0	0	0	0	0	
1085	Total Supply	4818	5942	5183	5183	5492	5773	
1086	Elec Curtailment (MWh)	0	0	0	0	0	0	
1087	Elec Curtailment Duration (h)	0	0	0	0	0	0	
1088	Avg Elec Curtailment (MW)	0	0	0	0	0	0	
1089	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%	
1090	Elec Curtailment (# of Customers)	0	0	0	0	0	0	
1091								
1092	Alt Energy (Small) / Otay Medium / L3010 Out							
1093	21.2.2.1	21.2.2.2	21.2.2.3	21.2.2.4	21.2.2.5	21.2.2.6		
1093	Curtailed NG-Fired Electric Gen (MW)	249	1686	927	927	820	1140	
1094	Total Supply	4569	4256	4256	4256	4672	4633	
1095	Elec Curtailment (MWh)	0	0	0	0	0	0	
1096	Elec Curtailment Duration (h)	0	0	0	0	0	0	
1097	Avg Elec Curtailment (MW)	0	0	0	0	0	0	
1098	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%	
1099	Elec Curtailment (# of Customers)	0	0	0	0	0	0	
1100								
1101	Alt Energy (Small) / Otay Low / L3010 80%							
1102	21.1.3.1	21.1.3.2	21.1.3.3	21.1.3.4	21.1.3.5	21.1.3.6		
1102	Curtailed NG-Fired Electric Gen (MW)	0	0	0	0	0	0	
1103	Total Supply	4818	5942	5183	5183	5492	5773	
1104	Elec Curtailment (MWh)	0	0	0	0	0	0	
1105	Elec Curtailment Duration (h)	0	0	0	0	0	0	
1106	Avg Elec Curtailment (MW)	0	0	0	0	0	0	
1107	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%	
1108	Elec Curtailment (# of Customers)	0	0	0	0	0	0	
1109								
1110	Alt Energy (Small) / Otay Low / L3010 Out							
1111	21.2.3.1	21.2.3.2	21.2.3.3	21.2.3.4	21.2.3.5	21.2.3.6		
1111	Curtailed NG-Fired Electric Gen (MW)	562	1686	927	927	1236	1517	
1112	Total Supply	4256	4256	4256	4256	4256	4256	
1113	Elec Curtailment (MWh)	0	0	0	0	0	0	
1114	Elec Curtailment Duration (h)	0	0	0	0	0	0	
1115	Avg Elec Curtailment (MW)	0	0	0	0	0	0	
1116	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%	
1117	Elec Curtailment (# of Customers)	0	0	0	0	0	0	
1118								
1119	Alt Energy (Small) / Otay Out / L3010 80%							
1120	21.1.4.1	21.1.4.2	21.1.4.3	21.1.4.4	21.1.4.5	21.1.4.6		
1120	Curtailed NG-Fired Electric Gen (MW)	0	112	534	759	56	393	
1121	Total Supply	4818	5829	4649	4424	5436	5380	
1122	Elec Curtailment (MWh)	0	0	0	0	0	0	
1123	Elec Curtailment Duration (h)	0	0	0	0	0	0	
1124	Avg Elec Curtailment (MW)	0	0	0	0	0	0	
1125	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%	
1126	Elec Curtailment (# of Customers)	0	0	0	0	0	0	
1127								
1128	Alt Energy (Small) / Otay Out / L3010 Out							
1129	21.2.4.1	21.2.4.2	21.2.4.3	21.2.4.4	21.2.4.5	21.2.4.6		
1129	Curtailed NG-Fired Electric Gen (MW)	562	1686	927	927	1236	1517	
1130	Total Supply	4256	4256	4256	4256	4256	4256	
1131	Elec Curtailment (MWh)	0	0	0	0	0	0	
1132	Elec Curtailment Duration (h)	0	0	0	0	0	0	
1133	Avg Elec Curtailment (MW)	0	0	0	0	0	0	
1134	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%	
1135	Elec Curtailment (# of Customers)	0	0	0	0	0	0	

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND SUPPLY (SA 1.2)
 EXAMPLE DAY OF ELECTRIC DEMAND AND SUPPLY DURING SEASONAL VARIATIONS FOR ANALYSIS OF CURTAILMENT AND METERS AFFECTED FOR EACH
 PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.		1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW	
	A	B	C	D	E	F	G	H
1								
2								
1136								
1137								
1138								
1139								
1140								
1141								
1142								
1143								
1144								
1145								
1146								
1147								
1148								
1149								
1150								
1151								
1152								
1153								
1154								
1155								
1156								
1157								
1158								
1159								
1160								
1161								
1162								
1163								
1164								
1165								
1166								
1167								
1168								
1169								
1170								
1171								
1172								
1173								
1174								
1175								
1176								
1177								
1178								
1179								
1180								
1181								
1182								
1183								
1184								
1185								
1186								
1187								
1188								
1189								
1190								
1191								
1192								
1193								
1194								
1195								
1196								
1197								
1198								
1199								
1200								
1201								
1202								
1203								
1204								
1205								
1206								
1207								
1208								
1209								

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND SUPPLY (SA 1.2)
 EXAMPLE DAY OF ELECTRIC DEMAND AND SUPPLY DURING SEASONAL VARIATIONS FOR ANALYSIS OF CURTAILMENT AND METERS AFFECTED FOR EACH
 PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.		1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW	
	A	B	C	D	E	F	G	H
1								
2								
1210								
1211								
1212								
1213	<i>Blythe to Santee Alternate 1</i>							
1214	<i>Blythe to Santee 1 / Otay Full / L3010 80%</i>							
1215		16.1.1.1	16.1.1.2	16.1.1.3	16.1.1.4	16.1.1.5	16.1.1.6	
1216		0	0	0	0	0	0	0
1217		3132	4256	3497	3497	3806	4087	
1218		0	0	0	0	0	0	0
1219		0	0	0	0	0	0	0
1220		0%	0%	0%	0%	0%	0%	0%
1221		0	0	0	0	0	0	0
1222	<i>Blythe to Santee 1 / Otay Full / L3010 Out</i>							
1223		16.2.1.1	16.2.1.2	16.2.1.3	16.2.1.4	16.2.1.5	16.2.1.6	
1224		0	0	0	0	0	0	0
1225		3132	4256	3497	3497	3806	4087	
1226		0	0	0	0	0	0	0
1227		0	0	0	0	0	0	0
1228		0%	0%	0%	0%	0%	0%	0%
1229		0	0	0	0	0	0	0
1230								
1231	<i>Blythe to Santee 1 / Otay Medium / L3010 80%</i>							
1232		16.1.2.1	16.1.2.2	16.1.2.3	16.1.2.4	16.1.2.5	16.1.2.6	
1233		0	0	0	0	0	0	0
1234		3132	4256	3497	3497	3806	4087	
1235		0	0	0	0	0	0	0
1236		0	0	0	0	0	0	0
1237		0%	0%	0%	0%	0%	0%	0%
1238		0	0	0	0	0	0	0
1239								
1240	<i>Blythe to Santee 1 / Otay Medium / L3010 Out</i>							
1241		16.2.2.1	16.2.2.2	16.2.2.3	16.2.2.4	16.2.2.5	16.2.2.6	
1242		0	0	0	0	0	0	0
1243		3132	4256	3497	3497	3806	4087	
1244		0	0	0	0	0	0	0
1245		0	0	0	0	0	0	0
1246		0%	0%	0%	0%	0%	0%	0%
1247		0	0	0	0	0	0	0
1248								
1249	<i>Blythe to Santee 1 / Otay Low / L3010 80%</i>							
1250		16.1.3.1	16.1.3.2	16.1.3.3	16.1.3.4	16.1.3.5	16.1.3.6	
1251		0	0	0	0	0	0	0
1252		3132	4256	3497	3497	3806	4087	
1253		0	0	0	0	0	0	0
1254		0	0	0	0	0	0	0
1255		0%	0%	0%	0%	0%	0%	0%
1256		0	0	0	0	0	0	0
1257								
1258	<i>Blythe to Santee 1 / Otay Low / L3010 Out</i>							
1259		16.2.3.1	16.2.3.2	16.2.3.3	16.2.3.4	16.2.3.5	16.2.3.6	
1260		0	0	0	0	0	0	0
1261		3132	4256	3497	3497	3806	4087	
1262		0	0	0	0	0	0	0
1263		0	0	0	0	0	0	0
1264		0%	0%	0%	0%	0%	0%	0%
1265		0	0	0	0	0	0	0
1266								
1267	<i>Blythe to Santee 1 / Otay Out / L3010 80%</i>							
1268		16.1.4.1	16.1.4.2	16.1.4.3	16.1.4.4	16.1.4.5	16.1.4.6	
1269		0	0	0	0	0	0	0
1270		3132	4256	3497	3497	3806	4087	
1271		0	0	0	0	0	0	0
1272		0	0	0	0	0	0	0
1273		0%	0%	0%	0%	0%	0%	0%
1274		0	0	0	0	0	0	0
1275								
1276	<i>Blythe to Santee 1 / Otay Out / L3010 Out</i>							
1277		16.2.4.1	16.2.4.2	16.2.4.3	16.2.4.4	16.2.4.5	16.2.4.6	
1278		0	0	0	0	0	0	0
1279		3132	4256	3497	3497	3806	4087	
1280		0	0	0	0	0	0	0
1281		0	0	0	0	0	0	0
1282		0%	0%	0%	0%	0%	0%	0%
1283		0	0	0	0	0	0	0

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND SUPPLY (SA 1.2)
 EXAMPLE DAY OF ELECTRIC DEMAND AND SUPPLY DURING SEASONAL VARIATIONS FOR ANALYSIS OF CURTAILMENT AND METERS AFFECTED FOR EACH
 PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW		
	A	B	C	D	E	F	G	H
1								
2								
1284								
1285	<i>Blythe to Santee Alternate 2</i>							
1286								
1287	<i>Blythe to Santee 2 / Otay Full / L3010 80%</i>							
1288	Curtailed NG-Fired Electric Gen (MW)	17.1.1.1	17.1.1.2	17.1.1.3	17.1.1.4	17.1.1.5	17.1.1.6	
1289	Total Supply	0	0	0	0	0	0	0
1290	Elec Curtailment (MWh)	3132	4256	3497	3497	3806	4087	
1291	Elec Curtailment Duration (h)	0	0	0	0	0	0	
1292	Avg Elec Curtailment (MW)	0	0	0	0	0	0	
1293	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%	
1294	Elec Curtailment (# of Customers)	0	0	0	0	0	0	
1295								
1296	<i>Blythe to Santee 2 / Otay Full / L3010 Out</i>							
1297	Curtailed NG-Fired Electric Gen (MW)	17.2.1.1	17.2.1.2	17.2.1.3	17.2.1.4	17.2.1.5	17.2.1.6	
1298	Total Supply	0	0	0	0	0	0	0
1299	Elec Curtailment (MWh)	3132	4256	3497	3497	3806	4087	
1300	Elec Curtailment Duration (h)	0	0	0	0	0	0	
1301	Avg Elec Curtailment (MW)	0	0	0	0	0	0	
1302	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%	
1303	Elec Curtailment (# of Customers)	0	0	0	0	0	0	
1304								
1305	<i>Blythe to Santee 2 / Otay Medium / L3010 80%</i>							
1306	Curtailed NG-Fired Electric Gen (MW)	17.1.2.1	17.1.2.2	17.1.2.3	17.1.2.4	17.1.2.5	17.1.2.6	
1307	Total Supply	0	0	0	0	0	0	0
1308	Elec Curtailment (MWh)	3132	4256	3497	3497	3806	4087	
1309	Elec Curtailment Duration (h)	0	0	0	0	0	0	
1310	Avg Elec Curtailment (MW)	0	0	0	0	0	0	
1311	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%	
1312	Elec Curtailment (# of Customers)	0	0	0	0	0	0	
1313								
1314	<i>Blythe to Santee 2 / Otay Medium / L3010 Out</i>							
1315	Curtailed NG-Fired Electric Gen (MW)	17.2.2.1	17.2.2.2	17.2.2.3	17.2.2.4	17.2.2.5	17.2.2.6	
1316	Total Supply	0	0	0	0	0	0	0
1317	Elec Curtailment (MWh)	3132	4256	3497	3497	3806	4087	
1318	Elec Curtailment Duration (h)	0	0	0	0	0	0	
1319	Avg Elec Curtailment (MW)	0	0	0	0	0	0	
1320	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%	
1321	Elec Curtailment (# of Customers)	0	0	0	0	0	0	
1322								
1323	<i>Blythe to Santee 2 / Otay Low / L3010 80%</i>							
1324	Curtailed NG-Fired Electric Gen (MW)	17.1.3.1	17.1.3.2	17.1.3.3	17.1.3.4	17.1.3.5	17.1.3.6	
1325	Total Supply	0	0	0	0	0	0	0
1326	Elec Curtailment (MWh)	3132	4256	3497	3497	3806	4087	
1327	Elec Curtailment Duration (h)	0	0	0	0	0	0	
1328	Avg Elec Curtailment (MW)	0	0	0	0	0	0	
1329	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%	
1330	Elec Curtailment (# of Customers)	0	0	0	0	0	0	
1331								
1332	<i>Blythe to Santee 2 / Otay Low / L3010 Out</i>							
1333	Curtailed NG-Fired Electric Gen (MW)	17.2.3.1	17.2.3.2	17.2.3.3	17.2.3.4	17.2.3.5	17.2.3.6	
1334	Total Supply	0	0	0	0	0	0	0
1335	Elec Curtailment (MWh)	3132	4256	3497	3497	3806	4087	
1336	Elec Curtailment Duration (h)	0	0	0	0	0	0	
1337	Avg Elec Curtailment (MW)	0	0	0	0	0	0	
1338	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%	
1339	Elec Curtailment (# of Customers)	0	0	0	0	0	0	
1340								
1341	<i>Blythe to Santee 2 / Otay Out / L3010 80%</i>							
1342	Curtailed NG-Fired Electric Gen (MW)	17.1.4.1	17.1.4.2	17.1.4.3	17.1.4.4	17.1.4.5	17.1.4.6	
1343	Total Supply	0	0	0	0	0	0	0
1344	Elec Curtailment (MWh)	3132	4256	3497	3497	3806	4087	
1345	Elec Curtailment Duration (h)	0	0	0	0	0	0	
1346	Avg Elec Curtailment (MW)	0	0	0	0	0	0	
1347	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%	
1348	Elec Curtailment (# of Customers)	0	0	0	0	0	0	
1349								
1350	<i>Blythe to Santee 2 / Otay Out / L3010 Out</i>							
1351	Curtailed NG-Fired Electric Gen (MW)	17.2.4.1	17.2.4.2	17.2.4.3	17.2.4.4	17.2.4.5	17.2.4.6	
1352	Total Supply	0	0	0	0	0	0	0
1353	Elec Curtailment (MWh)	3132	4256	3497	3497	3806	4087	
1354	Elec Curtailment Duration (h)	0	0	0	0	0	0	
1355	Avg Elec Curtailment (MW)	0	0	0	0	0	0	
1356	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%	
1357	Elec Curtailment (# of Customers)	0	0	0	0	0	0	

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND SUPPLY (SA 1.2)
 EXAMPLE DAY OF ELECTRIC DEMAND AND SUPPLY DURING SEASONAL VARIATIONS FOR ANALYSIS OF CURTAILMENT AND METERS AFFECTED FOR EACH
 PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.		1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW	
	A	B	C	D	E	F	G	H
1								
2								
1358								
1359	Cactus City to San Diego Alternate							
1360								
1361	Cactus City to SD / Otay Full / L3010 80%							
1362		18.1.1.1	18.1.1.2	18.1.1.3	18.1.1.4	18.1.1.5	18.1.1.6	
1362		0	0	0	0	0	0	0
1363		3132	4256	3497	3497	3806	4087	
1364		0	0	0	0	0	0	
1365		0	0	0	0	0	0	
1366		0	0	0	0	0	0	
1367		0%	0%	0%	0%	0%	0%	
1368		0	0	0	0	0	0	
1369								
1370	Cactus City to SD / Otay Full / L3010 Out							
1371		18.2.1.1	18.2.1.2	18.2.1.3	18.2.1.4	18.2.1.5	18.2.1.6	
1371		0	0	0	0	0	0	0
1372		3132	4256	3497	3497	3806	4087	
1373		0	0	0	0	0	0	
1374		0	0	0	0	0	0	
1375		0	0	0	0	0	0	
1376		0%	0%	0%	0%	0%	0%	
1377		0	0	0	0	0	0	
1378								
1379	Cactus City to SD / Otay Medium / L3010 80%							
1380		18.1.2.1	18.1.2.2	18.1.2.3	18.1.2.4	18.1.2.5	18.1.2.6	
1380		0	0	0	0	0	0	0
1381		3132	4256	3497	3497	3806	4087	
1382		0	0	0	0	0	0	
1383		0	0	0	0	0	0	
1384		0	0	0	0	0	0	
1385		0%	0%	0%	0%	0%	0%	
1386		0	0	0	0	0	0	
1387								
1388	Cactus City to SD / Otay Medium / L3010 Out							
1389		18.2.2.1	18.2.2.2	18.2.2.3	18.2.2.4	18.2.2.5	18.2.2.6	
1389		0	0	0	0	0	0	0
1390		3132	4256	3497	3497	3806	4087	
1391		0	0	0	0	0	0	
1392		0	0	0	0	0	0	
1393		0	0	0	0	0	0	
1394		0%	0%	0%	0%	0%	0%	
1395		0	0	0	0	0	0	
1396								
1397	Cactus City to SD / Otay Low / L3010 80%							
1398		18.1.3.1	18.1.3.2	18.1.3.3	18.1.3.4	18.1.3.5	18.1.3.6	
1398		0	0	0	0	0	0	0
1399		3132	4256	3497	3497	3806	4087	
1400		0	0	0	0	0	0	
1401		0	0	0	0	0	0	
1402		0	0	0	0	0	0	
1403		0%	0%	0%	0%	0%	0%	
1404		0	0	0	0	0	0	
1405								
1406	Cactus City to SD / Otay Low / L3010 Out							
1407		18.2.3.1	18.2.3.2	18.2.3.3	18.2.3.4	18.2.3.5	18.2.3.6	
1407		0	0	0	0	0	0	0
1408		3132	4256	3497	3497	3806	4087	
1409		0	0	0	0	0	0	
1410		0	0	0	0	0	0	
1411		0	0	0	0	0	0	
1412		0%	0%	0%	0%	0%	0%	
1413		0	0	0	0	0	0	
1414								
1415	Cactus City to SD / Otay Out / L3010 80%							
1416		18.1.4.1	18.1.4.2	18.1.4.3	18.1.4.4	18.1.4.5	18.1.4.6	
1416		0	0	0	0	0	0	0
1417		3132	4256	3497	3497	3806	4087	
1418		0	0	0	0	0	0	
1419		0	0	0	0	0	0	
1420		0	0	0	0	0	0	
1421		0%	0%	0%	0%	0%	0%	
1422		0	0	0	0	0	0	
1423								
1424	Cactus City to SD / Otay Out / L3010 Out							
1425		18.2.4.1	18.2.4.2	18.2.4.3	18.2.4.4	18.2.4.5	18.2.4.6	
1425		0	0	0	0	0	0	0
1426		3132	4256	3497	3497	3806	4087	
1427		0	0	0	0	0	0	
1428		0	0	0	0	0	0	
1429		0	0	0	0	0	0	
1430		0%	0%	0%	0%	0%	0%	
1431		0	0	0	0	0	0	

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND SUPPLY (SA 1.2)
 EXAMPLE DAY OF ELECTRIC DEMAND AND SUPPLY DURING SEASONAL VARIATIONS FOR ANALYSIS OF CURTAILMENT AND METERS AFFECTED FOR EACH
 PROJECT ALTERNATE
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW	
A	B	C	D	E	F	G	H
1							
2							
1432	Second Pipeline Along L3010 Alternate						
1433	Second Pipeline Along L3010 / Otay Full / L3010 80%						
1434	19.1.1.1	19.1.1.2	19.1.1.3	19.1.1.4	19.1.1.5	19.1.1.6	
1435	Curtailed NG-Fired Electric Gen (MW)	0	0	0	0	0	0
1436	Total Supply	3132	4256	3497	3497	3806	4087
1437	Elec Curtailment (MWh)	0	0	0	0	0	0
1438	Elec Curtailment Duration (h)	0	0	0	0	0	0
1439	Avg Elec Curtailment (MW)	0	0	0	0	0	0
1440	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%
1441	Elec Curtailment (# of Customers)	0	0	0	0	0	0
1442							
1443							
1444	Second Pipeline Along L3010 / Otay Full / L3010 Out						
1445	19.2.1.1	19.2.1.2	19.2.1.3	19.2.1.4	19.2.1.5	19.2.1.6	
1446	Curtailed NG-Fired Electric Gen (MW)	0	0	0	0	0	0
1447	Total Supply	3132	4256	3497	3497	3806	4087
1448	Elec Curtailment (MWh)	0	0	0	0	0	0
1449	Elec Curtailment Duration (h)	0	0	0	0	0	0
1450	Avg Elec Curtailment (MW)	0	0	0	0	0	0
1451	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%
1452	Elec Curtailment (# of Customers)	0	0	0	0	0	0
1453							
1454	Second Pipeline Along L3010 / Otay Medium / L3010 Out						
1455	19.1.2.1	19.1.2.2	19.1.2.3	19.1.2.4	19.1.2.5	19.1.2.6	
1456	Curtailed NG-Fired Electric Gen (MW)	0	0	0	0	0	0
1457	Total Supply	3132	4256	3497	3497	3806	4087
1458	Elec Curtailment (MWh)	0	0	0	0	0	0
1459	Elec Curtailment Duration (h)	0	0	0	0	0	0
1460	Avg Elec Curtailment (MW)	0	0	0	0	0	0
1461	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%
1462	Elec Curtailment (# of Customers)	0	0	0	0	0	0
1463							
1464	Second Pipeline Along L3010 / Otay Medium / L3010 Out						
1465	19.2.2.1	19.2.2.2	19.2.2.3	19.2.2.4	19.2.2.5	19.2.2.6	
1466	Curtailed NG-Fired Electric Gen (MW)	0	0	0	0	0	0
1467	Total Supply	3132	4256	3497	3497	3806	4087
1468	Elec Curtailment (MWh)	0	0	0	0	0	0
1469	Elec Curtailment Duration (h)	0	0	0	0	0	0
1470	Avg Elec Curtailment (MW)	0	0	0	0	0	0
1471	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%
1472	Elec Curtailment (# of Customers)	0	0	0	0	0	0
1473							
1474	Second Pipeline Along L3010 / Otay Low / L3010 80%						
1475	19.1.3.1	19.1.3.2	19.1.3.3	19.1.3.4	19.1.3.5	19.1.3.6	
1476	Curtailed NG-Fired Electric Gen (MW)	0	0	0	0	0	0
1477	Total Supply	3132	4256	3497	3497	3806	4087
1478	Elec Curtailment (MWh)	0	0	0	0	0	0
1479	Elec Curtailment Duration (h)	0	0	0	0	0	0
1480	Avg Elec Curtailment (MW)	0	0	0	0	0	0
1481	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%
1482	Elec Curtailment (# of Customers)	0	0	0	0	0	0
1483							
1484	Second Pipeline Along L3010 / Otay Low / L3010 Out						
1485	19.2.3.1	19.2.3.2	19.2.3.3	19.2.3.4	19.2.3.5	19.2.3.6	
1486	Curtailed NG-Fired Electric Gen (MW)	0	0	0	0	0	0
1487	Total Supply	3132	4256	3497	3497	3806	4087
1488	Elec Curtailment (MWh)	0	0	0	0	0	0
1489	Elec Curtailment Duration (h)	0	0	0	0	0	0
1490	Avg Elec Curtailment (MW)	0	0	0	0	0	0
1491	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%
1492	Elec Curtailment (# of Customers)	0	0	0	0	0	0
1493							
1494	Second Pipeline Along L3010 / Otay Out / L3010 80%						
1495	19.1.4.1	19.1.4.2	19.1.4.3	19.1.4.4	19.1.4.5	19.1.4.6	
1496	Curtailed NG-Fired Electric Gen (MW)	0	0	0	0	0	0
1497	Total Supply	3132	4256	3497	3497	3806	4087
1498	Elec Curtailment (MWh)	0	0	0	0	0	0
1499	Elec Curtailment Duration (h)	0	0	0	0	0	0
1500	Avg Elec Curtailment (MW)	0	0	0	0	0	0
1501	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%
1502	Elec Curtailment (# of Customers)	0	0	0	0	0	0
1503							
1504	Second Pipeline Along L3010 / Otay Out / L3010 Out						
1505	19.2.4.1	19.2.4.2	19.2.4.3	19.2.4.4	19.2.4.5	19.2.4.6	
	Curtailed NG-Fired Electric Gen (MW)	0	0	0	0	0	0
	Total Supply	3132	4256	3497	3497	3806	4087
	Elec Curtailment (MWh)	0	0	0	0	0	0
	Elec Curtailment Duration (h)	0	0	0	0	0	0
	Avg Elec Curtailment (MW)	0	0	0	0	0	0
	Elec Curtailment (%)	0%	0%	0%	0%	0%	0%
	Elec Curtailment (# of Customers)	0	0	0	0	0	0

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND OUTPUTS (SA 1.3)
 EXAMPLE ELECTRIC DEMAND DAY DURING SEASONAL VARIATIONS WITH ELECTRIC SUPPLY FOR THE ALTERNATIVES AND RELATED CURTAILMENT
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW	
1							
2							
3	L1600 / Otay Full / L3010 80%	1.1.1.1	1.1.1.2	1.1.1.3	1.1.1.4	1.1.1.5	1.1.1.6
4	Available Supply (MW)	3,132	4,256	3,497	3,497	3,806	4,087
5	Curtaiment (MWh)	0	0	0	0	0	0
6	Total # Hours w/ Outages	0.00	0.00	0.00	0.00	0.00	0.00
106	L1600 / Otay Full / L3010 Out	1.2.1.1	1.2.1.2	1.2.1.3	1.2.1.4	1.2.1.5	1.2.1.6
107	Available Supply (MW)	3,132	3,335	3,429	3,204	3,806	4,087
108	Curtaiment (MWh)	0	2,043	0	249	0	0
109	Total # Hours w/ Outages	0.00	9.25	0.00	3.00	0.00	0.00
209	L1600 / Otay Medium / L3010 80%	1.1.2.1	1.1.2.2	1.1.2.3	1.1.2.4	1.1.2.5	1.1.2.6
210	Available Supply (MW)	3,132	4,256	3,497	3,497	3,806	4,087
211	Curtaiment (MWh)	0	0	0	0	0	0
212	Total # Hours w/ Outages	0.00	0.00	0.00	0.00	0.00	0.00
312	L1600 / Otay Medium / L3010 Out	1.2.2.1	1.2.2.2	1.2.2.3	1.2.2.4	1.2.2.5	1.2.2.6
313	Available Supply (MW)	3,132	3,187	2,963	2,738	3,806	3,790
314	Curtaiment (MWh)	0	3,554	1	2,886	0	0
315	Total # Hours w/ Outages	0.00	11.00	0.25	10.75	0.00	0.00
415	L1600 / Otay Low / L3010 80%	1.1.3.1	1.1.3.2	1.1.3.3	1.1.3.4	1.1.3.5	1.1.3.6
416	Available Supply (MW)	3,132	4,256	3,497	3,497	3,806	4,087
417	Curtaiment (MWh)	0	0	0	0	0	0
418	Total # Hours w/ Outages	0.00	0.00	0.00	0.00	0.00	0.00
518	L1600 / Otay Low / L3010 Out	1.2.3.1	1.2.3.2	1.2.3.3	1.2.3.4	1.2.3.5	1.2.3.6
519	Available Supply (MW)	3,038	3,038	2,570	2,570	3,189	3,343
520	Curtaiment (MWh)	12	5,303	1,450	5,152	0	0
521	Total # Hours w/ Outages	0.50	12.50	5.25	16.75	0.00	0.00
621	L1600 / Otay Out / L3010 80%	1.1.4.1	1.1.4.2	1.1.4.3	1.1.4.4	1.1.4.5	1.1.4.6
622	Available Supply (MW)	3,132	4,256	3,497	3,497	3,806	4,087
623	Curtaiment (MWh)	0	0	0	0	0	0
624	Total # Hours w/ Outages	0.00	0.00	0.00	0.00	0.00	0.00
724	L1600 / Otay Out / L3010 Out	1.2.4.1	1.2.4.2	1.2.4.3	1.2.4.4	1.2.4.5	1.2.4.6
725	Available Supply (MW)	2,851	2,851	2,570	2,570	2,570	2,570
726	Curtaiment (MWh)	720	7,881	1,450	5,152	150	1,836
727	Total # Hours w/ Outages	6.00	14.75	5.25	16.75	1.75	8.00
827	L3602 / Otay Full / L3010 80%	2.1.1.1	2.1.1.2	2.1.1.3	2.1.1.4	2.1.1.5	2.1.1.6
828	Available Supply (MW)	3,132	4,256	3,497	3,497	3,806	4,087
829	Curtaiment (MWh)	0	0	0	0	0	0
830	Total # Hours w/ Outages	0.00	0.00	0.00	0.00	0.00	0.00
930	L3602 / Otay Full / L3010 Out	2.2.1.1	2.2.1.2	2.2.1.3	2.2.1.4	2.2.1.5	2.2.1.6
931	Available Supply (MW)	3,132	4,256	3,497	3,497	3,806	4,087
932	Curtaiment (MWh)	0	0	0	0	0	0
933	Total # Hours w/ Outages	0.00	0.00	0.00	0.00	0.00	0.00
1033	L3602 / Otay Medium / L3010 80%	2.1.2.1	2.1.2.2	2.1.2.3	2.1.2.4	2.1.2.5	2.1.2.6

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND OUTPUTS (SA 1.3)
 EXAMPLE ELECTRIC DEMAND DAY DURING SEASONAL VARIATIONS WITH ELECTRIC SUPPLY FOR THE ALTERNATIVES AND RELATED CURTAILMENT
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW
1						
1034	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
1035	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
1036	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
1136	L3602 / Otay Medium / L3010 Out 2.2.2.1	2.2.2.2	2.2.2.3	2.2.2.4	2.2.2.5	2.2.2.6
1137	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
1138	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
1139	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
1239	L3602 / Otay Low / L3010 80% 2.1.3.1	2.1.3.2	2.1.3.3	2.1.3.4	2.1.3.5	2.1.3.6
1240	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
1241	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
1242	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
1342	L3602 / Otay Low / L3010 Out 2.2.3.1	2.2.3.2	2.2.3.3	2.2.3.4	2.2.3.5	2.2.3.6
1343	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
1344	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
1345	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
1445	L3602 / Otay Out / L3010 80% 2.1.4.1	2.1.4.2	2.1.4.3	2.1.4.4	2.1.4.5	2.1.4.6
1446	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
1447	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
1448	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
1548	L3602 / Otay Out / L3010 Out 2.2.4.1	2.2.4.2	2.2.4.3	2.2.4.4	2.2.4.5	2.2.4.6
1549	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
1550	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
1651	Hydrotesting / Otay Full / L3010 80% 3.1.1.1	3.1.1.2	3.1.1.3	3.1.1.4	3.1.1.5	3.1.1.6
1652	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
1653	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
1654	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
1754	Hydrotesting / Otay Full / L3010 Out 3.2.1.1	3.2.1.2	3.2.1.3	3.2.1.4	3.2.1.5	3.2.1.6
1755	Available Supply (MW) 3,132	Available Supply (MW) 2,570	Available Supply (MW) 2,586	Available Supply (MW) 2,570	Available Supply (MW) 3,463	Available Supply (MW) 3,377
1756	Curtaiment (MWh) 0	Curtaiment (MWh) 12,380	Curtaiment (MWh) 1,368	Curtaiment (MWh) 5,152	Curtaiment (MWh) 0	Curtaiment (MWh) 0
1757	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 17.75	Total # Hours w/ Outages 5.25	Total # Hours w/ Outages 16.75	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
1857	Hydrotesting / Otay Medium / L3010 80% 3.1.2.1	3.1.2.2	3.1.2.3	3.1.2.4	3.1.2.5	3.1.2.6
1858	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
1859	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
1860	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
1960	Hydrotesting / Otay Medium / L3010 Out 3.2.2.1	3.2.2.2	3.2.2.3	3.2.2.4	3.2.2.5	3.2.2.6
1961	Available Supply (MW) 2,883	Available Supply (MW) 2,570	Available Supply (MW) 2,570	Available Supply (MW) 2,570	Available Supply (MW) 2,987	Available Supply (MW) 2,947
1962	Curtaiment (MWh) 542	Curtaiment (MWh) 12,380	Curtaiment (MWh) 1,450	Curtaiment (MWh) 5,152	Curtaiment (MWh) 0	Curtaiment (MWh) 70
1963	Total # Hours w/ Outages 5.25	Total # Hours w/ Outages 17.75	Total # Hours w/ Outages 5.25	Total # Hours w/ Outages 16.75	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 1.50
2063	Hydrotesting / Otay Low / L3010 80% 3.1.3.1	3.1.3.2	3.1.3.3	3.1.3.4	3.1.3.5	3.1.3.6
2064	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
2065	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
2066	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND OUTPUTS (SA 1.3)
 EXAMPLE ELECTRIC DEMAND DAY DURING SEASONAL VARIATIONS WITH ELECTRIC SUPPLY FOR THE ALTERNATIVES AND RELATED CURTAILMENT
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW
1						
2166	Hydrotesting / Otay Low / L3010 Out 3.2.3.1	3.2.3.2	3.2.3.3	3.2.3.4	3.2.3.5	3.2.3.6
2167	Available Supply (MW) 2,570	Available Supply (MW) 2,570	Available Supply (MW) 2,570	Available Supply (MW) 2,570	Available Supply (MW) 2,570	Available Supply (MW) 2,570
2168	Curtailment (MWh) 2,873	Curtailment (MWh) 12,390	Curtailment (MWh) 1,450	Curtailment (MWh) 5,152	Curtailment (MWh) 150	Curtailment (MWh) 1,636
2169	Total # Hours w/ Outages 9.25	Total # Hours w/ Outages 17.75	Total # Hours w/ Outages 5.25	Total # Hours w/ Outages 16.75	Total # Hours w/ Outages 1.75	Total # Hours w/ Outages 8.00
2269	Hydrotesting / Otay Out / L3010 80% 3.1.4.1	3.1.4.2	3.1.4.3	3.1.4.4	3.1.4.5	3.1.4.6
2270	Available Supply (MW) 3,132	Available Supply (MW) 4,143	Available Supply (MW) 2,963	Available Supply (MW) 2,739	Available Supply (MW) 3,750	Available Supply (MW) 3,694
2271	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 1	Curtailment (MWh) 2,881	Curtailment (MWh) 0	Curtailment (MWh) 0
2272	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.25	Total # Hours w/ Outages 10.75	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
2372	Hydrotesting / Otay Out / L3010 Out 3.2.4.1	3.2.4.2	3.2.4.3	3.2.4.4	3.2.4.5	3.2.4.6
2373	Available Supply (MW) 2,570	Available Supply (MW) 2,570	Available Supply (MW) 2,570	Available Supply (MW) 2,570	Available Supply (MW) 2,570	Available Supply (MW) 2,570
2374	Curtailment (MWh) 2,873	Curtailment (MWh) 12,380	Curtailment (MWh) 1,450	Curtailment (MWh) 5,152	Curtailment (MWh) 150	Curtailment (MWh) 1,636
2475	Alt Diameter 10" / Otay Full / L3010 80% 4.1.1.1	4.1.1.2	4.1.1.3	4.1.1.4	4.1.1.5	4.1.1.6
2476	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
2477	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0
2478	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
2578	Alt Diameter 10" / Otay Full / L3010 Out 4.2.1.1	4.2.1.2	4.2.1.3	4.2.1.4	4.2.1.5	4.2.1.6
2579	Available Supply (MW) 3,132	Available Supply (MW) 2,773	Available Supply (MW) 2,867	Available Supply (MW) 2,642	Available Supply (MW) 3,744	Available Supply (MW) 3,658
2580	Curtailment (MWh) 0	Curtailment (MWh) 9,051	Curtailment (MWh) 172	Curtailment (MWh) 4,053	Curtailment (MWh) 0	Curtailment (MWh) 0
2581	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 15.50	Total # Hours w/ Outages 2.75	Total # Hours w/ Outages 13.50	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
2681	Alt Diameter 10" / Otay Medium / L3010 80% 4.1.2.1	4.1.2.2	4.1.2.3	4.1.2.4	4.1.2.5	4.1.2.6
2682	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
2683	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0
2684	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
2784	Alt Diameter 10" / Otay Medium / L3010 Out 4.2.2.1	4.2.2.2	4.2.2.3	4.2.2.4	4.2.2.5	4.2.2.6
2785	Available Supply (MW) 3,132	Available Supply (MW) 2,625	Available Supply (MW) 2,570	Available Supply (MW) 2,570	Available Supply (MW) 3,268	Available Supply (MW) 3,228
2786	Curtailment (MWh) 0	Curtailment (MWh) 11,438	Curtailment (MWh) 1,450	Curtailment (MWh) 5,152	Curtailment (MWh) 0	Curtailment (MWh) 0
2787	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 16.75	Total # Hours w/ Outages 5.25	Total # Hours w/ Outages 16.75	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
2887	Alt Diameter 10" / Otay Low / L3010 80% 4.1.3.1	4.1.3.2	4.1.3.3	4.1.3.4	4.1.3.5	4.1.3.6
2888	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
2889	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0
2890	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
2990	Alt Diameter 10" / Otay Low / L3010 Out 4.2.3.1	4.2.3.2	4.2.3.3	4.2.3.4	4.2.3.5	4.2.3.6
2991	Available Supply (MW) 2,570	Available Supply (MW) 2,570	Available Supply (MW) 2,570	Available Supply (MW) 2,570	Available Supply (MW) 2,627	Available Supply (MW) 2,781
2992	Curtailment (MWh) 2,873	Curtailment (MWh) 12,390	Curtailment (MWh) 1,450	Curtailment (MWh) 5,152	Curtailment (MWh) 58	Curtailment (MWh) 473
2993	Total # Hours w/ Outages 9.25	Total # Hours w/ Outages 17.75	Total # Hours w/ Outages 5.25	Total # Hours w/ Outages 16.75	Total # Hours w/ Outages 1.50	Total # Hours w/ Outages 3.25
3093	Alt Diameter 10" / Otay Out / L3010 80% 4.1.4.1	4.1.4.2	4.1.4.3	4.1.4.4	4.1.4.5	4.1.4.6
3094	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,244	Available Supply (MW) 3,020	Available Supply (MW) 3,806	Available Supply (MW) 3,975
3095	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 912	Curtailment (MWh) 0	Curtailment (MWh) 0
3096	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 4.25	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
3196	Alt Diameter 10" / Otay Out / L3010 Out 4.2.4.1	4.2.4.2	4.2.4.3	4.2.4.4	4.2.4.5	4.2.4.6
3197	Available Supply (MW) 2,570	Available Supply (MW) 2,570	Available Supply (MW) 2,570	Available Supply (MW) 2,570	Available Supply (MW) 2,570	Available Supply (MW) 2,570

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND OUTPUTS (SA 1.3)
 EXAMPLE ELECTRIC DEMAND DAY DURING SEASONAL VARIATIONS WITH ELECTRIC SUPPLY FOR THE ALTERNATIVES AND RELATED CURTAILMENT
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW
1						
3198	Curtailment (MWh) 2,873	Curtailment (MWh) 12,380	Curtailment (MWh) 1,450	Curtailment (MWh) 5,152	Curtailment (MWh) 150	Curtailment (MWh) 1,636
3299	Alt Diameter 12" / Otay Full / L3010 80% 5.1.1.1	5.1.1.2	5.1.1.3	5.1.1.4	5.1.1.5	5.1.1.6
3300	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
3301	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0
3302	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
3402	Alt Diameter 12" / Otay Full / L3010 Out 5.2.1.1	5.2.1.2	5.2.1.3	5.2.1.4	5.2.1.5	5.2.1.6
3403	Available Supply (MW) 3,132	Available Supply (MW) 2,886	Available Supply (MW) 2,979	Available Supply (MW) 2,754	Available Supply (MW) 3,806	Available Supply (MW) 3,771
3404	Curtailment (MWh) 0	Curtailment (MWh) 7,374	Curtailment (MWh) 0	Curtailment (MWh) 2,716	Curtailment (MWh) 0	Curtailment (MWh) 0
3405	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 14.50	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 10.50	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
3505	Alt Diameter 12" / Otay Medium / L3010 80% 5.1.2.1	5.1.2.2	5.1.2.3	5.1.2.4	5.1.2.5	5.1.2.6
3506	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
3507	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0
3508	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
3608	Alt Diameter 12" / Otay Medium / L3010 Out 5.2.2.1	5.2.2.2	5.2.2.3	5.2.2.4	5.2.2.5	5.2.2.6
3609	Available Supply (MW) 3,132	Available Supply (MW) 2,737	Available Supply (MW) 2,570	Available Supply (MW) 2,570	Available Supply (MW) 3,380	Available Supply (MW) 3,341
3610	Curtailment (MWh) 0	Curtailment (MWh) 9,618	Curtailment (MWh) 1,450	Curtailment (MWh) 5,152	Curtailment (MWh) 0	Curtailment (MWh) 0
3611	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 16.00	Total # Hours w/ Outages 5.25	Total # Hours w/ Outages 16.75	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
3711	Alt Diameter 12" / Otay Low / L3010 80% 5.1.3.1	5.1.3.2	5.1.3.3	5.1.3.4	5.1.3.5	5.1.3.6
3712	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
3713	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0
3714	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
3814	Alt Diameter 12" / Otay Low / L3010 Out 5.2.3.1	5.2.3.2	5.2.3.3	5.2.3.4	5.2.3.5	5.2.3.6
3815	Available Supply (MW) 2,589	Available Supply (MW) 2,589	Available Supply (MW) 2,570	Available Supply (MW) 2,570	Available Supply (MW) 2,739	Available Supply (MW) 2,893
3816	Curtailment (MWh) 2,701	Curtailment (MWh) 12,054	Curtailment (MWh) 1,450	Curtailment (MWh) 5,152	Curtailment (MWh) 0	Curtailment (MWh) 170
3817	Total # Hours w/ Outages 9.25	Total # Hours w/ Outages 17.50	Total # Hours w/ Outages 5.25	Total # Hours w/ Outages 16.75	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 2.25
3917	Alt Diameter 12" / Otay Out / L3010 80% 5.1.4.1	5.1.4.2	5.1.4.3	5.1.4.4	5.1.4.5	5.1.4.6
3918	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,357	Available Supply (MW) 3,132	Available Supply (MW) 3,806	Available Supply (MW) 4,087
3919	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 486	Curtailment (MWh) 0	Curtailment (MWh) 0
3920	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 3.50	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
4020	Alt Diameter 12" / Otay Out / L3010 Out 5.2.4.1	5.2.4.2	5.2.4.3	5.2.4.4	5.2.4.5	5.2.4.6
4021	Available Supply (MW) 2,570	Available Supply (MW) 2,570	Available Supply (MW) 2,570	Available Supply (MW) 2,570	Available Supply (MW) 2,570	Available Supply (MW) 2,570
4022	Curtailment (MWh) 2,873	Curtailment (MWh) 12,380	Curtailment (MWh) 1,450	Curtailment (MWh) 5,152	Curtailment (MWh) 150	Curtailment (MWh) 1,636
4123	Alt Diameter 16" / Otay Full / L3010 80% 6.1.1.1	6.1.1.2	6.1.1.3	6.1.1.4	6.1.1.5	6.1.1.6
4124	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
4125	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0
4126	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
4226	Alt Diameter 16" / Otay Full / L3010 Out 6.2.1.1	6.2.1.2	6.2.1.3	6.2.1.4	6.2.1.5	6.2.1.6
4227	Available Supply (MW) 3,132	Available Supply (MW) 3,392	Available Supply (MW) 3,485	Available Supply (MW) 3,260	Available Supply (MW) 3,806	Available Supply (MW) 4,087
4228	Curtailment (MWh) 0	Curtailment (MWh) 1,539	Curtailment (MWh) 0	Curtailment (MWh) 105	Curtailment (MWh) 0	Curtailment (MWh) 0
4229	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 8.50	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 2.25	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
4329	Alt Diameter 16" / Otay Medium / L3010 80% 6.1.2.1	6.1.2.2	6.1.2.3	6.1.2.4	6.1.2.5	6.1.2.6

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND OUTPUTS (SA 1.3)
 EXAMPLE ELECTRIC DEMAND DAY DURING SEASONAL VARIATIONS WITH ELECTRIC SUPPLY FOR THE ALTERNATIVES AND RELATED CURTAILMENT
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW
1						
4330	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
4331	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
4332	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
4432	Alt Diameter 16" / Otay Medium / L3010 Out 6.2.2.1	6.2.2.2	6.2.2.3	6.2.2.4	6.2.2.5	6.2.2.6
4433	Available Supply (MW) 3,132	Available Supply (MW) 3,243	Available Supply (MW) 3,019	Available Supply (MW) 2,794	Available Supply (MW) 3,806	Available Supply (MW) 3,847
4434	Curtaiment (MWh) 0	Curtaiment (MWh) 2,953	Curtaiment (MWh) 0	Curtaiment (MWh) 2,315	Curtaiment (MWh) 0	Curtaiment (MWh) 0
4435	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 10.50	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 9.25	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
4535	Alt Diameter 16" / Otay Low / L3010 80% 6.1.3.1	6.1.3.2	6.1.3.3	6.1.3.4	6.1.3.5	6.1.3.6
4536	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
4537	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
4538	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
4638	Alt Diameter 16" / Otay Low / L3010 Out 6.2.3.1	6.2.3.2	6.2.3.3	6.2.3.4	6.2.3.5	6.2.3.6
4639	Available Supply (MW) 3,094	Available Supply (MW) 3,094	Available Supply (MW) 2,570	Available Supply (MW) 2,570	Available Supply (MW) 3,245	Available Supply (MW) 3,399
4640	Curtaiment (MWh) 0	Curtaiment (MWh) 4,618	Curtaiment (MWh) 1,450	Curtaiment (MWh) 5,152	Curtaiment (MWh) 0	Curtaiment (MWh) 0
4641	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 12.00	Total # Hours w/ Outages 5.25	Total # Hours w/ Outages 16.75	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
4741	Alt Diameter 16" / Otay Out / L3010 80% 6.1.4.1	6.1.4.2	6.1.4.3	6.1.4.4	6.1.4.5	6.1.4.6
4742	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
4743	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
4744	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
4844	Alt Diameter 16" / Otay Out / L3010 Out 6.2.4.1	6.2.4.2	6.2.4.3	6.2.4.4	6.2.4.5	6.2.4.6
4845	Available Supply (MW) 2,907	Available Supply (MW) 2,907	Available Supply (MW) 2,570	Available Supply (MW) 2,570	Available Supply (MW) 2,570	Available Supply (MW) 2,570
4846	Curtaiment (MWh) 417	Curtaiment (MWh) 7,065	Curtaiment (MWh) 1,450	Curtaiment (MWh) 5,152	Curtaiment (MWh) 150	Curtaiment (MWh) 1,836
4947	Alt Diameter 20" / Otay Full / L3010 80% 20.1.1.1	20.1.1.2	20.1.1.3	20.1.1.4	20.1.1.5	20.1.1.6
4948	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
4949	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
4950	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
5050	Alt Diameter 20" / Otay Full / L3010 Out 20.2.1.1	20.2.1.2	20.2.1.3	20.2.1.4	20.2.1.5	20.2.1.6
5051	Available Supply (MW) 3,132	Available Supply (MW) 3,897	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
5052	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
5053	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
5153	Alt Diameter 20" / Otay Medium / L3010 80% 20.1.2.1	20.1.2.2	20.1.2.3	20.1.2.4	20.1.2.5	20.1.2.6
5154	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
5155	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
5156	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
5256	Alt Diameter 20" / Otay Medium / L3010 Out 20.2.2.1	20.2.2.2	20.2.2.3	20.2.2.4	20.2.2.5	20.2.2.6
5257	Available Supply (MW) 3,132	Available Supply (MW) 3,749	Available Supply (MW) 3,497	Available Supply (MW) 3,300	Available Supply (MW) 3,806	Available Supply (MW) 4,087
5258	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 28	Curtaiment (MWh) 0	Curtaiment (MWh) 0
5259	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 1.25	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
5359	Alt Diameter 20" / Otay Low / L3010 80% 20.1.3.1	20.1.3.2	20.1.3.3	20.1.3.4	20.1.3.5	20.1.3.6
5360	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
5361	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
5362	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND OUTPUTS (SA 1.3)
 EXAMPLE ELECTRIC DEMAND DAY DURING SEASONAL VARIATIONS WITH ELECTRIC SUPPLY FOR THE ALTERNATIVES AND RELATED CURTAILMENT
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW
5462	Alt Diameter 20" / Otay Low / L3010 Out 20.2.3.1	20.2.3.2	20.2.3.3	20.2.3.4	20.2.3.5	20.2.3.6
5463	Available Supply (MW) 3,132	Available Supply (MW) 3,600	Available Supply (MW) 3,065	Available Supply (MW) 2,840	Available Supply (MW) 3,751	Available Supply (MW) 3,905
5464	Curtaiment (MWh) 0	Curtaiment (MWh) 297	Curtaiment (MWh) 0	Curtaiment (MWh) 1,906	Curtaiment (MWh) 0	Curtaiment (MWh) 0
5465	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 3.50	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 8.25	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
5565	Alt Diameter 20" / Otay Out / L3010 80% 20.1.4.1	20.1.4.2	20.1.4.3	20.1.4.4	20.1.4.5	20.1.4.6
5566	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
5567	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
5568	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
5668	Alt Diameter 20" / Otay Out / L3010 Out 20.2.4.1	20.2.4.2	20.2.4.3	20.2.4.4	20.2.4.5	20.2.4.6
5669	Available Supply (MW) 3,132	Available Supply (MW) 3,413	Available Supply (MW) 2,570	Available Supply (MW) 2,570	Available Supply (MW) 3,020	Available Supply (MW) 2,963
5670	Curtaiment (MWh) 0	Curtaiment (MWh) 1,363	Curtaiment (MWh) 1,450	Curtaiment (MWh) 5,152	Curtaiment (MWh) 0	Curtaiment (MWh) 49
5771	Alt Diameter 24" / Otay Full / L3010 80% 7.1.1.1	7.1.1.2	7.1.1.3	7.1.1.4	7.1.1.5	7.1.1.6
5772	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
5773	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
5774	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
5874	Alt Diameter 24" / Otay Full / L3010 Out 7.2.1.1	7.2.1.2	7.2.1.3	7.2.1.4	7.2.1.5	7.2.1.6
5875	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
5876	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
5877	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
5977	Alt Diameter 24" / Otay Medium / L3010 80% 7.1.2.1	7.1.2.2	7.1.2.3	7.1.2.4	7.1.2.5	7.1.2.6
5978	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
5979	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
5980	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
6080	Alt Diameter 24" / Otay Medium / L3010 Out 7.2.2.1	7.2.2.2	7.2.2.3	7.2.2.4	7.2.2.5	7.2.2.6
6081	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
6082	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
6083	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
6183	Alt Diameter 24" / Otay Low / L3010 80% 7.1.3.1	7.1.3.2	7.1.3.3	7.1.3.4	7.1.3.5	7.1.3.6
6184	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
6185	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
6186	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
6286	Alt Diameter 24" / Otay Low / L3010 Out 7.2.3.1	7.2.3.2	7.2.3.3	7.2.3.4	7.2.3.5	7.2.3.6
6287	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
6288	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
6289	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
6389	Alt Diameter 24" / Otay Out / L3010 80% 7.1.4.1	7.1.4.2	7.1.4.3	7.1.4.4	7.1.4.5	7.1.4.6
6390	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
6391	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
6392	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
6492	Alt Diameter 24" / Otay Out / L3010 Out 7.2.4.1	7.2.4.2	7.2.4.3	7.2.4.4	7.2.4.5	7.2.4.6
6493	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,076	Available Supply (MW) 2,851	Available Supply (MW) 3,806	Available Supply (MW) 3,806

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND OUTPUTS (SA 1.3)
 EXAMPLE ELECTRIC DEMAND DAY DURING SEASONAL VARIATIONS WITH ELECTRIC SUPPLY FOR THE ALTERNATIVES AND RELATED CURTAILMENT
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.	1. Example Summer Low-EG Day MW		2. Example Summer High-EG Day MW		3. Example Winter Day MW		4. Winter 1-in-10 Year Day MW		5. Example Spring Day MW		6. Example Fall Day MW	
1												
6494	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	1,819	Curtailment (MWh)	0	Curtailment (MWh)	0
6595	8.1.1.1		8.1.1.2		8.1.1.3		8.1.1.4		8.1.1.5		8.1.1.6	
6596	Available Supply (MW)	3,132	Available Supply (MW)	4,256	Available Supply (MW)	3,497	Available Supply (MW)	3,497	Available Supply (MW)	3,806	Available Supply (MW)	4,087
6597	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0
6598	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00
6698	8.2.1.1		8.2.1.2		8.2.1.3		8.2.1.4		8.2.1.5		8.2.1.6	
6699	Available Supply (MW)	3,132	Available Supply (MW)	4,256	Available Supply (MW)	3,497	Available Supply (MW)	3,497	Available Supply (MW)	3,806	Available Supply (MW)	4,087
6700	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0
6701	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00
6801	8.1.2.1		8.1.2.2		8.1.2.3		8.1.2.4		8.1.2.5		8.1.2.6	
6802	Available Supply (MW)	3,132	Available Supply (MW)	4,256	Available Supply (MW)	3,497	Available Supply (MW)	3,497	Available Supply (MW)	3,806	Available Supply (MW)	4,087
6803	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0
6804	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00
6904	8.2.2.1		8.2.2.2		8.2.2.3		8.2.2.4		8.2.2.5		8.2.2.6	
6905	Available Supply (MW)	3,132	Available Supply (MW)	4,256	Available Supply (MW)	3,497	Available Supply (MW)	3,497	Available Supply (MW)	3,806	Available Supply (MW)	4,087
6906	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0
6907	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00
7007	8.1.3.1		8.1.3.2		8.1.3.3		8.1.3.4		8.1.3.5		8.1.3.6	
7008	Available Supply (MW)	3,132	Available Supply (MW)	4,256	Available Supply (MW)	3,497	Available Supply (MW)	3,497	Available Supply (MW)	3,806	Available Supply (MW)	4,087
7009	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0
7010	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00
7110	8.2.3.1		8.2.3.2		8.2.3.3		8.2.3.4		8.2.3.5		8.2.3.6	
7111	Available Supply (MW)	3,132	Available Supply (MW)	4,256	Available Supply (MW)	3,497	Available Supply (MW)	3,497	Available Supply (MW)	3,806	Available Supply (MW)	4,087
7112	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0
7113	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00
7213	8.1.4.1		8.1.4.2		8.1.4.3		8.1.4.4		8.1.4.5		8.1.4.6	
7214	Available Supply (MW)	3,132	Available Supply (MW)	4,256	Available Supply (MW)	3,497	Available Supply (MW)	3,497	Available Supply (MW)	3,806	Available Supply (MW)	4,087
7215	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0
7216	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00
7316	8.2.4.1		8.2.4.2		8.2.4.3		8.2.4.4		8.2.4.5		8.2.4.6	
7317	Available Supply (MW)	3,132	Available Supply (MW)	4,256	Available Supply (MW)	3,497	Available Supply (MW)	3,497	Available Supply (MW)	3,806	Available Supply (MW)	4,087
7318	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0
7419	9.1.1.1		9.1.1.2		9.1.1.3		9.1.1.4		9.1.1.5		9.1.1.6	
7420	Available Supply (MW)	3,132	Available Supply (MW)	4,256	Available Supply (MW)	3,497	Available Supply (MW)	3,497	Available Supply (MW)	3,806	Available Supply (MW)	4,087
7421	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0
7422	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00
7522	9.2.1.1		9.2.1.2		9.2.1.3		9.2.1.4		9.2.1.5		9.2.1.6	
7523	Available Supply (MW)	3,132	Available Supply (MW)	4,256	Available Supply (MW)	3,497	Available Supply (MW)	3,497	Available Supply (MW)	3,806	Available Supply (MW)	4,087
7524	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0	Curtailment (MWh)	0
7525	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00
7625	9.1.2.1		9.1.2.2		9.1.2.3		9.1.2.4		9.1.2.5		9.1.2.6	

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND OUTPUTS (SA 1.3)
 EXAMPLE ELECTRIC DEMAND DAY DURING SEASONAL VARIATIONS WITH ELECTRIC SUPPLY FOR THE ALTERNATIVES AND RELATED CURTAILMENT
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW
1						
7626	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
7627	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
7628	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
7728	Alt Diameter 42" / Otay Medium / L3010 Out 9.2.2.1	9.2.2.2	9.2.2.3	9.2.2.4	9.2.2.5	9.2.2.6
7729	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
7730	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
7731	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
7831	Alt Diameter 42" / Otay Low / L3010 80% 9.1.3.1	9.1.3.2	9.1.3.3	9.1.3.4	9.1.3.5	9.1.3.6
7832	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
7833	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
7834	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
7934	Alt Diameter 42" / Otay Low / L3010 Out 9.2.3.1	9.2.3.2	9.2.3.3	9.2.3.4	9.2.3.5	9.2.3.6
7935	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
7936	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
7937	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
8037	Alt Diameter 42" / Otay Out / L3010 80% 9.1.4.1	9.1.4.2	9.1.4.3	9.1.4.4	9.1.4.5	9.1.4.6
8038	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
8039	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
8040	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
8140	Alt Diameter 42" / Otay Out / L3010 Out 9.2.4.1	9.2.4.2	9.2.4.3	9.2.4.4	9.2.4.5	9.2.4.6
8141	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
8142	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
8243	L1600 In-Kind / Otay Full / L3010 80% 10.1.1.1	10.1.1.2	10.1.1.3	10.1.1.4	10.1.1.5	10.1.1.6
8244	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
8245	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
8246	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
8346	L1600 In-Kind / Otay Full / L3010 Out 10.2.1.1	10.2.1.2	10.2.1.3	10.2.1.4	10.2.1.5	10.2.1.6
8347	Available Supply (MW) 3,132	Available Supply (MW) 3,392	Available Supply (MW) 3,485	Available Supply (MW) 3,260	Available Supply (MW) 3,806	Available Supply (MW) 4,087
8348	Curtaiment (MWh) 0	Curtaiment (MWh) 1,539	Curtaiment (MWh) 0	Curtaiment (MWh) 105	Curtaiment (MWh) 0	Curtaiment (MWh) 0
8349	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 8.50	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 2.25	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
8449	L1600 In-Kind / Otay Medium / L3010 80% 10.1.2.1	10.1.2.2	10.1.2.3	10.1.2.4	10.1.2.5	10.1.2.6
8450	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
8451	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
8452	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
8552	L1600 In-Kind / Otay Medium / L3010 Out 10.2.2.1	10.2.2.2	10.2.2.3	10.2.2.4	10.2.2.5	10.2.2.6
8553	Available Supply (MW) 3,132	Available Supply (MW) 3,243	Available Supply (MW) 3,019	Available Supply (MW) 2,794	Available Supply (MW) 3,806	Available Supply (MW) 3,847
8554	Curtaiment (MWh) 0	Curtaiment (MWh) 2,953	Curtaiment (MWh) 0	Curtaiment (MWh) 2,315	Curtaiment (MWh) 0	Curtaiment (MWh) 0
8555	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 10.50	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 9.25	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
8655	L1600 In-Kind / Otay Low / L3010 80% 10.1.3.1	10.1.3.2	10.1.3.3	10.1.3.4	10.1.3.5	10.1.3.6
8656	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
8657	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
8658	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND OUTPUTS (SA 1.3)
 EXAMPLE ELECTRIC DEMAND DAY DURING SEASONAL VARIATIONS WITH ELECTRIC SUPPLY FOR THE ALTERNATIVES AND RELATED CURTAILMENT
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW		
8758	L1600 In-Kind / Otay Low / L3010 Out	10.2.3.1	10.2.3.2	10.2.3.3	10.2.3.4	10.2.3.5	10.2.3.6	
8759	Available Supply (MW)	3,094	Available Supply (MW)	3,094	Available Supply (MW)	2,570	Available Supply (MW)	3,399
8760	Curtaiment (MWh)	0	Curtaiment (MWh)	4,618	Curtaiment (MWh)	1,450	Curtaiment (MWh)	0
8761	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	12.00	Total # Hours w/ Outages	5.25	Total # Hours w/ Outages	0.00
8861	L1600 In-Kind / Otay Out / L3010 80%	10.1.4.1	10.1.4.2	10.1.4.3	10.1.4.4	10.1.4.5	10.1.4.6	
8862	Available Supply (MW)	3,132	Available Supply (MW)	4,256	Available Supply (MW)	3,497	Available Supply (MW)	4,087
8863	Curtaiment (MWh)	0	Curtaiment (MWh)	0	Curtaiment (MWh)	0	Curtaiment (MWh)	0
8864	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00
8964	L1600 In-Kind / Otay Out / L3010 Out	10.2.4.1	10.2.4.2	10.2.4.3	10.2.4.4	10.2.4.5	10.2.4.6	
8965	Available Supply (MW)	2,907	Available Supply (MW)	2,907	Available Supply (MW)	2,570	Available Supply (MW)	2,570
8966	Curtaiment (MWh)	417	Curtaiment (MWh)	7,065	Curtaiment (MWh)	1,450	Curtaiment (MWh)	150
9067	Otay Mesa Alternate / Otay Full / L3010 80%	11.1.1.1	11.1.1.2	11.1.1.3	11.1.1.4	11.1.1.5	11.1.1.6	
9068	Available Supply (MW)	3,132	Available Supply (MW)	4,256	Available Supply (MW)	3,497	Available Supply (MW)	4,087
9069	Curtaiment (MWh)	0	Curtaiment (MWh)	0	Curtaiment (MWh)	0	Curtaiment (MWh)	0
9070	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00
9170	Otay Mesa Alternate / Otay Full / L3010 Out	11.2.1.1	11.2.1.2	11.2.1.3	11.2.1.4	11.2.1.5	11.2.1.6	
9171	Available Supply (MW)	3,132	Available Supply (MW)	2,570	Available Supply (MW)	2,570	Available Supply (MW)	3,377
9172	Curtaiment (MWh)	0	Curtaiment (MWh)	12,380	Curtaiment (MWh)	1,368	Curtaiment (MWh)	0
9173	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	17.75	Total # Hours w/ Outages	5.25	Total # Hours w/ Outages	0.00
9273	Otay Mesa Alternate / Otay Medium / L3010 80%	11.1.2.1	11.1.2.2	11.1.2.3	11.1.2.4	11.1.2.5	11.1.2.6	
9274	Available Supply (MW)	3,132	Available Supply (MW)	4,256	Available Supply (MW)	3,497	Available Supply (MW)	4,087
9275	Curtaiment (MWh)	0	Curtaiment (MWh)	0	Curtaiment (MWh)	0	Curtaiment (MWh)	0
9276	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00
9376	Otay Mesa Alternate / Otay Medium / L3010 Out	11.2.2.1	11.2.2.2	11.2.2.3	11.2.2.4	11.2.2.5	11.2.2.6	
9377	Available Supply (MW)	2,883	Available Supply (MW)	2,570	Available Supply (MW)	2,570	Available Supply (MW)	2,987
9378	Curtaiment (MWh)	542	Curtaiment (MWh)	12,380	Curtaiment (MWh)	1,450	Curtaiment (MWh)	0
9379	Total # Hours w/ Outages	5.25	Total # Hours w/ Outages	17.75	Total # Hours w/ Outages	5.25	Total # Hours w/ Outages	0.00
9479	Otay Mesa Alternate / Otay Low / L3010 80%	11.1.3.1	11.1.3.2	11.1.3.3	11.1.3.4	11.1.3.5	11.1.3.6	
9480	Available Supply (MW)	3,132	Available Supply (MW)	4,256	Available Supply (MW)	3,497	Available Supply (MW)	4,087
9481	Curtaiment (MWh)	0	Curtaiment (MWh)	0	Curtaiment (MWh)	0	Curtaiment (MWh)	0
9482	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00
9582	Otay Mesa Alternate / Otay Low / L3010 Out	11.2.3.1	11.2.3.2	11.2.3.3	11.2.3.4	11.2.3.5	11.2.3.6	
9583	Available Supply (MW)	2,570	Available Supply (MW)	2,570	Available Supply (MW)	2,570	Available Supply (MW)	2,570
9584	Curtaiment (MWh)	2,873	Curtaiment (MWh)	12,380	Curtaiment (MWh)	1,450	Curtaiment (MWh)	150
9585	Total # Hours w/ Outages	9.25	Total # Hours w/ Outages	17.75	Total # Hours w/ Outages	5.25	Total # Hours w/ Outages	1.75
9685	Otay Mesa Alternate / Otay Out / L3010 80%	11.1.4.1	11.1.4.2	11.1.4.3	11.1.4.4	11.1.4.5	11.1.4.6	
9686	Available Supply (MW)	3,132	Available Supply (MW)	4,143	Available Supply (MW)	2,963	Available Supply (MW)	3,694
9687	Curtaiment (MWh)	0	Curtaiment (MWh)	0	Curtaiment (MWh)	1	Curtaiment (MWh)	0
9688	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.00	Total # Hours w/ Outages	0.25	Total # Hours w/ Outages	0.00
9788	Otay Mesa Alternate / Otay Out / L3010 Out	11.2.4.1	11.2.4.2	11.2.4.3	11.2.4.4	11.2.4.5	11.2.4.6	
9789	Available Supply (MW)	2,570	Available Supply (MW)	2,570	Available Supply (MW)	2,570	Available Supply (MW)	2,570

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND OUTPUTS (SA 1.3)
 EXAMPLE ELECTRIC DEMAND DAY DURING SEASONAL VARIATIONS WITH ELECTRIC SUPPLY FOR THE ALTERNATIVES AND RELATED CURTAILMENT
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW
1						
9790	Curtailment (MWh) 2,873	Curtailment (MWh) 12,380	Curtailment (MWh) 1,450	Curtailment (MWh) 5,152	Curtailment (MWh) 150	Curtailment (MWh) 1,636
9891	LNG Storage / Otay Full / L3010 80% 13.1.1.1	13.1.1.2	13.1.1.3	13.1.1.4	13.1.1.5	13.1.1.6
9892	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
9893	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0
9894	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
9994	LNG Storage / Otay Full / L3010 Out 13.2.1.1	13.2.1.2	13.2.1.3	13.2.1.4	13.2.1.5	13.2.1.6
9995	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
9996	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0
9997	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
10097	LNG Storage / Otay Medium / L3010 80% 13.1.2.1	13.1.2.2	13.1.2.3	13.1.2.4	13.1.2.5	13.1.2.6
10098	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
10099	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0
10100	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
10200	LNG Storage / Otay Medium / L3010 Out 13.2.2.1	13.2.2.2	13.2.2.3	13.2.2.4	13.2.2.5	13.2.2.6
10201	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
10202	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0
10203	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
10303	LNG Storage / Otay Low / L3010 80% 13.1.3.1	13.1.3.2	13.1.3.3	13.1.3.4	13.1.3.5	13.1.3.6
10304	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
10305	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0
10306	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
10406	LNG Storage / Otay Low / L3010 Out 13.2.3.1	13.2.3.2	13.2.3.3	13.2.3.4	13.2.3.5	13.2.3.6
10407	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
10408	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0
10409	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
10509	LNG Storage / Otay Out / L3010 80% 13.1.4.1	13.1.4.2	13.1.4.3	13.1.4.4	13.1.4.5	13.1.4.6
10510	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
10511	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0
10512	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
10612	LNG Storage / Otay Out / L3010 Out 13.2.4.1	13.2.4.2	13.2.4.3	13.2.4.4	13.2.4.5	13.2.4.6
10613	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
10614	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0
10715	Alt Energy (Grid) / Otay Full / L3010 80% 14.1.1.1	14.1.1.2	14.1.1.3	14.1.1.4	14.1.1.5	14.1.1.6
10716	Available Supply (MW) 4,818	Available Supply (MW) 5,942	Available Supply (MW) 5,183	Available Supply (MW) 5,183	Available Supply (MW) 5,492	Available Supply (MW) 5,773
10717	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0
10718	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
10818	Alt Energy (Grid) / Otay Full / L3010 Out 14.2.1.1	14.2.1.2	14.2.1.3	14.2.1.4	14.2.1.5	14.2.1.6
10819	Available Supply (MW) 4,818	Available Supply (MW) 4,256	Available Supply (MW) 4,272	Available Supply (MW) 4,256	Available Supply (MW) 5,149	Available Supply (MW) 5,063
10820	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0
10821	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
10921	Alt Energy (Grid) / Otay Medium / L3010 80% 14.1.2.1	14.1.2.2	14.1.2.3	14.1.2.4	14.1.2.5	14.1.2.6

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND OUTPUTS (SA 1.3)
 EXAMPLE ELECTRIC DEMAND DAY DURING SEASONAL VARIATIONS WITH ELECTRIC SUPPLY FOR THE ALTERNATIVES AND RELATED CURTAILMENT
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW
1						
10922	Available Supply (MW) 4,818	Available Supply (MW) 5,942	Available Supply (MW) 5,183	Available Supply (MW) 5,183	Available Supply (MW) 5,492	Available Supply (MW) 5,773
10923	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
10924	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
11024	<i>Alt Energy (Grid) / Otay Medium / L3010 Out</i> 14.2.2.1	14.2.2.2	14.2.2.3	14.2.2.4	14.2.2.5	14.2.2.6
11025	Available Supply (MW) 4,569	Available Supply (MW) 4,256	Available Supply (MW) 4,256	Available Supply (MW) 4,256	Available Supply (MW) 4,672	Available Supply (MW) 4,633
11026	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
11027	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
11127	<i>Alt Energy (Grid) / Otay Low / L3010 80%</i> 14.1.3.1	14.1.3.2	14.1.3.3	14.1.3.4	14.1.3.5	14.1.3.6
11128	Available Supply (MW) 4,818	Available Supply (MW) 5,942	Available Supply (MW) 5,183	Available Supply (MW) 5,183	Available Supply (MW) 5,492	Available Supply (MW) 5,773
11129	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
11130	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
11230	<i>Alt Energy (Grid) / Otay Low / L3010 Out</i> 14.2.3.1	14.2.3.2	14.2.3.3	14.2.3.4	14.2.3.5	14.2.3.6
11231	Available Supply (MW) 4,256	Available Supply (MW) 4,256	Available Supply (MW) 4,256	Available Supply (MW) 4,256	Available Supply (MW) 4,256	Available Supply (MW) 4,256
11232	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
11233	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
11333	<i>Alt Energy (Grid) / Otay Out / L3010 80%</i> 14.1.4.1	14.1.4.2	14.1.4.3	14.1.4.4	14.1.4.5	14.1.4.6
11334	Available Supply (MW) 4,818	Available Supply (MW) 5,829	Available Supply (MW) 4,649	Available Supply (MW) 4,424	Available Supply (MW) 5,436	Available Supply (MW) 5,380
11335	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
11336	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
11436	<i>Alt Energy (Grid) / Otay Out / L3010 Out</i> 14.2.4.1	14.2.4.2	14.2.4.3	14.2.4.4	14.2.4.5	14.2.4.6
11437	Available Supply (MW) 4,256	Available Supply (MW) 4,256	Available Supply (MW) 4,256	Available Supply (MW) 4,256	Available Supply (MW) 4,256	Available Supply (MW) 4,256
11438	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
11539	<i>Alt Energy (Small) / Otay Full / L3010 80%</i> 21.1.1.1	21.1.1.2	21.1.1.3	21.1.1.4	21.1.1.5	21.1.1.6
11540	Available Supply (MW) 4,818	Available Supply (MW) 5,942	Available Supply (MW) 5,183	Available Supply (MW) 5,183	Available Supply (MW) 5,492	Available Supply (MW) 5,773
11541	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
11542	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
11642	<i>Alt Energy (Small) / Otay Full / L3010 Out</i> 21.2.1.1	21.2.1.2	21.2.1.3	21.2.1.4	21.2.1.5	21.2.1.6
11643	Available Supply (MW) 4,818	Available Supply (MW) 4,256	Available Supply (MW) 4,272	Available Supply (MW) 4,256	Available Supply (MW) 5,149	Available Supply (MW) 5,063
11644	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
11645	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
11745	<i>Alt Energy (Small) / Otay Medium / L3010 80%</i> 21.1.2.1	21.1.2.2	21.1.2.3	21.1.2.4	21.1.2.5	21.1.2.6
11746	Available Supply (MW) 4,818	Available Supply (MW) 5,942	Available Supply (MW) 5,183	Available Supply (MW) 5,183	Available Supply (MW) 5,492	Available Supply (MW) 5,773
11747	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
11748	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
11848	<i>Alt Energy (Small) / Otay Medium / L3010 Out</i> 21.2.2.1	21.2.2.2	21.2.2.3	21.2.2.4	21.2.2.5	21.2.2.6
11849	Available Supply (MW) 4,569	Available Supply (MW) 4,256	Available Supply (MW) 4,256	Available Supply (MW) 4,256	Available Supply (MW) 4,672	Available Supply (MW) 4,633
11850	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
11851	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
11951	<i>Alt Energy (Small) / Otay Low / L3010 80%</i> 21.1.3.1	21.1.3.2	21.1.3.3	21.1.3.4	21.1.3.5	21.1.3.6
11952	Available Supply (MW) 4,818	Available Supply (MW) 5,942	Available Supply (MW) 5,183	Available Supply (MW) 5,183	Available Supply (MW) 5,492	Available Supply (MW) 5,773
11953	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
11954	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND OUTPUTS (SA 1.3)
 EXAMPLE ELECTRIC DEMAND DAY DURING SEASONAL VARIATIONS WITH ELECTRIC SUPPLY FOR THE ALTERNATIVES AND RELATED CURTAILMENT
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW
12054	Alt Energy (Small) / Otay Low / L3010 Out 21.2.3.1	21.2.3.2	21.2.3.3	21.2.3.4	21.2.3.5	21.2.3.6
12055	Available Supply (MW) 4,256	Available Supply (MW) 4,256	Available Supply (MW) 4,256	Available Supply (MW) 4,256	Available Supply (MW) 4,256	Available Supply (MW) 4,256
12056	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0
12057	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
12157	Alt Energy (Small) / Otay Out / L3010 80% 21.1.4.1	21.1.4.2	21.1.4.3	21.1.4.4	21.1.4.5	21.1.4.6
12158	Available Supply (MW) 4,818	Available Supply (MW) 5,829	Available Supply (MW) 4,649	Available Supply (MW) 4,424	Available Supply (MW) 5,436	Available Supply (MW) 5,380
12159	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0
12160	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
12260	Alt Energy (Small) / Otay Out / L3010 Out 21.2.4.1	21.2.4.2	21.2.4.3	21.2.4.4	21.2.4.5	21.2.4.6
12261	Available Supply (MW) 4,256	Available Supply (MW) 4,256	Available Supply (MW) 4,256	Available Supply (MW) 4,256	Available Supply (MW) 4,256	Available Supply (MW) 4,256
12262	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0
12363	Offshore / Otay Full / L3010 80% 15.1.1.1	15.1.1.2	15.1.1.3	15.1.1.4	15.1.1.5	15.1.1.6
12364	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
12365	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0
12366	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
12466	Offshore / Otay Full / L3010 Out 15.2.1.1	15.2.1.2	15.2.1.3	15.2.1.4	15.2.1.5	15.2.1.6
12467	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
12468	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0
12469	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
12569	Offshore / Otay Medium / L3010 80% 15.1.2.1	15.1.2.2	15.1.2.3	15.1.2.4	15.1.2.5	15.1.2.6
12570	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
12571	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0
12572	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
12672	Offshore / Otay Medium / L3010 Out 15.2.2.1	15.2.2.2	15.2.2.3	15.2.2.4	15.2.2.5	15.2.2.6
12673	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
12674	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0
12675	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
12775	Offshore / Otay Low / L3010 80% 15.1.3.1	15.1.3.2	15.1.3.3	15.1.3.4	15.1.3.5	15.1.3.6
12776	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
12777	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0
12778	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
12878	Offshore / Otay Low / L3010 Out 15.2.3.1	15.2.3.2	15.2.3.3	15.2.3.4	15.2.3.5	15.2.3.6
12879	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
12880	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0
12881	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
12981	Offshore / Otay Out / L3010 80% 15.1.4.1	15.1.4.2	15.1.4.3	15.1.4.4	15.1.4.5	15.1.4.6
12982	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
12983	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0	Curtailment (MWh) 0
12984	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
13084	Offshore / Otay Out / L3010 Out 15.2.4.1	15.2.4.2	15.2.4.3	15.2.4.4	15.2.4.5	15.2.4.6
13085	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND OUTPUTS (SA 1.3)
 EXAMPLE ELECTRIC DEMAND DAY DURING SEASONAL VARIATIONS WITH ELECTRIC SUPPLY FOR THE ALTERNATIVES AND RELATED CURTAILMENT
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW
1						
14218	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
14219	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
14220	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
14320	<i>Blythe to Santee 2 / Otay Medium / L3010 Out</i>					
14321	17.2.2.1	17.2.2.2	17.2.2.3	17.2.2.4	17.2.2.5	17.2.2.6
14321	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
14322	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
14323	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
14423	<i>Blythe to Santee 2 / Otay Low / L3010 80%</i>					
14423	17.1.3.1	17.1.3.2	17.1.3.3	17.1.3.4	17.1.3.5	17.1.3.6
14424	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
14425	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
14426	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
14526	<i>Blythe to Santee 2 / Otay Low / L3010 Out</i>					
14526	17.2.3.1	17.2.3.2	17.2.3.3	17.2.3.4	17.2.3.5	17.2.3.6
14527	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
14528	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
14529	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
14629	<i>Blythe to Santee 2 / Otay Out / L3010 80%</i>					
14629	17.1.4.1	17.1.4.2	17.1.4.3	17.1.4.4	17.1.4.5	17.1.4.6
14630	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
14631	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
14632	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
14732	<i>Blythe to Santee 2 / Otay Out / L3010 Out</i>					
14732	17.2.4.1	17.2.4.2	17.2.4.3	17.2.4.4	17.2.4.5	17.2.4.6
14733	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
14734	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
14835	<i>Cactus City to SD / Otay Full / L3010 80%</i>					
14835	18.1.1.1	18.1.1.2	18.1.1.3	18.1.1.4	18.1.1.5	18.1.1.6
14836	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
14837	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
14838	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
14938	<i>Cactus City to SD / Otay Full / L3010 Out</i>					
14938	18.2.1.1	18.2.1.2	18.2.1.3	18.2.1.4	18.2.1.5	18.2.1.6
14939	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
14940	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
14941	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
15041	<i>Cactus City to SD / Otay Medium / L3010 80%</i>					
15041	18.1.2.1	18.1.2.2	18.1.2.3	18.1.2.4	18.1.2.5	18.1.2.6
15042	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
15043	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
15044	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
15144	<i>Cactus City to SD / Otay Medium / L3010 Out</i>					
15144	18.2.2.1	18.2.2.2	18.2.2.3	18.2.2.4	18.2.2.5	18.2.2.6
15145	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
15146	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
15147	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
15247	<i>Cactus City to SD / Otay Low / L3010 80%</i>					
15247	18.1.3.1	18.1.3.2	18.1.3.3	18.1.3.4	18.1.3.5	18.1.3.6
15248	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
15249	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
15250	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND OUTPUTS (SA 1.3)
 EXAMPLE ELECTRIC DEMAND DAY DURING SEASONAL VARIATIONS WITH ELECTRIC SUPPLY FOR THE ALTERNATIVES AND RELATED CURTAILMENT
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.	1. Example Summer Low-EG Day MW	2. Example Summer High-EG Day MW	3. Example Winter Day MW	4. Winter 1-in-10 Year Day MW	5. Example Spring Day MW	6. Example Fall Day MW
1						
15350	Cactus City to SD / Otay Low / L3010 Out 18.2.3.1	18.2.3.2	18.2.3.3	18.2.3.4	18.2.3.5	18.2.3.6
15351	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
15352	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
15353	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
15453	Cactus City to SD / Otay Out / L3010 80% 18.1.4.1	18.1.4.2	18.1.4.3	18.1.4.4	18.1.4.5	18.1.4.6
15454	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
15455	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
15456	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
15556	Cactus City to SD / Otay Out / L3010 Out 18.2.4.1	18.2.4.2	18.2.4.3	18.2.4.4	18.2.4.5	18.2.4.6
15557	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
15558	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
15659	Second Pipeline Along L3010 / Otay Full / L3010 80% 19.1.1.1	19.1.1.2	19.1.1.3	19.1.1.4	19.1.1.5	19.1.1.6
15660	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
15661	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
15662	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
15762	Second Pipeline Along L3010 / Otay Full / L3010 Out 19.2.1.1	19.2.1.2	19.2.1.3	19.2.1.4	19.2.1.5	19.2.1.6
15763	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
15764	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
15765	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
15865	Second Pipeline Along L3010 / Otay Medium / L3010 80% 19.1.2.1	19.1.2.2	19.1.2.3	19.1.2.4	19.1.2.5	19.1.2.6
15866	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
15867	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
15868	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
15968	Second Pipeline Along L3010 / Otay Medium / L3010 Out 19.2.2.1	19.2.2.2	19.2.2.3	19.2.2.4	19.2.2.5	19.2.2.6
15969	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
15970	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
15971	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
16071	Second Pipeline Along L3010 / Otay Low / L3010 80% 19.1.3.1	19.1.3.2	19.1.3.3	19.1.3.4	19.1.3.5	19.1.3.6
16072	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
16073	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
16074	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
16174	Second Pipeline Along L3010 / Otay Low / L3010 Out 19.2.3.1	19.2.3.2	19.2.3.3	19.2.3.4	19.2.3.5	19.2.3.6
16175	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
16176	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
16177	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
16277	Second Pipeline Along L3010 / Otay Out / L3010 80% 19.1.4.1	19.1.4.2	19.1.4.3	19.1.4.4	19.1.4.5	19.1.4.6
16278	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087
16279	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0	Curtaiment (MWh) 0
16280	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00	Total # Hours w/ Outages 0.00
16380	Second Pipeline Along L3010 / Otay Out / L3010 Out 19.2.4.1	19.2.4.2	19.2.4.3	19.2.4.4	19.2.4.5	19.2.4.6
16381	Available Supply (MW) 3,132	Available Supply (MW) 4,256	Available Supply (MW) 3,497	Available Supply (MW) 3,497	Available Supply (MW) 3,806	Available Supply (MW) 4,087

WORK PAPER TABLE - SCENARIO ANALYSIS ELECTRIC DEMAND AND OUTPUTS (SA 1.3)
 EXAMPLE ELECTRIC DEMAND DAY DURING SEASONAL VARIATIONS WITH ELECTRIC SUPPLY FOR THE ALTERNATIVES AND RELATED CURTAILMENT
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.	1. Example Summer Low-EG Day MW		2. Example Summer High-EG Day MW		3. Example Winter Day MW		4. Winter 1-in-10 Year Day MW		5. Example Spring Day MW		6. Example Fall Day MW	
1 16382	Curtaiment (MWh)	0	Curtaiment (MWh)	0	Curtaiment (MWh)	0	Curtaiment (MWh)	0	Curtaiment (MWh)	0	Curtaiment (MWh)	0

WORK PAPER TABLE - SCENARIO ANALYSIS SUMMARY OF OUTPUTS (SA 1.5)
SUMMARY OF SCENARIO ANALYSIS OUTCOMES FOR % CURTAILMENT TO CUSTOMERS AND CUSTOMERS OR METERS AFFECTED
APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

41

42

43

44

45

46

47

48

49

50

51

52

53

54

55

56

57

58

59

60

61

62

63

64

65

66

67

68

69

70

71

72

73

74

75

76

77

78

79

80

81

82

Project Alternate	L3010 Status	Scenarios Analyzed	Customer Class	% of Scenarios in Curtailment	Curtailment %			Customers Affected		
					Min	Max	Avg	Min	Max	Avg
					F	G	H	I	J	K
L1600 (Pre/Post Hydrotesting)	Complete Outage	24	Gas Non-Core Non-EG	88%	68%	100%	86.0%			
			Gas Electric Generation (EG)	79%	7%	100%	51.6%			
			Gas Core	25%	4%	57%	6.5%	33,352	496,479	56,422
	Derated to 80%	24	Gas Non-Core Non-EG	8%	11%	76%	3.6%	2,665	200,930	59,984
			Gas Electric Generation (EG)	0%	0%	0%	0.0%			
			Gas Core	0%	0%	0%	0.0%	0	0	0
L3602 (Proposed Project)	Complete Outage	24	Gas Non-Core Non-EG	0%	0%	0%	0.0%			
			Gas Electric Generation (EG)	0%	0%	0%	0.0%			
			Gas Core	0%	0%	0%	0.0%	0	0	0
	Derated to 80%	24	Gas Non-Core Non-EG	0%	0%	0%	0.0%			
			Gas Electric Generation (EG)	0%	0%	0%	0.0%			
			Gas Core	0%	0%	0%	0.0%	0	0	0
L1600 (During Hydrotesting)	Complete Outage	24	Gas Non-Core Non-EG	96%	100%	100%	95.8%			
			Gas Electric Generation (EG)	96%	28%	100%	85.8%			
			Gas Core	71%	7%	100%	41.6%	60,119	868,838	361,471
	Derated to 80%	24	Gas Non-Core Non-EG	42%	12%	100%	30.6%	21,550	262,272	112,989
			Gas Electric Generation (EG)	21%	5%	82%	7.4%			
			Gas Core	0%	0%	0%	0.0%	0	0	0
Alternate Diameter Pipeline 10"	Complete Outage	24	Gas Non-Core Non-EG	96%	92%	100%	95.5%			
			Gas Electric Generation (EG)	92%	5%	100%	77.5%			
			Gas Core	50%	10%	86%	23.1%	84,319	744,718	200,920
	Derated to 80%	24	Gas Non-Core Non-EG	25%	16%	100%	17.6%	19,934	262,272	101,932
			Gas Electric Generation (EG)	13%	7%	52%	3.6%			
			Gas Core	0%	0%	0%	0.0%	0	0	0
Alternate Diameter Pipeline 12"	Complete Outage	24	Gas Non-Core Non-EG	96%	66%	100%	93.9%			
			Gas Electric Generation (EG)	88%	21%	100%	73.9%			
			Gas Core	42%	3%	80%	17.6%	28,265	695,070	152,860
	Derated to 80%	24	Gas Non-Core Non-EG	21%	20%	100%	14.7%	35,092	262,272	94,844
			Gas Electric Generation (EG)	8%	15%	39%	2.3%			
			Gas Core	0%	0%	0%	0.0%	0	0	0
Alternate Diameter Pipeline 16"	Complete Outage	24	Gas Non-Core Non-EG	88%	55%	100%	84.8%			
			Gas Electric Generation (EG)	79%	1%	100%	48.7%			
			Gas Core	25%	1%	54%	5.5%	5,325	471,655	47,877
	Derated to 80%	24	Gas Non-Core Non-EG	54%	1%	13%	3.9%	19,607	183,210	55,144
			Gas Core	4%	60%	60%	2.5%			
			Gas Electric Generation (EG)	0%	0%	0%	0.0%	0	0	0
Alternate Diameter Pipeline 20"	Complete Outage	24	Gas Non-Core Non-EG	71%	23%	100%	61.9%			
			Gas Electric Generation (EG)	54%	4%	100%	26.4%			
			Gas Core	8%	19%	29%	2.0%	168,162	248,239	17,350
	Derated to 80%	24	Gas Non-Core Non-EG	29%	1%	9%	1.4%	9,493	130,224	19,928
			Gas Electric Generation (EG)	0%	0%	0%	0.0%			
			Gas Core	0%	0%	0%	0.0%	0	0	0
Alternate Diameter Pipeline 24"	Complete Outage	24	Gas Non-Core Non-EG	0%	0%	0%	0.0%			
			Gas Electric Generation (EG)	0%	0%	0%	0.0%			
			Gas Core	0%	0%	0%	0.0%	0	0	0
	Derated to 80%	24	Gas Non-Core Non-EG	0%	0%	0%	0.0%			
			Gas Electric Generation (EG)	0%	0%	0%	0.0%			
			Gas Core	0%	0%	0%	0.0%	0	0	0
Alternate Diameter Pipeline 30"	Complete Outage	24	Gas Non-Core Non-EG	0%	0%	0%	0.0%			
			Gas Electric Generation (EG)	0%	0%	0%	0.0%			
			Gas Core	0%	0%	0%	0.0%	0	0	0
	Derated to 80%	24	Gas Non-Core Non-EG	0%	0%	0%	0.0%			
			Gas Electric Generation (EG)	0%	0%	0%	0.0%			
			Gas Core	0%	0%	0%	0.0%	0	0	0
Alternate Diameter Pipeline 42"	Complete Outage	24	Gas Non-Core Non-EG	0%	0%	0%	0.0%			
			Gas Electric Generation (EG)	0%	0%	0%	0.0%			
			Gas Core	0%	0%	0%	0.0%	0	0	0
	Derated to 80%	24	Gas Non-Core Non-EG	0%	0%	0%	0.0%			
			Gas Electric Generation (EG)	0%	0%	0%	0.0%			
			Gas Core	0%	0%	0%	0.0%	0	0	0

WORK PAPER TABLE - SCENARIO ANALYSIS SUMMARY OF OUTPUTS (SA 1.5)
 SUMMARY OF SCENARIO ANALYSIS OUTCOMES FOR % CURTAILMENT TO CUSTOMERS AND CUSTOMERS OR METERS AFFECTED
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

1

2

3

83

84

85

86

87

88

89

90

91

92

93

94

95

96

97

98

99

100

101

102

103

104

105

106

107

108

109

110

111

112

113

114

115

116

117

118

119

120

121

122

123

124

125

126

127

128

129

130

131

132

133

134

135

136

137

138

139

140

141

142

143

144

145

146

147

148

149

150

151

152

153

154

155

156

157

158

159

160

161

Line No.	Project Alternate	L3010 Status	Scenarios Analyzed	Customer Class	% of Scenarios in Curtailment	Curtailment %			Customers Affected		
						Min	Max	Avg	Min	Max	Avg
						F	G	H	I	J	K
				Electric	0%	0%	0%	0.0%	0	0	0
				Gas Non-Core Non-EG	88%	55%	100%	84.8%			
				Gas Electric Generation (EG)	79%	1%	100%	48.7%			
				Gas Core	25%	1%	54%	5.5%	5,325	471,655	47,877
				Electric	54%	1%	13%	3.9%	19,607	183,210	55,144
				Gas Non-Core Non-EG	4%	60%	60%	2.5%			
				Gas Electric Generation (EG)	0%	0%	0%	0.0%			
				Gas Core	0%	0%	0%	0.0%	0	0	0
				Electric	0%	0%	0%	0.0%	0	0	0
				Gas Non-Core Non-EG	96%	100%	100%	95.8%			
				Gas Electric Generation (EG)	96%	28%	100%	85.8%			
				Gas Core	71%	7%	100%	41.6%	60,119	868,838	361,471
				Electric	83%	2%	19%	8.1%	21,550	262,272	112,989
				Gas Non-Core Non-EG	42%	12%	100%	30.6%			
				Gas Electric Generation (EG)	21%	5%	82%	7.4%			
				Gas Core	0%	0%	0%	0.0%	0	0	0
				Electric	8%	0%	8%	0.3%	2,440	112,734	4,799
				Gas Non-Core Non-EG	96%	100%	100%	95.8%			
				Gas Electric Generation (EG)	96%	28%	100%	85.8%			
				Gas Core	71%	7%	100%	41.6%	60,119	868,838	361,471
				Electric	0%	0%	0%	0.0%	0	0	0
				Gas Non-Core Non-EG	42%	12%	100%	30.6%			
				Gas Electric Generation (EG)	21%	5%	82%	7.4%			
				Gas Core	0%	0%	0%	0.0%	0	0	0
				Electric	0%	0%	0%	0.0%	0	0	0
				Gas Non-Core Non-EG	96%	100%	100%	95.8%			
				Gas Electric Generation (EG)	96%	28%	100%	85.8%			
				Gas Core	71%	7%	100%	41.6%	60,119	868,838	361,471
				Electric	0%	0%	0%	0.0%	0	0	0
				Gas Non-Core Non-EG	42%	12%	100%	30.6%			
				Gas Electric Generation (EG)	21%	5%	82%	7.4%			
				Gas Core	0%	0%	0%	0.0%	0	0	0
				Electric	0%	0%	0%	0.0%	0	0	0
				Gas Non-Core Non-EG	96%	100%	100%	95.8%			
				Gas Electric Generation (EG)	96%	28%	100%	85.8%			
				Gas Core	71%	7%	100%	41.6%	60,119	868,838	361,471
				Electric	0%	0%	0%	0.0%	0	0	0
				Gas Non-Core Non-EG	42%	12%	100%	30.6%			
				Gas Electric Generation (EG)	21%	5%	82%	7.4%			
				Gas Core	0%	0%	0%	0.0%	0	0	0
				Electric	0%	0%	0%	0.0%	0	0	0
				Gas Non-Core Non-EG	0%	0%	0%	0.0%			
				Gas Electric Generation (EG)	0%	0%	0%	0.0%			
				Gas Core	0%	0%	0%	0.0%			
				Electric	0%	0%	0%	0.0%			
				Gas Non-Core Non-EG	0%	0%	0%	0.0%			
				Gas Electric Generation (EG)	0%	0%	0%	0.0%			
				Gas Core	0%	0%	0%	0.0%			
				Electric	0%	0%	0%	0.0%			
				Gas Non-Core Non-EG	0%	0%	0%	0.0%			
				Gas Electric Generation (EG)	0%	0%	0%	0.0%			
				Gas Core	0%	0%	0%	0.0%			
				Electric	0%	0%	0%	0.0%			
				Gas Non-Core Non-EG	0%	0%	0%	0.0%			
				Gas Electric Generation (EG)	0%	0%	0%	0.0%			
				Gas Core	0%	0%	0%	0.0%			
				Electric	0%	0%	0%	0.0%			
				Gas Non-Core Non-EG	0%	0%	0%	0.0%			
				Gas Electric Generation (EG)	0%	0%	0%	0.0%			
				Gas Core	0%	0%	0%	0.0%			
				Electric	0%	0%	0%	0.0%			
				Gas Non-Core Non-EG	0%	0%	0%	0.0%			
				Gas Electric Generation (EG)	0%	0%	0%	0.0%			
				Gas Core	0%	0%	0%	0.0%			
				Electric	0%	0%	0%	0.0%			
				Gas Non-Core Non-EG	0%	0%	0%	0.0%			
				Gas Electric Generation (EG)	0%	0%	0%	0.0%			
				Gas Core	0%	0%	0%	0.0%			
				Electric	0%	0%	0%	0.0%			
				Gas Non-Core Non-EG	0%	0%	0%	0.0%			
				Gas Electric Generation (EG)	0%	0%	0%	0.0%			
				Gas Core	0%	0%	0%	0.0%			
				Electric	0%	0%	0%	0.0%			

WORK PAPER TABLE - SCENARIO ANALYSIS SUMMARY OF OUTPUTS (SA 1.5)
 SUMMARY OF SCENARIO ANALYSIS OUTCOMES FOR % CURTAILMENT TO CUSTOMERS AND CUSTOMERS OR METERS AFFECTED
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

Line No.	Project Alternate	L3010 Status	Scenarios Analyzed	Customer Class	% of Scenarios in Curtailment	Curtailment %			Customers Affected		
						Min	Max	Avg	Min	Max	Avg
	A	B	C	D	E	F	G	H	I	J	K
1											
2											
3											
162		80%		Gas Core	0%	0%	0%	0.0%	0	0	0
163				Electric	0%	0%	0%	0.0%	0	0	0

WORK PAPER TABLE - SCENARIO ANALYSIS HEAT MAP OF CURTAILMENT LEVELS (SA 1.4)
 EXAMPLE ELECTRIC DEMAND FOR DAY DURING SEASONAL VARIATIONS WITH ELECTRIC SUPPLY FOR THE ALTERNATIVES
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

1	Dynamic dropdown list for heatmap of curtailment:							
2	Project Alternate	Line 1600 (During Hydrotesting)					Curtailment Avg: 0%	
3	Line 3010 Status	Line 3010 at 80% Supply					Curtailment Min: 0%	
4	Output Type	Non-Core [%]	% of Scenarios in Curtailment: 0%	Count of Scenarios in Curtailment: 0			Curtailment Max: 0%	
5								
6	Curtailment Type: Non-Core [%]	1. Example Summer Low-EG Day	2. Example Summer High-EG Day	3. Example Winter Day	4. Winter 1-in-10 Year Day	5. Example Spring Day	6. Example Fall Day	
7	Otay Mesa Full Supply	0.00	0.00	0.00	0.00	0.00	0.00	
8	Otay Mesa Medium Supply	0.00	0.00	0.00	0.00	0.00	0.00	
9	Otay Mesa Low Supply	0.00	0.00	0.00	0.00	0.00	0.00	
10	Otay Mesa No Supply	0.00	0.00	0.00	0.00	0.00	0.00	
11								
12	Color Scale:							
13	Lowest value	Highest value						
14								
15								


WORK PAPER TABLE - SCENARIO ANALYSIS HEAT MAP OF CURTAILMENT LEVELS (SA 1.XX)
 EXAMPLE ELECTRIC DEMAND FOR DAY DURING SEASONAL VARIATIONS WITH ELECTRIC SUPPLY FOR THE ALTERNATIVES
 AMENDED APPLICATION, VOLUME III - COST-EFFECTIVENESS ANALYSIS

21	Otay Mesa Supply	1. Example Summer Low-EG Day	2. Example Summer High-EG Day	3. Example Winter Day	4. Winter 1-in-10 Year Day	5. Example Spring Day	6. Example Fall Day
22							
23	<u>Line 1600 (Pre/Post Hydrotesting)</u>						
54	<u>Line 3602 (Proposed Project)</u>						
85	<u>Line 1600 (During Hydrotesting)</u>						
116	<u>Alternate Diameter Pipeline 10"</u>						
147	<u>Alternate Diameter Pipeline 12"</u>						
178	<u>Alternate Diameter Pipeline 16"</u>						
209	<u>Alternate Diameter Pipeline 20"</u>						
240	<u>Alternate Diameter Pipeline 24"</u>						
271	<u>Alternate Diameter Pipeline 30"</u>						
302	<u>Alternate Diameter Pipeline 42"</u>						
333	<u>L1600 In-Kind Replacement</u>						
364	<u>Otay Mesa Alternate</u>						
395	<u>LNG Storage Alternate</u>						
426	<u>Alt Energy Alternate (Grid-Scale)</u>						
457	<u>Alt Energy Alternate (Smaller-Scale)</u>						
488	<u>Offshore Route</u>						
519	<u>Blythe to Santee Alternate 1</u>						
550	<u>Blythe to Santee Alternate 2</u>						
581	<u>Cactus City to San Diego Alternate</u>						
612	<u>Second Pipeline Along L3010 Alternate</u>						
643	<u>Electric Curtailment Heat Maps</u>						

WORK PAPER TABLE - SCENARIO ANALYSIS GRAPH (SA 1.6)
 GRAPH OF CURTAILMENT IMPACTS FOR EACH ALTERNATE WITH GAS CUSTOMERS AND ELECTRIC METERS AFFECTED
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35



WORK PAPER TABLE - SCENARIO ANALYSIS SCORING (SA 1.7)
 TABLE OF AVERAGE GAS CURTAILMENT % FOR GAS CUSTOMERS & ELECTRIC OUTAGES FOR ELECTRIC CUSTOMERS RANKED BY AVERAGE CURTAILMENT %
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.	Avg Curtailment %					Normalized Average Curtailment				Benefits Evaluation Model Scoring of Avg Curtailment %			
	A	B	C	D	E	F	G	H	I	J	K	L	M
	Project Alternate	Gas Non-Core Non-EG	Gas Electric Generation (EG)	Gas Core	Electric	Gas Non-Core Non-EG	Gas Electric Generation (EG)	Gas Core	Electric	Gas Non-Core Non-EG	Gas Electric Generation (EG)	Gas Core	Electric
1													
2													
3													
4	L1600 (Pre/Post Hydrotesting)	44.8%	25.8%	3.2%	2.1%	71%	55%	16%	51%	2	3	5	3
5	L1600 (During Hydrotesting)	63.2%	46.6%	20.8%	4.2%	100%	100%	100%	100%	1	1	1	1
6	L3602 (Proposed Project)	0.0%	0.0%	0.0%	0.0%	0%	0%	0%	0%	5	5	5	5
7	Alt Diameter Pipeline 10"	56.6%	40.5%	11.6%	3.8%	89%	87%	56%	90%	1	1	3	1
8	Alt Diameter Pipeline 12"	54.3%	38.1%	8.8%	3.5%	86%	82%	42%	83%	1	1	3	1
9	Alt Diameter Pipeline 16"	43.7%	24.3%	2.8%	2.0%	69%	52%	13%	47%	2	3	5	3
10	Alt Diameter Pipeline 20"	30.9%	13.2%	1.0%	0.7%	49%	28%	5%	17%	3	4	5	5
11	Alt Diameter Pipeline 24"	12.7%	2.8%	0.0%	0.1%	20%	6%	0%	3%	4	5	5	5
12	Alt Diameter Pipeline 30"	0.0%	0.0%	0.0%	0.0%	0%	0%	0%	0%	5	5	5	5
13	Alt Diameter Pipeline 42"	0.0%	0.0%	0.0%	0.0%	0%	0%	0%	0%	5	5	5	5
14	L1600 In-Kind Replacement	43.7%	24.3%	2.8%	2.0%	69%	52%	13%	47%	2	3	5	3
15	Otay Mesa Alternate	63.2%	46.6%	20.8%	4.2%	100%	100%	100%	100%	1	1	1	1
16	LNG Storage Alternate	63.2%	46.6%	20.8%	0.0%	100%	100%	100%	0%	1	1	1	5
17	Alt Energy (Grid-Scale)	63.2%	46.6%	20.8%	0.0%	100%	100%	100%	0%	1	1	1	5
18	Alt Energy (Smaller-Scale)	63.2%	46.6%	20.8%	0.0%	100%	100%	100%	0%	1	1	1	5
19	Offshore Route	0.0%	0.0%	0.0%	0.0%	0%	0%	0%	0%	5	5	5	5
20	Blythe to Santee Alt 1	0.0%	0.0%	0.0%	0.0%	0%	0%	0%	0%	5	5	5	5
21	Blythe to Santee Alt 2	0.0%	0.0%	0.0%	0.0%	0%	0%	0%	0%	5	5	5	5
22	Cactus City to San Diego Alt	0.0%	0.0%	0.0%	0.0%	0%	0%	0%	0%	5	5	5	5
23	Second Pipeline Along L3010	0.0%	0.0%	0.0%	0.0%	0%	0%	0%	0%	5	5	5	5
24													
25													
26													
27													
28													
29													
30													
31													

Max **63.2%** **46.6%** **20.8%** **4.2%**

Average Curtailment Percentage
 Returns the average curtailment to each gas customer class and electric meters by project alternate, under all 48 scenarios evaluated for that alternate.

Normalization
 The scores in this table have been normalized against the maximum curtailment percentage under each customer class.
 For example, (Column F - Line 4) = (Column B - Line 4) / (Column F - Line 25)

Benefits Evaluation Model Scoring
 This table scored the Alternatives 1 through 5 using data in the 'Normalized Average Curtailment' table.
 Scores are ranked as 1 being worst (curtailment >= 80%) and 5 being best (curtailment <= 20%)

WORK PAPER TABLE - SCENARIO ANALYSIS GRAPH DATA SET (SA 1.8)
 DATA SET OF CURTAILMENT IMPACTS WITH GAS CUSTOMERS AND ELECTRIC METERS AFFECTED FOR GRAPH INPUT
 APPLICATION 15-09-013 VOLUME III – COST-EFFECTIVENESS ANALYSIS (CORRECTED FEBRUARY 2017)

Line No.

1	Column Labels										
2	Electric		Gas Non-Core Non-EG		Gas Electric Generation (EG)		Gas Core		Total Average of Curtailment %	Total Average of Electric Meters Affected	
3	Row Labels	Average of Curtailment %	Average of Electric Meters Affected	Average of Curtailment %	Average of Electric Meters Affected	Average of Curtailment %	Average of Electric Meters Affected	Average of Curtailment %	Average of Electric Meters Affected		
4	L1600 (Pre/Post Hydrotesting)	0.021422862	29992.00627	0.447922939	0	0.257788988	0	0.03246967	28210.88279	0.189901115	14550.72226
5	L1600 (During Hydrotesting)	0.042067286	58894.2007	0.63212371	0	0.465656104	0	0.208019672	180735.3956	0.336966693	59907.39906
6	L3602 (Proposed Project)	0	0	0	0	0	0	0	0	0	0
7	Alt Diameter Pipeline 10"	0.037748364	52847.71015	0.565588889	0	0.405443448	0	0.115625752	100460.0471	0.281094113	38326.93932
8	Alt Diameter Pipeline 12"	0.03474192	48638.68849	0.543171389	0	0.380634018	0	0.087968353	76430.24831	0.26162892	31267.2342
9	Alt Diameter Pipeline 16"	0.019694133	27571.78659	0.436655018	0	0.243303859	0	0.02755221	23938.40683	0.181801305	12877.54835
10	Alt Diameter Pipeline 20"	0.007117018	9963.824973	0.309465936	0	0.13191479	0	0.009984639	8675.033794	0.114620596	4659.714692
11	Alt Diameter Pipeline 24"	0.001423519	1992.926133	0.126914633	0	0.027847924	0	0	0	0.039046519	498.2315333
12	Alt Diameter Pipeline 30"	0	0	0	0	0	0	0	0	0	0
13	Alt Diameter Pipeline 42"	0	0	0	0	0	0	0	0	0	0
14	L1600 In-Kind Replacement	0.019694133	27571.78659	0.436655018	0	0.243303859	0	0.02755221	23938.40683	0.181801305	12877.54835
15	Otay Mesa Alternate	0.042067286	58894.2007	0.63212371	0	0.465656104	0	0.208019672	180735.3956	0.336966693	59907.39906
16	LNG Storage Alternate	0	0	0.63212371	0	0.465656104	0	0.208019672	180735.3956	0.326449871	45183.84889
17	Alt Energy (Grid-Scale)	0	0	0.63212371	0	0.465656104	0	0.208019672	180735.3956	0.326449871	45183.84889
18	Alt Energy (Smaller-Scale)	0	0	0.63212371	0	0.465656104	0	0.208019672	180735.3956	0.326449871	45183.84889
19	Offshore Route	0	0	0	0	0	0	0	0	0	0
20	Blythe to Santee Alt 1	0	0	0	0	0	0	0	0	0	0
21	Blythe to Santee Alt 2	0	0	0	0	0	0	0	0	0	0
22	Cactus City to San Diego Alt	0	0	0	0	0	0	0	0	0	0
23	Second Pipeline Along L3010	0	0	0	0	0	0	0	0	0	0
24	Grand Total	0.011298826	15818.35653	0.301348119	0	0.20092587	0	0.06706256	58266.50017	0.145158844	18521.21418