

**TABLE 4.4.1
SDG&E POWER PLANT NPDES PERMITS SUMMARY**

Power Plant	Permit Number	Order Number	Expiration Date	Outfall Number	Receiving Water	Allowable Maximum Flow (mgd)	Allowable Maximum Temperatures (°F)
Encina	CA0001350	94-59	11/10/99	001	Pacific Ocean	862.5	20 degrees above incoming lagoon water. 25 degrees above incoming lagoon water during heat treatment, not to exceed 120 degrees.
South Bay	CA0001368	96-05	11/14/2001	001	San Diego Bay	601.2	15 degrees above intake water during any 24-hour period. At no time shall the discharge exceed 25 degrees above intake water.

NOTES: mgd = million gallons per day. °F = degrees Fahrenheit.