

TABLE 4.5.10
SDG&E'S COMBUSTION TURBINES CRITERIA AIR POLLUTANT EMISSIONS

Site	Emissions (tons per year) ^a				
	CO	ROG	NO _x	SO _x	PM-10
Division Street	0.1	< 0.05	0.4	1.2	< 0.05
El Cajon	< 0.05	< 0.05	0.2	0.1	< 0.05
Kearny	0.4	0.1	5.6	1.6	0.3
Miramar Yard	0.2	0.1	3.3	0.4	0.2
Naval Station	0.2	< 0.05	2.2	0.7	0.1
Naval Training Center	< 0.05	< 0.05	0.4	0.1	< 0.05
North Island	<u>0.3</u>	<u>< 0.05</u>	<u>1.5</u>	<u>2.1</u>	<u>0.1</u>
TOTAL:	1.3	0.3	13.7	6.2	0.7

^a Emissions estimates are based on fuel consumption data provided in SDG&E, *Proponent's Environmental Assessment, San Diego Gas & Electric Company's Proposed Sale of its Electrical Generation Facilities and Power Contracts*, December 19, 1997; NO_x source test data; and U.S. EPA emissions factors (U.S. Environmental Protection Agency, 1998).

SOURCE: Environmental Science Associates