

Chapter 2

Project Description

2.1 Introduction

The California Public Utilities Commission (CPUC) is responsible for environmental review and permitting of NextEra Energy Transmission West, LLC's (NEET West's) proposed Suncrest Dynamic Reactive Power Support Project (Proposed Project). The Proposed Project would involve construction of a dynamic reactive device and an approximately one-mile-long transmission line interconnecting with the existing Suncrest Substation in San Diego County, near the community of Alpine. The dynamic reactive device would provide voltage regulation and support for the existing transmission system in accordance with the California Independent System Operator Corporation's (CAISO's) 2013-2014 Transmission Plan.

This chapter describes the Proposed Project's objectives, location, components, construction process, operations, and anticipated permits and approvals. Information presented in this chapter is based primarily on the Proponent's Application and Proponent's Environmental Assessment (PEA) submitted to the CPUC by NEET West.

2.2 Proposed Project Background, Purpose and Objectives

The Proposed Project originates from the CAISO's 2013-2014 transmission planning process, which identified a need for a +300-million/-100-million volt-ampere reactive (megavar)¹ dynamic reactive device at the existing Suncrest Substation's 230-kilovolt (kV) bus² (CAISO 2014). CAISO determined that the retirement of the San Onofre Nuclear Generating Station (SONGS) and projected increases in renewable generating capacity in the Imperial Valley would cause loading and voltage stability issues in the transmission system in the area of the existing Suncrest Substation. CAISO recommended reactive power support at the Suncrest Substation to correct these deficiencies and allow the transmission system to function as designed.

The existing Suncrest Substation is operated by San Diego Gas & Electric Company (SDG&E) and was completed in 2012 as part of SDG&E's Sunrise Powerlink project. The Sunrise Powerlink is a high-voltage electric transmission system connecting the Imperial Valley to major demand centers in San Diego, and is depicted on Figure 2-1. Among other things, the Suncrest Substation functions to "step down" the incoming energy on the 500-kV transmission line from the southeast to a voltage where it can be transported on the two

¹ Volt-ampere reactive (var) is a unit by which reactive power is expressed in an alternating current (AC) electric power system. Reactive power is described in the following paragraphs in this section. Megavar means one million vars. Reactive power may also be expressed as megavolt amperes reactive (MVAR).

² A bus or busbar is a metallic strip or bar that conducts electricity within a substation or other electrical apparatus. Buses are often the connection points for incoming transmission lines into a substation.

1 230-kV lines leaving the substation to the northwest towards the Sycamore Canyon
2 Substation and San Diego.

3 The retirement of SONGS and anticipated increases in renewable energy production to meet
4 the state's 50 percent Renewable Portfolio Standard (RPS),¹ as well as anticipated future
5 retirement of coastal gas-fired generation utilizing once-through cooling, are causing issues
6 throughout the transmission grid in Southern California. In addition to the proposed dynamic
7 reactive device at the Suncrest Substation, CAISO's 2013-2014 Transmission Plan
8 recommended a number of other upgrades in the Southern California area, including a similar
9 reactive support facility at the San Luis Rey Substation (CAISO 2014). Previous transmission
10 plans had also recommended reactive support facilities at the Talega Substation and in the
11 vicinity of SONGS.

12 Part of the challenge with the retirement of SONGS is that many renewable power sources do
13 not produce reactive power at the same level as traditional power sources, such as natural
14 gas or nuclear. As opposed to "real power," which is the element of electricity that performs
15 useful work² and is measured in watts, reactive power functions to support voltage levels
16 needed to maintain transmission system reliability. One way of thinking about reactive
17 power is that it is the portion of electricity in an AC system³ that carries the voltage⁴ and
18 current⁵ up and down around an average value, analogous to a person climbing up and down
19 a ladder to fill a water tank, one bucket at a time (Sauer 2003). The energy that it takes to
20 climb up and down the ladder without carrying anything is solely reactive power because the
21 start and end state are the same from an energy conservation perspective. Carrying a bucket
22 of water up the ladder and dumping it into the water tank requires both reactive and real
23 power because energy is lost in the transfer of water or the work performed (Sauer 2003).

¹ California's RPS, first established in 2002 under Senate Bill (SB) 1078 and most recently expanded in 2015 under SB 350, requires electric retail sellers and publicly owned utilities to procure 50 percent of their electricity from eligible renewable energy resources by 2030.


² In physics, work is said to have been done when a force acting upon an object causes a displacement of that object.

³ AC is an electric current in which the flow of electric charge periodically reverses direction. By contrast, direct current is a current where electric charge flows in one direction. The U.S. interconnected grid is almost entirely an AC system where the voltages and currents alternate up and down 60 times per second (Sauer 2003).


⁴ Voltage, also known as electric potential difference or electric pressure, is the difference in electric potential energy between two points per unit electric charge.

⁵ Current is the flow of electric charge.

C:\Users\GIS\Documents\ArcGIS\PROJECTS\151018_CPUC_Suncrest\mxd\figures\ADEIR\Figure_2-1_RegionalTransmissionSystem.mxd PG_5/11/2016



**Figure 2-1
Regional Transmission System**



- | | | | |
|---------------------------|---------------------|----------------------------|-------------------------------|
| Proposed Project Location | Sunrise Powerlink | Transmission System | Other Substations (by owner) |
| Other Transmission Lines | Suncrest Substation | | Imperial Irrigation District |
| | | | Southern California Edison Co |
| | | | Undetermined Company |

Prepared by:



Sources: Content may not reflect National Geographic's current map policy.
Sources: National Geographic, Esri, DeLorme, HERE, UNEP-WCMC, USGS, NASA, ESA, METI, NRCAN, GEBCO, NOAA, increment P Corp. NEET West, 2015.

**Suncrest Dynamic Reactive
Power Support Project**

1 In an electric transmission system, reactive power is essential to the ability to transmit power
2 to meet demands and the operation of the system as a whole. For example, if the reactive
3 power in a transmission system is too low, inductive loads¹ such as transformers will be
4 unable to maintain the voltages necessary to operate, resulting in a “voltage collapse” causing
5 blackouts. In terms of the water-carrying analogy, a situation where reactive power is not
6 sufficient to maintain voltage may be represented by the person carrying the water up the
7 ladder getting too tired and ultimately collapsing under the weight of the water, which may
8 then create additional pressure on other “people” carrying water up their ladders causing
9 them to collapse as well (Sauer 2003). Such a voltage collapse failure may occur even if there
10 is sufficient real power (water in the analogy) available to meet the load.

11 For these reasons, reactive power support is needed at certain substations in Southern
12 California. Substations represent large inductive loads in the system, and with the loss of a
13 large producer of reactive power in SONGS and projected increases in power sources that do
14 not produce as much reactive power as traditional sources, additional reactive power is
15 needed for transformers to maintain adequate voltages. Without additional reactive power,
16 it is possible that the transmission system will not be able to deliver new solar photovoltaic
17 and other renewable power generation from the Imperial Valley to consumers in the San
18 Diego and Los Angeles areas.

19 The +300/-100 megavar reactive device at the Suncrest Substation was identified as a policy-
20 driven need in CAISO’s 2013-2014 Transmission Plan to meet California’s 50 percent RPS.
21 CAISO conducted a competitive bid solicitation process for the Suncrest dynamic reactive
22 facility and selected NEET West to construct the Proposed Project. NEET West’s proposal
23 included a Static VAR compensator (SVC) interconnected with the existing Suncrest
24 Substation via an approximately one-mile-long transmission line. The proposed SVC device
25 would provide +300/-100 megavar of continuous or quasi-continuous reactive power
26 response following system disturbances. The addition of the proposed SVC device allows the
27 transmission system to operate reliably and to import the same amounts of power as
28 originally designed, regardless of whether it is from a conventional or renewable source.

29 Following its selection by CAISO in January 2015 as the approved project sponsor, NEET West
30 submitted a PEA to the CPUC in August 2015, as part of its application (A.15-08-027) for a
31 Certificate of Public Convenience and Necessity, as specified in CPUC General Order (G.O.)
32 131-D.

33 The objectives of the Proposed Project are as follows:

- 34 ■ Provide reactive support at or connected to the Suncrest Substation;
- 35 ■ Improve and maintain the reliability of the transmission grid; and
- 36 ■ Support achievement of the state’s RPS by facilitating delivery of a higher percentage
37 of renewable energy generation from the Imperial Valley area to population centers
38 to the west.


¹ A load is a device to which power is delivered. An inductive load is a part of an electrical circuit that uses magnetic energy to produce work. Examples of inductive loads would be most types of motors and transformers.

2.3 Proposed Project Location and Setting

The Proposed Project would be located in unincorporated south-central San Diego County, approximately 3.75 miles southeast of the community of Alpine, off of Bell Bluff Truck Trail. Figure 2-2 shows the Project location. The lands surrounding the Proposed Project are primarily undeveloped, with some rural-residential development present to the east and south, and the existing Suncrest Substation at the Project's western terminus. The nearest residence is approximately 0.6 mile to the southeast. Interstate-8 is located approximately 1.8 miles to the north of the Project area and Japatul Valley Road is approximately 1.2 miles to the southeast. The Proposed Project would be located on property (assessor's parcel numbers [APNs] 523-040-080 and 523-030-130) currently owned by private parties within the administrative boundary of the Cleveland National Forest. Elevations in the Project area range from 3,000 to 3,200 feet above mean sea level, and the area's topography is undulating with steep hills interspersed with narrow valleys and relatively deep canyons. The habitat types in the Project vicinity are primarily chaparral scrub and oak woodlands.


The proposed SVC facility, described below in Section 2.4.1.1, would be constructed immediately south of Bell Bluff Truck Trail within a portion of APN 523-040-080 (see Figure 2-3). NEET West has an option agreement to purchase a 6-acre portion of this parcel for construction of the SVC. This area, known as the Wilson Construction Yard (shown on Figure 2-4), was used as a construction staging/laydown area during construction of the Suncrest Substation. The area was used for storage and staging of materials, assemblage of the lattice tower segments, helicopter transport operations of materials and tower segments, and as a temporary water basin (SDG&E Undated). As part of the initial brush clearing for the area, native vegetation was cut into small pieces and incorporated into the topsoil, which was salvaged to a depth of approximately 6 inches. Grading was required within the Wilson Construction Yard, with a total of 10.27 acres impacted, and rock/gravel less than 3 inches in diameter was imported to the yard for soil stabilization and dust control during helicopter activities (the imported rock was removed following construction activities). The initial phase of construction at the yard occurred in June 2011 and the yard was utilized through a portion of 2012 (SDG&E Undated).



Following completion of the Suncrest Substation, in accordance with the restoration plan prepared for the Sunrise Powerlink, *Sunrise Powerlink Restoration Plan for Sensitive Vegetation in Temporary Impact Areas*, and the site-specific restoration plan prepared for the Wilson Construction Yard, *Site-Specific Restoration Plan (SRP): SRP AS-47 Southern Foothills; Link 3; Wilson* (AECOM and RECON Environmental 2012), the Wilson Construction Yard was de-compacted by ripping and cross-ripping between 18-24 inches and then recontoured to its original topography (SDG&E Undated). The salvaged topsoil was then redistributed over the site and seeded with a mix of native plant species representative of the pre-project valley needlegrass habitat condition at the site. The recontouring and seeding was conducted in fall of 2012, and maintenance and monitoring of the restoration site has been conducted since. In March 2016, the Wilson Construction Yard restoration was signed-off as complete by both the California Department of Fish and Wildlife (CDFW) and the U.S. Fish and Wildlife Service (USFWS). CDFW and USFWS certified that the site had achieved the restoration plan's primary success standards, which primarily relate to percentage of native species cover.



C:\Users\GIS\Documents\ArcGIS\PROJECTS\15018_CPUC_Suncrest\mxd\figures\Figure_1_ProjectLocation.mxd, PG. 12/15/2015



Basemap Sources: Content may not reflect National Geographic's current map policy. Sources: National Geographic, Esri, DeLorme, HERE, UNEP-WCMC, USGS, NASA, ESA, METI, NRCAN, GEBCO, NOAA, increment P Corp.



-  Proposed Project Location
-  Cleveland National Forest

**Figure 2-2
Project Location**

C:\Users\GIS\Documents\ArcGIS\PROJECTS\15018_CPUC_Suncrest\figures\ADEIR\Figure 2-3_ProjectOverview.mxd PG 11/21/2016




- Project Components**
- Project Area (limit of disturbance)
 - Underground Transmission Line
 - Overhead Transmission Line
 - SVC Area
 - Fenced Area

Parcel Boundary (with APN and Owner)


**Figure 2-3
Project Overview**




Prepared by:

**Suncrest Dynamic Reactive
Power Support Project**



**Figure 2-4
Wilson Construction Yard**



-  WilsonConstructionYard
-  Total SVC Area
-  Proposed Project Area (limit of disturbance)

Prepared by:



Imagery Source: NAIP

**Suncrest Dynamic Reactive
Power Support Project**

1 The one-mile-long transmission line component of the Proposed Project, described in Section
2 2.4.1.2, would be located primarily within Bell Bluff Truck Trail, as shown on Figure 2-3. Bell
3 Bluff Truck Trail is a private, paved, secured road in the area of the Proposed Project.
4 Approximately one mile east of the proposed SVC site there is a security gate operated by
5 SDG&E restricting public access to the existing substation site. Bell Bluff Truck Trail is
6 approximately 30 feet wide from the location of the proposed SVC west to the intersection
7 with the access road to the existing Suncrest Substation (this portion of the road was widened
8 and newly constructed as part of the Suncrest Substation construction), and approximately
9 12 feet wide west of the intersection with the substation access road.

10 The lands surrounding Bell Bluff Truck Trail west of the proposed SVC are included as part
11 of the Lightner Mitigation Site, which was established in accordance with the Sunrise
12 Powerlink environmental review documents. The Lightner Mitigation Site encompasses the
13 Suncrest Substation (see Figure 2-5) and would include APN 523-030-130. This property is
14 scheduled to be transferred from SDG&E to the U.S. Forest Service for conservation in
15 perpetuity (SDG&E 2011). The Lightner Mitigation Site was established in part to compensate
16 for impacts to waters of the U.S. and waters of the state during construction of the Suncrest
17 Substation/Sunrise Powerlink, and is described in the Final Habitat Mitigation and
18 Monitoring Plan for the Sunrise Powerlink (SDG&E 2011).

19 **2.4 Proposed Project**

20 The Proposed Project would involve construction and operation of a SVC dynamic reactive
21 device and approximately one-mile-long transmission line. Figure 2-3 above shows the
22 primary Project components. The Proposed Project would disturb approximately 12 acres
23 during construction, with Project features occupying a permanent footprint of approximately
24 6 acres. The following subsections describe the Proposed Project's components, anticipated
25 construction process, and operation.



26 **2.4.1 Proposed Project Components**




27 **2.4.1.1 SVC Components**

28 The SVC would be a set of electrical devices, including thyristor¹-controlled reactors and
29 capacitor² banks, designed to provide fast-acting reactive power to the existing transmission
30 system. The SVC would have no moving parts, other than internal switchgear, and would be
31 operated based on the load and voltage conditions at the Suncrest Substation. Essentially, if
32 the power system's reactive load is capacitive (i.e., leading), the SVC would use the thyristor-
33 controlled reactors to consume vars from the system, thus lowering the voltage. If the
34 system's reactive load is inductive (i.e., lagging), the capacitor banks would be automatically
35 switched in, thereby increasing voltage.

¹ A thyristor is a solid-state semiconductor device that acts as a bistable switch.

² A capacitor is a passive two-terminal electrical component used to store energy temporarily in an electric field. In electric transmission systems, capacitors can be used to provide local sources of reactive power.



-  Lightner Mitigation Site Parcels
-  Project Area (limit of disturbance)
-  Suncrest Powerlink ROW

**Figure 2-5
Lightner Mitigation Site**

Prepared by:



**Suncrest Dynamic Reactive
Power Support Project**

1 The proposed SVC's electrical equipment would be contained within a fenced area of
 2 approximately 2.58 acres. The total size of the SVC, however, including associated site
 3 improvements (e.g., access driveways, stormwater detention basin), would be approximately
 4 6 acres.

5 **Electrical Equipment and Facilities**

6 While the final design and layout of the SVC facility may vary based on manufacturer's specific
 7 proposals (the final design would be procured through an engineering, procurement, and
 8 construction contract and functional specification, where manufacturers would have the
 9 flexibility to configure their SVC candidate designs in an optimal manner to meet the
 10 requirements of the specification), all candidate designs would be anticipated to include the
 11 following electrical equipment and facilities:

- 12 ▪ Lightning shielding masts
- 13 ▪ 230-kV circuit breaker
- 14 ▪ 230-kV main stringbus and busbar
- 15 ▪ 230-kV group operated air break switch
- 16 ▪ 230-kV lightning arresters
- 17 ▪ 230-kV potential measurement transformers
- 18 ▪ Two single phase 230-kV main power transformers (one would be a spare), outdoor
 19 heating, venting and air conditioning equipment and thyristor/convertor cooling
 20 equipment
- 21 ▪ Outdoor capacitor banks
- 22 ▪ Outdoor air core reactors
- 23 ▪ Outdoor medium voltage¹ busbars
- 24 ▪ Outdoor medium voltage instrument/auxiliary transformers
- 25 ▪ Outdoor medium voltage surge arrestors
- 26 ▪ Outdoor medium voltage group-operated air break switches
- 27 ▪ Control house of approximately 2,500 square feet containing the following
 28 equipment:
 - 29 ○ Thyristor valves and/or insulated-gate bipolar transistor (IGBT)² convertors


¹ Medium voltage is commonly defined as greater than 1 kV and less than 100 kV. The actual voltage rating of the Proposed Project equipment may vary based on manufacturer's proposals.

² An IGBT is a three-terminal power semiconductor device primarily used as an electronic switch.

- 1 ○ Protective relaying and control equipment
- 2 ○ Supervisory control and data acquisition (SCADA)¹ equipment
- 3 ○ Cooling equipment
- 4 ○ AC/DC auxiliary power equipment
- 5 ○ Spare parts and maintenance tool storage
- 6 ○ Miscellaneous support facilities

7 The preliminary layout and arrangement of the outdoor equipment at the proposed SVC is
8 shown in Figure 2-6; however, as noted above, the actual layout of the equipment at the
9 Proposed Project facility may vary from the figure based on the candidate designs submitted
10 by manufacturers. All major equipment (e.g., power transformers, power circuit breakers,
11 control buildings, capacitors, and reactors) would be installed on concrete foundations. The
12 transformers at the SVC would each require a maximum of 10,000 to 13,000 gallons of oil.
13 Secondary containment structures designed to contain the oil volume of the transformers
14 plus the 25-year, 24-hour storm event would be included as part of the project, as described
15 further below. The lightning shielding masts would be the tallest structures within the SVC at
16 approximately 75-feet-high.

¹ SCADA is a system for remote monitoring and control that operates with coded signals over communication channels. It is commonly used to remotely operate large industrial processes such as electric power transmission systems.



1	Transformer
2	Reactor
3	Capacitor
4	Resistor
5	Disconnector
6	Grounding switch
7	Circuit breaker
8	Current transformer
9	Voltage transformer
10	Surge capacitor
11	Surge arrester
12	Cooling tower
13	Auxiliary Transformer
14	Fuse
15	Lightning mast

PRELIMINARY




Figure 2-6
Preliminary SVC Layout

Page intentionally left blank.

1 **Associated Site Improvements**

2 In addition to the electrical equipment, the SVC would include the following facilities or
3 components:

- 4 ▪ Two new 20-foot-wide by 95-foot-long access driveways from Bell Bluff Truck Trail
5 to the SVC;
- 6 ▪ A stormwater detention basin, sized to capture the runoff from the 85th percentile of
7 a 25-year, 24-hour rain event, and earthen swales to divert run-on stormwater;
- 8 ▪ A Mechanically Stabilized Earth retaining wall approximately 480 feet long and 15
9 feet tall at its highest point (an average height of 8 feet) along the east side of the
10 facility;
- 11 ▪ Chain link and barb wire security fencing approximately 7 feet high with secure gates
12 accessible only by NEET West staff and emergency services personnel;
- 13 ▪ Transformer oil containment basins designed to contain the oil volume of the
14 transformers plus stormwater from the 25-year 24-hour storm event;
- 15 ▪ A 10,000-gallon water tank for fire suppression outside the Suncrest SVC fence and
16 adjacent to the northeastern driveway; and
- 17 ▪ Signage and lighting.

18 The new driveways would be graveled and would include paved turning aprons off of Bell
19 Bluff Truck Trail, an internal circulation route, and associated improvements. The turning
20 aprons would be designed to accommodate large construction and haul vehicles and would
21 occupy a total area of approximately 5,000 square feet. The access driveways would be
22 entirely located within the 6-acre area of APN 523-040-080 that NEET West intends to
23 acquire in fee title.

24 The stormwater detention basin would be sized based on the 85th percentile of the 25-year,
25 24-hour rainfall event. It would be designed to capture the runoff from such an event and
26 then release the captured water over 48 hours. Overflow from the basin would occur through
27 a rip-rap spillway that would provide for sheet-flow of the stormwater to the adjacent land
28 surface during storms that exceed the basin's design capacity. A series of earthen swales
29 would be constructed around the SVC facility to divert stormwater that would otherwise run
30 onto the site. The swales would discharge any run-on water via shallow, concentrated sheet
31 flow to the adjacent land surface, and would include rip rap aprons at discharge locations for
32 erosion control.

33 The retaining wall would be built on grade (i.e., not above grade) on the east side of the SVC
34 to provide slope stability, minimize the potential for erosion, and avoid the need for
35 additional land and impacts to oak woodlands east of the Proposed Project site. The retaining
36 wall would be supported by a concrete foundation constructed of concrete blocks, installed 1
37 to 2 feet below grade. Depending on the soil and rock conditions, anchors or reinforced
38 geogrid strips, with a maximum embedment length of approximately 12 feet, may be installed
39 to support the wall.

1 The lighting at the SVC facility would conform to National Electric Safety Code (NESC)
2 requirements and applicable outdoor San Diego County outdoor lighting codes. NESC
3 recommends illuminating substation facilities to a minimum of 22 lux or 2 foot-candles.
4 Remotely-controlled lighting would be provided at a level sufficient to provide safe entry and
5 exit to the SVC site and control building. Additional manually-controlled lighting would be
6 available for use, when required, to further support safe working conditions at the SVC.

7 **2.4.1.2 Transmission Line Components**

8 The transmission line connecting the SVC to the existing Suncrest Substation would be
9 approximately one mile in length and would be installed primarily underground. As shown
10 in Figure 2-3, the proposed transmission line would follow the alignment of, and be located
11 within, Bell Bluff Truck Trail for the majority of its length. The last approximately 300 feet of
12 the line would transition to an overhead span via a new riser pole to be installed just north
13 of the road. The overhead span would contain two poles in total; the 85- to 95-foot-tall riser
14 pole (at the transition from underground to overhead) and an approximately 116-foot-tall
15 intermediate pole which would be installed approximately 35 feet outside the Suncrest
16 Substation. NEET West would own the riser pole. The intermediate pole would become the
17 change of ownership pole, with NEET West owning the overhead span between the riser pole
18 and the intermediate pole and SDG&E owning the overhead span from the intermediate pole
19 into the Suncrest Substation.

20 Note: NEET West had originally proposed a single riser pole for the overhead transmission
21 line connecting to the Suncrest Substation in the PEA they submitted to CPUC. Under this
22 original proposal, it was believed that the single riser pole could be maintained via bucket
23 trucks extended from Bell Bluff Truck Trail. Coordination with SDG&E, however, indicated
24 that SDG&E would need a larger permanent maintenance pad to maintain the pole. As
25 installation of a maintenance pad would involve cutting into the hillside, and would
26 potentially introduce new significant impacts, NEET West developed the current “two-pole”
27 design. This design allows SDG&E to maintain the intermediate pole (i.e., the new change of
28 ownership pole) from the existing graveled access road, which runs along the perimeter of
29 the existing Suncrest Substation, thereby avoiding the need for a new permanent work pad.

30 **Underground Transmission Line**

31 The proposed transmission line would be a new 230-kV single-circuit line composed of cross-
32 linked polyethylene-insulated, solid-dielectric, copper or aluminum conductor cables. The
33 line would consist of three separate 230-kV conductor cables. The cables would be installed
34 within polyvinyl chloride (PVC) conduits in a concrete-encased duct bank system. The duct
35 bank system would include four conduits for the 230-kV cables (three for the cables plus one
36 spare) as well as four smaller conduits for fiber optic cables, which would provide
37 communications for line relaying, SCADA, and other devices as required. The duct bank
38 system would be approximately 30 inches wide by 24 inches tall, with the bottom of the duct
39 bank approximately 5 feet below grade. Up to five underground splice vaults would be
40 installed along the transmission line alignment (roughly every 900 feet) to allow for
41 installation of the underground cables and for operation and maintenance of the
42 transmission line.

43 While the majority of the transmission line would be installed within Bell Bluff Truck Trail,
44 at vault locations, temporary disturbance may be required outside of the roadbed to facilitate

1 installation of the vaults. The permanent vault structures would be located within the existing
2 paved roadbed.

3 **Riser Pole and Above-Ground Transmission Line Segment**

4 A riser pole would be installed on the road shoulder north of Bell Bluff Truck Trail. The riser
5 pole would be between 85 to 95 feet tall, with a base of approximately 7 feet in diameter plus
6 an area of permanent disturbance approximately 15 feet in radius from the pole. The riser
7 pole would be accessed by Bell Bluff Truck Trail. In between the riser pole and Suncrest
8 Substation, a secondary or intermediate pole would be installed approximately 35 feet north
9 of the existing substation fence line. This intermediate pole would be approximately 116 feet
10 tall, with a base of approximately 7 feet in diameter. The intermediate pole would be accessed
11 by the existing Suncrest Substation paved driveway and graveled service road leading to and
12 around Suncrest Substation. The intermediate pole would be situated on the hillside on the
13 north side of the graveled service road, between 5 and 10 feet from the road edge.
14 Approximately 0.37 acre of temporary and 0.01 acre of permanent disturbance would be
15 required to construct, operate, and maintain this intermediate pole.

16 The slope on which the intermediate pole would be constructed is currently undergoing
17 revegetation by SDG&E per mitigation requirements in the Sunrise Powerlink EIR/EIS.

18 Depending on the results of geotechnical testing, alternative construction methods, such as
19 pole installation on micropile foundations, may be required for installation of the riser and
20 intermediate poles. Micropile foundations typically consist of small-diameter (i.e., less than
21 300 millimeters) drilled and grouted replacement piles (i.e., a pile placed or constructed
22 within a previously drilled borehole replacing the excavated ground). Micropiles are installed
23 by drilling a borehole, reinforcing the hole with a casing or other enforcement structure, and
24 grouting the hole. The new riser and intermediate poles would facilitate entry into the
25 existing substation via an approximately 300-foot-long overhead span of 1272 kcmil¹ (45/7)
26 aluminum steel reinforced, non-specular, "Bittern" conductors. The approximate vertical
27 distance between the conductors would be 16.5 feet and clearance to the ground would be a
28 minimum of 30 feet in compliance with CPUC G.O. 95, *Rules for Overhead Electric Line*
29 *Construction*. SDG&E would be responsible for stringing the conductor cables required to
30 connect SDG&E equipment at the Suncrest Substation.

31 Additionally, SDG&E would need to add electrical infrastructure to facilitate interconnection
32 to SDG&E equipment at the Suncrest Substation. SDG&E would add foundations, support
33 structures, grounding, conduits and wiring, bus work, breakers, disconnect switches, control,
34 protection, metering, communication support racks and SCADA and communication facilities
35 to the existing 230-kV substation yard.

36 **Communication Cables**

37 Primary and secondary optical ground wires (OPGW) would be used to carry the fiber optic
38 communications and protective relaying from the termination structure into the substation.
39 Two splice boxes, one for each OPGW, would be installed on the base of the riser pole, and

¹ A circular mil is a unit of area equal to the area of a circle with the diameter of one mil (i.e., one thousandth of an inch). One thousand circular mils is abbreviated as kcmil, and is often used to define large electrical wire sizes.

1 two splice boxes on the base of the intermediate pole. Surge arresters would be placed on the
2 riser pole arms to protect the underground cable from transient surges.

3 **2.4.2 Project Construction**

4 Construction of the SVC and transmission line would require similar methods of site
5 preparation, excavation, installation of equipment and structures, and restoration.
6 Substantial grading would only be anticipated for the SVC; a very limited amount of grading
7 would be necessary for construction of the transmission line. Anticipated construction
8 methods are described further below for each project component. Information on the
9 construction schedule, equipment, access and staging, water use, and utility connections for
10 the project as a whole is presented in the following section.

11 **2.4.2.1 SVC Construction**

12 Construction of the SVC would occur in a phased approach beginning with site preparation
13 and grading of the site, followed by installation of the foundations and underground
14 equipment, and finally, installation and testing of the electrical equipment. Prior to clearing
15 and grubbing, all necessary surveys, marking, and installation of stormwater management
16 features (e.g., silt fence, fiber rolls, etc.) would be completed.

17 **Site Preparation, Grading, and Earthwork**

18 Construction of the SVC would require clearing of approximately 8.56 acres of California
19 buckwheat scrub, non-native grassland, and ruderal lands. The SVC facility would be located
20 on the site of the old Wilson Construction Yard, which was impacted during construction of
21 the existing Suncrest Substation. Vegetation removal would be completed using mechanized
22 removal equipment or by hand using chain saws. Following initial clearing, topsoil would be
23 salvaged to a depth of approximately 6 inches (or less if subsoil is not present to that depth)
24 in all areas to be restored and would be stored on-site or at a nearby approved work area for
25 use in site restoration, as appropriate.

26 Following site clearing/vegetation removal, grading and excavation would be conducted.
27 Grading would include both removal of excess material as well as importation of fill and
28 gravel material. Table 2-1 provides a summary of anticipated grading activities and material
29 quantities.

30 In general, earthwork activities (e.g., grading, excavation) would be completed such that the
31 site meets project design specifications and matches proposed grades. Geotechnical borings
32 completed to date in the vicinity of the SVC site have found predominately gravel, clayey sand,
33 and decomposed granite. Based on information obtained from soil borings performed near
34 the corners of the proposed SVC site and the results of the geotechnical investigation
35 performed for the Proposed Project, NEET West anticipates that the majority of the SVC site
36 can be excavated by conventional methods, although a minimal amount of hydraulic
37 hammering or blasting may be required.

1 **Table 2-1. SVC Grading Summary**

Item	Description	Quantity/Height
Total Cut	Excavated earthwork material (including topsoil)	21,000 cubic yards (cy)
Excess Material	Material to be removed from site	4,000 cy
Total Fill	Placed and compacted material (including surfacing material)	17,000 cy
Surfacing Material	Gravel to be imported (included in "Total Fill")	2,500 cy
Maximum Cut-Slope Depth	Maximum depth of excavation from ground surface	15 feet
Maximum Fill-Slope	Maximum height of filling from ground surface	13 feet
Maximum Retaining Wall Height	Maximum height of retaining wall	15 feet

2

3 Conventional excavation practices would be used first to excavate to the location where
4 bedrock is encountered. In areas where shallow bedrock is found, detonation blast holes
5 would be drilled into the bedrock. Explosives would be detonated in the blast holes to crack
6 the rock around the blast hole. Blast intensity is dependent on the amount of explosives used,
7 frequency, and diameter of the holes where the explosives are placed, and timing of the
8 detonation. NEET West describes the type of blasting that may be used for the Proposed
9 Project as low-energy, localized blast, also referred to as micro-blasting. Micro-blasting is
10 blasting in a highly controlled manner involving time delays between numerous small micro
11 blasts to fracture rock without injecting material and to minimize noise effects. While it is
12 anticipated that a minimal amount of blasting may be required for construction of the SVC, it
13 is impossible to determine the exact location where blasting would be required until
14 conventional excavation is conducted and areas of bedrock are identified.

15 Removal of material would typically extend to depths where competent materials, with high
16 mechanical strength and resistance to erosion and deformation, are encountered. The
17 maximum anticipated depth of excavation from ground surface would be 15 feet. Any
18 material that requires processing prior to placement as fill will be mechanically processed
19 on-site to achieve a maximum particle size and distribution suitable for conventional
20 placement in engineered fills. As shown in Table 2-1, grading for construction of the SVC
21 would be anticipated to result in the generation of 4,000 cy of excess material that would
22 require off-site removal and disposal at a landfill. Additionally, approximately 2,500 cy (or 6
23 inches over the SVC footprint) of gravel would need to be imported and installed at the SVC
24 site for grounding purposes. All clean spoils excavated by the Proposed Project would be
25 reused on-site as fill, as feasible.

26 **Foundations, Below-Grade Construction, and Equipment Installation**

27 Following earthwork, all necessary below-grade construction, including structure and
28 equipment foundations, underground ducts, ground grid, and construction of the control
29 shelter, would begin. After below-grade work is completed, major equipment and structures
30 would be installed and anchored on their respective foundations. It is anticipated that all

1 major electrical and SVC equipment, such as power transformers, power circuit breakers,
2 control building, capacitors, and reactors would be delivered to the SVC footprint and placed
3 directly on the previously constructed foundations. Other SVC equipment such as air
4 disconnect switches, instrument transformers, transmission structures, insulators,
5 conductors, rigid bus, connectors, conduit, cable trench, rebar, etc., will be received and
6 temporarily stored at the staging area prior to installation.

7 **Work Area Restoration**

8 Following completion of construction and demobilization, all temporarily disturbed work
9 areas would be restored to their pre-construction conditions. Areas that were disturbed by
10 grading, augering, or equipment movement would be recontoured to their original contours.
11 Work areas would be decompacted, and salvaged topsoil materials would be re-spread
12 following recontouring to aid in restoration of disturbed areas.

13 **2.4.2.2 Transmission Line Construction**

14 Similar to the SVC, construction of the transmission line would occur in a phased approach
15 beginning with site preparation, followed by trenching, with duct bank and splice vault
16 installation occurring concurrently, and finally, cable pulling, splicing, and termination. Prior
17 to trenching, all necessary surveys, marking, and installation of stormwater management
18 features (e.g., silt fence, fiber rolls) would be completed.

19 **Site Preparation**

20 Construction of the transmission line is anticipated to require minimal vegetation clearing,
21 as the transmission line would be located primarily within (underneath) the paved surface of
22 Bell Bluff Truck Trail. Vegetation clearing would only be required for the portion of the line
23 alignment on the road shoulder in the areas of the new riser and intermediate poles. This
24 area of impacts would be approximately 0.85 acre, with approximately 0.02 acre of
25 permanent impacts at the riser and intermediate pole locations.

26 **Trenching**

27 Trenching required for duct bank and vault installation would involve asphalt cutting to
28 expose the soil layer below the paved surface of Bell Bluff Truck Trail, followed by open-cut
29 trenching techniques. The typical trench width for duct bank installation would be
30 approximately 2.5 feet wide by 5 feet deep, while the typical trench width for vault
31 installation would be 9 feet wide by 13 feet deep.

32 Excavation methods for digging the trenches for the underground alignment would include
33 both conventional practices (e.g., a backhoe) and, potentially, blasting techniques. NEET West
34 anticipates that 10 percent of the alignment, or approximately 530 linear feet of trench, could
35 require blasting. Conventional excavation practices would be used first to excavate to the
36 location where bedrock is encountered. In areas where shallow bedrock is found, detonation
37 blast holes would be drilled into the bedrock. Explosives would be detonated in the blast
38 holes to crack the rock around the blast hole. NEET West describes the type of blasting that
39 may be used for construction of the Proposed Project as low-energy, localized rock blasting,
40 which is also referred to as micro-blasting. Micro-blasting is blasting in a highly controlled
41 manner involving time delays between numerous small micro blasts to fracture rock without
42 injecting material and to minimize noise effects. NEET West states that it is not possible to

1 determine the exact location where blasting would be required until conventional excavation
2 is conducted and areas of bedrock are identified.

3 All excavated material, including soil, rock, concrete, and asphalt would be temporarily
4 staged on-site and hauled off to an appropriate disposal facility, such as Miramar Landfill. It
5 is anticipated that a total of 3,000 cy would be generated and hauled off-site from trenching
6 for transmission line construction at a rate of 30 cy (three truck trips) per day.

7 **Duct Bank & Splice Vault Installation**

8 Within each open trench section, the duct bank would be installed approximately 5 feet deep,
9 or 3 feet below the ground surface to the top of the duct bank. As mentioned above, the duct
10 bank would be approximately 2.5 feet wide by 2 feet in height. The duct bank would be
11 constructed by first installing the conduit (6-inch diameter for the electrical cable and 2-inch
12 diameter for the telecommunications cable) separated by spacers and then placing 3,000-
13 pounds-per-square-inch concrete around the conduits to form the duct bank. After duct
14 banks have been installed, the trenches would be backfilled. It is anticipated that
15 approximately 800 cy of native, non-thermal, or thermal backfill would be used in backfilling
16 trenches for the Proposed Project. Each duct bank would be anticipated to have a minimum
17 of 36 inches of cover, including 18 inches of road and sub-road material.

18 In areas where the duct bank alignment runs parallel to water lines, telecommunications
19 utilities, or drainage culverts, a minimum horizontal clearance of 12 inches and vertical
20 clearance of 6 inches would be provided. This clearance would need to be increased to 24
21 inches in all directions for existing SDG&E electric distribution feeder lines or other utilities
22 that operate at temperatures greater than the surrounding earth temperature. Currently, it is
23 known that there is an existing underground 12-kV distribution line owned by SDG&E,
24 located on the south side of Bell Bluff Truck Trail, which the duct bank/transmission line
25 would parallel for approximately 3,400 feet (0.64 mile). From the intersection of Bell Bluff
26 Truck Trail and the Suncrest Substation access road (see Figure 2-2), NEET West anticipates
27 having to cross a 12-kV distribution feeder, which powers a communication site on the north
28 side of the Suncrest Substation, and a water pipe connecting SDG&E's water tank to the
29 existing substation. Adequate clearance would be given to these existing utilities, as
30 described above, and in accordance with CPUC G.O. 128, *Rules for Construction of*
31 *Underground Electric Supply and Communication Systems*. Prior to construction, all existing
32 utilities and culverts within the roadway would be located and potholed to ensure proper
33 separation and avoidance.

34 During trenching for the underground duct bank, additional excavation would occur in the
35 location of the proposed splice vaults; up to five underground splice vaults may be required
36 for the underground transmission line, spaced approximately 900 feet apart. The vaults
37 would be pre-fabricated steel-reinforced concrete with approximate dimensions of 30 feet
38 long by 8 feet wide by 11 feet deep, so the excavation would be large enough to accommodate
39 these dimensions. Installation of each vault would occur over a 1-week period following a
40 sequence of: excavation and shoring of the vault pit; delivery and installation of the vault; fill
41 and compaction of backfill; and restoration of the excavated area to pre-construction
42 conditions. Backfill for the vaults would consist of either compacted native soil, slurry, or
43 concrete.

1 **Riser Pole and Intermediate Pole Construction**

2 The work areas for the riser pole and intermediate pole would first be cleared of vegetation
3 and then be slightly graded prior to excavating for the pole foundations. Temporary work
4 pads may be required to excavate for the foundations or install the poles at either location.
5 The excavation depths would be approximately 20 feet deep. Approximately 30 cy of material
6 would be removed from each pole location and re-used onsite or disposed of at an approved
7 off-site location. Following construction of the pole foundations, the riser pole and
8 intermediate pole structures would be installed.

9 Due to the likely presence of rock either at or very near the ground surface, installation of the
10 riser pole and intermediate pole may require localized blasting or other alternative
11 excavation techniques to install the poles. Alternative methods may include pole installation
12 on a micro-pile foundation. Micropiles typically consist of small-diameter (less than 300
13 millimeters) drilled and grouted replacement piles (i.e., a pile placed or constructed within a
14 previously drilled borehole replacing the excavated ground). Micropiles are installed by
15 drilling a borehole, reinforcing the hole with a casing or other enforcement structure, and
16 grouting the hole. Micropiles would be 35 to 40 feet deep under a 10-foot-deep pile cap. These
17 foundations would use up to 70 cy of concrete.

18 **Cable Pulling, Splicing & Termination**

19 Following installation of the duct bank, splice vaults, and riser and intermediate poles, the
20 electric and telecommunications cables would be installed in the duct banks. The cables
21 would be pulled into the duct banks by placing a pulling rig on one end of the duct bank
22 section and a cable reel on the other. Cables would be pulled through each segment between
23 splice vaults, and then spliced at each splice vault location. Stringing of the conductor and
24 OPGW between the intermediate pole and riser pole would be conducted using pulling and
25 tensioning equipment set up on Bell Bluff Truck Trail and the Suncrest Substation service
26 road. For the last span into the Suncrest Substation, SDG&E would place pulling and
27 tensioning equipment on their service road and within the substation to pull the conductor
28 and OPGW into place to make the final terminations at the A-frame structure.

29 A splice trailer would be located adjacent to the vault manhole to facilitate splicing (i.e.,
30 stripping of the cable jacket, shield, and insulation, and connection of the two cables on either
31 side of the vault). At the ends of cables in the SVC facility and on the riser pole, the cable jacket,
32 shield, and insulation would be stripped back to facilitate the installation of a terminator.¹
33 Temporary scaffolding may be required to reach the elevated terminations on the riser pole.
34 Prior to energizing, each phase would be tested to ensure proper splicing and continuity.

35 Electric and telecommunication cable would be spliced into the SVC facility after being pulled
36 through their respective ducts. Fiber optic cable routed to the existing Suncrest Substation
37 would need to be spliced to connect to the OPGW in a splice box located on the intermediate
38 pole. A splice box would also be installed on the riser pole to connect the underground fiber
39 to the OPGW.

40 SDG&E would be responsible for construction activities necessary for supporting
41 interconnection of the Project Applicant's facility and equipment to SDG&E equipment within

¹ A terminator is a resistor placed at the end of an electrical wire or cable to prevent a radio frequency signal from being reflected back from the end, causing interference.

1 the Suncrest Substation. This would involve adding foundations, support structures,
2 grounding, conduits and wiring, bus work, breakers, disconnect switches, control, protection,
3 metering, communication support racks and SCADA and communication facilities to the
4 existing 230-kV substation yard.

5 **Work Area Restoration**

6 Following completion of construction and demobilization, all work areas utilized for
7 construction would, to the extent practicable, be restored to their pre-construction
8 conditions. All residual construction debris and waste would be removed and transported
9 off-site to an approved disposal and/or recycling facility. The disturbed portion of Bell Bluff
10 Truck Trail would be restored by replacing the aggregate road base and installing an asphalt
11 cap. Any road signage or markings removed or disturbed during construction would be
12 replaced.

13 **2.4.2.3 Overall Construction Schedule, Equipment, Access, Water Use, and Utility** 14 **Connections Information**

15 **Construction Schedule**

16 Construction of the SVC and transmission line is expected to occur simultaneously. Overall,
17 the Proposed Project would be anticipated to take 11 months to construct (6.5 months for
18 construction; 2.5 months for testing and commissioning; and 2 months for restoration and
19 cleanup) and is targeted to be operational by early 2018. Typically, construction would occur
20 10 hours per day, 6 days per week, Monday through Saturday, between 7 a.m. and 7 p.m.;
21 however, certain time-sensitive activities and/or activities which are not noise-intensive may
22 occur outside these hours.

23 **Construction Workforce & Equipment**

24 The peak employment during Project construction is anticipated to be 64 workers, although
25 on average, the workforce on site would be less (approximately 40 to 50 persons [or less] per
26 day). As a conservative assumption for the environmental impacts analysis in later chapters
27 of this EIR, the total number of unique construction workers over the entire construction
28 period will be approximately 120. In addition to construction workers, visitors to the site
29 during construction would include NEET West management, engineering consultants,
30 government inspectors, and construction monitors, who would visit the site intermittently.
31 The workers for the more common development tasks of grading and building foundations
32 for the SVC and riser pole structure are likely to be hired from San Diego County. Workers for
33 installing the SVC and underground transmission line will have specialized skills and may be
34 drawn from either San Diego County or further away. Equipment to be used during Project
35 construction would be anticipated to include, but not be limited to, bulldozers, excavators,
36 backhoes, loaders, graders, scrapers, cranes, drill rigs, skid steer, dump trucks, tractor-
37 trailers, splice trailers, water trucks, concrete mixer trucks, line trucks, fork lifts, pulling rigs,
38 reel trailers, transformer low-boy trucks and trailers, and pick-up trucks.

39 **Site Access & Construction Staging**

40 The primary access to the Project site during construction would be along Bell Bluff Truck
41 Trail. Bell Bluff Truck Trail is an existing, private, approximately 30-foot-wide (though it
42 decreases to 12-foot-wide west of the intersection with the Suncrest Substation access road;
43 see Figure 2-3), paved road that provides access to the proposed SVC site and the existing

1 Suncrest Substation from Jatapul Valley Road. As described under Section 2.4.1, “Proposed
2 Project Components,” two new access driveways would be constructed off of Bell Bluff Truck
3 Trail to allow for access of the proposed SVC site. During construction of the transmission
4 line, the Project would use nearly all of the one mile of Bell Bluff Truck Trail between the SVC
5 site westward to the Suncrest Substation for vehicle movements and staging. Bell Bluff Truck
6 Trail would also be used to access the riser pole structure, while the paved Suncrest
7 Substation driveway and graveled service road would be used to access the intermediate pole
8 outside the Suncrest Substation fence. No new temporary or permanent access roads would
9 be required for construction of the underground transmission line.

10 During construction of the transmission line, work would primarily occur within the paved
11 portions of Bell Bluff Truck Trail. Excavation would extend onto the road shoulder or outside
12 the paved portion of the road only at the splice vault locations and for installation of the riser
13 and intermediate poles. The Proposed Project would use one primary 2.56-acre material
14 receiving and staging area located immediately west of the proposed SVC on APN 523-040-
15 080. The Project Applicant would obtain a temporary construction easement from the private
16 landowner to use this staging area prior to construction. Preparation of the staging area
17 would involve grubbing, clearing, and limited grading. Perimeter security fencing would be
18 installed around the outer limits of the SVC work area, and lighting would also be installed
19 for security purposes. A security professional would monitor the staging area nightly, after
20 normal working hours, and on weekends during the day if no construction personnel are
21 present.

22 While it is anticipated that all major electrical and SVC equipment, such as power
23 transformers, power circuit breakers, the control building, etc., would be delivered to the SVC
24 site and placed directly on the previously constructed foundations, other SVC equipment,
25 such as air break switches, instrument transformers, transmission structures, insulators, etc.,
26 would be received and temporarily stored at the staging area prior to installation. All
27 construction equipment and vehicles associated with SVC construction would be parked
28 within the staging area while inactive and at the completion of each workday, where practical.

29 Materials associated with the transmission line (e.g., conductor cable reels, fiber reels,
30 manholes, vaults) would be stored at the SVC staging area. Construction equipment used in
31 construction of the transmission line may be staged along Bell Bluff Truck Trail at active work
32 sites based on safety considerations and/or to reduce potential environmental impacts
33 associated with moving heavy equipment back to staging areas at the end of each workday.

34 **Water Use**

35 Overall, it is anticipated that approximately 2,600,000 gallons (~8 acre-feet) of water will be
36 required during project construction. This water would be used on-site for the cutting of
37 asphalt pavement, dust control, fire suppression reserve in compliance with the Project’s
38 Construction Fire Protection Plan, concrete washout, and other construction activities,
39 including restoration work. Water usage would vary based on the construction
40 activity/phase, but would average approximately 13,100 gallons per day for the entire
41 project for the approximate construction duration of 196 workdays. All water to be used
42 during Project construction would be supplied by water truck.

43 Currently, NEET West is negotiating a water services agreement with the Padre Dam
44 Municipal Water District (PDMWD) for use of recycled water from their water recycling
45 facility, located approximately 19 miles from the Project site. NEET West is also coordinating

1 with the owner of the property on which the SVC would be built for use of the property
2 owner's storage ponds. There already exists a PVC pipeline between the property owner's
3 storage ponds and a water tank at the SVC site, so use of this water could potentially reduce
4 substantially the number of truck trips necessary. Assuming the on-site water source is not
5 available and water must be hauled in from an off-site location such as PDMWD's Water
6 Recycling Facility, it is anticipated truck trips would average three per day (with a peak of up
7 to 6 trips per day during below-grade construction for the SVC).

8 **Utility Connections**

9 AC power for construction and operation at the SVC facility (e.g., for power during
10 construction and permanent lighting) would be provided from a nearby underground 12-kV
11 distribution line located underneath Bell Bluff Truck Trail. This distribution line would be
12 tapped and service would be brought into the SVC site. The service line would be brought in
13 via an underground duct bank and would be installed in cooperation with SDG&E. All
14 disturbances associated with the distribution would be contained within previously
15 described areas of disturbance associated with other Project components. In addition to the
16 power provided by the SDG&E distribution line, additional power for construction activities
17 may be supplied by portable gas or diesel generators.

18 No new temporary or permanent sewer connections would be required for the Proposed
19 Project. Portable toilets would be located at the staging area at the SVC facility. Portable
20 toilets may be towed behind vehicles to the work locations for the underground transmission
21 line each morning and then taken off of the road each evening and stored overnight at the
22 SVC staging area.

23 **2.4.3 Project Operation and Maintenance**

24 **2.4.3.1 Operation**

25 NEET West anticipates remotely operating the Proposed Project from its affiliate Lone Star
26 Transmission, LLC's control center in Austin, Texas. No staff would be needed on site to
27 operate the Proposed Project. The SVC would operate in response to system disturbances or
28 based on voltage/load conditions experienced at the Suncrest Substation. Depending on the
29 conditions, the SVC would either produce or consume reactive power (i.e., vars) primarily
30 through automatic operation/response of its thyristor-controlled reactors and capacitor
31 banks. Essentially, if the power system's reactive load is capacitive (i.e., leading), the SVC
32 would use the thyristor-controlled reactors to consume vars from the system, thus lowering
33 the voltage. If the system's reactive load is inductive (i.e., lagging), the capacitor banks would
34 be automatically switched in, thereby increasing voltage.

35 NEET West would use standard monitoring, control, and protection equipment, including
36 circuit breakers and other line relay protection equipment, and would monitor and operate
37 the Proposed Project via an Energy Management System (EMS) with redundant servers and
38 telecommunications to two data centers based in North and South Florida. The Proposed
39 Project facilities would be dual scanned from both data centers and redundant Inter-Control
40 Center Communications Protocol (ICCP or IEC 60870-6/TASE.2) servers would exchange
41 SCADA data with the CAISO and neighboring transmission operator entities. The EMS would
42 include displays and alarm processing to ensure transmission operations have real-time
43 situational awareness. The EMS support personnel would perform daily checks of the
44 applications and hardware to ensure they are in proper working order. The EMS system also

1 would be maintained to ensure compliance with North American Electric Reliability
2 Corporation (NERC) Critical Infrastructure Protection Standard requirements.

3 **2.4.3.2 Inspections and Maintenance**

4 Maintenance of the Proposed Project would be anticipated to include routine monthly
5 inspections of SVC equipment, the balance of the substation equipment and the transmission
6 line cable terminations. A more thorough annual inspection and assessment of the main SVC
7 components would be performed and drive any planned equipment outages. While an annual
8 offline outage of the SVC is typical, offline maintenance will be driven by the monthly and
9 annual inspections and assessments. NEET West does not anticipate any transmission line
10 inspections, other than the monthly and annual inspections and assessments of the
11 termination points. Inspection and maintenance would be performed by NEET West local
12 personnel, augmented as necessary by NEET West subject matter experts and the equipment
13 Original Equipment Manufacturer.

14 NEET West anticipates creating a maintenance plan in accordance with the equipment
15 vendors' directives, industry practice, NEET West's internal guidelines, and regulatory
16 requirements. The plan would comply with the CAISO Transmission Control Agreement and
17 Maintenance Practices Procedures and be approved by the CAISO before the start of
18 commercial operation.

19 **2.5 Permits and Approvals**

20 The Proposed Project may be subject to a number of other regulatory permits and approvals,
21 depending in part on the environmental analysis contained in this draft EIR, further surveys
22 of environmental resources on or near the Project site, and the discretion of the regulatory
23 agencies. Anticipated required permits and regulatory approvals for the Proposed Project are
24 listed in Table 2-2 below.

25 **Table 2-2. Proposed Project Permits and Approvals**

Regulatory Agency	Law/Regulation	Permit/Authorization Type	Triggering Action
San Diego Regional Water Quality Control Board	Clean Water Act, Section 402	National Pollutant Discharge Elimination System (NPDES) General Construction Stormwater Permit	Disturbance of more than one acre of land during construction.
County of San Diego, Department of Environmental Health	Unified Program: various laws and regulations related to hazardous waste	Unified Program Facility Permit	Storage of transformer oil, which is classified as a hazardous substance under State law.
County of San Diego, Sheriff's Department	Blasting Permission	Blasting Permit	Potential use of blasting materials during construction

1 2.6 Applicant Proposed Measures

2 The Applicant, NEET West, would implement several measures to reduce the potential
3 impacts of Project construction. Applicant proposed measures (APMs) that would be
4 implemented for the Proposed Project are listed in Table 2-3.

5 **Table 2-3. Applicant Proposed Measures (APMs) to be Implemented during Project**
6 **Construction**

APM Number and Title	APM Text
AIR-1: Fugitive Dust Control	During construction, water or non-toxic soil stabilizers will be applied in sufficient quantities on access roads, staging areas, work areas, and on stockpiles to control fugitive dust.
AIR-2: Speed Limits	During construction, vehicle speeds will be limited to 15 miles per hour on unpaved roads or work areas and vehicles should be turned around in established or designated areas only.
AIR-3: Vehicle Use and Idling Time	To the extent feasible construction vehicle use and idling time will be minimized. The ability to limit construction vehicle idling time is dependent upon the sequence of construction activities and when and where vehicles are needed or staged. Certain vehicles, such as large diesel powered vehicles, have extended warm-up times following start-up that limit their availability for use following startup. Where such diesel-powered vehicles are required for repetitive construction tasks, these vehicles may require more idling time. The Proposed Project will apply a “common sense” approach to vehicle use; if a vehicle is not required for use immediately or continuously for construction activities, its engine will be shut off. Construction foremen will include briefings to crews on vehicle use as part of preconstruction conferences. Those briefings will include discussion of a “common sense” approach to vehicle use.
AIR-4: Construction Equipment Emissions	Low-emission construction equipment will be utilized during construction of the Proposed Project. Construction equipment will be maintained per manufacturer specifications. All off-road construction diesel engines not registered under the CARB Statewide Portable Equipment Registration Program shall meet at a minimum the Tier 2 California Emission Standards for Off-Road Compression-Ignition Engines as specified in Cal. Code Regs., tit. 13 § 2423(b)(1).
AIR-5: Loss of Sulfur Hexafluoride (SF₆)	In operation of the SVC, NEET West will maintain the 230-kv circuit breaker so that the loss of SF ₆ is less than 0.5% per year. To assess the loss of SF ₆ , NEET West will conduct monthly inspections and maintain the records of such inspections. NEET West will also participate in the U.S. Environmental Protection Agency’s voluntary SF ₆ Emission Reduction Partnership for Electric Power Systems.

7

1 2.7 Electric and Magnetic Fields

2 2.7.1 Overview

3 The CPUC does not consider electric and magnetic fields (EMF) to be an environmental issue
 4 in the context of CEQA because there is no agreement among scientists that EMF creates a
 5 potential health risk and because CEQA does not define or adopt standards for defining any
 6 potential risk from EMF.

7 The weather and the earth's geomagnetic field cause naturally occurring EMF, while various
 8 technological applications, such as communications technologies, personal electronic
 9 devices, electric generation and transmission, and radiological imaging cause man-made EMF
 10 (CPUC 2016). EMFs are typically characterized by their wavelength or frequency as either
 11 "non-ionizing"¹ or "ionizing" radiation, as shown in Table 2-4 below. In general, the higher
 12 the frequency of EMFs, the shorter their wavelength, and the shorter the wavelength, the
 13 greater the amount of energy is imparted when interacting with physical objects (CPUC
 14 2016). From this table it can be seen that the EMF from the Proposed Project's 1-mile
 15 transmission line would be "non-ionizing."

16 Hertz (Hz) is a unit of frequency that is defined as one cycle per second. With respect to EMF,
 17 Hz values reflect the rate at which electric and magnetic fields change their direction each
 18 second. In the U.S., electric transmission lines typically operate at 60 Hz, which is considered
 19 an extremely low frequency (ELF) (CPUC 2016). By comparison, mobile phones operate at
 20 between 1.9 and 2.2 billion Hz (gigahertz), while X-rays operate at upwards of 30×10^{19} Hz
 21 (National Cancer Institute 2016).

22 **Table 2-4. Types of EMF Radiation**

Radiation Type	Definition	Forms of Radiation	Source Examples
Non-Ionizing	Low to mid-frequency radiation which is generally perceived as harmless due to its lack of potency.	<ul style="list-style-type: none"> ▪ Extremely Low Frequency (ELF) ▪ Radiofrequency (RF) ▪ Microwaves ▪ Visual Light 	<ul style="list-style-type: none"> ▪ Microwave ovens ▪ Computers ▪ House energy smart meters ▪ Wireless (wifi) networks ▪ Cell phones ▪ Bluetooth devices ▪ Power lines ▪ MRIs
Ionizing	Mid to high-frequency radiation which can, under certain circumstances, lead to cellular and/or DNA damage with prolonged exposure.	<ul style="list-style-type: none"> ▪ Ultraviolet (UV) ▪ X-Rays ▪ Gamma 	<ul style="list-style-type: none"> ▪ Ultraviolet light ▪ X-Rays ranging from 30×10^{16} Hz to 30×10^{19} Hz ▪ Some gamma rays

¹ Ionization is the process by which electrons are freed from atoms or electrons, thereby creating ions or charged particles. Ionizing radiation is radiation that carries enough energy to create ions.

Source: NIEHS 2016

1 2.7.1.1 Electric Fields

2 Electric fields from power lines from power lines are created whenever the lines are
 3 energized, with the strength of the field dependent directly on the voltage of the line creating
 4 it. Electric field strength is typically described in terms of kV per meter (kV/m). Electric field
 5 strength attenuates (reduces) rapidly as the distance from the source increases. Electric fields
 6 are reduced in many locations because they are effectively shielded by most objects or
 7 materials such as trees or houses.

8 Unlike magnetic fields, which penetrate almost everything and are unaffected by buildings
 9 trees, and other obstacles, electric fields are distorted by any object that is within the electric
 10 field including the human body. Even trying to measure an electric field with electronic
 11 instruments is difficult because the devices themselves will alter the levels recorded.

12 2.7.1.2 Magnetic Fields

13 Magnetic fields from power lines are created whenever current flows through power lines at
 14 any voltage. The strength of the field is directly dependent on the current in the line. Magnetic
 15 field strength is typically measured in milligauss (mG). Similar to electric fields, magnetic field
 16 strength attenuates rapidly with distance from the source. However, unlike electric fields,
 17 magnetic fields are not easily shielded by objects or materials. The nature of a magnetic field
 18 can be illustrated by considering a household appliance. When the appliance is energized by
 19 being plugged into an outlet but not turned on, no current flows through it. Under such
 20 circumstances, an electric field is generated around the cord and appliance, but no magnetic
 21 field is created. If the appliance is switched on, the electric field would still be present and a
 22 magnetic field would also be created. The electric field strength is directed related to the
 23 magnitude of the voltage from the outlet and the magnetic field strength is directly related to
 24 the magnitude of the current flowing in the cord and appliance. Table 2-5 shows typical
 25 magnetic fields from household appliances.

26 **Table 2-5. Typical Magnetic Fields from Household Appliances**

Appliance	Magnetic Field (mG) – 12” Distant	Magnetic Field (mG) – Maximum
Electric Range	3-30	100-1,200
Garbage Disposal	10-20	850-1,250
Clothes Washer	1-3	10-400
Toaster	0.6-8	70-150
Vacuum Cleaner	20-200	2,000-8,000
Hair Dryer	1-70	60-20,000
Electric Shaver	1-100	150-15,000
Fluorescent Desk Lamp	6-20	400-3,500
Circular Saw	10-250	2,000-10,000

Appliance	Magnetic Field (mG) – 12” Distant	Magnetic Field (mG) – Maximum
Electric Drill	25-35	4,000-8,000
Refrigerator	0.3-3	4-15

Source: CPUC 2016; Gauger 1985

1 At a distance of 12 inches, the magnetic field strengths range from 0.3 to 250 mG. At the
 2 source, magnetic field strengths from household appliances included in the table range from
 3 4 mG to 20,000 mG. Field strength attenuates rapidly with distance from the source. Similar
 4 to household appliances, an underground transmission line will have a magnetic field that
 5 varies dependent upon the current in the transmission line and distance from the
 6 transmission line. The CPUC conducted an investigation of EMF levels along the underground
 7 double-circuit 230-kV transmission line located in Alpine Boulevard (CPUC 2016). Spot
 8 magnetic field measurements ranging from 21.4 mG to 29.0 mG were recorded directly above
 9 these buried transmission lines. The Proposed Project would include an underground single-
 10 circuit 230-kV transmission line. EMF levels in the vicinity of the Proposed Project’s 230 kV
 11 single-circuit line are discussed in Section 2.7.4. The CPUC previously conducted an
 12 investigation of EMF levels along the underground double-circuit 230-kV transmission line
 13 located in Alpine Boulevard (CPUC 2016).

14 2.7.2 Scientific Background and Regulations Applicable to EMF

15 2.7.2.1 EMF Research

16 For more than 20 years, questions have been asked regarding the potential effects of EMFs
 17 from power lines, and research has been conducted to provide some basis for response.
 18 Earlier studies focused primarily on interactions with the electric fields from power lines. In
 19 the late 1970s, the subject of magnetic field interactions began to receive additional public
 20 attention and research levels increased. A substantial amount of research investigating both
 21 electric and magnetic fields has been conducted over the past several decades; however,
 22 much of the body of national and international research regarding EMF and public health
 23 risks remains contradictory or inconclusive (see Section 2.7.3 below).

24 Research related to EMF can be grouped into three general categories: cellular level studies,
 25 animal and human experiments, and epidemiological studies. Epidemiological studies have
 26 provided mixed results, with some studies showing an apparent relationship between
 27 magnetic fields and health effects while other similar studies do not. Laboratory studies and
 28 studies investigating a possible mechanism for health effects (mechanistic studies) provide
 29 little or no evidence to support this link.

30 Since 1979, public interest and concern specifically regarding magnetic fields from power
 31 lines has increased. The increase has generally been attributed to publication of the results
 32 of a single epidemiological study (Wertheimer and Leeper 1979). This study observed a
 33 statistical association between the high-current configuration (the “wire code”) of electric
 34 power lines outside of homes in Denver and the incidence of childhood cancer. The “wire
 35 code” was assumed to be related to current flow of the line. The study did not take
 36 measurements of magnetic field intensity. Since publication of the Wertheimer and Leeper
 37 study, many epidemiological, laboratory, and animal studies regarding EMF have been
 38 conducted.

1 Research on ambient magnetic fields in homes and buildings in several western states found
2 average magnetic field levels within most rooms to be approximately 1mG, while in a room
3 with appliances present, the measured values ranged from 9 to 20 mG (Severson et al. 1988;
4 Silva 1988). Immediately adjacent to appliances (within 12 inches), field values are much
5 higher.

6 **2.7.2.2 Methods to Reduce EMF**

7 EMF levels from transmission lines can be reduced in three primary ways: shielding, field
8 cancellation, or increasing the distance from the source. Shielding, which reduces exposure
9 to electric fields, can be actively accomplished by placing trees or other physical barriers
10 along the transmission line ROW. Shielding also results from existing structures the public
11 may use or occupy along the line. Since electric fields can be blocked by most materials,
12 shielding is effective for the electric fields but is not effective for magnetic fields.

13 Magnetic fields can be reduced either by cancellation or by increasing distance from the
14 source. Cancellation is achieved in two ways. A transmission line circuit consists of three
15 "phases": three separate wires (conductors) on a transmission tower. The configuration of
16 these three conductors can reduce magnetic fields. First, when the configuration places the
17 three conductors closer together, the interference, or cancellation, of the fields from each
18 wire is enhanced. This technique has practical limitations because of the potential for short
19 circuits if the wires are placed too close together. There are also worker safety issues to
20 consider if spacing is reduced. In underground lines, the three phases typically can be placed
21 much closer together than for overhead lines because the cables are have dielectric
22 insulation.

23 The distance between the source of fields and the public can be increased by either placing
24 the wires higher aboveground, burying underground cables deeper, or by increasing the
25 width of the right-of-way. For transmission lines, these methods can prove effective in
26 reducing fields because the reduction of the field strength drops rapidly with distance.

27 **2.7.2.3 Scientific Panel Reviews**

28 Numerous panels of expert scientists have convened to review the data relevant to the
29 question of whether exposure to power-frequency EMF is associated with adverse health
30 effects. These evaluations have been conducted in order to advise governmental agencies or
31 professional standard-setting groups. These panels of scientists first evaluate the available
32 studies individually, not only to determine what specific information they can offer, but also
33 in terms of the validity of their experimental design, methods of data collection, analysis, and
34 suitability of the authors' conclusions to the nature and quality of the data presented.
35 Subsequently, the individual studies, with their previously identified strengths and
36 weaknesses, are evaluated collectively in an effort to identify whether there is a consistent
37 pattern or trend in the data that would lead to a determination of possible or probable
38 hazards to human health resulting from exposure to these fields.

39 These reviews include those prepared by international agencies such as the World Health
40 Organization (WHO 1984, 1987, 2001, and 2007), the international Non-Ionizing Radiation
41 Committee of the International Radiation Protection Association (IRPA/INIRC 1990), and
42 governmental agencies of a number of countries, such as the U.S. Environmental Protection

1 Agency, the National Radiological Protection Board of the United Kingdom, the Health Council
2 of the Netherlands, and the French and Danish Ministries of Health.

3 As noted below, these scientific panels have varied conclusions on the strength of the
4 scientific evidence suggesting that power frequency EMF exposures pose any health risk.

5 In May 1999, the National Institute of Environmental Health Services (NIEHS) submitted to
6 Congress its report titled, Health Effects from Exposure to Power-Line Frequency Electric and
7 Magnetic Fields, containing the following conclusion regarding EMF and health effects:

8 Using criteria developed by the International Agency for Research on Cancer (IARC),
9 none of the Working Group considered the evidence strong enough to label ELF-EMF
10 exposure as a known human carcinogen or probable human carcinogen. However, a
11 majority of the members of this Working Group concluded that exposure to power-
12 line frequency ELF-EMF is a possible carcinogen.

13 In June 2001, a scientific working group of IARC (an agency of WHO) reviewed studies related
14 to the carcinogenicity of EMF. Using standard IARC classification, magnetic fields were
15 classified as “possibly carcinogenic to humans” based on epidemiological studies. “Possibly
16 carcinogenic to humans” is a classification used to denote an agent for which there is limited
17 evidence of carcinogenicity in humans and less than sufficient evidence of carcinogenicity in
18 experimental animals. Other agents identified as “possibly carcinogenic to humans” include
19 gasoline exhaust, styrene, welding fumes, and coffee (WHO 2001).

20 On behalf of the CPUC, the California Department of Health Services (DHS) completed a
21 comprehensive review of existing studies related to EMF from power lines and potential
22 health risks. This risk evaluation was undertaken by three staff scientists with the DHS. Each
23 of these scientists is identified in the review results as an epidemiologist, and their work took
24 place from 2000 to 2002. The results of this review titled *An Evaluation of the Possible Risks
25 From Electric and Magnetic Fields From Power Lines, Internal Wiring, Electrical Occupations,
26 and Appliances* were published in June 2002. The conclusions contained in the executive
27 summary are provided below:

- 28 ▪ To one degree or another, all three of the DHS scientists are inclined to believe that
29 EMFs can cause some degree of increased risk of childhood leukemia, adult brain
30 cancer, Lou Gehrig’s Disease, and miscarriage.
- 31 ▪ They strongly believe that EMFs do not increase the risk of birth defects, or low birth
32 weight.
- 33 ▪ They strongly believe that EMFs are not universal carcinogens, since there are a
34 number of cancer types that are not associated with EMF exposure.
- 35 ▪ To one degree or another, they are inclined to believe that EMFs do not cause an
36 increased risk of breast cancer, heart disease, Alzheimer’s Disease, depression, or
37 symptoms attributed by some to sensitivity to EMFs. However, all three scientists had
38 judgments that were “close to the dividing line between believing and not believing”
39 that EMFs cause some degree of increased risk of suicide.

- 1 ▪ For adult leukemia, two of the scientists are “close to the dividing line between
2 “believing or not believing” and one was “prone to believe” that EMFs cause some
3 degree of increased risk.

4 The report indicates that the DHS scientists are more inclined to believe that EMF exposure
5 increased the risk of the health problems than the majority of the members of scientific
6 committees that have previously convened to evaluate the scientific literature. With regard
7 to why the DHS review’s conclusions differ from those of other recent reviews, the report
8 states:

9 The three DHS scientists thought there were reasons why animal and test
10 tube experiments might have failed to pick up a mechanism or a health
11 problem; hence, the absence of much support from such animal and test tube
12 studies did not reduce their confidence much or lead them to strongly distrust
13 epidemiological evidence from statistical studies in human populations. They
14 therefore had more faith in the quality of the epidemiological studies in
15 human populations and hence gave more credence to them.

16 While the results of the DHS report indicate these scientists believe that EMF can cause some
17 degree of increased risk for certain health problems, the report did not quantify the degree
18 of risk or make any specific recommendations to the CPUC.

19 In addition to the uncertainty regarding the level of health risk posed by EMF, individual
20 studies and scientific panels have not been able to determine or reach consensus regarding
21 what level of magnetic field exposure might constitute a health risk. In some early
22 epidemiological studies, increased health risks were discussed for daily time-weighted
23 average field levels greater than 2 mG. However, the IARC scientific working group indicated
24 that studies with average magnetic field levels of 3 to 4 mG played a pivotal role in their
25 classification of EMF as a possible carcinogen.

26 The 2007 WHO [Environmental Health Criteria 238] report concluded that:

- 27 ▪ Evidence for a link between Extremely Low Frequency (50 to 60 Hz) magnetic fields
28 and health risks is based on epidemiological studies demonstrating a consistent
29 pattern of increased risk for childhood leukemia. However, “...virtually all of the
30 laboratory evidence and the mechanistic evidence fail to support a relationship
31 between low-level ELF magnetic fields and changes in biological function or disease
32 status...the evidence is not strong enough to be considered causal but sufficiently
33 strong to remain a concern.”
- 34 ▪ “For other diseases, there is inadequate or no evidence or health effects at low
35 exposure levels.”

36 **2.7.3 Policies, Standards, and Regulations**

37 A number of counties, states, and local governments have adopted or considered regulations
38 or policies related to EMF exposure. The reasons for these actions have been varied; in
39 general, however, the actions can be attributed to addressing public reaction to and
40 perception of EMF as opposed to responding to the findings of any specific scientific research.

1 In 1991, the CPUC initiated an investigation into electric and magnetic fields associated with
2 electric power facilities. This investigation explored the approach to potential mitigation
3 measures for reducing public health impacts and possible development of policies,
4 procedures or regulations. Following is a brief summary of CPUC guidelines and regulatory
5 activity regarding EMF.

6 **2.7.3.1 CPUC Decision No. 93-11-013**

7 In Decision No. 93-11-013, CPUC took interim steps to address EMFs related to electric utility
8 facilities and power lines. Based on its investigation of the possible impacts of EMF exposure
9 associated with electric utility installations, CPUC recommended the following:

- 10 ▪ No-cost and low-cost steps to reduce EMF levels;
- 11 ▪ Workshops to develop EMF design guidelines;
- 12 ▪ Uniform residential and workplace EMF measurement programs;
- 13 ▪ Stakeholder and public involvement; and
- 14 ▪ Funding for educational and research programs.

15 In explaining and justifying its decision, CPUC stated that although the scientific community
16 had not yet isolated the impact, if any, of utility-related EMF exposures on public health, other
17 jurisdictions and agencies have concluded that the best response to EMFs is to avoid
18 unnecessary new exposure to EMFs if such avoidance can be achieved at a cost that is
19 reasonable in light of the risk identified. The decision stated that “low-cost” steps to reduce
20 EMF levels should be defined as roughly 4 percent of the total cost of a budgeted project, but
21 emphasized that this should not be a hard-and-fast rule and that utilities should implement
22 more or less costly solutions as they are determined to be effective.

23 **2.7.3.2 CPUC Decision No. 06-01-042 and More Information**

24 In 2006, CPUC revisited the EMF issue it had covered in its Decision No. 93-11-013 and
25 affirmed its “low-cost/no-cost” policy for mitigation of EMF exposure for new utility
26 transmission and substation projects. Decision No. 06-01-042 also reaffirmed the CPUC’s
27 policy of using a benchmark of 4 percent of transmission and substation project costs for EMF
28 mitigation. In addition, Decision No, 06-01-042 adopted rules and policies to improve utility
29 design guidelines for reducing EMF, and provided for a utility workshop to implement the
30 policies and standardize design guidelines. Finally, Decision No. 06-01-042 restated CPUC’s
31 position that it is unable to determine whether there is a significant scientifically verifiable
32 relationship between EMF exposure and negative health consequences.

33 The CPUC’s EMF Design Guidelines for Electrical Facilities (July 21, 2006) document is
34 available at <http://www.cpuc.ca.gov/WorkArea/DownloadAsset.aspx?id=4884>. More
35 information about activities taken by CPUC with respect to EMFs can be found at:
36 <http://www.cpuc.ca.gov/General.aspx?id=4879>. In addition, the results of a 2016 CPUC field
37 investigation on EMF levels along an underground 230-kV transmission line in Alpine,
38 California can be found here: [http://www.cpuc.ca.gov/environment/info/asp/en/sunrise/
39 Alpine%20Electromagnetic%20Field%20Investigation%20Report_Appendices.pdf](http://www.cpuc.ca.gov/environment/info/asp/en/sunrise/Alpine%20Electromagnetic%20Field%20Investigation%20Report_Appendices.pdf).

1 **2.7.4 EMF Data Applicable to the Proposed Project**

2 Notable existing sources of EMFs in the vicinity of the Proposed Project include SDG&E's
3 Suncrest Substation, and Sunrise Powerlink transmission lines

4 The Proposed Project would not generate any real power and is not a "power plant." The
5 Proposed Project does not increase or decrease the amount of power flow over existing
6 transmission lines, it only acts to support the line voltage on existing lines depending upon
7 the proportion of renewable power flowing on the lines. The Proposed Project does not
8 modify existing transmission lines nor alter the rated capacity of the existing Sunrise
9 Powerlink 500-kV and 230-kv transmission lines, therefore, any potential future power flow
10 along these existing lines would be within the levels foreseen when these facilities were
11 originally approved.

12 The proposed SVC would inject or absorb reactive power based on system conditions so as
13 to maintain adequate or desirable voltage levels in response to various possible system
14 disturbances. The reactive power flow between the new SVC facility and the existing Suncrest
15 Substation will vary throughout the day and will also vary from day to day and season to
16 season. Since the EMF along the transmission line is directly related to the power flow on the
17 line, it also vary over time. The maximum reactive power flow is expected to occur rarely,
18 under certain emergency or contingency situations. The SVC is designed to provide a
19 maximum +300/-100 MVAR of reactive power. Based on modeling of the maximum output,
20 the EMF along the new 1-mile 230-kV transmission line, at the edges of its 20 foot-wide right-
21 of-way, would be 41 mG at one edge of the right-of-way and 41.9 mG at the other edge of the
22 right-of-way.

23 The Electric and Magnetic FMP for the Proposed Project evaluated EMF mitigation measures
24 in its design and construction plan and adopted certain no-cost mitigation options
25 (Appendix D of this DEIR). The no-cost EMF mitigation design options that have been
26 included in the Suncrest Project design are as follows:

- 27 ▪ Locate high current devices, such as transformers, capacitors, and reactors near the
28 center of the SVC Facility to the extent practicable.
- 29 ▪ Locate the SVC Facility fencing so as to maximize the distance between the EMF
30 generating equipment and the property fence to the extent practicable.
- 31 ▪ Arrange the underground 230-kv transmission cables in a triangular configuration
32 and install these cables at a minimum of 36 inches below grade where practicable.

33

Page intentionally left blank.