

Chapter 20 Alternatives

20.1 Introduction

This chapter describes the alternatives considered for the Proposed Project and evaluates their environmental impacts as compared to the Proposed Project. The purpose of the alternatives analysis in an environmental impact report (EIR) is to describe a range of reasonable, potentially feasible alternatives to the project that can feasibly attain most of the identified project objectives, but reduce or avoid one or more of the project's significant impacts. This chapter provides a detailed description of the California Environmental Quality Act (CEQA) regulatory requirements for alternatives analysis, describes the alternatives development process for the Proposed Project, and evaluates the impacts of the selected alternatives. This chapter relies on information provided in NextEra Energy Transmission West, LLC's (NEET West's) Proponent's Environmental Assessment (PEA).

20.1.1 Regulatory Requirements

CEQA requires that an EIR evaluate a reasonable range of potentially feasible alternatives to the proposed project, including the No Project Alternative. The No Project Alternative allows decision-makers to compare the impacts of approving the action against the impacts of not approving the action. While there is no clear rule for determining a reasonable range of alternatives, CEQA provides guidance that can be used to define the range of alternatives for consideration in the environmental document.

The alternatives described in an EIR must feasibly accomplish most of the basic project objectives, should reduce or eliminate one or more of the significant impacts of the proposed project (although the alternative could have greater impacts overall), and must be potentially feasible (State CEQA Guidelines Section 15126.6(a)). In determining whether alternatives are potentially feasible, Lead Agencies are guided by the definition of feasibility found in State CEQA Guidelines Section 15364: "capable of being accomplished in a successful manner within a reasonable period of time, taking into account economic, environmental, legal, social, and technological factors." In accordance with State CEQA Guidelines Section 15126.6(f), the Lead Agency should consider site suitability, economic viability, availability of infrastructure, general plan consistency, other regulatory limitations, and jurisdictional boundaries in determining the feasibility of alternatives to be evaluated in an EIR. An EIR must briefly describe the rationale for selection and rejection of alternatives and the information that the Lead Agency relied on in making the selection. It also should identify any alternatives that were considered by the Lead Agency but were rejected as infeasible during the scoping process and briefly explain the reason for their exclusion (State CEQA Guidelines Section 15126.6[c]).

In addition, alternatives with effects that cannot be reasonably ascertained and for which implementation is remote and speculative are screened from full analysis (State CEQA Guidelines Section 15126.6[f][3]).

1 An EIR's analysis of alternatives is required to identify the environmentally superior
2 alternative among all those considered (State CEQA Guidelines Sections 15126.6[a] and
3 [e][2]). If the No Project Alternative is identified as the environmentally superior alternative,
4 then the EIR must also identify an environmentally superior alternative amongst the other
5 alternatives.

6 These guidelines were used in developing and evaluating the alternatives as described below.

7 **20.2 Alternatives Development Process**

8 The Proposed Project's purpose and objectives, as well as its potentially significant
9 environmental impacts were considered in developing alternatives. Alternatives were
10 developed to achieve most of the basic objectives of the Proposed Project while reducing one
11 or more of its significant adverse environmental impacts. Alternatives also were developed
12 based on potential feasibility.

13 **20.2.1 Project Purpose and Objectives**

14 As described in Chapter 2, *Project Description*, the purpose of the Proposed Project is to
15 provide reactive power support to the existing Suncrest Substation to allow for improved
16 operation following system disturbances and importation of renewable generation from the
17 Imperial Valley to demand centers in San Diego and Los Angeles. This was identified as a
18 policy-driven need in the California Independent System Operator's (CAISO's) 2013-2014
19 Transmission Plan. Specifically, the objectives of the Proposed Project are as follows:

- 20 1. Provide reactive support to Suncrest Substation;
- 21 2. Improve and maintain transmission grid reliability; and
- 22 3. Facilitate delivery of renewable energy generation from the Imperial Valley area to
23 population centers to the west and support achievement of California's Renewables
24 Portfolio Standard.

25 **20.2.2 Significant Environmental Impacts of the Proposed Project**

26 A number of impacts have been identified as significant but would be mitigated to a level of
27 less-than-significant through implementation of mitigation measures. These impacts are
28 listed in Table ES-1 in the Executive Summary of this draft EIR (DEIR). No impacts were
29 identified as significant and unavoidable.

30 **20.2.3 Alternatives Screening and Development**

31 Numerous alternatives were identified during development of the Proposed Project. These
32 alternatives were screened based on the following factors:

- 33 ■ Does the alternative meet most of the project objectives?
- 34 ■ Is the alternative feasible?

1 ▪ Does the alternative avoid or substantially lessen any of the environmental impacts
2 of the Proposed Project?

3 ▪ Is the alternative speculative?

4 Based on this initial screening, alternatives were either dismissed from further consideration
5 or carried forward for detailed analysis. Table 20-1 shows all of the alternatives considered
6 and the results of the screening process.

7 As shown in Table 20-1, the EIR analysis considered the No Project Alternative, as required
8 by CEQA, as well as several technology alternatives, hypothetical system alternatives, siting
9 alternatives, and one transmission line alternative. Due either to their inability to meet most
10 of the project objectives, be feasibly implemented, or avoid or substantially less one or more
11 of the Proposed Project's environmental impacts, of if they were deemed speculative, a
12 number of these initial alternatives were dismissed from further consideration.

13 **Alternatives Dismissed from Further Consideration**

14 ***Technology Alternatives***

15 The California Independent System Operator's (CAISO's) 2013-2014 Transmission Plan
16 (CAISO 2014) identified a need for a +300/-100 megavar dynamic reactive power device at
17 the Suncrest Substation's 230-kilovot (-kV) bus. The reactive power device would provide
18 continuous or quasi-continuous reactive power response following system disturbances and
19 assist in the deliverability of renewable generation from the Imperial Valley zone. The
20 Transmission Plan did not specify the type of device, but the CAISO's Functional
21 Specifications for the Suncrest 230-kV 300 Mvar Dynamic Reactive Power Support Project
22 requested that project applicants submit a bid for one of the following types of devices:

- 23 ▪ Static VAR Compensator (SVC)
- 24 ▪ Static Synchronous Compensator (STATCOM)
- 25 ▪ Synchronous Condenser

26 SVCs and STATCOMs are devices within the Flexible AC Transmission Systems (FACTS)
27 family. They use power electronics to control power flow and improve transient stability on
28 power grids. A synchronous condenser is essentially a spinning, electromagnetic,
29 synchronous motor, but its shaft spins freely, rather than being connected to a machine. A
30 voltage regulator controls the electrical field to either generate or absorb reactive power in
31 response to system conditions.

32 In preparing its bid package for the CAISO, NEET West considered several commercially-
33 available transmission technologies that would meet the CAISO's description and functional
34 specifications. In addition to the Proposed Project, which is a SVC, NEET West considered
35 three other technology combinations, as follows:

- 36 ▪ Hybrid SVC with Mechanically-Switched Capacitors
- 37 ▪ Hybrid STATCOM with Mechanically-Switched Capacitor
- 38 ▪ Synchronous Condensers

1 **Table 20-1. Alternatives Screening Summary**

Type of Alternative	Alternative	Does it meet most of the basic project objectives?	Is it feasible?	Does it avoid or substantially lessen any environmental impacts of the Proposed Project?	Is it speculative?	Carry forward for detailed analysis?
No Project Alternative	No Project Alternative	No	Yes	Yes	No	Yes
Technology Alternatives	Hybrid SVC with Mechanically-switched Capacitors	Yes	Yes	No	No	No
	Hybrid STATCOM with Mechanically-switched Capacitor	Yes	Yes	No	No	No
	Synchronous Condensers	Yes	Yes	No	No	No
System Alternatives	Traditional Generator Reactive Power Support	Yes	Yes	No	No	No
	CAISO Initiative for Reactive Power Support from Asynchronous Generators	Yes	Yes	Yes	Yes	No
	Energy Conservation/Energy Efficiency	No	Yes	Yes	Yes	No
	Demand Response/Load Management	No	No	Yes	Yes	No

Type of Alternative	Alternative	Does it meet most of the basic project objectives?	Is it feasible?	Does it avoid or substantially lessen any environmental impacts of the Proposed Project?	Is it speculative?	Carry forward for detailed analysis?
Siting Alternatives	Northeast Site Alternative	Yes	Yes	Yes	No	Yes
	West Site Alternative	Yes	No	Yes	No	No
	Suncrest Substation Alternative	Yes	Yes	Yes	No	Yes
Transmission Line Alternative	Overhead Transmission Line Alternative	Yes	Yes	Yes	No	Yes

1

1 All three of these technology combinations would require a similar construction footprint as
2 a proposed SVC, but they would be more expensive. None of these three technology
3 alternatives would avoid or reduce any environmental impacts of the Proposed Project. All of
4 these options would involve similar ground disturbance and similar impacts to the physical
5 environment. Therefore, these alternatives were not carried forward for detailed analysis in
6 the EIR.

7 ***System Alternatives***

8 **Traditional Generator Reactive Power Support**

9 One hypothetical system alternative to the Proposed Project is development of traditional
10 generating facilities in the area of the existing Suncrest Substation. Traditional fossil-fuel,
11 hydroelectric, geothermal, solar-thermal, and nuclear power generating units create reactive
12 power along with real power. These are synchronous generators, meaning that they have a
13 mechanical rotor that rotates in synchronization with the system frequency. It is estimated
14 that a 500 to 600 MW combined-cycle gas-fired power plant may provide approximately
15 +240 Mvar, or close to the +300 Mvar required of the Proposed Project. Therefore, a new
16 synchronous generator could theoretically meet the CAISO's identified need for reactive
17 power at the Suncrest Substation 230-kV bus.

18 A new fossil-fuel generating plant in California would likely be a natural gas-fired combined-
19 cycle or peaker unit. Such facilities would require a natural gas supply. A new hydroelectric
20 power plant would likely involve raising an existing dam and installing one or more new
21 turbines. Geothermal power resources are not in the vicinity of the Suncrest Substation and
22 would require a lengthy transmission line. Solar thermal devices using a mechanical motor
23 generator could provide reactive power capability, but would not have the same flexibility as
24 a gas-fired unit has for ramping up and down to absorb or inject reactive power. The
25 construction requirements for a nuclear power plant would be extensive.

26 System alternatives involving traditional generator reactive power support would not
27 substantially avoid or lessen any of the environmental impacts of the Proposed Project.
28 Instead, these alternatives would result in greater impacts as compared to the Proposed
29 Project. It is also questionable whether any of these traditional generators could be feasibly
30 planned, permitted, and constructed within an acceptable time frame for CAISO. For these
31 reasons, this subset of system alternatives was dismissed from further consideration in
32 the EIR.

33 **CAISO Initiative for Reactive Power Support from Asynchronous Generators**

34 Another alternative identified in the alternatives development and screening process was
35 reliance on CAISO's initiative for reactive power support from asynchronous generators. In
36 contrast to traditional generating facilities, most renewable electricity generating resources,
37 such as solar, wind, and energy storage, do not use mechanical rotors rotating in
38 synchronicity with the system. These "asynchronous" resources do not inherently have
39 reactive power capability (or, in the case of wind, do not have the same reactive power
40 capability as a synchronous resource). By adding inverters, capacitors, or using other
41 methods, however, asynchronous resources may provide reactive power to the grid.

42 CAISO's Board of Governors recently (August 31, 2016) approved a new policy for reactive
43 power requirements and financial compensation for asynchronous resources (CAISO 2016).

1 This policy, currently under review by the Federal Energy Regulatory Commission (FERC),
2 would require that new or repowered asynchronous resources provide reactive power and
3 voltage regulation. In its PEA submitted to the California Public Utilities Commission (CPUC),
4 NEET West theorized that if the new CAISO requirements were to go into effect and several
5 large solar or wind facilities were to be required to provide reactive power capability, it could
6 reduce the amount of reactive power needed at the Suncrest Substation. Therefore, instead
7 of building the SVC, the transmission grid could potentially receive reactive power support
8 from new renewable generating facilities built in compliance with CAISO's initiative.

9 Several problems were identified with this alternative. First, at the time of writing of this
10 DEIR, FERC is reviewing the proposed policy and it is unknown if or when it will be approved.
11 Second, it is unknown if and what size renewable generating facilities may be constructed in
12 the future in close enough proximity to the existing Suncrest Substation to address the
13 reactive power deficit identified by CAISO. Reliance on reactive power provided by new or
14 repowered renewable generating facilities may avoid the environmental impacts of the
15 Proposed Project (by avoiding the need to construct the proposed SVC and transmission line),
16 but it is unknown what impacts the new generating facilities may have. Altogether, it was
17 determined that this alternative may not be feasible, its effects cannot be reasonably
18 ascertained, and its implementation is considered remote and speculative at this time (State
19 CEQA Guidelines Section 15126.6[f][3]).

20 **Energy Conservation/Energy Efficiency**

21 Energy conservation and energy efficiency are ways to reduce load and avoid the need for
22 providing real power. These approaches, however, would not address the identified need for
23 reactive power at the Suncrest Substation 230-kV bus. As described in Chapter 2, *Project*
24 *Description*, reactive power is the component of electricity that functions to maintain
25 adequate voltages for system reliability. Real power, by contrast, is the element of electricity
26 that performs useful work and is measured in watts. Therefore, while this alternative would
27 reduce the amount of real power or generation needed to meet demands in the San Diego
28 area, it would not reduce the amount of reactive power needed at the existing Suncrest
29 Substation and would not meet the project objectives. This alternative also was considered
30 speculative in that it was not known how or where the energy conservation/energy efficiency
31 measures would be implemented. As such, this alternative was dismissed from further
32 consideration.

33 **Demand Response/Load Management**

34 Similar to energy conservation/energy efficiency, demand response/load management are
35 techniques for reducing loads, specifically peak loads. Demand response is a change in the
36 power consumption of an electric utility customer to better match the demand for power with
37 the supply. For example, utilities may provide incentives or signals to their customers
38 encouraging them to use electricity during off-peak hours, such as through off-peak metering,
39 when power is cheaper at certain times of the day. As described above, reactive power is
40 distinct from real power and does not perform any useful work or meet load demands.
41 Rather, reactive power serves to maintain voltage levels for transmission system reliability.
42 Demand response/load management would not meet project Objective 1 or 3 of the Proposed
43 Project. Reactive power support would not be provided at Suncrest Substation (Objective 1),
44 and the delivery of renewable energy would not be facilitated (Objective 3). This alternative
45 was also considered speculative in that it was not known how or where it would be
46 implemented. Therefore, this alternative was dismissed from further consideration.

1 **West Site Alternative**

2 The West Site Alternative is not feasible because it would be located on the Lightner
3 Mitigation site and is scheduled to be transferred to the U.S. Forest Service for conservation
4 in perpetuity. This alternative could not be accomplished within a reasonable period of time
5 taking in account environmental and legal factors and regulatory limitations and
6 jurisdictional boundaries. Therefore, this siting alternative was screened out from further
7 consideration.

8 **Alternatives Carried Forward for Analysis**

9 The remaining alternatives shown in Table 20-1 and not dismissed due to infeasibility, lack
10 of environmental impact reduction, or other reasons were carried forward for analysis. In
11 addition to the No Project Alternative, which was analyzed as required by CEQA, these include
12 the following alternatives:

- 13 ▪ Northeast Site Alternative
- 14 ▪ Suncrest Substation Alternative
- 15 ▪ Overhead Transmission Line Alternative

16 These alternatives were determined to: (1) meet most of the project objectives; (2) be
17 feasible; (3) avoid or reduce one or more of the Proposed Project's significant impacts, and
18 (4) not be too speculative or ill-defined. These alternatives are evaluated in the following
19 section, "Alternatives Analysis."

20 **20.2.4 California Public Utilities Code Section 1002.3**

21 California Public Utilities Code Section 1002.3 requires that CPUC consider cost-effective
22 alternatives to transmission facilities when evaluating project applications for a Certificate of
23 Public Convenience and Necessity. The following alternatives would be cost-effective
24 alternatives that meet Section 1002.3 requirements: Energy Conservation/Energy Efficiency,
25 Demand Response/Load Management, and the CAISO Initiative for Reactive Power Support
26 from Asynchronous Generators. In addition, the Suncrest Substation Alternative would be a
27 cost-effective alternative that does not require construction of the proposed mile-long
28 230-kV underground transmission line.

29 As described in Section 20.2.3, the Suncrest Substation Alternative was carried forward for
30 full analysis in this DEIR. The Energy Conservation/Energy Efficiency, Demand
31 Response/Load Management, and CAISO Initiative for Reactive Power Support from
32 Asynchronous Generators alternatives were screened out from further analysis.

33 **20.3 Alternatives Analysis**

34 **20.3.1 No Project Alternative**

35 **Characteristics of this Alternative**

36 Under the No Project Alternative, NEET West would not construct the SVC and underground
37 transmission line and the Proposed Project would not be built. The No Project Alternative

1 would not provide any reactive power at the Suncrest Substation's 230-kV bus and would not
2 meet any of the project objectives.

3 **Impact Analysis**

4 The No Project Alternative would avoid all of the environmental impacts associated with
5 construction and/or operation of the Proposed Project. These include dust and air pollutant
6 emissions, noise and traffic effects during construction, impacts that may occur by disrupting
7 previously undiscovered cultural resources, and impacts on existing views and aesthetic
8 effects during operation.

9 **20.3.2 Northeast Site Alternative**



10 **Characteristics of this Alternative**

11 Under the Northeast Site Alternative, the SVC would be located approximately 0.3 mile north
12 of Bell Bluff Truck Trail, as shown on Figure 20-1. This site is relatively undeveloped and is
13 accessed via an existing dirt road. Use of this site for the SVC would require a slightly longer
14 (1.4-mile) transmission line to connect to the existing Suncrest Substation. Figure 20-1 shows
15 the transmission line alignment under the Northeast Site Alternative.

16 **Impact Analysis**

17 Relative to the Proposed Project, the Northeast Site Alternative would reduce some biological
18 resources impacts. As shown in Figure 20-2, the Northeast Site Alternative is located
19 predominantly in chamise chaparral. No part of the site is mapped as California Buckwheat
20 Scrub habitat. In this respect, the Northeast Site Alternative would reduce potential impacts
21 on Hermes copper butterfly habitat. As described in Chapter 7, *Biological Resources*, Hermes
22 copper butterfly is a candidate for listing as Federally Endangered which depends on its host
23 plant, spiny redberry (*Rhamnus crocea*) as a larval food source, and nectars mainly on
24 California buckwheat. Given that buckwheat would not be a dominant plant in the Northeast
25 Site Alternative location, suitable habitat for Hermes copper butterfly is unlikely to be
26 present.

27 In other ways, the Northeast Site Alternative would increase environmental impacts
28 compared to the Proposed Project. As noted above, the Northeast Site Alternative would
29 require a longer (1.4-mile) transmission line component to connect the SVC to the existing
30 Suncrest Substation, some of which would go through relatively undisturbed habitat.
31 Additional trenching for installation of the longer underground transmission line would
32 result in additional air and greenhouse gas emissions, and greater potential for disturbance
33 of biological resources (including wetlands) or buried cultural resources.



Prepared by:





Source: SCWA 2015a

Existing Roads	Alternative Overhead Transmission Line	Alternative SVC Areas
SVC Access Road	Approximate Overhead and Underground Transmission Route	Northeast Site Area
Unnamed Road Rerouted	Proposed Project Area	Northeast Site Footprint
	Proposed Project Footprint	Suncrest Substation Area
		West Site Area
		West Site Footprint

**Figure 20-1
Alternative
Site Locations**

**Suncrest Dynamic Reactive
Power Support Project**

C:\Users\GIS\Documents\ArcGIS\PROJECTS\16018_CPUC_Suncrest\mxd\figures\ADEIR\Figure 20-2_Vegetation altis.mxd PG - 11/21/2016



Vegetation Communities

- | | |
|--|---|
| Bigberry Manzanita – Chamise Chaparral | Engelmann Oak-Coast Live Oak/Poison Oak/Grass Association |
| California Buckwheat Scrub | Non-native Grassland |
| Chamise Chaparral | Ruderal |
| | Urban/Developed |

- Project Area (limit of disturbance)
- Subject to repeated disturbance
- Alternative Transmission Lines
- Alternative SVC Areas

Figure 20-2
Vegetation Types
Alternatives

Suncrest Dynamic Reactive
Power Support Project

1 **20.3.3 Suncrest Substation Alternative**

2 **Characteristics of this Alternative**

3 Under the Suncrest Substation Alternative, the SVC would be installed within the existing
4 Suncrest Substation and, therefore, no transmission line would be required. San Diego Gas &
5 Electric (SDG&E) has indicated that there is room within the existing substation to construct
6 the SVC without expanding the substation footprint.^{1,2} Under this alternative, NEET West
7 would construct, own, and operate the SVC.

8 **Impact Analysis**

9 The Suncrest Substation Alternative would avoid virtually all of the potential environmental
10 impacts of the Proposed Project. Under the Suncrest Substation Alternative, there would be
11 no land disturbance, trenching, or installation of new structures outside of the existing
12 substation. As such, there would be no potential for impacts to aesthetics, biological
13 resources, cultural resources, geology and soils, or hydrology and water quality. The Suncrest
14 Substation Alternative would require use of some construction equipment and therefore
15 would generate some air emissions, greenhouse gas emissions, and noise; however, these
16 would all be substantially less than under the Proposed Project. Earth-moving construction
17 equipment would not be required under the Suncrest Substation Alternative.

18 **20.3.4 Overhead Transmission Line Alternative**

19 **Characteristics of this Alternative**

20 Under the Overhead Transmission Line Alternative, the SVC would be at the same location as
21 the Proposed Project, but the transmission line would be overhead instead of underground.
22 The overhead transmission line connecting the SVC to the existing Suncrest Substation would
23 be approximately 1 mile in length and would generally parallel Bell Bluff Truck Trail, as
24 shown on Figure 20-1. A 70- to 100-foot-wide transmission line right-of-way would be
25 required to account for the land needed for operations and maintenance, as well as
26 transmission line clearance requirements under CPUC General Order 95. This alternative
27 would include installation of approximately 17 tubular steel pole transmission structures
28 between the SVC and existing Suncrest Substation. The types of transmission line structures
29 would vary depending on location, and may include tangent, running angle, and dead-end
30 structures, but pole heights would range between 80 and 140 feet above the ground.

¹ SDG&E submitted a data response to CPUC Energy Division staff on April 15, 2016, that stated the footprint required to install the SVC device within Suncrest Substation would be 1.72 acres. Additional space would be needed for the 230-kV breaker area, access road, and working clearances, resulting in a total area requirement of 2.4 acres. SDG&E's response was to a CPUC data request to estimate the project footprint for the device and all associated new facilities that would achieve the same objectives achieved by NEET West's proposed facility but would be installed within Suncrest Substation.

² In its February 8, 2016, comment on the Notice of Preparation of this DEIR, SDG&E requested that an alternative be evaluated that locates a dynamic reactive device within Suncrest Substation and stated that such an alternative would be feasible. SDG&E submitted a project sponsor bid to CAISO to locate an SDG&E-owned dynamic reactive device within the Suncrest Substation based on SDG&E's determination that doing so was feasible.

1 **Impact Analysis**

2 Compared to the Proposed Project, the Overhead Transmission Line Alternative would
3 reduce impacts associated with trenching within Bell Bluff Truck Trail. These include
4 emissions from hauling of spoils, and traffic impacts from temporary closures of the roadway.
5 The Overhead Transmission Line Alternative would have greater aesthetic impacts than the
6 Proposed Project because the steel pole transmission structures would be visible from Bell
7 Bluff Truck Trail, as well as several nearby residences, and would contrast with the
8 surrounding landscape. By locating the poles outside the roadbed, the Overhead
9 Transmission Line Alternative would have greater biological and cultural resources impacts
10 compared to the Proposed Project. Other environmental impacts of the Overhead
11 Transmission Line Alternative would be similar to the Proposed Project.

12 **20.3.5 Summary of Alternatives Analysis and Comparison with the** 13 **Proposed Project**

14 Table 20-2 contains a summary of the alternatives analysis. The Proposed Project and
15 alternatives are ranked in terms of having the least overall impacts to the physical
16 environment. The No Project Alternative was assigned a rank of 1 because it would not result
17 in any impacts to the physical environment. The Suncrest Substation Alternative was
18 assigned a rank of 2, and the Proposed Project received a rank of 3.

19 **20.4 Environmentally Superior Alternative**

20 An EIR must identify the environmentally superior alternative. Of the alternatives evaluated
21 in this DEIR, the No Project Alternative is the environmentally superior alternative because
22 it would avoid all construction- and operation-related impacts of the Proposed Project.
23 However, in cases when the No Project Alternative is the environmentally superior
24 alternative, an EIR must also identify an environmentally superior alternative from among
25 the other alternatives (State CEQA Guidelines Section 15126.6[e][2]). Accordingly, in
26 addition to the No Project Alternative, the Suncrest Substation Alternative is considered to
27 be the environmentally superior alternative.

28 As described above, the Suncrest Substation Alternative would avoid virtually all of the
29 environmental impacts of the Proposed Project. Because this alternative would be located
30 within an existing substation, substantial construction impacts to biological or cultural
31 resources would not occur. Likewise, the Suncrest Substation Alternative would have no
32 substantial impact on aesthetics or hydrology and water quality, and would avoid the need
33 for a transmission line. The Suncrest Substation Alternative would still generate some
34 construction-related emissions from transport of equipment and materials to the site and use
35 of construction equipment to install the SVC, but these emissions would be substantially less
36 than under the Proposed Project or any of the other alternatives.

1 **Table 20-2. Summary of Alternatives and Comparison to the Proposed Project**

Alternative	Characteristics	Relationship to Project Objectives	Impacts Compared to the Proposed Project	Rank
Proposed Project	<ul style="list-style-type: none"> ▪ NEET West would construct an SVC facility at the former Wilson Construction Yard and an approximately one-mile-long transmission line connecting the SVC to the existing Suncrest Substation 	<ul style="list-style-type: none"> ▪ Would meet all of the project objectives 	<ul style="list-style-type: none"> ▪ Would generate air and GHG emissions, noise, and limited traffic associated with Project construction ▪ Would impact biological resources due to site clearing and ground disturbance, including possible impacts to Hermes copper butterfly ▪ Could disrupt previously undiscovered, buried cultural resources from ground disturbance ▪ Would adversely affect existing visual quality of the Project site ▪ Would adversely affect existing drainage patterns at the site and increase potential for water quality impacts due to addition of impervious surface area to the site 	3
No Project Alternative	<ul style="list-style-type: none"> ▪ NEET West would not construct the SVC or transmission line 	<ul style="list-style-type: none"> ▪ Would not meet any of the project objectives 	<ul style="list-style-type: none"> ▪ Would avoid all environmental impacts associated with the Proposed Project 	1

Alternative	Characteristics	Relationship to Project Objectives	Impacts Compared to the Proposed Project	Rank
<p>Northeast Site Alternative</p>	<ul style="list-style-type: none"> ▪ NEET West would construct the SVC at an alternative site northeast of the Proposed Project site ▪ Alternative would require a longer (1.4-mile) transmission line compared to the Proposed Project, a portion of which would pass through relatively undisturbed habitat 	<ul style="list-style-type: none"> ▪ Would meet all of the project objectives 	<ul style="list-style-type: none"> ▪ Would increase air emissions, greenhouse gas emissions, energy consumption, and potential impacts to biological and cultural resources due to longer transmission line ▪ Would reduce potential for impacts to Hermes copper butterfly, as butterfly individuals and habitat would be less likely to occur on this site ▪ Would have similar aesthetic impacts, though the facility may be less visible from Bell Bluff Truck Trail and certain sensitive receptors, while possibly more visible from other locations ▪ Would have similar hydrology/water quality impacts associated with addition of impervious surface to the area ▪ Would impact ephemeral drainages within site footprint 	<p>5</p>

Alternative	Characteristics	Relationship to Project Objectives	Impacts Compared to the Proposed Project	Rank
Suncrest Substation Alternative	<ul style="list-style-type: none"> ▪ NEET West would construct the SVC within the existing Suncrest Substation ▪ No transmission line or expansion of existing substation footprint would be required 	<ul style="list-style-type: none"> ▪ Would meet all of the project objectives 	<ul style="list-style-type: none"> ▪ Would avoid virtually all of the environmental impacts associated with the Proposed Project ▪ No potential for impacts to aesthetics, biological and cultural resources, geology and soils, and hydrology and water quality ▪ Would emit some air emissions, greenhouse gas emissions, and generate noise, but these would all be substantially less than the Proposed Project 	2
Overhead Transmission Line Alternative	<ul style="list-style-type: none"> ▪ SVC would be constructed in same location as Proposed Project, but transmission line connecting SVC to existing Suncrest Substation would be above-ground rather than below-ground ▪ Would include installation of 17 tubular steel poles primarily along Bell Bluff Truck Trail 	<ul style="list-style-type: none"> ▪ Would meet all of the project objectives 	<ul style="list-style-type: none"> ▪ Assumed to generate similar or less air and greenhouse gas emissions, noise, and traffic from construction of steel poles compared to underground transmission line ▪ Would have the potential for additional impacts to unknown buried archaeological resources ▪ Would increase aesthetic/visual impacts, as steel pole transmission structures would be visible from roadway and nearby residences and would contrast with surrounding landscape ▪ Would increase biological resources impacts from installing poles outside roadway 	4

1 The Suncrest Substation Alternative would produce reactive power at the same level as the
2 Proposed Project and would meet all of the project alternatives. The Proposed Project is not
3 environmentally superior to the Suncrest Substation Alternative because it would have a
4 number of environmental impacts that could be avoided by the Suncrest Substation
5 Alternative. These impacts include biological and potential cultural resources impacts from
6 ground-disturbing activities for construction of the SVC and underground transmission line;
7 aesthetic impacts from the SVC and associated facilities; and stormwater/water quality
8 impacts from development of a new impervious surface. As the SVC would be placed within
9 the existing Suncrest Substation under the Suncrest Substation Alternative, there would be
10 no potential for any of these impacts under this alternative.

11 The other alternatives were not selected as the environmentally superior alternative for the
12 following reasons:

13 ▪ **Northeast Site Alternative.** The Northeast Site Alternative was not selected as the
14 environmentally superior alternative because it would have a number of impacts that
15 could be avoided by the Suncrest Substation Alternative. While it would reduce
16 impacts to Hermes copper butterfly compared to the Proposed Project, it would have
17 greater overall biological resources impacts by disturbing a previously undisturbed
18 site. Like the Proposed Project, it would involve constructing the SVC at a distance
19 from the existing Suncrest Substation and connecting it to the existing substation via
20 a transmission line, all of which would be avoided by the Suncrest Substation
21 Alternative.

22 ▪ **Overhead Transmission Line Alternative.** The Overhead Transmission Line
23 Alternative was not selected as the environmentally superior alternative because it
24 would have a number of impacts which could be avoided entirely by the Suncrest
25 Substation Alternative. As described above, by placing the SVC on the existing
26 Suncrest Substation, the Suncrest Substation Alternative would avoid the need for a
27 transmission line altogether. As such, the Suncrest Substation Alternative would
28 avoid the aesthetic impacts, possible biological resources impacts, and construction-
29 related emissions associated with constructing an overhead transmission line.

30

1

This page intentionally blank