

Lincoln Allen

From: Lincoln Allen
Sent: Thursday, February 21, 2019 10:49 AM
To: Lincoln Allen
Subject: FW: EXTERNAL:RE: Suncrest project fire safety

See confirmation below from James Pine (Assistant Fire Marshal for San Diego County Fire) regarding use of two 2,000 gallon water capacity tenders instead of a single 4,000 gallon tender as specified in the project's approved CFPP.

From: K Keenan
Sent: Wednesday, February 20, 2019 1:42 PM
To: Farkas, David
Subject: Fwd: Suncrest project fire safety

CAUTION - EXTERNAL EMAIL

Sent from my iPhone

Begin forwarded message:

From: Pine, James
Date: February 20, 2019 at 1:20:58 PM PST
To: K Keenan
Subject: RE: Suncrest project fire safety

Good Afternoon Keith,

We can accept two 2,000 gallon water tenders in lieu of one 4,000 gallon water tender.

Best Regards,

James Pine
Assistant Fire Marshal
San Diego County Fire
Office Hrs: M-Th 7-5:30
Sent from my iPhone

-----Original Message-----

From: K Keenan
Sent: Wednesday, February 20, 2019 12:35 PM
To: Pine, James
Subject: Re: Suncrest project fire safety

Good afternoon Deputy Fire Marshall Pine, I have been asked to reach out to you on behalf of the suncrest project in regards to the fire plan water tender

requirement. The fire plan states that the water tender will be of 4,000 gal capacity. The project is asking if they can have (2) 2,000 gal capacity water tenders instead. I am not sure if you can make adjustments or if it is a committee is required to change the fire plan. Thank you for your time.

Sent from my iPhone