

Lincoln Allen

From: Lincoln Allen
Sent: Monday, February 25, 2019 12:28 PM
To: Lincoln Allen
Subject: CFPP Addendum No. 2 and MPR #2 / Suncrest Construction Fire Prevention Plan (CFPP)

See confirmation below from James Pine (Assistant Fire Marshall for San Diego County Fire) regarding the use of 10lb 3A:40BC fire extinguishers on equipment instead of 20lb 3A:40BC. This change or minor project modification to the CFPP is due to the fact that the 20 lb extinguishers are difficult to mount safely on working equipment and the ten pound extinguishers are equally sufficient. Actual rating is 10lb 4A:80BC.

The Construction Fire Protection Plan (CFPP) Section 7.1.1 – Construction and Decommissioning Phase Risks / Fire Prevention Measures for all Construction Activities / Bullet point number 12 states that:

“All vehicles shall be equipped with a 20 pound, 3A-40BC Dry Chemical Fire Extinguisher...”

From: K Keenen
Sent: Monday, February 25, 2019 10:36 AM
To: David Farkas; Lincoln Allen; Steve Combs; Adrienne Charbonneau; D Hochart
Subject: EXTERNAL:Fwd: Suncrest emergency access

Sent from my iPhone

Begin forwarded message:

From: Pine, James
Date: February 25, 2019 at 10:20:16 AM PST
To: K Keenen
Subject: RE: Suncrest emergency access

That would be acceptable.

Best Regards,

James Pine
Assistant Fire Marshal
San Diego County Fire
Office Hrs: M-Th 7-5:30
Sent from my iPhone

-----Original Message-----

From: K Keenen
Sent: Monday, February 25, 2019 10:14 AM
To: Pine, James
Subject: Re: Suncrest emergency access

Deputy Fire Marshal Pine, the fire plan is calling for fire extinguishers on equipment to

be 20lb 3A:40BC, we were hoping to reduce the weight size to 10lb 3A:40BC min on equipment. Actual rating is 10lb 4A:80BC. The 20 lb extinguishers are difficult to mount safely on working equipment and I feel the ten pound is sufficient and still meets or exceeds to 3A:40BC requirement. Please let me know if that would be acceptable. Thank you.

Sent from my iPhone