

## PUBLIC UTILITIES COMMISSION

505 VAN NESS AVENUE  
SAN FRANCISCO, CA 94102-3298



November 20, 2017

Pat Adams, Principal Advisor  
Southern California Edison Company  
8651 Rush St., 2nd Floor  
Rosemead, CA 91770  
Email: Patricia.Adams@sce.com

**RE: Revised Data Request #10 - Certificate of Public Convenience and Necessity for the Riverside Transmission Reliability Project – Application No. A.15-04-013**

Dear Ms. Adams,

The California Public Utilities Commission's (CPUC) Energy Division CEQA Unit has completed its review of Southern California Edison's (SCE's) Application (A. 15-04-013) for a Certificate of Public Convenience and Necessity (CPCN) for the Riverside Transmission Reliability Project (RTRP) and SCE's responses to Data Requests #1 through #9.

The CPUC has identified additional data needs that are required to complete the description of alternatives and environmental resource assessment for the Subsequent Environmental Impact Report (EIR). These data needs are identified in the attached Request for Additional Data.

Information provided by SCE in response to this Request for Additional Data should be filed as supplements to Application A. 15-04-013. One set of responses should be sent to the Energy Division and one to our consultant, Panorama Environmental, in both hardcopy and electronic format. We request that SCE respond to this request no later than December 5, 2017. Please let us know if you cannot provide the information by this date. Delays in responding to these data needs will result in associated delays in preparation of the Subsequent EIR.

The Energy Division reserves the right to request additional information at any point in the application proceeding and during subsequent construction of the project should SCE's CPCN be approved.

Please direct questions related to this application to me at (415) 703-5484 or [Jensen.Uchida@cpuc.ca.gov](mailto:Jensen.Uchida@cpuc.ca.gov).

Sincerely,

A handwritten signature in blue ink that reads "Jensen Uchida".

Jensen Uchida  
Project Manager

Energy Division, CEQA Unit

cc: Mary Jo Borak, Supervisor  
Jack Mulligan, CPUC Attorney  
Jeff Thomas, Panorama Environmental, Inc.

# REQUEST FOR ADDITIONAL DATA: DATA NEEDS #10 FOR THE RIVERSIDE TRANSMISSION RELIABILITY PROJECT - APPLICATION (A. 15-04-013)

---

## REPORT OVERVIEW

The California Public Utilities Commission (CPUC) has identified an area where more information is needed to prepare a complete and adequate analysis of the proposed project in accordance with the requirements of the California Environmental Quality Act (CEQA), as follows:

Table 1: SCE Riverside Transmission Reliability Project Application 15-04-013 Data Needs #10	
Number	Data Need
<b>Alternatives</b>	
ALT-1	<b>Provide a revised preliminary engineering layout for Alternative 4 that locates the underground duct banks within Landon Drive, versus on the adjacent property to the south side of the road (refer to attached map).</b> Southern California Edison has recently indicated that this is feasible. The revised preliminary engineering should include the potential locations for vaults, tubular steel riser pokes, and lattice steel towers as indicated on the attached map.












# Riverside Transmission Reliability Project

Alternative 4  
Wineville - Landon Road


Map 1 of 2

## Legend

-  Tubular Steel Pole (TSP)
-  Lattice Steel Tower (LST)
-  Vault
-  Alternative 4 Wineville Landon Rd
-  Alternative 4 GDAD
-  2013 Alignment



Scale = 1:3,000



Aerial Imagery: 2015  
Date Created: 7/19/2017

