

A.13-09-014 SDG&E 11/14/14 Response
Salt Creek Substation Project PTC
Energy Division Request #20 on 11/3/14
ED-SDGE-020

Please note that the items highlighted in yellow are confidential pursuant to CPUC Section 583, General Order 66-C and any applicable Non-Disclosure Agreements; Confidential Non-Public Information exempted from disclosure under federal and state law.

DUE NOVEMBER 14TH

#	Data Request #	Request	SDG&E Response
9.	DR 16.2-1	Define the approximate size of the detention basin for the 230/12-kV substation. Will a larger detention basin be required relative to the proposed project?	Yes – a larger detention basin would likely be required; we estimate the 230/12 kV substation basin to be approximately 20,000 square feet relative to the estimated 15,560 square feet for the 69/12 kV substation basin.