



Sycamore- Penasquitos 230 kv Transmission Line Draft EIR

1 message

Rubalcava, Eric <ERubalcava@sandiego.gov>

Mon, Sep 28, 2015 at 1:23 PM

To: "sycamorepenasquitos@panoramaenv.com" <sycamorepenasquitos@panoramaenv.com>

Cc: "Amen, Rania" <RAmen@sandiego.gov>, "jeff.thomas@panoramaenv.com" <jeff.thomas@panoramaenv.com>

Jeff, attached are our comments for the water review side of City of San Diego Public Utilities, Wastewater comments to follow. Thanks.

ES-52, There needs to be language more specific than "mitigation", there needs to be language that project will protect underground water and sewer utilities in place or relocate existing utilities prior to 230-kV Transmission Line Work.

4-17, There needs to be language in place in regards to expected water usage post construction, where the expected service will come from, and what day to day demand variations will be.

4-17 There needs to be language on protecting water lines in place or relocating prior to 230-kV Transmission Line Work.

4-17 Identify specific water lines that will be potentially impacted for each stretch of work. The ability to supply fire flow depends on impacted water utilities. Every water main out of service due to project will result in reduce fire flow supply for the region and water hydrants out of service. These impacts need to be identified to develop a contingency plan for water supply and emergency fire flow.

Eric Rubalcava, P.E., MPA

Senior Civil Engineer | EPM Division | Public Utilities Department

9192 Topaz Way | San Diego, CA 92123

Ph. (858) 654-4284 | Erubalcava@sandiego.gov

