



Sycamore Penasquitos

1 message

Faramarzi, Mike <MFaramarzi@sandiego.gov>

Wed, Oct 7, 2015 at 7:42 AM

To: "sycamorepenasquitos@panoramaenv.com" <sycamorepenasquitos@panoramaenv.com>

Cc: "Wedeking, Matthew" <MWedeking@sandiego.gov>, "Amen, Rania" <RAmen@sandiego.gov>

Hi Jeff; We looked at the draft EIR and since we don't have the selected alignment yet and we do not see detail drawings, we do not have a substantial comment that would be really important at this point. We may have some in the future if we have the detail drawings. We just have this general comment for you.

Both the alternative and proposed transmission lines share similar alignments with existing sewer mains and trunk sewers. We prefer to have 10-foot horizontal separation between sewer mains and any other utility infrastructure. Separations of less than 10 feet must be approved by the Senior Civil Engineer of Water and Sewer Development Section, Public Utilities Department.

Thanks

Mike Faramarzi

Senior Civil Engineer

Public Utilities Department

[858-614-4518](#)

SDGE EIR.PDF
567K