

**ORIGINAL**Decision No. 50122

BEFORE THE PUBLIC UTILITIES COMMISSION OF THE STATE OF CALIFORNIA

Richard H. Duncan, et al.,

Complainants,

vs.

Donaghy Water Company, et al.,

Defendants.

Case No. 5498  
(Petition for Modification  
of Decision No. 49814)OPINION AND ORDER

Susan M. Donaghy, operator of Donaghy Water Company, which supplies water for domestic use to some 80 residents of Donaghy Tract, near Glen Ellen, has filed a petition seeking modification of a Commission decision so as to permit her to use 2-inch pipe instead of 3-inch pipe in completing certain improvements ordered by the Commission. (Dec. No. 49814, March 23, 1954.) The other improvements specified by the Commission have been installed.

The Commission has been advised by its Hydraulic Section, following an investigation of the system, that the use of 2-inch rather than 3-inch pipe is not objectionable in the circumstances.

Therefore, good cause appearing, IT IS ORDERED that ordering paragraph "a." of Decision No. 49814 herein be and it is modified to read as follows:

- "a. Connect the 245-foot well to the 60,000-gallon storage tank by installing approximately 400 feet of not less than 2-inch diameter pipe as indicated on the diagram, Chart 3-A, in Exhibit No. 2 herein."

Except as modified herein said Decision No. 49814 shall otherwise be and remain in full force and effect.

The effective date of this order shall be the date hereof.

Dated at San Francisco, California, this  
7th day of June, 1954.

Richard E. Mitchell  
PRESIDENT

Justus J. Cassel

Herbert Potts

Gene Higgins

COMMISSIONERS