

ORIGINALDecision No. 55236

BEFORE THE PUBLIC UTILITIES COMMISSION OF THE STATE OF CALIFORNIA

In the Matter of the Application)	
of Pacific Water Co., a California)	
corporation, for a Certificate of)	
public convenience and necessity)	Application No. 38189
under Section 1001 of the Public)	(First Supplemental)
Utilities Code for land adjoining)	
its Westside Water System, San)	
Bernardino County, California.)	

FIRST SUPPLEMENTAL OPINION AND ORDER

Prior to December 18, 1956, applicant had authority from this Commission to furnish domestic water to a parcel of land in San Bernardino County, containing approximately 550 acres in Sections 5, 7, 8, and 17, Township 9 North, Range 2 West, S.B.B.&M.^{1/} This service area was designated by applicant as its Westside Water System. By Decision No. 54278, dated December 18, 1956, in Application No. 38189, this authority was extended to include all of Sections 8, 9, 10, 15, 16, and 17, Township 9 North, Range 2 West, S.B.B.&M., in said county, subject to the conditions that:

"Applicant shall not extend service beyond its existing Westside service area to any area other than (1) the Lenwood area, (2) original Tract No. 4552, and (3) the improved lots along the existing transmission line east of Tract No. 4552 and south of U. S. Highway No. 66, without further order of this Commission. Such order may be applied for by supplemental application or applications, which shall include a proper showing as to an adequately

^{1/} Decision No. 41619, dated May 25, 1948, in Application No. 28642; Decision No. 50095, dated June 1, 1954, in Application No. 35290.

engineered water system, an adequate water supply, and adequate financing."

On May 10, 1957, applicant filed its First Supplemental Application No. 38189 wherein it requests authority to serve water to Tract No. 5607, in said county, located in Sections 4, 8, and 9 of Township 9 North, Range 2 West, S.B.B.&M. (Exhibit A on First Supplemental Application No. 38189). This tract, the major portion of which is in applicant's certificated Westside area and a small portion of which is outside of, but contiguous to said service area, is being subdivided by Depue, Duitsmand and Aday and consists of 51 residential lots (Exhibit B on the First Supplemental Application No. 38189).

The presently certificated service area contains in the east, Tract 4552, which has its own wells and water system not connected to the rest of the system. Tract No. 5607 is in the west end of the Westside service area and approximately 2,000 feet from applicant's three wells in that area. Well No. 1 with its pumping equipment is capable of producing 237 gallons of water per minute. Well No. 2, formerly producing with its pumping equipment, 600 gallons of water per minute, has been placed in stand-by service, and will have a 15 hp pump capable of producing 150 gallons of water per minute. Applicant has a new well 220 feet deep, designated as Well No. 4, in the vicinity of Well No. 2, which has produced 1,227 gallons of water per minute with a 9-foot 6-inch draw-down from a static level of 44-foot 6-inches. It has taken the 60 hp pump from Well No. 2 and placed it in Well No. 4. This well and pump now have a production capacity of 600 gallons per minute. These facilities give the

system a supply of 837 gallons of water per minute, together with a stand-by supply of 150 gallons of water per minute. Applicant has a 100,000-gallon storage tank together with pressure tanks.

The wells will be connected to Tract No. 5607. Wells 2 and 4 will be connected through the existing distribution system and the storage tank. Well No. 1, which also feeds into the storage tank, will be connected to the northwest corner of Tract No. 5607 by an 8-inch transite pipe and the tract will be served through 8-, 6-, and 4-inch mains (Exhibit B on the First Supplemental Application No. 38189). The transmission, feeder and service pipes in the tract will be paid for by the subdivider, pursuant to applicant's standard contract on file with the Commission for main extensions to serve subdivisions. Well No. 4 has been paid for by applicant.

There are in the Westside system, exclusive of Tract No. 4552 and customers east thereof, 335 metered service connections. There are 51 lots in Tract No. 5607. Applicant will have a total water supply in this area at the outset of service in said tract of 1,037 gallons per minute.

Upon the allegations of the First Supplemental Application No. 38189, together with the information furnished by the applicant in its letter to the Commission dated May 28, 1957, it appears and we find that applicant has an adequately engineered water system, an adequate water supply and adequate financing to enable it to serve Tract No. 5607.

Now, therefore, good cause appearing,

IT IS ORDERED that pursuant to paragraph (1) (b) of the order of Decision No. 54278, dated December 18, 1956, in

Application No. 38189, Pacific Water Co., a California corporation, may furnish domestic water service to Tract No. 5607 located in Sections 4, 8, and 9, Township 9 North, Range 2 West, S.B.B.&M., provided that the costs of the installation in the subdivision, other than the meters, be advanced by the subdivider and refunded by the applicant pursuant to its filed rule concerning extensions to serve subdivisions.

IT IS FURTHER ORDERED that Pacific Water Co. is authorized and directed to revise within thirty days after the effective date of this order, its presently filed tariff schedules and tariff service area map applicable to its Westside tariff area, in accordance with the procedure prescribed by General Order No. 96, to provide for the application of said tariff schedules in the area being certificated by this order. Such revised tariff sheets shall become effective upon five days' notice to the Commission and the public after filing as hereinabove provided.

The effective date of this order shall be twenty days after the date hereof.

Dated at San Francisco, California, this 9th day of July, 1957.

Paul L. Luterer President
W. H. ...
H. ...
C. L. Fox Commissioners