

Decision No. 56160

ORIGINAL

BEFORE THE PUBLIC UTILITIES COMMISSION OF THE STATE OF CALIFORNIA

Application of Thelma B. Wood for)	
authority to increase rates of)	Application No. 37377
Campton Heights Water Service.)	(Petition for Modification)
<hr/>	

FIRST SUPPLEMENTAL OPINION AND ORDER

Thelma B. Wood, ^{1/} doing business as Campton Heights Water Service, by petition filed November 20, 1957, seeks an order modifying certain requirements of Decision No. 53276, dated June 26, 1956. Further, applicant requests approval, if required by the Commission, of an agreement covering the lease of a well and certain pumping equipment owned by John Rooney and Logan Rooney, his wife.

By ordering paragraph 3 of said Decision No. 53276, applicant was directed to have installed a new well and associated pumping facilities of approximately 300 g.p.m. capacity and additional water storage of approximately 50,000 gallons. These installations were directed to be completed and in operation by December 1, 1956, which date was subsequently extended to September 13, 1957.

The required additional supply of 300 g.p.m. is requested by applicant to be modified to correspond to the delivery capacity of the facilities proposed to be leased, which is stated to be 150 g.p.m.

^{1/} Sometimes herein called applicant.

Applicant alleges that the delivery of 150 g.p.m. is adequate to supply the system during periods of peak demand even in the event of failure of the existing sources of supply. Further, the recently installed storage capacity of 250,000 gallons is a further protection against interruption of service.

With respect to applicant's request for approval of the lease agreement, no Commission action is required. However, any amounts paid or payable by applicant under the terms of the proposed lease will be subject to further review by the Commission in any future rate proceeding.

The Commission having considered the request of applicant and being of the opinion that Decision No. 53276 should be modified, and that a public hearing in the matter is not necessary, therefore,

IT IS HEREBY ORDERED that paragraph numbered 3 of the order in Decision No. 53276 shall be modified to read as follows:

3. In addition to the system water supply available and the water storage capacity installed and connected to applicant's system prior to June 26, 1956, applicant shall procure or develop a water supply of not less than 150 g.p.m., and shall have installed a water storage capacity of approximately 250,000 gallons, such additions and improvements to be completed and in normal operation by not later than February 28, 1958. Further, applicant shall notify this Commission in writing on or before March 10, 1958 of the date or dates of the completion of such improvements or facilities.

IT IS HEREBY FURTHER ORDERED that in all other respects said Decision No. 53276 shall remain in full force and effect.

The effective date of this order shall be twenty days after the date hereof.

Dated at San Francisco, California, this 28th day of January, 1958.

[Handwritten signature]

President

[Handwritten signature]

[Handwritten signature]

[Handwritten signature]

[Handwritten signature]

Commissioners