

62355

Decision No. _____

ORIGINAL

BEFORE THE PUBLIC UTILITIES COMMISSION OF THE STATE OF CALIFORNIA

In the Matter of the Application of
 Aztec Water Company, Inc., a California
 Corporation, for a Certificate that the
 Present and Future Public Convenience
 and Necessity Require and Will Require the
 Extension of the Water System and Service
 Lines of Applicant into, adjacent and
 adjoining Areas in the Unincorporated
 Community known as Apple Valley, in
 the County of San Bernardino, State of
 California under Section 1001 of the
 Public Utilities Code of the State of
 California.

Application No. 42038

ORDER ON PETITION FOR MODIFICATION

It appearing that Decision No. 60314 provided, in part,
 as follows:

- "2. a. That applicant shall, within 180 days after the effective date hereof, install and place in operation a 10-HP booster pump of not less than 140 gallons per minute capacity at the southeast corner of Lot 61, Tract No. 5745, and shall report to the Commission in writing that such has been accomplished within ten days thereafter.
- "b. That applicant shall, within 180 days after the effective date hereof, secure a standby source of water supply with a capacity not less than that of the present well, and shall report to the Commission in writing that such has been accomplished, within ten days thereafter.",
 and

It further appearing that on June 21, 1961, applicant
 filed a petition for modification herein, which petition alleged:

1. In lieu of the 10-HP booster pump ordered by paragraph 2.a. to be installed at the southeast corner of Lot 61, Tract No. 5745, the utility proposes to replace the existing 15-HP pumping unit at the northeast corner of Tract No. 4286 with a 25-HP booster pump. The proposed installation will increase the output of water and will provide pressures which will meet the requirements set forth in Section 11.3 of General Order No. 103.

- 2. The requirement of paragraph 2.b., to secure a standby source of supply is proposed to be met by a new well for which the utility has made arrangements to have drilled on Lot 93 in Tract No. 3787, and

It further appearing that applicant has requested an appropriate modification of the requirement for installation of a booster pump on Lot 61, Tract No. 5745, and

It further appearing that the time allowed for installing the booster pump and the standby supply has expired and applicant has requested an extension of time within which to enlarge its existing booster pumping facilities and obtain a standby supply,

Now, therefore, IT IS ORDERED that ordering paragraph 2 of Decision No. 60314 is amended as follows:

- 2.a. That applicant shall, prior to September 1, 1961, install and place in operation a 25-HP booster pumping unit of not less than 500 gallons per minute capacity to replace the existing 15-HP booster pump which delivers water into the distributing system from the 60,000 gallon tank located at the northeast corner of Tract No. 4286. Applicant shall, within ten days thereafter, notify the Commission in writing of the date the 25-HP booster pump is placed in operation.
- b. That applicant shall, prior to January 1, 1962, secure a standby source of water supply with a capacity not less than that of the present well, and shall report to the Commission in writing that such has been accomplished, within ten days thereafter.

In all other respects Decision No. 60314 shall remain in full force and effect.

The effective date of this order shall be the date hereof.

Dated at San Francisco, California, this 10th day of AUGUST, 1961.

[Signature]
President
[Signature]
[Signature]
George T. Hoover
[Signature]
Commissioners