

ORIGINAL

Decision No. 72262

BEFORE THE PUBLIC UTILITIES COMMISSION OF THE STATE OF CALIFORNIA

ALEXANDER TIMBER CO., INC. Complainant, vs. REYNOLDS WATER COMPANY, INC. Defendant	} } }	Case No. 8404
--	-------------	---------------

SUPPLEMENTAL ORDER

Ordering Paragraph 2 of Decision No. 71530, dated November 9, 1966, in C-8404 requires defendant, within 90 days after the effective date of the order, to construct and place in operation either a storage tank, a standpipe, or a pressure reducing valve to facilitate the flow of water to complainant's subdivision.

In a letter received February 17, 1967, the utility requests that the required capacity of the storage tank be reduced from 30,000 gallons to 18,000 gallons. An 18,000-gallon tank is tentatively available at considerable savings.

It appears that an 18,000-gallon tank should be adequate to serve the present and potential customers in the Parkwood Subdivision in the foreseeable future; therefore,

IT IS ORDERED that:

Paragraph 2 of Decision No. 71530 is modified to read as follows:

"On or before June 1, 1967, defendant, at its own expense, shall construct and place in operation and file in this proceeding written notice of completion of one of the following three installations to serve Parkwood Subdivision:"

IT IS FURTHER ORDERED that:

Paragraph 2a of Decision No. 71530 is modified to read as follows:

"a. A storage tank of at least 18,000-gallon capacity, together with automatic float valve or altitude valve of at least 1½-inch diameter to replace the present 2-inch pressure reducing valve."

Dated at San Francisco, California, this 11th day of APRIL, 1967.

[Signature]
President

[Signature]

[Signature]

[Signature]

[Signature]
Commissioners