

ds/nb

ORIGINAL

Decision No. 75039

BEFORE THE PUBLIC UTILITIES COMMISSION OF THE STATE OF CALIFORNIA

Application of JENSEN WATER CO.,
a California corporation, to
extend service outside present
certificated area.

Application No. 50137
(Filed April 3, 1968)

SUPPLEMENTAL ORDER

By letter dated September 11, 1968, applicant requests to be relieved of the requirement of ordering paragraph 3(d) of Decision No. 74497, dated August 6, 1968, requiring the replacement of control wires between its reservoir and pump on the basis that such wires are unnecessary because system water pressures have been adequately maintained by the use of a pressure system for the past two years.

The Commission staff engineer's investigation shows that adequate pressures are being maintained without the control wires.

The Commission finds that applicant's request should be authorized.

IT IS ORDERED that subparagraph 3(d) is deleted from Decision No. 74497.

The effective date of this order shall be the date hereof.

Dated at San Francisco, California, this 3rd day of DECEMBER, 1968.

William Lyons Jr.
President
William W. Bennett

August
Paul P. Morrison
Commissioners

Commissioner Peter E. Mitchell, being necessarily absent, did not participate in the disposition of this proceeding.