

ORIGINAL

Decision No. 72531

BEFORE THE PUBLIC UTILITIES COMMISSION OF THE STATE OF CALIFORNIA

In the Matter of the Application of)
James R. Mills)
doing business as)
SNOBOWL WATER COMPANY)
Under Section 454 of the Public)
Utilities Code for Authority to)
Increase Rates for Water Service.)

Application No. 49985
(Filed January 31, 1968)

SUPPLEMENTAL ORDER

Decision No. 74644, dated September 4, 1968, in Ordering Paragraph No. 5 provided that applicant shall not furnish water service outside his present Snobowl service area and shall not provide water service to more than 25 customers without further order of this Commission. This order was based on a finding that applicant's water supply and storage would not adequately serve more than 25 customers.

In a letter dated April 23, 1970, applicant presents evidence of an improved water supply. R. F. Walter, Civil Engineer of Jorgenson-Tolladay Engineers, made a 72-hour pump test which shows a water production capacity of approximately 35 gallons per minute for the No. 2 well which has been equipped with a 15-hp pump. A 10,000-gallon storage tank has been moved to a higher location and a 12,500-gallon storage tank installed adjacent to it with the two tanks interconnected.

Applicant has installed water mains to serve the 18 parcel Snobowl Subdivision Unit No. 2 and in his letter dated May 14, 1970 states that if authority is granted for the proposed service to

55 lots a standard form of main extension agreement will be executed in accordance with Rule No. 15. The installed pipe is adequate to serve the proposed area. A booster pump will be installed to serve the high level lots when service is requested. A revised map of the installed pipe will be made a part of the record of this proceeding as Exhibit No. 3.

A staff engineer has reviewed applicant's request and made a field investigation of applicant's water plant. It is his recommendation that the Snobowl Water Company be authorized to increase its service from 25 to 55 customers.

IT IS ORDERED that the water service restriction ordered in Decision No. 74644 be raised from 25 to 55 customers and the effective date of this order shall be the date hereof.

Dated at San Francisco, California, this 28th day of JULY, 1970.

[Signature] Chairman
[Signature]
[Signature]
[Signature] Commissioners