

ORIGINAL

Decision No. 86478

BEFORE THE PUBLIC UTILITIES COMMISSION OF THE STATE OF CALIFORNIA

PAUL CLIFFORD MILLIKEN,

Complainant,

vs.

ANTELOPE VALLEY WATER COMPANY and
DOMINGUEZ WATER CORPORATION,

Defendants.

Case No. 9787
(Filed August 26, 1974)

ORDER MODIFYING DECISION NO. 85675

Decision No. 85675, dated April 13, 1976, ordered defendant to constrict customer meters with an orifice that reduced the flow capability of the meters to less than five gallons per minute. This procedure was implemented because the available potable water supply was less than 40% of normal summer demands.

The utility, by letter dated September 15, 1976, has informed the Commission that customer demands have been reduced sufficiently to enable the utility to adequately serve present customers under normal operating conditions. In addition, a new permanent adequate water supply will be available in July, 1977.

The Commission staff has confirmed the above information, therefore, there is presently no need to continue restricting with orifices the water use of defendants' customers. The moratorium on adding customers imposed by defendants' Advice Letter No. 21 and continued by Decision No. 83995, however, will remain in effect.

Due to the current inconvenience to the customers, the effective date of this order will be made the date hereof.

IT IS THEREFORE ORDERED that Ordering Paragraphs 4 and 6 in Decision No. 85675 are rescinded and that defendant remove all orifices restricting customer flows.

The effective date of this order is the date hereof.

Dated at San Francisco, California, this 5th day of OCTOBER, 1976.

[Signature] President
William Aguona Jr.
Vernon L. Sturgeon
Flora
Phil Batminal Commissioners