

ddb

Decision No. 87282

ORIGINAL

BEFORE THE PUBLIC UTILITIES COMMISSION OF THE STATE OF CALIFORNIA

JACK D. NELSON & RICHARD B. GIVANS,)

Complainants,)

vs.)

HONOR OAK WATER COMPANY,)

Defendant.)

Case No. 10274
(Filed March 1, 1977)

O P I N I O N

The complaint alleges an excess of sand, rust, and calcium in the drinking water provided by defendant's water system and a lack of water pressure at certain lots. It is suggested that a sand filter be installed and that the water be tested by chemical analysis.

Defendant's witness advised that the water has been certified as safe for human consumption although calcium is present in all water obtained from its source of supply. Defendant agreed to flush out its mains and to uncover portions of its system and to locate and replace worn or deteriorated mains.

Pursuant to Rule 13.2 of the Commission's Rules of Practice and Procedure, complainants and defendant consented to the Expedited Complaint Procedure and waived the presence of a court reporter and a record of the hearing and findings of fact and conclusions of law. This matter was heard on April 14, 1977 by Examiner Fraser.

O R D E R

IT IS ORDERED that:

1. Within thirty days of the effective date of this order, Honor Oak Water Company shall flush the mains and extensions serving the fourteen homes on the lower portion of its system and will open mains and connections where necessary to remove accumulated sand or rust.

2. Defendant will uncover its mains and extensions in the area noted to the extent necessary to determine the age and condition of the pipes which will be replaced where needed with plastic or copper inserts.

The effective date of this order shall be twenty days after the date hereof.

Dated at San Francisco, California, this 3rd day of May, 1977.

Robert Batemanich

President

William J. Leguina

Leguina L. Leguina

Richard D. Howell

Commissioners

A.54540

APPENDIX A

NOTICE OF DETERMINATION

TO: ☒ Secretary for Resources
1416 Ninth Street, Room 1311
Sacramento, CA 95814

FROM: (Lead Agency)

☐ County Clerk
County of _____

SUBJECT: Filing of Notice of Determination in compliance with Section 21108 or
21152 of the Public Resources Code

Project Title	
Jurupa-Mira Loma Jurupa-Vista 220 kv Transmission Lines	
State Clearinghouse Number (If submitted to State Clearinghouse) 75061714	
Contact Person	Executive
Phillip E. Blecher, Director	Telephone Number (415) 557-1487
Project Location Mira Loma and Vista Substations near Riverside, California	
Project Description Application by Southern California Edison Company to construct 220 kv transmission lines from a proposed Jurupa Substation to existing Mira Loma and Vista Substations.	

This is to advise that the California Public Utilities Commission
(Lead Agency)

has made the following determinations regarding the above-described project:
as modified

1. The project ~~has been~~ ☒ approved by the Lead Agency.
☐ disapproved
2. The project ☒ **modified** will have a significant effect on the environment.
☐ will not (See Decision No. 87280 attached)
3. ☒ An Environmental Impact Report was prepared for this project pursuant to the provisions of CEQA.
☐ A Negative Declaration was prepared for this project pursuant to the provisions of CEQA. A copy of the Negative Declaration is attached.

Date Received for Filing

Signature Phillip E. Blecher
Executive Director

Title

Date