

**PACIFIC GAS AND ELECTRIC COMPANY
General Rate Case 2011 Phase I
Application 09-12-020
Data Response**

PG&E Data Request No.:	DRA_177-06		
PG&E File Name:	GRC2011-Ph-I_DR_DRA_177-Q06		
Request Date:	March 4, 2010	Requester DR No.:	DRA-177-TXB
Date Sent:	March 17, 2010	Requesting Party:	DRA
PG&E Witness:	Redacted	Requester:	Truman Burns

SUBJECT: FOSSIL AND OTHER GENERATION OPERATIONS COSTS

QUESTION 6

Referring to p. WP 5-79, Ins. 19 and 24, please provide workpapers explaining why PG&E increased the contingency percentage from 15% to 25% for Gateway.

ANSWER 6

PG&E based its Gateway decommissioning contingency percentage on the percentage used in its 2009 Nuclear Decommissioning Cost Triennial Proceeding for Redacted and Humboldt Bay Unit 3.