From: Meadows, James L

Sent: 12/13/2010 7:03:00 PM

To: Nwamu, Chonda (Law) (/O=PG&E/OU=Corporate/cn=Recipients/cn=CJN3); Kiraly, Gregory (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=GKK6); Lokey, Felecia K (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=FKL3); DeRosa, Darleen (/O=PG&E/OU=Corporate/cn=Recipients/cn=DDDR); Meadows, James L (/O=PG&E/OU=Corporate/cn=Recipients/cn=J7M2); Dietz, Sidney (/O=PG&E/OU=Corporate/cn=Recipients/cn=SBD4); Moniz-Witten, Tanya (/O=PG&E/OU=Corporate/cn=Recipients/cn=TDM0); McDonagh, Colin (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=C1MS); 'marcel@turn.org' (marcel@turn.org); Miller, Suzy (/O=PG&E/OU=Corporate/cn=Recipients/cn=SLMc); Mitchell, Lavern (/O=PG&E/OU=Corporate/cn=Recipients/cn=LRM4); 'Roberts, Thomas' (thomas.roberts@cpuc.ca.gov); Jenab, Reza (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=RXJS); 'tcr@cpuc.ca.gov' ('tcr@cpuc.ca.gov'); 'Gupta, Aloke' (aloke.gupta@cpuc.ca.gov); 'Erich W. Gunther' (erich@enernex.com); 'mtoney@turn.org' ('mtoney@turn.org'); Redacted
Redacted
'christopher.danforth@cpuc.ca.gov' (christopher.danforth@cpuc.ca.gov); 'David.Hungerford@energy.ca.gov' ('David.Hungerford@energy.ca.gov')

Cc: 'Stephen C Hoefer' (shoefer@csc.com); Redacted
Redacted

Bcc:

Subject: PG&E update to the TAP

To the PG&E Technology Advisory Panel: our discussion last week included the issue affecting approximately 4,700 commercial / industrial grade meters (KV2C) that require a firmware update to resolve a time synchronization error. This note is to update the technical elements required in that effort. PG&E began the process of applying this firmware to the meters the day after our meeting last week. Some of the meters will require the patch to be applied directly by a technician to the extent network connectivity is not satisfactory for a firmware deployment.

As of Monday, December 13:

Attempted over the air:		4,548
Resolved so far:	4,455 (98%)	
Required local application of firmware upgrade:		196
Resolved so far:	58 (30%)	
Total required:		4,744
Completed so far:	4,513 (95%)	

Jim