

From: Cherry, Brian K
Sent: 2/4/2011 12:56:14 PM
To: 'richard.clark@cpuc.ca.gov' (richard.clark@cpuc.ca.gov)
Cc: Horner, Trina (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=TNHC);
'michael.robertson@cpuc.ca.gov' (michael.robertson@cpuc.ca.gov);
'rst@maildmz02.pge.com' (rst@maildmz02.pge.com); 'jmh@maildmz02.pge.com'
(jmh@maildmz02.pge.com)
Bcc:
Subject: Re: CPUC Directive of 12-16-10

Richard - I have been told the line numbers you have identified are correct. We have not, however, sent you a confirming letter. If you would like a confirming letter, we will have one prepared for you. Just let me know.

From: Cherry, Brian K
Sent: Friday, February 04, 2011 12:20 PM
To: 'richard.clark@cpuc.ca.gov' <richard.clark@cpuc.ca.gov>
Cc: 'jmh@maildmz02.pge.com' <jmh@maildmz02.pge.com>; 'rst@maildmz02.pge.com' <rst@maildmz02.pge.com>; 'michael.robertson@cpuc.ca.gov' <michael.robertson@cpuc.ca.gov>
Subject: Re: CPUC Directive of 12-16-10

Let me check.

From: Clark, Richard W. [mailto:richard.clark@cpuc.ca.gov]
Sent: Friday, February 04, 2011 12:19 PM
To: Cherry, Brian K
Cc: Julie Halligan <jmh@maildmz02.pge.com>; Raffy Stepanian <rst@maildmz02.pge.com>; Robertson, Michael <michael.robertson@cpuc.ca.gov>
Subject: CPUC Directive of 12-16-10

Brian – PAC sent you a directive on 12-16-10 to reduce pressure by 20% in lines with pre 1962 installed, 30 inch, non-hydro tested pipe segments.

My notes reflect you took that reduction on three lines - 131, 132 and 153. Two questions:

1. Do I have the correct line numbers?
2. Did you ever respond in writing?

Richard W. Clark

Director

Consumer Protection & Safety Division