

From: Clanon, Paul
Sent: 2/2/2011 11:26:42 AM
To: Cherry, Brian K (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=BKC7)
Cc: Bottorff, Thomas E (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=TEB3)
Bcc:
Subject: Re: RE: RE:

Let's talk. Call me at 703 3808?

On Feb 2, 2011, at 11:24 AM, "Cherry, Brian K" <BKC7@pge.com> wrote:

How about "received a letter" and we will send it to you in an hour ?

From: Clanon, Paul [<mailto:paul.clanon@cpuc.ca.gov>]
Sent: Wednesday, February 02, 2011 11:23 AM
To: Cherry, Brian K
Cc: Clanon, Paul; Bottorff, Thomas E
Subject: Re: RE:

We changed it in this version. Got a suggestion?

On Feb 2, 2011, at 11:22 AM, "Cherry, Brian K" <BKC7@pge.com> wrote:

What about the "has received information" issue ?

From: Clanon, Paul [<mailto:paul.clanon@cpuc.ca.gov>]
Sent: Wednesday, February 02, 2011 11:10 AM
To: Cherry, Brian K; Bottorff, Thomas E
Subject: RE:

We want to keep the list in Paragraph 1.

Dear Mr. Johns:

The California Public Utilities Commission ("Commission") has received information from Pacific Gas and Electric Company ("PG&E") regarding planned and unplanned increased pressurization events over the Maximum Allowable Operating Pressure ("MAOP") in several of PG&E's gas transmission lines. Portions of these gas transmission lines are located in

High Consequence Areas (“HCAs”).

Given this information, I direct PG&E to take the following actions:

1. PG&E shall reduce the operating pressure by 20% below the MAOP, as defined in 49 CFR 192, of all segments of the following transmission lines located in HCAs: Line 148, DFM 0805-01, DFM 0807-01 and DFM 1816-01. PG&E shall maintain these pressure reductions until such time as the Commission allows PG&E to return to the lines to their normal operating pressures.
2. PG&E shall reduce the operating pressure by 20% below MAOP, as defined in 49 CFR 192, for any additional segments of transmission lines located in HCAs that are found, through further investigation, to have experienced planned or unplanned events in which the segments experienced pressure greater than 110% of MAOP, as defined in 49 CFR 192. PG&E shall maintain these pressure reductions until such time as the Commission allows PG&E to return to the lines to their normal operating pressures.

To the extent there is a reasonable possibility that any of the above ordered pressure reductions could adversely affect service to core customers, PG&E will consult with the Commission concerning appropriate actions to address adverse customer impacts.