

**PACIFIC GAS AND ELECTRIC COMPANY
SmartMeter™ CPUC Staff Inquiry
Data Response**

PG&E Data Request No.:	DRA_002		
PG&E File Name:	SM CSI_DR_DRA_002-Q11		
Request Date:	December 21, 2010	Requester DR No.:	DRA_2
Date Sent:	February 18, 2011	Requesting Party:	DRA
PG&E Witness:	N/A	Requester:	Tom Roberts

QUESTION 11

How often do gas modules transmit usage to the Aclara network?

ANSWER 11

The gas SmartMeter™ module transmits gas usage data to the Aclara network every six hours.