



---

# CPUC Meeting Materials

FEBRUARY 18, 2011

PG&E Privileged and Confidential

1

SB\_GT&S\_0044938



- Pressure Test Records Criteria
  - Verifiable, Traceable and Complete
- MAOP Validation Methodology



# Pressure Test Records Criteria

## *Verifiable, Traceable and Complete*

VERIFIABLE	TRACEABLE	COMPLETE
<b>INITIAL PASS</b>		
<p><b><u>Criteria:</u></b></p> <ul style="list-style-type: none"> <li>▪ Pressure test record (e.g. STPR<sup>1</sup>, chart) exists</li> <li>▪ Record has been collected and available for review</li> </ul>	<p><b><u>Criteria:</u></b></p> <ul style="list-style-type: none"> <li>▪ Total pipeline footage that is pressure tested per the pressure test records correlates with information contained on the Job Estimate Face Sheet</li> </ul>	<p><b><u>Criteria:</u></b></p> <ul style="list-style-type: none"> <li>▪ Pressure test record contains the following 4 elements required by current regulations (CFR Title 49, Part 192.517<sup>2</sup>):               <ul style="list-style-type: none"> <li>- Name of Operator</li> <li>- Test Pressure</li> <li>- Test Duration</li> <li>- Test Medium</li> </ul> </li> </ul>
<b>ADDITIONAL ANALYSIS REQUIRED</b> (One or more of the above criteria has not been met)		
<p><b><u>Criteria:</u></b></p> <ul style="list-style-type: none"> <li>▪ Other data sources need to be researched (e.g. test logs, As Builts, etc.)</li> </ul>	<p><b><u>Criteria:</u></b></p> <ul style="list-style-type: none"> <li>▪ Other data sources need to be researched (e.g. As Builts, Bill of Materials, etc.)</li> </ul>	<p><b><u>Criteria:</u></b></p> <ul style="list-style-type: none"> <li>▪ Other data sources need to be researched to identify 4 key elements above</li> </ul>

<sup>1</sup>Strength Test Pressure Report. Please refer to the Appendix for an example report.

<sup>2</sup>CFR Title 49, Part 192 includes 3 additional elements including pressure chart, elevation and leak and failure survey. These elements are being documented when available as part of the Data Validation Project.



### **1. MAOP Validation of the Job**

- Establishes MAOP of the pipe segment


### **2. MAOP Validation of the HCA Pipeline System**

- Establishes MAOP of the pipeline system based on the lowest MAOP of the HCA pipe segment or component



# MAOP Validation Methodology

## 1. MAOP Validation of Job



**Notes:**

\*Validation in accordance with the code requirements relevant at the time the test was conducted

\*\*Low stress is defined as pipelines operating  $\leq 20\%$  SMYS

<sup>1</sup>MAOP can be established using the grandfather clause (highest actual operating pressure to which the segment was subjected during the 5 years preceding July 1, 1970) per CFR Title 49, Part 192.619



# MAOP Validation Methodology

## 2. MAOP Validation of HCA Pipeline System

Establish  
MAOP of  
the Job  
*(prior step)*

Develop  
comprehensive  
Pipeline Features  
List (PFL)

Follow 1998 PHMSA  
guideline,  
Determination of  
MAOP in Natural Gas  
Pipelines

Determine valid  
MAOP of HCA  
pipeline system

**Components include  
(but not limited to):**

- Pipe
- Valves
- Fittings
- Overpressure Protection Devices
- *Other*

**PHMSA References**

- Based on requirements as outlined in CFR Title 49, Part 192

**PHMSA Guideline**

- Determine the appropriate pressure limit for each pipeline component
- Lowest value of the component establishes the MAOP of the pipeline system

# Appendix

STPR EXAMPLE

## MAOP VALIDATION METHODOLOGY DETAILS

## Criteria for Complete

- Four key elements:
  1. Operator name
  2. Test pressure
  3. Test medium
  4. Test duration
  
- Additional information (captured if available):
  - Elevation variation
  - Pressure charts
  - Leaks and failures

USE IN ACCORDANCE WITH  
GAS STD. 4-14 AND G.O. 112

PG AND K  
GAS OPERATIONS  
STRENGTH TEST PRESSURE REPORT  
(FOR PIPE FACILITIES OPERATING OVER 100 PSIG)

SHEET 1 OF 1

---

**PART I - DESIGN DATA - TO BE PREPARED BY PROJECT ENGINEER OR GAS SYSTEM DESIGN DEPT.**

DIST. MAIN OR LINE NO. NAPA VALLEY FEEDER	DIVISION NORTH DAY	DISTRICT VAL-NAPA "I"	W.O. OR G.O. NO. GM 180428	DATE APPROVED 4-10-73
DESCRIPTION OF JOB - INCLUDE REFERENCE DRAWING NUMBERS Reinforce Napa Valley distribution feeder main				
LOCATION CLASS I and III	DESIGN FACTOR .5	PRESENT MAP OF LINE (PSIG) 450	DESIGN PRESSURE - THIS SECTION 675	PLANNED FUTURE MAP 675
SPECIAL PROTECTION REQUIRED WHERE COVER OVER PIPE IS LESS THAN SPECIFIED IN PAR. 15.5.27 G.O. 112 - SEE PAR. 14.1.2(B) GIVE W.P. & REF. DWG. NO. FOR EACH LOCATION				
STATIC HEAD DUE TO ELEVATION DIFFERENCE (WHERE APPLICABLE)	MAX. ELEVATION FT. MIN. ELEVATION FT. DIFF. N/A	STATIC HEAD CALCULATION FOR WATER K DIFF. N/A PSIG		
PIPE SIZE S.D. 10.750 W.T. 0.188	PIPE SPECIFICATION API SIX CR. X-42	TESTED IN FIELD YES	DESIGN PRESS. 45.0	AT MIN. TEST PRESS. 90
		AT MAX. TEST PRESS. 100		PRESS. TO ONE SOLMSYS 1323
				FOOTAGE TO BE TESTED IN FIELD 875
				VERIFIED IN FIELD 705
MINIMUM PRESSURE FOR TEST 1323 PSIG		TEST FLUID TO BE USED Water		MINIMUM TEST DURATION UNDER SOLMSYS (IN HRS) 8 HRS.
MAXIMUM PERMISSIBLE TEST PRESSURE 1469 PSIG				PROFESSIONAL TESTER (SEE SOLMSYS 112)
PREPARED BY Redacted	DATE 4-10-73	FOR INFORMATION OR CHANGES CALL EXT. 7191		

---

**PART II - TEST DATA - TO BE PREPARED BY PERSON SUPERVISING TEST AT TIME OF TEST.**

TIME AND DATE REACHED TEST PRESSURE 6-28-73	ELEVATION AT TEST POINT NA FT.	INDICATED TEST PRESSURE 1390 PSIG
TIME AND DATE TEST ENDED 6-29-73	MAX. ELEVATION IN TEST SECTION NA FT.	MINIMUM TEST PRESSURE 1323 PSIG
ACTUAL DURATION OF TEST 9 Hours 45 Min.	MIN. ELEVATION IN TEST SECTION NA FT.	MAXIMUM TEST PRESSURE 1469 PSIG

TEST FLUID USED 0-2000 PSI  
MARK, RANGE & SERIAL NO. OF RECORDING GAUGE Bristol's 6741466  
DATE LAST CALIBRATION 04-0-73  
MAKE, RANGE & SERIAL NO. OF DEAD WEIGHT TESTER  
TEST SUPERVISED BY Redacted  
APPROVED BY Redacted  
DATE

Job Number GM 180428  
SEE ATTACHED SHEET FOR DRAWING.

**DISTRIBUTION**

ENST. GAS SUPT. FOR FILE

ENST. GAS SUPT. FOR GAS ASSIGNED JOBS

ENST. GAS SUPT. DESIGN (S)

PLANN. ACCO. DIVISION

FOREMAN'S COPY OF JOB

FIELD HISTORY FILE

REPORT FAILURE UNDER

REPORT FAILURE UNDER





# Job Estimate Face Sheet Example

## Criteria for Complete

- Face sheet includes footage
- Used to correlate with footage on STPR's

REV. 8-68  
 PACIFIC GAS AND ELECTRIC COMPANY  
 ESTIMATE FOR AUTHORIZATION  
 RC#04-445

DATE OF ESTIMATE May 5, 1972  
 DEPARTMENT Gas DISTRICT Vjo.-Napa "L" DIVISION North Bay OFFICE 04  
 NAMES OF APPLICANTS Pacific Gas & Electric Company ESTIMATE NO. 0-40306  
 LOCATION Oakville to South of Rutherford, Napa Rural COUNTY Napa  
 JOB TITLE Reinforce Napa Valley Distribution Fender Main.  
 REASON FOR PROPOSED WORK AND DESCRIPTION THEREOF:  
 In order to supply firm gas demands to North Napa Valley, (Calistoga, St. Helena, Sanitarium & Angwin), it is proposed to install 8350' of 10" HP gas main from south of Oakville to South of Rutherford along hwy. #29.  
 This reinforcement is recommended by Gas System Planning and is another portion of a master plan to maintain 150 PSI level to the Northern Napa Valley Area.  
 This extension will assure adequacy of supply into 1974.  
 CP Area NC-TP

RECOMMENDATION & RULE NO.  
 Company Expense

ACCOUNT NO.	ACTIVITY ITEM NO.	LOCATION SAS/FORM ITEM NO.	ESTIMATE OF DIRECT COST - LMB (FOR UNLIM. ESTIMATED GIVE SUMMARY HERE - DETAIL EXTRA SHEETS)	UNIT AMOUNT (WHEN REQ'D)	AMOUNT (DOLLARS ONLY)			TOTAL
					FROM UNIT COST	OTHER		
122h	1000		Install 8350'- 10" HP Gas Main		65628	32888	59040	157556
122h	2000		Install 35'-6" HP Gas Main		400	75		475
122h	3000		Install 6" Valve in P&C		400	1500		1900

PLANT TO BE REMOVED OR ABANDONED (GIVE ITEM NO., WHEREAS COUNTY AND PERIOD OF INSTALLATION AS APPROPRIATE)

TOTAL DIRECT COSTS (MATERIAL, LABOR, & OVERHEAD)	106,991
INDIRECT COSTS (MATERIAL, LABOR, & OVERHEAD)	32,675
SUB-TOTAL	139,666
GEN. OVERHEADS (8.93%)	12,428
APPROPRIATION (MATERIAL, LABOR, & OVERHEAD)	214,484
MAINTENANCE & OPER.	
AMOUNT AUTHORIZED	214,484
INSTALLER'S WAREHOUSE	
REVOLVING STOCK (NET)	
INSTALL AND/OR REMOVE SERVICES	
DEDUCT SALVAGE AND/OR OTHER CREDITS	
NET AMOUNT	214,484

CHECK LIST	REQ'D.	SEC'D.	CHECK LIST	REQ'D.	SEC'D.	PROGRESS REPORT CODES (ACT'S ONLY)	REMARKS
J.P./S.T. INTENTION			RIGHT OF WAY			100	
J.P./S.T. APR. NO.			OVER 20% YIELD	Yes			
TREE TRIMMING			STRENGTH TEST	Yes			175
CITY OR CO. PERMIT			PAYMENT - \$2. FT.	25000			
HIWAY PERMIT		X	MACHINE FRENCH - FT.	974			
R.R. TIME PERMIT			MAN DAYS	1054			
OTHER PERMITS			COST REPORT REQUIRED	YES	NO X		

Redacted

PG&E



# Appendix


STPR EXAMPLE

MAOP VALIDATION METHODOLOGY DETAILS



# MAOP Validation Methodology Details

## MAOP Validation of Job





### Sufficient Pressure

$$[ \text{MAOP to be established} ] * [ \text{Pressure Test Class Factor} ] \leq [ \text{Minimum Test Pressure} ]$$

Critical Inputs*
MAOP to be established
Class location
Minimum Test Pressure
Installation date

Class location	Pressure Test Class Factors		
	Installed before Nov. 12, 1970	Installed after Nov. 11, 1970	Converted under §192.14
1	1.1	1.1	1.25
2	1.25	1.25	1.25
3	1.4	1.5	1.5
4	1.4	1.5	1.5

\* Note: See Appendix for sources

Code References: Operations (DOT § 192 Subpart L), MAOP (DOT § 192.619), Pressure Test (DOT § 192.619 paragraph [a,2,ii])



### Sufficient Duration

Test Date:	Prior to July 1, 1961	Between July 1, 1961 and Prior to March 12, 1971	March 12, 1971 and Beyond
Minimum Duration:	<b>No minimum threshold required</b>	<b>1 hour</b>	<b>1 hour</b> if %SMYS < 30% and P > 100 psig  - OR -  <b>8 hours</b> if %SMYS ≥ 30%

Critical Inputs*
Test Date
Test Duration
%SMYS

Where %SMYS =  $P / [(2 St / D) * E]$ , and:

P = MAOP to be established

S = Yield strength in pounds per square inch

t = Nominal wall thickness of the pipe in inches

D = Nominal outside diameter of the pipe in inches

E = Longitudinal joint factor

\* Note: See Appendix for sources

Code References: DOT § 192 Subpart J, DOT § 192.505, DOT § 192.507, DOT § 192.105



### Operating Within Current Class Location

$$[ \text{MAOP to be established} ] * [ \text{Pressure Test Class Factor} ] \leq [ \text{Minimum Test Pressure} ]$$

Critical Inputs*
MAOP to be established
Class location
Minimum Test Pressure
Installation date

Class location	Pressure Test Class Factors		
	Installed before Nov. 12, 1970	Installed after Nov. 11, 1970	Converted under §192.14
1	1.1	1.1	1.25
2	1.25	1.25	1.25
3	1.4	1.5	1.5
4	1.4	1.5	1.5

\* Note: See Appendix for sources

Code References: Operations (DOT § 192 Subpart L), MAOP (DOT § 192.619), Pressure Test (DOT § 192.619 paragraph [a,2,ii])



# MAOP Validation Methodology Details

4

## 20% SMYS Calculation

$$\%SMYS = [ \text{MOP from PG\&E Engineering Drawing*} ] / [ ( 2 St / D ) * E ]$$

MAOP OF NUMBERED TRANSMISSION LINES

Line Number	MP	to	MP	Description	Pipe Diameter (inches)	MOP (psig)	Min. MAOP for Segment (psig)	Future Design Pressure (psig)
2	39.81		129.10	Redacted	26.36	890	890	890
2	129.10		142.50		26	890	890	890
2	142.50		158.00		26	890	890	890
21A	12.05		31.84		8, 12, 24, 26	450	450	675
21B	0.00		18.64		12, 16	450	450	720
21C	31.84		53.12		12, 16, 20	450	450	675
21C-1	95.22		96.28		12	450	450	675
21D	18.64		31.81		16	450	500	675
21D-1	0.00		1.15		12, 16	450	675	675
21E	53.12		137.38		8, 10, 12, 16	610 (32)	720	720
21F	0.00		21.11		12, 16, 20	450	500	500
21G	0.00		20.82		12, 16, 20	450	500	500
21H	0.00		1.07		24, 26	400	473	675
21H	1.07		1.52		24	400	675	675
21H	1.52		2.85		12, 16	250	375	585
21H	2.65		2.71		16	250	258	585
21H	2.71		12.05		12, 16	250	275	585
*50A-1	0.00		2.87		8, 12	400	400	720
*50A	2.87		16.93		8	250	250	720
*50A	16.93		26.94		6, 8	250	250	720
*50A	26.94		45.05		6, 8, 10, 12	400	400	720
50B	0.00		7.81		8	400	720	720
56					4	1300	1300	1440
56					4, 8	1300	1440	1440
57					4-12	2160	2160	2160
57A	6.34		16.64		14, 16, 18	722	722	867
57B	0.00		16.46		22	2160	2160	2160
57C	0.00		6.44		24	2160	2160	2160
65					12, 20, 22	600	720	720
65					4, 20, 22	1800	1800	1800
100	138.43		150.13	20	375 (8)	400	400	
101	0.00		32.17	20, 24, 30, 34, 36	375 (8)	400	400	
101	32.17		33.88	20	375 (8)	398	400	
*101	33.88		44.55	20, 24	145 (1)	275	275	

MAOP OF LINES OPERATING AT OR OVER 20% SMYS

SHEET 3 OF 25 SHEETS

DRAWING NO. 086868 REV 20

\* Source: PG&E Engineering Drawing DWG 086868 Rev 20