

From: Dowdell, Jennifer
Sent: 6/21/2011 5:22:50 PM
To: Daubin, Brian M (GT&D)
(/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=BMD5); 'Shori, Sunil'
(sunil.shori@cpuc.ca.gov)
Cc: Fassett, Robert (GT&D)
(/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=RPF2); Horner, Trina
(/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=TNHC); Garber, Stephen
(Law) (/o=PG&E/ou=Corporate/cn=Recipients/cn=SLG0)

Bcc:

Subject: RE:

Thanks Sunil

Jennifer

-----Original Message-----

From: Shori, Sunil [mailto:sunil.shori@cpuc.ca.gov]

Sent: Tuesday, June 21, 2011 5:20 PM

To: Daubin, Brian M (GT&D)

Cc: Dowdell, Jennifer; Fassett, Robert (GT&D)

Subject:

Brian:

As a follow-up to our earlier teleconference, PG&E's A-Form shows that a leak on the girth weld was found on 11/16/2009 (Leak# 09-30255-1). The location of the leak was at [Redacted] Specifications for the pipe are: 30-inch DSAW, .375-inch wall, installed under Job #98015.

The line was isolated and repaired via a sleeve installed on the pipe in front of [Redacted] The project is detailed in response to NTSB_080-001.

We would like to receive a copy of the root cause analysis performed for the leak and/or who within PG&E's IM Group was involved in reviewing the repair and determining how the leak on the girth weld affected the threats on the segment and the overall pipeline.

Thanks, Brian.

Sunil