

From: Cherry, Brian K  
Sent: 8/15/2011 6:54:20 PM  
To: 'pac@cpuc.ca.gov' (pac@cpuc.ca.gov)  
Cc:  
Bcc:  
Subject: Fw: Incident at [Redacted] Sacramento

2 inch

**From:** [Redacted]  
**Sent:** Monday, August 15, 2011 06:16 PM  
**To:** UO EP Gas Incident Notify  
**Subject:** Incident at [Redacted] Sacramento

At 1130 hours on 8/15/11 at [Redacted] Sacramento, County of Sacramento employees dug into a 2 inch steel gas main allowing gas to escape. A USA request had been received and the line was properly marked.


PG&E was notified of this incident by [Redacted] at 1148 hours. Company personnel arrived at 1148 hours. The area was blocked off and 10 homes were evacuated.

The incident was determined to be reportable at 1415 hours due to media (KXTV and KCRA) being present. The CPUC was notified at 1431 hours.

There were no fatalities or injuries as a result of this incident. Estimated damages are not known at this time but will be less than \$50,000.

The flow of gas was stopped at 1545 hours. Repairs were then made and completed. Five customers were out of service for approximately 10 customer hours. Relights began at 1800 hours.

Please call [Redacted] at [Redacted] if you have any questions or require additional information.



Redacted PE

## Gas Engineering - Technical Applications

Redacted

Redacted

Redacted

Redacted

Redacted

Redacted

