

STRENGTH TEST INFORMATION

1. JOB PG & E HYDRO TEST S/N 41497318
2. LOCATION ARVIN, CA - MP 256.22 - 257.0763 L-300-A
3. DATE 8-9-11 PRESSURE 963
4. TIME 11:26AM to 8:00 PM DURATION 8 HR. 30 MIN
5. LENGTH 24.9 SIZE 34 W.T. .505
6. PIPE SPEC. API 5L, GR X-60, DSAW
7. RECORDING GAUGE BARTON SER 624082
8. RANGE 0-3000 LAST CALIBRATED 6-17-11
9. DEAD WGT. CHANDLER SER 5198
10. RANGE 50-3000 LAST CALIBRATED 6-17-11
11. TEST FLUID [REDACTED]
12. SUPERVISED [REDACTED] DATE 8-9-11
13. APPROVED [REDACTED] DATE _____

COPY
AUG 10 2011
PG & E

14. LENGTH 50.7 SIZE 34 W.T. .375
15. PIPE SPEC. API 5L, GR X-65, DSAW
16. LENGTH 4510.1 SIZE 34 W.T. .375
17. PIPE SPEC. API 5L GR X-52, DSAW
18. LENGTH _____ SIZE _____ W.T. _____
19. PIPE SPEC. _____
20. LENGTH _____ SIZE _____ W.T. _____
21. PIPE SPEC. _____
22. LENGTH _____ SIZE _____ W.T. _____
23. PIPE SPEC. _____
24. LENGTH _____ SIZE _____ W.T. _____
25. PIPE SPEC. _____