Application No.:	R.10-05-006
Exhibit No.:	
Witness:	Mark Rothleder

Order Instituting Rulemaking to Integrate and Refine Procurement Policies and Consider Long-Term Procurement Plans.))

Rulemaking 10-05-006

TRACK I DIRECT TESTIMONY OF MARK ROTHLEDER ON BEHALF OF THE CALIFORNIA INDEPENDENT SYSTEM OPERATOR **CORPORATION (CORRECTED)**

)

2		BEFORE THE PUBLIC UTILITIES COMMISSION OF THE
3		STATE OF CALIFORNIA
4	Refin	r Instituting Rulemaking to Integrate and) ne Procurement Policies and Consider Long-) Rulemaking 10-05-006 ne Procurement Plans.)
5 6 7 8 9 10 11	(TRACK I DIRECT TESTIMONY OF MARK ROTHLEDER ON BEHALF OF THE CALIFORNIAINDEPENDENT SYSTEM OPERATOR CORPORATION
12 13 14	I.	BACKGROUND
14	Q.	What is your name and by whom are you employed?
16	А.	My name is Mark A. Rothleder and I am employed by the California Independent
17		System Operator Corporation (ISO) as Director, Market Analysis and Development.
18		
19	Q.	Please describe your educational and professional background.
20		I am the Director of Market Analysis and Development for the ISO. Prior to this
21		role, I was a Principle Market Developer for the ISO in the lead role in the
22		implementation of market rules and software modifications related to the ISO's
23		Market Redesign and Technology Upgrade ("MRTU"). Since joining the ISO over
24		ten years ago, I have worked extensively on implementing and integrating the
25		approved market rules for California's competitive Energy and Ancillary Services
26		markets and the rules for Congestion Management, Real-Time Economic Dispatch,
27		and Real-Time Market Mitigation into the operations of the ISO Balancing
28		Authority Area ("BAA"). I also have held the position of Director of Market
29		Operations. I am a registered Professional Electrical Engineer in the state State of

Page 2 of 50

	California. I hold a B.S. degree in Electrical Engineering from the California State
	University, Sacramento. I have taken post-graduate coursework in Power System
	Engineering from Santa Clara University and earned a M.S. in Information Systems
	from the University of Phoenix. I have co-authored technical papers on aspects of
	the California market design in professional journals and have frequently presented
	to industry forums. Prior to joining the ISO in 1997, I worked for eight years in the
	Electric Transmission Department of Pacific Gas & Electric Company, where my
	responsibilities included Operations Engineering, Transmission Planning and
	Substation Design.
Q.	What is the purpose of your testimony?
	I will describe the results of the ISO's evaluation of potential operational and
	resource capacity needs driven by the state of California's requirement that load
	serving entities (LSEs) develop 33% renewable resource portfolios by 2020. For
	the purposes of this testimony, I will refer to this requirement as "33% RPS" and the
	ISO's study of operational requirements and market impacts at 33% RPS in 2020,
	using its renewable integration model, as the ISO's "33% integration study."
Q.	Why does the ISO conduct renewable integration studies?
A.	As part of the ISO's continuing effort to understand and prepare for increasing
	levels of renewable integration consistent with California's energy and
	environmental policy objectives, the ISO performs renewable integrations studies to
	1) identify operational requirements necessary to support increased variability and
	uncertainty in supply with increasing renewable penetration; 2) assess the expected
	generation fleet needed to meet simultaneously both the operational requirements
	for renewable energy integration and the forecasted demand for energy; and 3)
	identify any additional operational needs for integration of renewable resources.
	Q.

Page 3 of 50

1		The ISO released a study of grid impacts associated with a 20% RPS level in 2012
2		on August 31, 2010. ¹ In support of this renewable integration study work, the ISO
3		produced a technical appendix ² that explained in detail the technical methodology.
4		Also starting in 2010, the ISO performed some preliminary studies of operational
5		requirements and needs to meet the 33% renewable integration objective in 2020.
6		The 33% integration study builds on the work done in the 20% RPS analysis and
7		was intended to accomplish the following four objectives:
8		□ Provide information for the long-term procurement docket that could
9		be used to identify potential planning needs, costs or other options.
10		□ Inform other CPUC and state agency regulatory decisions.
11		□ Inform ISO transmission planning decisions regarding the need for
12		additional infrastructure to integrate renewable resources.
13		□ Inform the ISO in potential energy and ancillary services market
14		enhancements for needed renewable integration capabilities.
15		
16	Q.	How has the ISO participated in this proceeding?
17	А.	The preliminary 33% integration study work was performed in coordination and
18		support of this Long Term Procurement Plans (LTPP) proceeding using assumptions
19		from the prior LTPP assumptions (Docket No. R. 08-02-007 and predecessor
20		dockets). In the context of this case, in 2010 the 33% study work was primarily
21		used to familiarize parties and gain agreement regarding the renewable integration
22		study methodology. During the third and fourth quarters of 2010, the ISO
23		conducted Step 1 modeling and Step 2 production simulation using 2009 vintage
24		scenarios developed by the CPUC's Energy Division (ED) staff. The ISO described
25		its 33% integration model at a workshop on August 24, 2010; the Step 1 modeling at
26		a workshop on October 22, 2010; and the Step 2 results at a workshop on November
27		30, 2010. In addition, the ISO reviewed the Lawrence Berkeley National Lab's

 ¹ See Integration of Renewable Resources-Operational Requirements and Generation Fleet Capability at 20% RPS at <u>http://www.caiso.com/2804/2804d036401f0.pdf</u>
 ² Draft Technical Appendices for Renewable Integration Studies - Operational Requirements and Generation Fleet Capability <u>http://www.caiso.com/282d/282d85c9391b0.pdf</u>

Page 4 of 50

(LBNL) report and responded to comments and questions submitted by parties to the proceeding following each workshop.

4 On December 3, 2010, the CPUC issued a scoping memo in which new assumptions 5 and scenarios were identified. The ISO has now revised its 33% integration study 6 consistent with the CPUC's new assumptions and scenarios identified in the scoping 7 memo. At the same time, the ISO has incorporated other identified data updates 8 and methodological refinements to the 33% integration study. The preliminary 9 study results based on these new assumptions and scenarios were distributed to the parties in this proceeding on April 29, 2011 and presented at a May 10, 2011 10 11 workshop. Here I describe the updates and refinements to the input data and 12 methodology used for the 33% integration study to produce final study results, 13 including the changes made to the preliminary study results.

14

1

2

3

15 16

17

Q. Do the 33% integration study methodology and the renewable portfolio scenarios that the ISO studied and that you describe in your testimony provide sufficient information to make procurement and infrastructure decisions?

18 A. As I describe in detail in this testimony, the study results show the flexibility 19 requirements to support a 33% RPS result in a range of possibilities, from no 20 additional capacity needs to the need for substantial capacity additions depending on 21 the scenario assumptions. For this reason, the ISO believes that the study results 22 should only be used making least regrets procurement decisions considering the lead 23 time needed for such development. The study work that the ISO will be performing 24 this year may provide additional insights to the plausible range of resource needs 25 under different assumptions, which can also inform incremental procurement 26 decisions. For example, the ISO, along with the CPUC, the CEC and other 27 agencies, is in the process of conducting power flow and stability studies to evaluate local area capacity needs created by once through cooling (OTC) environmental 28 29 restrictions. These study results will likely impact capacity input assumptions for

Page 5 of 50

future renewable scenarios that the ISO intends to run and will make available in the 1 2 next LTPP proceeding. 3 4 In future studies, assumption areas needing further validation are the levels of 5 energy efficiency and demand response captured in some of the renewable portfolio 6 scenarios because such levels may take many years to achieve. Forecast error 7 improvements should also be considered in future study work. 8 9 Because of the uncertainty around many of the study assumptions, the ISO believes that infrastructure decisions regarding the resources needed to support renewable 10 11 integration is best determined on an incremental basis over the course of several 12 years. For now it is important that the programs needed to achieve the levels of 13 energy efficiency and demand response load reduction assumptions must be put in 14 place as soon as possible. As the OTC study results become available, decisions 15 about repowering or new generation siting must be considered. At the same time, 16 the ISO will be developing market rules and integration policies that will align the 17 operational and environmental objectives. 18 19 Q. Please describe how your testimony is organized. 20 The ISO's April 29, 2011 preliminary results were provided in the form of a slide A. 21 deck. Those results now have been updated to account for the changes in modeling 22 assumptions described in the May 31, 2011 ALJ ruling on the joint motion for 23 extension of time to file testimony, and the ISO has updated the slide deck 24 accordingly. In addition, the ISO has added summary information about the 25 additional sensitivity scenarios that were modeled to test the results of the four 26 scenarios. The updated slides are attached as Exhibit 1 and I describe them in this 27 testimony. In the sections that follow, I will describe the 33% integration study methodology, input assumptions and the CPUC's renewable scenarios, study results, 28 29 and how these results can be interpreted.

Page 6 of 50

1	II.	MODELING THE REQUIRED CPUC RENEWABLE PORTFOLIO
2		SCENARIOS AND OTHER CASES
3		
4	Q.	You stated that the ISO ran the 33% integration model using 2009 vintage
5		renewable scenarios, and these results were presented during workshops in
6		2010. What was the ISO's role with respect to the updated renewable scenarios
7		described in the December 3, 2010 Scoping Ruling?
8	А.	The ISO 33% integration study was updated to reflect the latest scenario
9		assumptions developed by the ED staff and described in the December 3, 2010
10		scoping ruling ³ . Seven scenarios were specified:
11 12 13 14 15 16 17 18 19 20		 33% Trajectory Base Load 33% Environmentally Constrained 33% Cost Constrained 33% Time Constrained 20% Trajectory 33% Trajectory High Load 33% Trajectory Low Load The assumptions for load and renewable resources vary depending on the scenario.
20		There are a set of assumed resources that are common to all scenarios. This
21		common assumption is referred to as the "discounted core." The discounted core
22		consists of projects with signed power purchase agreements and filed applications
24		for major permits. As a general observation, the load assumed in the 2010 scenarios
25		is lower than the 2009 vintage scenarios. The ISO studied five of the seven 2010
26		scenarios: 33% Trajectory Base Load, Environmentally Constrained, Cost
27		Constrained, Time Constrained, and 33% Trajectory High Load. Of these five, the
28		first four were prioritized by the CPUC and are referred to in this testimony as the
29		four priority scenarios. The preliminary results from modeling and production
30		simulation runs for the four priority scenarios were provided to the parties on April

 $[\]underline{http://www.cpuc.ca.gov/PUC/energy/Procurement/LTPP/LTPP2010/2010+LTPP+Tools+and+Spreadsheets.ht}{\underline{m}}$

Page 7 of 50

29, 2011 and discussed at the workshop held on May 10, 2011. In addition to the five CPUC scenarios, the ISO also studied an "All Gas" scenario in support of development of metrics by the IOUs, and conducted a sensitivity analysis assuming all three Helms pumps are available year round. I discuss in this testimony the results of those studies.

6

1

2

3

4

5

7 8

Q. Please provide a general description of the five scenarios and the All Gas scenario?

9 A. The four priority scenarios described in the scoping memo and modeled by the ISO all have the same load assumption based on the 2009 California Energy 10 11 Commission (CEC) load forecast. The priority scenarios differ with respect to the 12 assumptions about the type and location of renewables needed to achieve 33% RPS. 13 Of these scenarios, the Environmentally Constrained scenario relies more heavily on 14 distributed solar (about 9000 MW), which includes small to medium sized solar 15 photovoltaic (PV) plants selling their entire output to utilities. The Cost 16 Constrained and Time Constrained scenarios have higher levels of out of state 17 renewables. The fifth CPUC scenario studied, the 33% Trajectory High Load 18 scenario, has a 10% higher load assumption than the four priority scenarios to 19 reflect any combination of future uncertainties (e.g., increased load growth and 20 programmatic performance). The Trajectory High Load scenario also had 21 1,497MW of additional renewable resource versus the Trajectory Base Load 22 scenario. Slide 5 in Exhibit 1 contains a list of the load and renewable assumptions 23 for the five CPUC scenarios that the ISO ran. The All Gas scenario uses similar 24 base load assumptions but does not include new renewable resources. The All Gas 25 scenario does include existing renewables and 1750 MW of expected customer PV.

- 26
- 27

Q. How do these scenarios differ from the 2009 vintage scenarios?

A. The five CPUC scenarios assumed higher quantities of energy efficiency, behind the
 meter combined heat and power (CHP) and different assumptions about renewable
 portfolio build-out than the vintage scenarios. The increased energy efficiency and

Page 8 of 50


1		CHP assumption reduce the peak load from the 70,180MW statewide peak in the
2		vintage scenarios to a 63,755MW statewide peak for the 2010 scenarios. Slide 6 of
3		Exhibit 1 compares assumptions between the two sets of scenarios.
4		
5	Q.	How did the ISO work with the utilities to model all the scenarios?
6	А.	The ISO collaborated with the three investor-owned utilities (IOUs) - PG&E,
7		SDG&E and SCE - and their consultant, Environmental Energy and Economics, Inc.
8		(E3), through the working group. As I describe later in this testimony, the ISO
9		conducted the Step 1 modeling and Step 2 production simulation for the five
10		scenarios. Additionally, the ISO ran the All Gas scenario to support the cost metrics
11		that E3 was retained to provide for the IOUs. E3 also assisted with reconciling the
12		Step 2 model and the portfolio assumptions from the scoping memo.
13		
14	0	How did the ISO use the input ecoumptions in the December 2, 2010 Second
14	Q.	How did the ISO use the input assumptions in the December 3, 2010 Scoping
14	Ų.	Ruling (as modified in later rulings) to develop the database to run the
	Q.	
15	Q. A.	Ruling (as modified in later rulings) to develop the database to run the
15 16		Ruling (as modified in later rulings) to develop the database to run the renewables scenarios you described?
15 16 17		Ruling (as modified in later rulings) to develop the database to run the renewables scenarios you described? The ISO found that the input assumptions (or, at times, lack thereof) in the scoping
15 16 17 18		Ruling (as modified in later rulings) to develop the database to run the renewables scenarios you described? The ISO found that the input assumptions (or, at times, lack thereof) in the scoping memo fell into four general categories. Some of the assumptions could be used
15 16 17 18 19		Ruling (as modified in later rulings) to develop the database to run the renewables scenarios you described? The ISO found that the input assumptions (or, at times, lack thereof) in the scoping memo fell into four general categories. Some of the assumptions could be used directly in developing the database. Other assumptions needed to be clarified with
15 16 17 18 19 20		Ruling (as modified in later rulings) to develop the database to run the renewables scenarios you described? The ISO found that the input assumptions (or, at times, lack thereof) in the scoping memo fell into four general categories. Some of the assumptions could be used directly in developing the database. Other assumptions needed to be clarified with Energy Division staff in order to be consistent with the scoping memo. The third
15 16 17 18 19 20 21		Ruling (as modified in later rulings) to develop the database to run the renewables scenarios you described? The ISO found that the input assumptions (or, at times, lack thereof) in the scoping memo fell into four general categories. Some of the assumptions could be used directly in developing the database. Other assumptions needed to be clarified with Energy Division staff in order to be consistent with the scoping memo. The third category consisted of input assumptions that were needed to successfully model and
 15 16 17 18 19 20 21 22 		Ruling (as modified in later rulings) to develop the database to run the renewables scenarios you described? The ISO found that the input assumptions (or, at times, lack thereof) in the scoping memo fell into four general categories. Some of the assumptions could be used directly in developing the database. Other assumptions needed to be clarified with Energy Division staff in order to be consistent with the scoping memo. The third category consisted of input assumptions that were needed to successfully model and run the scenarios but were not in the scoping memo. Finally, some assumptions
 15 16 17 18 19 20 21 22 23 		Ruling (as modified in later rulings) to develop the database to run the renewables scenarios you described? The ISO found that the input assumptions (or, at times, lack thereof) in the scoping memo fell into four general categories. Some of the assumptions could be used directly in developing the database. Other assumptions needed to be clarified with Energy Division staff in order to be consistent with the scoping memo. The third category consisted of input assumptions that were needed to successfully model and run the scenarios but were not in the scoping memo. Finally, some assumptions were simply incorrect and required revisions. For the last two categories, the ISO
 15 16 17 18 19 20 21 22 23 24 		Ruling (as modified in later rulings) to develop the database to run the renewables scenarios you described? The ISO found that the input assumptions (or, at times, lack thereof) in the scoping memo fell into four general categories. Some of the assumptions could be used directly in developing the database. Other assumptions needed to be clarified with Energy Division staff in order to be consistent with the scoping memo. The third category consisted of input assumptions that were needed to successfully model and run the scenarios but were not in the scoping memo. Finally, some assumptions were simply incorrect and required revisions. For the last two categories, the ISO used its independent judgment and operational experience, supplemented by
 15 16 17 18 19 20 21 22 23 24 25 		Ruling (as modified in later rulings) to develop the database to run the renewables scenarios you described? The ISO found that the input assumptions (or, at times, lack thereof) in the scoping memo fell into four general categories. Some of the assumptions could be used directly in developing the database. Other assumptions needed to be clarified with Energy Division staff in order to be consistent with the scoping memo. The third category consisted of input assumptions that were needed to successfully model and run the scenarios but were not in the scoping memo. Finally, some assumptions were simply incorrect and required revisions. For the last two categories, the ISO used its independent judgment and operational experience, supplemented by expertise from Nexant (the ISO's consultant), to develop the needed assumptions or

Page 9 of 50

1	Q.	What was the basis for the changes made to the input assumptions?
2	А.	Slides 36-39 set forth the changes to the assumptions in the scoping memo for
3		accuracy.
4		
5	Q.	Did the ISO make additional input assumptions and clarifications?
6	А.	Yes. As I noted above, following the release of the preliminary study results on
7		April 29, 2011, the ISO, in collaboration with the IOUs, developed a list of input
8		assumption modifications required to finalize the studies. These assumption
9		modifications were described in the May 31, 2011 ALJ ruling in this proceeding.
10		
11	III.	STUDY METHODOLOGY
12		
13	Q.	Can you provide an overview of the 33% integration model, and the study
14		methodology steps followed by the ISO, to develop the results summarized in
15		Exhibit 1?
16	А.	Yes. The study methodology is divided into stages: Steps 0, 1 and 2, conducted by
17		the ISO, and Step 3, undertaken by E3 and the IOUs. The first stage, Step 0, is the
18		development of load, wind and solar profiles, based on the resource assumptions in
19		each portfolio. The profiles are then used as inputs into the Step 1 statistical analysis
20		to calculate regulation and load following requirements. These requirements, along
21		with hourly load and other operating reserves, are then used as inputs to a
22		production simulation in Step 2. Figure 1 illustrates the study process. The results
23		of production simulation were then provided to the IOUs to develop integration
24		metrics referred to as Step 3.


Page 10 of 50

Figure 1: Renewable Integration Study Process





1



Page 11 of 50

1 Q. How were the different categories of out-of-state renewable resources treated

2 in the different steps of the study process?

- 3 A. Table 1 summarizes how the different categories were reflected in the study steps.
- 4

Table 1: Modeling of Out-of-State Renewable Resources

Type of Out-of-	Step 1	Step 2	Post Processing
State Renewable		•	Costs and
			Emissions
Dynamic	Use 1 minute	Hourly profiled production	Zero production
Schedule/Pseudo	profiles as if the	should be modeled using import	costs and
Tie (15%)	plant is in CA.	lines to carry this flow.	emissions should
	Forecast error		all be attributed to
	included.		CA related to
			imports.
15 minute intra-	Average 1 minute	Hourly profiled production	Zero production
hour scheduled	data over 15	should be modeled using import	costs and
(15%)	minutes with	lines to carry this flow. (same as	emissions should
	appropriate	above).	all be attributed to CA related to
	schedule ramps. Forecast error not		imports.
	included.		imports.
Hourly Schedule	Not used in Step	Hourly production is modeled as	Zero production
Type 2 ⁴		if the plant's production will be	costs and
(40%)		injected in the bubble that the	emissions should
		plant resides in and will have	all be attributed to
		only an indirect impact on CA	CA related to
		through any possible re-dispatch	imports.
		in the region the plant is located	
		in.	
Unbundled RECs	Not used in Step	Hourly production is modeled as	RECs should be
(30%)	1	if the plant's production will be	attributed to CA.
		injected in the bubble that the	Imports would be
		plant resides in and will have	at costs and
		only an indirect impact on CA	emissions of the
		through any possible re-dispatch	WECC.
		in the region the plant is located	
		111.	

⁴ It is assumed that the schedule for these projects are such that the yearly production from the plant is scheduled into California without any other constraints on hourly, weekly, or monthly schedules. Within the hour balancing, and any additional balancing and shaping, is not supplied by California.

Page 12 of 50

1		
2		A. <u>STEP 0 - IDENTIFYING RESOURCE CHARACTERISTICS TO BE</u>
3		USED IN EACH SCENARIO
4		
5	Q.	What is the purpose of Step 0?
6	А.	The purpose of Step 0 profile development is to produce a series of 1 minute and
7		hourly generation production profiles for each minute and hour of the of the year
8		based on the resource location, quantity and a capacity factor identified in the CPUC
9		scoping memo. The ISO has summarized the plant locations used in each CPUC
10		scenario and capacity factors by technology in support used for this analysis at
11		Exhibit 2 attached to this testimony. This information can also be found on the ISO
12		website at http://www.caiso.com/23bb/23bbc01d7bd0.
13		
14	Q.	How did the ISO develop the Step 0 profiles?
15	А.	As I discuss below, wind and solar 1 minute and hourly profiles were developed
16		using different methods. In addition, the solar method was further refined to
17		develop profiles for small-scale photovoltaic (PV), defined in the CPUC scoping
18		memo as small distribution solar at the wholesale level. Four types of small-scale
19		PV were specified depending on size and location: 1) large rooftop (0-2MW), 2)
20		large ground (5-20MW), 3) mid ground (2-5MW), and 4) small ground (0-2MW).
21		Due to the relatively small quantity and size of mid and small ground, the ISO
22		combined the mid and small ground into the large ground profile development.
23		The ISO modeled customer-side PV as supply in order to capture the intermittent
24		nature of these facilities. The ISO and Nexant consulted with ED staff and E3 to
25		clarify information provided in the scoping memo prior to developing the profiles.
26		
27		
28		
29		

Page 13 of 50

1	Q.	Please provide additional detail about how the ISO developed the Step 0 wind
2		profiles.
3	А.	For existing wind plant, the ISO used actual historical wind production from 2005.
4		Aggregate data for existing wind resources is available at
5		http://www.caiso.com/2b53/2b53c0f95d330.csv
6		
7		For new wind resources, the ISO used wind generation profiles that were developed
8		based upon NREL mesoscale wind data for 2005. ⁵ For new plants, wind plant
9		production modeling was based on NREL 10 minute data production data from the
10		year 2005 for 21 distinct locations in California and 22 distinct locations throughout
11		the remainder of the WECC where wind plants were identified in the CPUC study
12		scenarios. ⁶
13		
14	Q.	What steps did the ISO take to develop profiles for new wind resources?
15	А.	The 1 minute wind data used for all new wind plants was developed using a
16		methodology that included the following steps or processes:
17		
18		First, a representative number of plants and their geographical locations were
19		developed, whose total capacities (MW) matched the MW in each Competitive
20		Renewable Energy Zone (CREZ), based on the resources included in each of the
21		scenarios developed by the CPUC. To identify the number of units and locations
22		for the projected additions the CPUC used data from the IOU procurement
23		processes as a starting point and generic plant information from the Renewable
24		Energy Transmission Initiative (RETI) process and other sources. The number of
25		plants that were ultimately used to represent the wind generation were chosen so
26		that no one plant represented more than about 5% of the total wind generation.
27		

⁵ Data for the year 2005 was used in the ISO 33% RPS Studies because 2005 was designated as a normal hydro year. Thus load, wind, solar and hydro run of river profiles were based on conditions (wind speeds, solar irradiance, and hydro flows) that existed in 2005. ⁶ NREL production data is based upon a wind farm using Vestas V-90 3 MW generators.

Page 14 of 50

1	Second, geographic information system (GIS) software was used to find one or
2	more appropriate NREL data sites for each CREZ to represent wind plants in that
3	CREZ. Multiple NREL data sets within a CREZ were used to capture the diversity
4	within a CREZ where there were multiple plants within a CREZ in the study
5	definition. In selecting the NREL points to use from among the many NREL
6	mesoscale points available, wind sites that represented likely sites for wind farms
7	(ridge location, etc.) and that had capacity factors that were as close as possible to
8	the plants specified in the scenario definitions were carefully selected.
9	
10	Third, the 10 minute production data sets for the selected sites were downloaded
11	from the NREL website. These data sets were then shifted in time to Pacific
12	Standard Time and then the days of the week were shifted to match the days of the
13	week for the study year -2020 . Fourth, necessary if there were any capacity
14	factors that did not closely match the study definition plant capacity factors, the
15	resulting data was adjusted as necessary. These adjustments were minimal since the
16	data sets were chosen to closely match the desired capacity factors.
17	
17 18	Fifth, the 10 minute production data for each site was curve fit with a cubic spline
	Fifth, the 10 minute production data for each site was curve fit with a cubic spline curve fit function to produce 1 minute data without 1 minute variability.
18	
18 19	
18 19 20	curve fit function to produce 1 minute data without 1 minute variability.
18 19 20 21	curve fit function to produce 1 minute data without 1 minute variability. Sixth, a statistical model was developed using historical ISO data from several
18 19 20 21 22	curve fit function to produce 1 minute data without 1 minute variability. Sixth, a statistical model was developed using historical ISO data from several existing wind farms to capture the 1 minute variability (compared to a 10 minute
18 19 20 21 22 23	curve fit function to produce 1 minute data without 1 minute variability. Sixth, a statistical model was developed using historical ISO data from several existing wind farms to capture the 1 minute variability (compared to a 10 minute average) as a function of the size of the plant/wind farm. This statistical model
18 19 20 21 22 23 24	curve fit function to produce 1 minute data without 1 minute variability. Sixth, a statistical model was developed using historical ISO data from several existing wind farms to capture the 1 minute variability (compared to a 10 minute average) as a function of the size of the plant/wind farm. This statistical model captures the standard deviation of the 1 minute variability as it varies with wind
 18 19 20 21 22 23 24 25 	curve fit function to produce 1 minute data without 1 minute variability. Sixth, a statistical model was developed using historical ISO data from several existing wind farms to capture the 1 minute variability (compared to a 10 minute average) as a function of the size of the plant/wind farm. This statistical model captures the standard deviation of the 1 minute variability as it varies with wind
 18 19 20 21 22 23 24 25 26 	curve fit function to produce 1 minute data without 1 minute variability. Sixth, a statistical model was developed using historical ISO data from several existing wind farms to capture the 1 minute variability (compared to a 10 minute average) as a function of the size of the plant/wind farm. This statistical model captures the standard deviation of the 1 minute variability as it varies with wind farm size.
 18 19 20 21 22 23 24 25 26 27 	 curve fit function to produce 1 minute data without 1 minute variability. Sixth, a statistical model was developed using historical ISO data from several existing wind farms to capture the 1 minute variability (compared to a 10 minute average) as a function of the size of the plant/wind farm. This statistical model captures the standard deviation of the 1 minute variability as it varies with wind farm size. Finally, using this 1 minute statistical model, variability was then added to each 1
 18 19 20 21 22 23 24 25 26 27 28 	 curve fit function to produce 1 minute data without 1 minute variability. Sixth, a statistical model was developed using historical ISO data from several existing wind farms to capture the 1 minute variability (compared to a 10 minute average) as a function of the size of the plant/wind farm. This statistical model captures the standard deviation of the 1 minute variability as it varies with wind farm size. Finally, using this 1 minute statistical model, variability was then added to each 1 minute splined set of data using a process that adds variability randomly as a

Page 15 of 50

1		statistical model to determine operational regulation and load following
2		requirements. The hourly wind generation profiles were developed by averaging the
3		60 - 1 minute production data over each hour of the year.
4		
5	Q.	How did the ISO develop the Step 0 profiles for solar resources?
6	А.	The solar profiles were developed based on upon satellite irradiation data. The 1
7		minute solar data used for all new large solar plants was developed using a
8		methodology that includes the following steps or processes:
9		
10		First, a representative number of plants and their geographical orientation were
11		developed whose totals match the technology and number of megawatts in each
12		CREZ ⁷ in the CPUC study definition. The process to identify the number of units,
13		types, and locations for the projected additions uses as a starting point the renewable
14		additions identified as per the renewable portfolios being modeled and assumptions
15		about the renewable net short. Similar to wind, solar plants have a maximum size to
16		ensure that no single profile represented more than 10% of the total solar generation
17		to capture diversity properly.
18		
19		Second, selected representative half-hourly satellite solar irradiance data points
20		available in the 2005 Solar Anywhere solar data set were identified for each plant to
21		be modeled. Table 2, below, shows the number of square miles of land needed by a
22		solar plant that produces from 60-80 MWs, depending on the technology and
23		location. Thus for a plant of 140 MWs two 1 km square areas that are adjacent to
24		each other would be selected from the Solar Anywhere irradiance data set.
25		
26		

 $^{^7} Used \ solar \ CREZ \ info \ from \ RETI \ study \ \underline{http://www.energy.ca.gov/reti/documents/index.html}$

Page 16 of 50

Plant Technology Area Required in Square Miles for 10 **MW Facility** 0.0855 Square Miles⁸ Solar Thermal 0.093 Square Miles Solar PV without Tracking Solar PV with Tracking 0.093 Square Miles 2 3 Third, using this information about the land area needed for specific technologies, 4 5 the third step was to download the half-hourly irradiance data from the Solar Anywhere⁹ website for all of the 1 square kilometer areas needed to model all of the 6 7 large solar plants. 8 9 Fourth, hourly production data was developed for the plant for the appropriate 10 technology in each CREZ using hourly average Solar Anywhere irradiation data sets 11 for 2005 for each plant as input to the NREL SAM. The SAM model was used to 12 develop production data for six types of technologies – Solar PV with tracking, Solar PV without tracking and Solar Thermal using a Trough, Central Tower, 13 14 Central Tower with Storage, or Stirling engine. 15 16 Fifth, 1 minute production data was synthesized from the plant hourly production 17 data using a smooth cubic spline curve fitting function. This data did not yet 18 represent the minute to minute production variability that can be present in the 19 output of solar plants due to clouds or other factors. What it does represent is a plant 20 that captures the hourly variation of irradiance over its full plant footprint. 21 22 Sixth, Clear Sky profiles were developed for each plant by calculating the maximum 23 production for each hour for each month under clear skies (without clouds, fog, or

Table 2: Plant Area by Technology

⁸ Average of solar thermal tower and trough technology.

⁹ The Solar Anywhere satellite solar irradiance data can be found at: https://www.solaranywhere.com/Public/About.aspx

Page 17 of 50

other factors that would reduce the amount of irradiance that falls on earth's surface).

4 Seventh, variability was introduced into the smoothed 1 minute plant production 5 data using a process that inserted the variability captured from historical 1 minute 6 irradiance data from measurements collected by NREL's Measurement and Instrumentation Data Center (MIDC)¹⁰ at the SMUD Anatolia site in Rancho 7 Cordova, CA, Loyola Marymount University in Los Angeles, and the SolarCAT 8 9 station in Phoenix, AZ. At this stage in the process, the 1 minute data captures the variability of a plant that occupies the full plant footprint. This step is discussed in 10 11 more detail below.

Eighth, to reflect the fact that certain technologies have inherent time delays in their response to changes in irradiance, the data described in step 7 was processed in an inertial delay algorithm to arrive at the final 1 minute production data. This step was applied only to solar thermal plants as it is believed that solar PV plants have negligible time delay in their response to changes in irradiance. For the three types of solar thermal technologies (trough, tower and Stirling) three different characteristics were used as shown in Figure 22.




12

1

2

3



21 22 23

Figure 2: Response to Step Increase in Irradiance by Solar Thermal Technology v, Time in Minutes

¹⁰ www.nrel.gov/midc

Page 18 of 50

1		
2	Q.	Please provide additional detail about how the variability was introduced into
3		the Step 0 solar profiles.
4	А.	One minute variability is introduced into the smoothed 1 minute production data in
5		Step 7 above. This step in turn is made up of several steps.
6		First, a Data Library was developed of 1 minute variability from historical 1 minute
7		irradiance data collected by Sacramento Municipal Utility District (SMUD) in
8		Sacramento, Loyola Marymount University in Los Angeles, and the SolarCAT in
9		Phoenix, AZ. A summary plot of the raw historical irradiance data (in W/M^2) for the
10		Sacramento sites for a single month is shown in Figure 3.
11		
12		Second, this 1 minute data was converted to a normalized derate value by dividing
13		the 1 minute actual irradiance data by the irradiance measurement that would have
14		existed had there been no clouds in that minute (clear sky). The resulting data was
15		a set of 1 minute historical per unit irradiance derate values that ranged from 0 to
16		1.0, with 0 representing full reduction from a clear sky level to a zero irradiance
17		level and 1.0 representing no reduction from a clear sky level. Six different sets of
18		this 1 minute derate data were developed for solar thermal and solar PV for the
19		various sizes of plants (number of 1 kilometer squares in the plants footprint). A
20		moving average was applied to each of the libraries, based on the number of 1km
21		irradiance grids, to represent the 1 minute variability over the full footprint of the
22		plant. Thus six libraries are developed for use in the subsequent steps.
23		

Page 19 of 50





Figure 3: SMUD 1 Minute Irradiance Data for September 2009

The data plotted in the diagrams in Figure 3demonstrates that some days have little variability and other days have significant variability. Figure 4 shows the variability of a single day.





1 2 3

4 5

6

7

Figure 4: 1 Minute Irradiance for September 13, 2009

Page 20 of 50

2 To capture the fact that some hours are cloudless and other hours have clouds which 3 reduce the irradiance below its clear or cloudless sky level, variability was added to only those hours of production which show cloud cover impacts. The process first 4 5 converted the 1 minute smoothed production data for the plant into 1 minute derate 6 values that ranged from 0 to 1.0 similar to the 1 minute derate values in the 7 irradiance data library discussed earlier. This was accomplished by dividing the 8 smoothed 1 minute generation by the 1 minute generation that would have been 9 produced if there were no clouds in that minute (clear sky).

11 Next, average production derate values were calculated on an hourly basis from the 12 1 minute derate values. Then for each hour of the year that had a derate value lower 13 than 0.95, the 1 minute production derate values were replaced by an hour of 14 irradiance derate values from the library developed that had the same hourly derate 15 value. Which of the six libraries was used for this substitution depended on the 16 plant size (number of 1 Kilometer squares in the plant footprint). This step added 17 variability based upon historical data to the 1 minute production derate values while 18 maintaining the average derate over the hour at the same level as in the production 19 data.

20

22

23 24

25

26

27

28 29

30

31

32

1

10

21 Q. Did the ISO validate the variability results before finalizing the solar profiles?


Yes, we performed the following checks:

- □ To ensure that there were no significant step changes caused by the derate data substitution, the start minute and end minute derate values were tested to make sure they were within 1% of the minute before and the minute after the starting and ending minutes, respectively.
- □ To ensure that historical data was as representative as possible, substitution data was required to come from hours in the library that were within +/- 2 hours. For example, afternoon variability would not be applied to morning hours.
- 33□To increase the number of library "hours" available for substitution, sets of 60 134minute values (library hours) were created by shifting the start of the 60 minute

Page 21 of 50

1 2 3		period by 1 minute. For example, data from 2 hours could be used to construct 60 library hours.
4 5 6 7 8		□ To ensure that a bias was not introduced in the substitution process, a random selection process was used to find the derate data that met the end effects tolerances. This hourly process proceeded through the entire year to develop a full year of 1 minute production derate values.
9 10	Q.	What was the final step in developing the variability results?
11	A.	The final step converted the derate values into 1 minute production values by
12		multiplying the derate values by the 1 minute production expected from a plant
13		under clear sky conditions.
14		
15	Q.	Can you provide an example of the results of the variability process?
16	А.	Yes. The results of this process are shown graphically in the figures below. Figure
17		5 shows the hourly production data output of the SAM for May 16, 2020. Figure 6
18		shows the smoothed 1 minute production data and Figure 7 shows the production
19		data after historical variability has been added.
20		
21		
22 23		
23 24		

Page 22 of 50



1 Minute Smoothed Production Data for a Tracking PV in the Mountain Pass/Tehachapi for May 16, 2020

1 2

Figure 5: Hourly Production Data Output from SAM Model







Figure 6: Hourly Production Data Output from the SAM After Spline Fit

Page 23 of 50



2

1

3

Figure 7: Hourly Production Data Output from the SAM After Variability Is Added

4 Q. How did the ISO develop the Step 0 profiles for small solar PV?

5 Developing profiles for small solar PV resources presented a challenge. There are A. 6 approximately 9000 MW of various types of small solar PV in the Environmentally 7 Constrained Scenario and either 1000 MW or 2000 MW in the other scenarios. In 8 addition, there are approximately 2000 MW of small PV on the customer side of the 9 meter in all scenarios. The number of these plants is in the thousands, which 10 precludes these plants from being analyzed or modeled on an individual plant basis. 11 In addition, because of data confidentiality limitations, the supply side projects are 12 not easily located geographically.

13

14 Q. What was the ISO's approach to modeling the small solar profiles?

- A. Due to numbers, geographic and size diversity, and other factors, we decided to
 model these projects at an aggregate level.
- 17

Page 24 of 50

For the supply side, we defined a number of rectangular geographical areas as
 shown in Table 3 below to cover about 4-500 MWs of generation in each rectangle.
 (The use of a predetermined shape allowed more efficient coding and data
 processing).

The numbers in the column labeled "Number of Sites" is not the actual number of sites, which are in the thousands, but the number of projects selected from RPS Calculator, each of which would be distributed over many sites. The first five columns of the Table contain clarifying information provided to Nexant by ED staff as the profiles were being developed. The last two columns, "grids" and "MWs/ grid," were developed by Nexant as part of their modeling effort.

11 12

5 6

7

8

9

10

13

 Table 3: Small Supply Solar Projects as Defined by the CPUC

		<u> </u>		Defined by the CP		
Location	Sub-Type	Number of Sites				MWs/Grid
Central Valley	Large Ground	52	2677.7	23.56%	6	446
	Large Roof	7	710	20.37%	2	355
	Mid Ground	22	132.9	23.56%		Combine
	Small Ground	21	26.1	25.57%		Combine
Mojave	Large Ground	46	836.1	26.68%	2	418
	Large Roof	19	513.7	22.68%	1	514
	Mid Ground	21	12.5	26.68%		Combine
	Small Ground	21	3	29.36%		Combine
North Coast	Large Ground	31	725.2	21.87%	2	363
	Large Roof	19	929.9	19.56%	2	465
	Mid Ground	15	48.4	21.87%		Combine
	Small Ground	14	13.1	23.71%		Combine
South Coast	Large Ground	27	923.1	24.34%	2	462
	Large Roof	24	1517.7	21.17%	3	506
	Mid Ground	14	6.7	24.34%		Combine
	Small Ground	14	1.1	26.09%		Combine
Total		367	9077.2	Total	20	

- 14 15
- 15 16

17

18

For each square grid, we assumed that the plants are uniformly distributed over the grid. For the categories (rows) with relatively small amounts of generation, we decided that accuracy would not suffer if they were combined with other categories

- 19 that had similar technologies and capacity factors. For example, under Central
- 20 Valley there is 133 MW of Mid Ground and 26 MW of Small Ground. We

Page 25 of 50

determined that for modeling purposes these projects should be added to others in the same region with the same or similar characteristics.

Figure 8 shows the grids that are used for the 9000 MWs of solar PV.

How were the grids distributed geographically?


Q.

1

2

- 7 8
- 9

Figure 8: Distributed Solar Geographic Areas



10 11 12

In this geographic representation, blue squares are for large ground projects and 14 red squares are for large roof projects.

Page 26 of 50

1	Q.	Once the geographic boundaries were determined, what process did you follow
2		to develop the profiles?
3		
4		We selected 25 1 km by 1 km satellite irradiance data that was evenly distributed
5		over the grid. For some grids this might be one every 5 km and others might be one
6		every 20 km. That data was averaged on an hourly basis for each rectangle.
7		
8		Next, we processed the averaged irradiance data in the SAM to develop hourly
9		production for the MWs represented by the group. Using a cubic spline curve fit
10		function on the hourly production, we then developed 1 minute profiles for each
11		geographic area, which has no 1 minute variability.
12		
13		We added 1 minute variability to the 1 minute production data using algorithms
14		similar to those described above used for developing large solar plant profiles and,
15		as the final step, we developed clear sky production for each geographic area in the
16		same manner as with the large solar – by selecting the maximum production in each
17		hour for each month.
18		
19 20	Q.	What was the process used for developing small customer-side PV?
21	A.	The process for small PV on the customer side of the meter was similar to the
22		process used for small supply PV plants. Five grids were used, as presented on
23		Figure 9. Table 4 provides the location, size and capacity factor planning
24		assumptions for these customer side solar resources.
25		

Page 27 of 50

Location	Profile Name	Size MW	Туре	Capacity Factor
Central Valley	Distributed_Solar_1	349.9	fixed tilt	21.00%
Central Valley	Distributed_Solar_2	349.9	fixed tilt	21.00%
North Coast	Distributed_Solar_3	349.9	fixed tilt	21.00%
South Coast	Distributed_Solar_4	349.9	fixed tilt	21.00%
South Coast	 Distributed_Solar_5	349.9	fixed tilt	21.00%

Table 4: Aggregated Customer Side Distributed Solar

Figure 9: Customer Side PV Geographic Areas



1

Page 28 of 50

1	Q.	How were the 1-minute and hourly load profiles developed?
2	А.	The 1-minute load profiles were developed from actual 1-2005 actual load data.
3		The total system load was scaled up to match the hourly peak load in the CPUC
4		defined scenarios. The 1-minute hourly data was then averaged over 60-minutes to
5		produce an hourly load profile. The hourly load profiles were further adjusted to
6		ensure the total energy over the year was consistent with the CPUC planning
7		assumptions.
8		
9		These load profiles were posted to the ISO website as the ISO conducted its Step 0
10		modeling: 1-minute load http://www.caiso.com/2b3e/2b3ed83725ee0.csv and
11		hourly load: http://www.caiso.com/2b41/2b41d086444a0.zip.
12		
13		B. <u>STEP 1- MODELING LOAD FOLLOWING AND REGULATION</u>
14		<u>REQUIREMENTS</u>
15		
16	Q.	How did the ISO develop the Step 1 load following and statistical regulation
16 17	Q.	How did the ISO develop the Step 1 load following and statistical regulation requirements?
	Q. A.	
17		requirements?
17 18		requirements? The Step 1 load following and regulation requirements were developed from the
17 18 19		requirements? The Step 1 load following and regulation requirements were developed from the load, wind and solar 1 minute profiles developed in Step 0 along with distributions
17 18 19 20		requirements? The Step 1 load following and regulation requirements were developed from the load, wind and solar 1 minute profiles developed in Step 0 along with distributions of load, wind and solar forecast errors. This step in the study uses a stochastic
17 18 19 20 21		requirements? The Step 1 load following and regulation requirements were developed from the load, wind and solar 1 minute profiles developed in Step 0 along with distributions of load, wind and solar forecast errors. This step in the study uses a stochastic process developed by the ISO and PNNL that employs Monte Carlo simulation, a
17 18 19 20 21 22		requirements? The Step 1 load following and regulation requirements were developed from the load, wind and solar 1 minute profiles developed in Step 0 along with distributions of load, wind and solar forecast errors. This step in the study uses a stochastic process developed by the ISO and PNNL that employs Monte Carlo simulation, a sampling over multiple trials or iterations used to estimate the statistical
 17 18 19 20 21 22 23 		requirements? The Step 1 load following and regulation requirements were developed from the load, wind and solar 1 minute profiles developed in Step 0 along with distributions of load, wind and solar forecast errors. This step in the study uses a stochastic process developed by the ISO and PNNL that employs Monte Carlo simulation, a sampling over multiple trials or iterations used to estimate the statistical characteristics of a mathematical system. The simulation is designed to model
 17 18 19 20 21 22 23 24 		requirements? The Step 1 load following and regulation requirements were developed from the load, wind and solar 1 minute profiles developed in Step 0 along with distributions of load, wind and solar forecast errors. This step in the study uses a stochastic process developed by the ISO and PNNL that employs Monte Carlo simulation, a sampling over multiple trials or iterations used to estimate the statistical characteristics of a mathematical system. The simulation is designed to model aspects of the daily sequence of ISO operations and markets in detail, from hour-
 17 18 19 20 21 22 23 24 25 		requirements? The Step 1 load following and regulation requirements were developed from the load, wind and solar 1 minute profiles developed in Step 0 along with distributions of load, wind and solar forecast errors. This step in the study uses a stochastic process developed by the ISO and PNNL that employs Monte Carlo simulation, a sampling over multiple trials or iterations used to estimate the statistical characteristics of a mathematical system. The simulation is designed to model aspects of the daily sequence of ISO operations and markets in detail, from hour- ahead to real-time dispatch. The objective is to measure changes in operations at the
 17 18 19 20 21 22 23 24 25 26 		requirements? The Step 1 load following and regulation requirements were developed from the load, wind and solar 1 minute profiles developed in Step 0 along with distributions of load, wind and solar forecast errors. This step in the study uses a stochastic process developed by the ISO and PNNL that employs Monte Carlo simulation, a sampling over multiple trials or iterations used to estimate the statistical characteristics of a mathematical system. The simulation is designed to model aspects of the daily sequence of ISO operations and markets in detail, from hour- ahead to real-time dispatch. The objective is to measure changes in operations at the aggregate power system level, rather than at any particular location in the system.
 17 18 19 20 21 22 23 24 25 26 27 		requirements? The Step 1 load following and regulation requirements were developed from the load, wind and solar 1 minute profiles developed in Step 0 along with distributions of load, wind and solar forecast errors. This step in the study uses a stochastic process developed by the ISO and PNNL that employs Monte Carlo simulation, a sampling over multiple trials or iterations used to estimate the statistical characteristics of a mathematical system. The simulation is designed to model aspects of the daily sequence of ISO operations and markets in detail, from hour- ahead to real-time dispatch. The objective is to measure changes in operations at the aggregate power system level, rather than at any particular location in the system. The model provides realistic representations of the interaction of load, wind, and

Page 29 of 50

- 1 analysis is provided on Slides 3 and 4 of Exhibit 1. The detailed Step 1 hourly 2 results for the following scenarios are available at:
- 3

Scenario	Step 1 Results
Trajectory	http://www.caiso.com/2b49/2b4980da2f1e0.xls
Environmentally Constrained	http://www.caiso.com/2b49/2b49906560a70.xls
Cost Constrained	http://www.caiso.com/2b49/2b4980da2f1e0.xls
Time Constrained	http://www.caiso.com/2b4c/2b4c96c04f880.xls
Trajectory High Load	http://www.caiso.com/2b59/2b59ed4521ce0.xls

- 4
- 5

6

- **Q**.
 - Are the load, wind and solar forecast errors inputs into the Step 1 stochastic modeling process you described above?
- 8 A. Yes. As I describe below, the ISO developed distributions of forecast errors that are 9 defined by the standard deviation and correlation of error from time interval to the next based on actual forecast and load data for load and based on a T-1 persistence 10 11 method using the wind and solar profiles developed in Step 0.
- 12
- 13 Q. What are forecast errors and why is this data important to the Step 1 14 determination of grid operating characteristics?
- 15 A. Forecast errors quantify the magnitude of uncertainty one can expect when 16 forecasting load or generation production from variable resources such as wind and
- 17 solar resources. To ensure the ISO can balance supply and demand in real-time, the 18 ISO must consider the difference between supply and demand that can arise in case 19 actual conditions differ from forecasted conditions.
- 20
- 21
- 22

Page 30 of 50

1	Q.	Did you observe differences in the level of forecast errors between the 2009
2		vintage scenarios and the priority scenarios?
3	А.	Yes. These differences are depicted on Slide 59 of Exhibit 1. For the load
4		forecasts, we observed a significant reduction in hour ahead load forecast error.
5		This reduction is because our forecast is now based on forecasts that are produced
6		75 minutes prior to actual operating hour. The load forecast errors in the vintage
7		scenarios were based on load forecast that was produced 2 hours prior the operating
8		hour. In addition, the ISO has made improvements to its load forecasting tools.
9		
10		However, the 5 minute ahead forecast errors have increased some from prior
11		analysis. The 5-minute ahead forecast errors affect regulation more than load
12		following requirements.
13		
14		The wind forecast errors determined using the T-1 persistence method discussed
15		above resulted in modest reduction in forecast when compared the wind forecast
16		error used in vintage scenarios. However, the forecast errors observed in the T-1
17		persistence method have the level observed when compared to current Participating
18		Intermittent Resource Program (PIRP) resource wind forecast errors.
19		
20		Depending the technology and clear sky index, the solar forecast errors are in some
21		cases lower and other cases higher than the forecast errors used in the 2009 vintage
22		scenarios.
23		
24	Q.	How did the changes in forecast errors affect the Step 1 regulation and load
25		following requirements?
26	A.	The lower hour ahead and wind forecast errors contributed to a reduction in the load
27		following requirements observed in these priority scenarios when compared to the
28		vintage scenarios results. Only modest reductions in regulation requirements were
29		observed in part due to the offsetting effects of the high 5 minute load forecast
30		errors.

Page 31 of 50

1	Q.	How were the load forecast errors determined?
2	А.	The load forecast errors were determined for two different timeframes, the hour
3		ahead and each 5-minute interval within the operating hour. For each timeframe,
4		the forecast errors were calculated by taking the difference between the forecast
5		demand for that timeframe and the actual average demand for the corresponding
6		timeframe. Four probability density functions were approximated using a truncated
7		normal distribution that is defined by using the mean and standard deviation for the
8		forecast errors for each season. The hour ahead and 5-minute aggregated load
9		forecast errors were calculated using actual and forecast data for 2010.
10		
11	Q.	What were the load forecast errors that were calculated?
12	А.	The hour-ahead and 5-minute load forecast errors determined are presented on Slide
13		59 of Exhibit 1.
14		
15	Q.	How were the wind forecast errors determined?
16	А.	The hour ahead wind forecast errors are based on a T-1 persistence analysis.
17		
18	Q.	What is T-1 persistence analysis?
19	А.	T-1 persistence analysis compares the average production for an hour "t" with the
20		actual production from the previous hour "T-1 hour." The basis for this approach is
21		that a forecasting approach should be able to at least be no worse than an
22		assumption that what is produced in one hour will persist and reflect what is
23		produced the next hour.
24		
25	Q.	Why was a 1 hour comparison used?
26	А.	1 hour is used because currently the market structure and scheduling timelines in the
27		west require occurring on an hourly basis and are determined approximately 1 hour
28		ahead of the actual operating hour.
29 30		
30		

Page 32 of 50

1	Q.	What were the wind forecast errors that were calculated using the T-1 hour
2		persistence method?
3	А.	The hour-ahead wind forecast errors we determined are presented on Slide 61 of
4		Exhibit 1.
5		
6	Q.	How were the solar forecast errors determined?
7	А.	The solar forecast errors were determined based on a T-1 persistence analysis of the
8		clearness index for hours 12 though 16, separately for different solar technologies-
9		PV, solar thermal, distributed solar and customer side PV- using the profiles
10		developed in Step 0, and broken down into 4 different clearness index categories.
11		
12 13	Q.	Why were the solar forecast errors separated into the technology and clearness
14		index groupings you described above?
15	A.	The solar forecast error analysis was separated due to different solar technology
16		production patterns and variability as a function of solar irradiance. As a result,
17		separating the forecast error analysis by solar technology and clearness index
18		allows the ISO to better reflect the impacts of the relative quantity of different solar
19		technology.
20	0	
21	Q.	Why was the solar forecast error analysis limited to hours 12-16?
22	А.	The forecast error analysis was limited to hours 12-16 to avoid introducing errors
23		that result from sunrise and sunset which would distort T-1 persistence error
24		analysis. Hours 12-16 are hours where the clear sky solar irradiance is relatively
25		stable from one hour to the next and better reflects forecast conditions.
26		
27	Q.	Did the methodology for developing forecast error consider dispatch or
28		thermal inertial capabilities of solar thermal resources?
29	А.	No. In the analysis of solar forecast errors conducted so far, the ISO recognized
30		that there is further research needed to refine the impact on forecasting modeling of
31		plant-scale effects, operational properties and performance characteristics and

Page 33 of 50

1		capabilities of different solar technologies, including startup-up in the morning and
2		shutdown-down during the evening hours.
3		
4	Q.	Did you consult with others to develop the application of T-1 persistence
5		forecast error analysis method?
6	А.	Yes, this method was developed in collaboration with Andrew Mills, Principle
7		Research Associate with LBNL, who provided consultation services to ED staff.
8		
9	Q.	What were the solar forecast errors that were calculated using the T-1 hour
10		persistence method?
11	А.	The hour-ahead solar forecast errors determined are presented on Slide 65 of Exhibit
12		1.
13		
14	Q.	Please provide additional details about how the Step 1 modeling process was
15		used to calculate operational requirements.
16		A. A detailed description of the statistical analysis methodology is found in the
17		technical appendix to the ISO's 20% RPS integration study that I discussed earlier
18		in my testimony. The basic method is as follows: First, the load and renewable
19		production data is aggregated from the 1-minute data set to create averaged hour-
20		ahead and 5-minute dispatch schedules for each hour of the year. Second, the
21		probability distributions of forecast errors, and other statistical properties, such as
22		autocorrelation, for load, and wind and solar production in the hour-ahead and 5-
23		minute-ahead timeframes are constructed. Both wind and solar forecast errors are
24		used in the hour-ahead random draws. However, in the 5-minute time frame, the
25		ISO uses a wind persistence forecast, which is the basis for the simulation. Hence,
26		in the 5-minute sampling, the wind variability is preserved but the forecast error is
27		static for the period of the persistence model. For the solar resources, the 5-minute
28		forecast errors are modeled explicitly because of the more extreme morning and

Page 34 of 50

- evening ramp periods for solar in which persistence would not be an appropriate
 assumption.
- Third, the Monte Carlo sampling then conducts random draws from the load, wind and solar forecast errors, with consideration of autocorrelations between the errors, to vary the initial hour-ahead and 5-minute schedules. The Monte Carlo sampling is done on each hour in the sequence individually.¹¹
- Each simulation of a seasonal case includes 100 iterations over all hours in the
 season to capture a large number of randomly generated values. Of these simulated
 values, five percent are eliminated as extreme points, using a methodology that
 considers all dimensions being measured in the analysis (capacity, ramp and ramp
 duration).
- 12

13

C.

STEP 2 - USING PRODUCTION SIMULATION TO EVALUATE THE NETWORK AND DETERMINE OPERATIONAL NEEDS

14 Q. Please describe how the Step 2 production simulation analysis is used to 15 determine grid needs.

Step 2 production simulation is an hourly deterministic production simulation of the 16 A. 17 WECC, including California hourly dispatch with the objective of minimizing cost 18 while meeting the hourly load, spinning reserves, non-spinning reserves, regulation 19 requirements and load following requirements, subject to resource and inter-regional 20 transmission constraints. The regulation and load following requirements are 21 determined in the Step 1 analysis. If the production simulation is not able to meet 22 one or more of these requirements, a shortfall is identified and generic resource 23 capacity is introduced to resolve the shortfall. The generic resource additions are 24 identified as "needs" because additional resource capacity was needed to meet the 25 simultaneous requirements. A more detailed description of the production

¹¹ However, the twenty (20) minute ramps that characterize the boundary between actual hourly schedules are represented in the model to ensure that in those periods, deviations between the underlying schedules and the random draws do not exaggerate the result.

Page 35 of 50

1		simulation and its formulation can be found in Section D of the Integration of
2		Renewable Resources: Technical Appendix for California ISO Renewable
3		Integration Studies ¹²
4		
5	Q.	What model was used in the production simulation?
6	А.	The Step 2 underlying model is a Plexos Solutions representation of the WECC
7		Transmission Expansion Planning Policy Committee (TEPPC) model version PC0
8		dated March 21, 2011.
9		
10	Q.	Was this TEPPC PC0 model modified in any way to support these studies?
11	А.	Yes, the California portion of the model had to be reconciled and modified to
12		comply with the assumptions for the renewable scenarios described in the December
13		3, 2010 scoping memo.
14		
15	Q.	What specific modifications to the TEPPC model were made to comply with
16		the scoping memo?
17	А.	The load pattern in California was modified to reflect assumptions in the scoping
18		memo including accounting for energy efficiency and demand response. Supply
19		resources and patterns were modified to reflect the renewable resource build out as
20		well as planned retirement additions specified in scoping memo including expected
21		retirements of once through cooled (OTC) resources. The maximum import
22		capability into California was modified to reflect expected condition. The natural
23		gas prices in California were modified to reflect Market Price Referent (MPR)
24		method specified in the CPUC scoping memo. The natural gas prices used in
25		California can be found on slide 42 of Exhibit 1. CO2 price assumptions were used.
26		The details of these changes can be found at slides 32-43 of Exhibit 1.
27		

¹² <u>http://www.caiso.com/282d/282d85c9391b0.pdf</u>

Page 36 of 50

Q. Were there any other modification made to the model that were not specified in the CPUC LTPP scoping memo?

3 Yes. The allocation of regulation and load following reserves were distributed A. 4 between ISO and municipal load. Generator operating characteristics, profiles and 5 outage profiles were updated to reflect ISOs operational experience. Southern 6 California Import Transmission (SCIT) and Path 26 interface limits were modified. 7 Gas prices outside of California were updated to utilize a similar methodology used 8 to develop the California gas prices. Coal resource assumptions, including planned 9 retirements outside of California, were updated to reflect publicly available information about planned retirements. Details of these changes can be found at 10 11 Slides 45-55 of Exhibit 1.


12

Q. Do you have any more detail regarding how the gas prices outside of California were developed?

15 A. Yes, the ISO found it necessary to extend the MPR methodology to develop natural 16 gas prices for generators located outside of California. While the TEPPC PC0 case 17 does have pre-loaded fuel prices for all generators, it was important to ensure that the natural gas prices used outside of California were consistent with those used 18 19 inside of California in order to avoid introducing bias into the model's dispatch 20 calculations. E3 assisted the ISO in developing these natural gas prices by obtaining 21 basis spread prices from the New York Mercantile Exchange (NYMEX) for pricing 22 points outside of California that are contemporaneous with the Henry Hub natural 23 gas prices and basis spread prices used for California pricing points. The basis 24 spread prices represent locational price differences between Henry Hub, Louisiana 25 (the delivery location for the benchmark NYMEX natural gas futures contracts) and 26 local market pricing points throughout the West: Sumas, Permian, San Juan, and 27 Rockies. These basis spread prices are established through bilateral trading of basis "swaps," which are then cleared through the NYMEX Clearport clearing system. 28 29 Figure 10, below, shows the wholesale natural gas prices derived using this 30 methodology.

Page 37 of 50

1 2 3 Figure 10: 2020 Average Wholesale Natural Gas Prices for Major Western Pricing Points (2010 Dollars per MMBtu, based on a Henry Hub price of \$5.61/MMBtu)



4 5

6

7

8

9

E3 then applied the natural gas delivery charges from the TEPPC PC0 case, with two modifications to better reflect actual market conditions: (1) eliminated the TEPPC delivery charge for natural gas in British Columbia, and (2) established SoCal Border instead of Permian as the reference pricing point for Arizona. The table below shows the delivery charges applied in 2020.

11

- 12
- 13
- 14
- 15
- 16

Page 38 of 50

Generator Location	Natural Gas Hub	Natural Gas Delivery Point	Delivery Charge (2010 \$/MMBtu)
AESO	Rockies	AECO_C	-
APS	SoCal Border	Arizona	0.303
AVA	Sumas	Pacific_NW	0.094
BCTC	Sumas	Sumas	-
BPA	Sumas	Pacific_NW	0.094
CFE	SoCal Border	Baja	-
EPE	San Juan	San_Juan	
ID	SoCal Border	SoCal_BurnerTip	0. 438
LDWP	SoCal Border	SoCal Border	-
LDWP	SoCal Border	SoCal_BurnerTip	0.438
NEVP	SoCal Border	SoCal_Border	
NWMT	Rockies	Idaho_Mont	0.512
PACE UT	Rockies	Utah	0.271
PACW	Sumas	Pacific NW	0.094
PG&E BAY	PG&E Citygate	PGE Citygate BB	0.069
PG&E BAY	PG&E Citygate	PGE Citygate LT	0.230
PG&E VLY	SoCal Border	Kern River	0.359
PG&E VLY	PG&E Citygate	PGE Citygate BB	0.069
PG&E VLY	PG&E Citygate	PGE Citygate LT	0.230
PG&E VLY	SoCal Border	SoCal BurnerTip	0.359
PGN	Sumas	Pacific NW	0.094
PNM	San Juan	San Juan	-
PSC	Rockies	Colorado	0.553
PSE	Sumas	Pacific NW	0.094
SCE	SoCal Border	SoCal BurnerTip	0,438
SDGE	SoCal Border	Baja	-
SDGE	SoCal Border	SoCal BurnerTip	0.438
SMUD	PG&E Citygate	PGE Citygate BB	0.069
SMUD	PG&E Citygate	PGE Citygate LT	0.230
SPP	PG&E Citygate	Sierra Pacific	0.167
SRP	SoCal Border	Arizona	0.303
TEP	SoCal Border	Arizona	0.303
TIDC	PG&E Citygate	PGE_Citygate LT	0.281
TREAS VLY	Rockies	Idaho Mont	0.512
UTS	Rockies	Utah	0.271
WACM	Rockies	Wyoming	0.553
WALC	SoCal Border	SoCal Border	-

Table 5: Natural Gas Delivery Charges in 2020 (2010 \$/MMBtu)

1

In addition to the delivery charges, electric generators must pay state or local taxes in some areas. The following table lists these additional charges applied for the ISO's Step 2 analysis.

- 7
- 8

Page 39 of 50

		Natural Gas Delivery Point	Charge	Description	
		Arizona	5.6%	State excise tax	
		SoCal BurnerTip	1.5%	Municipal	
			1.570	Surcharge	
		PGE_Citygate BB	0.9%	Municipal Surcharge	
		PGE_Citygate LT	0.9%	Municipal Surcharge	
2					
3		The Natural Gas Prices in 202	20 (2010 \$/MM	Btu) for locations external to California	
4		locations can be found on slid	e 52 of Exhibit	: 1.	
5					
6	Q.	Were there any other modif	ications made	to the model after the presentation of	
7		the preliminary results at th	e workshop M	Iay 10, 2011?	
8	А.	Yes. As I have previously de	escribed, certain	n proposed changes to the model were	
9		the basis for the ISO and IOU	motion for ext	ension of time to submit testimony and	
10		were described in the May 31	, 2011 ALJ ruli	ng. Details of these changes are	
11		presented in Slides 77-80 of E	Exhibit 1.		
12		-			
13	Q.	Were there any production s	simulation me	thodology improvements	
14		incorporated into running tl	hese scenarios	?	
15	A.	Yes. Based on what the ISO	learned from r	unning the 2009 vintage scenarios, the	
16		ISO worked with Plexos to de	evelop improve	ements to the production simulation	
17		methodology to enhance perfo	ormance. These	se improvements are presented in Slides	
18		67-75 of Exhibit 1.			
19					
20	Q.	How was the production sin	ulation run u	sad to produce results?	
	-	-		-	
21	А.	-		r an 8760 hour/year long run using	
22			•	simulation was first run to determine	
23		any shortfalls and incremental	l resource need	s to resolve identified shortfalls. This	

Table 6: Additional Natural Gas Costs (2010 \$/MMBtu)

Page 40 of 50

run is referred to as the "need" run. For this "need" run, monthly maximum 1 2 requirements for regulation and load following were used for each hour to ensure 3 that the fleet had sufficient capability to meet a wide range of expected conditions for each month. After the "need" run was completed, a second production 4 simulation run was performed to determine production costs, annual fuel burn, 5 6 emissions and capacity factors. This second run is referred to as a "cost" run. For 7 the "cost" run, the hourly regulation and load following requirements were used to 8 better reflect the expected knowledge of requirements based on operational 9 conditions.

10

11 Q. What was the ISO's involvement in Step 3?

12 A. The ISO provided the production simulation results to E3, who was consulting for the IOUs to perform the Step 3 metrics. The ISO did not independently perform or 13 14 review the Step 3 metric analysis. As a working group member, E3 also performed 15 reconciliation of the model and the resource planning assumptions, as well as 16 developing the gas prices described above in my testimony. Because E3 produced 17 its work product as part of the working group, the ISO had an opportunity to review the results and verify the reasonableness of the data before adopting it into the 18 19 ISO's studies.

20

Q. Was the same load profile and distribution methodology used for the four priority scenarios?

A. Yes. For the peak demand calculation, Nexant consulted with ED staff and
 developed load profiles, based on the Statewide Net Peak Demand (70,964 MW)
 from Form 1.4¹³ of the CEC's 2009 IEPR. Exhibit 3 attached to my testimony sets
 forth the load profile energy and demand assumptions and adjustments made to the
 Form 1.4 peak quantities:

¹³ Form 1.4, Second Edition, <u>http://www.energy.ca.gov/2009publications/CEC-200-2009-012/adopted_forecast_forms/Chap1Stateforms-Adopted-09.xls</u>
Statewide Revised Demand Forecast Forms

Page 41 of 50

1		
2		□ 1,131 MW of upward adjustment were made to account for behind the meter PV
3		that was modeled as supply.
4		7005MW of downward adjustment was made to account for incremental energy
5		efficiency.
6		□ 1008MW of downward adjustment were made to account for behind the meter
7		CHP.
8		□ 327MW of downward adjustment was made to account for demand side
9		programs.
10		
11	Q.	How was the load distributed in the model?
12	A.	For the four priority scenarios, the load (hourly demand) was distributed on a pro-
13		rata basis to the eight bubbles using allocation factors based, in part, on the energy
14		data set forth on Exhibit 4 to this testimony. Exhibit 4 contains a set of data
15		developed by the CEC which contains annual peak energy and demand data for each
16		of the eight bubbles modeled in California. The peak energy values for each bubble
17		were used after an adjustment for the customer side PV energy to calculate
18		allocation factors for each of the eight bubbles used in the production simulation
19		analysis. These allocation factors were then used to allocate the hourly California
20		demand to the eight bubbles modeled. The customer side PV energy adjustment
21		was made by allocating 52% of the total customer side PV energy to the Northern
22		California bubbles and 48% to the Southern California bubbles based upon CEC
23		historical data.
24		
25		
26		
27		
28		

Page 42 of 50

1	Q.	Was the same load profile and distribution methodology used for the All Gas								
2		scenario?								
3	А.	No. For the All Gas scenario, the non-coincident peak demand for each bubble								
4		from Form 1.5b ¹⁴ was used. The total state wide, non-coincident peak demand in								
5		Form 1.5b is 70,799 MW. The load was adjusted to account for energy efficiency,								
6		CHP, demand response and customer side PV, using the same adjustments								
7		contained in Exhibit 3. Using this approach for the All Gas scenario resulted in a								
8		slightly lower total statewide load of 166MW versus the total load in the four CPUC								
9		priority scenarios discussed in the previous question.								
10										
11	Q.	How was the Helms Pumps storage facility modeled?								
12 13	А.	The model contains the following assumptions about the Helms pumps:								
13		□ There are three pumps that can operate simultaneously from January to May and								
15		from October to December. There will be only one pump available for the rest								
16		of year 2020.								
17 18		□ PG&E provided the following pump and usage targets. The storage should reach reservoir maximum volume at the end of May.								
		Pump/Usage								
		TargetJanFebMarAprMayJunJulAugSepOctNovDecPump (GWh)30.229.9								
		Usage (GWh) 13.5 18.0 18.0 10.6								
19		□ Based on that, the monthly initial and end storage volumes are set as follows:								
		Reservoir Storage Jan Feb Mar Apr May Jun Jul Aug Sep Oct Nov Dec								
		Initial Volume (GWh) 120 120 120 124 154 184 171 153 135 124 120 120								
•		End Volume (GWh) 120 120 124 154 184 171 153 135 124 120 120 120								
20										
21										

¹⁴ Form 1.5b, Second Edition, <u>http://www.energy.ca.gov/2009publications/CEC-200-2009-012/adopted_forecast_forms/Chap1Stateforms-Adopted-09.xls</u>

Page 43 of 50

1		
2	Q.	What was the basis for restricting Helms pumps in the scenarios?
3	A.	Based on ISO transmission planning studies and planned transmission upgrades for
4		2020, the ISO determined that the Helms pumping window would be restricted to
5		one pump due to the load level in the Fresno area.
6		
7	IV.	STUDY RESULTS
8		
9	Q.	Please describe the 33% integration study results for the four priority
10		scenarios.
11	А.	No upward incremental shortfalls were identified for the four priority scenarios,
12		and, thus, no incremental needs of resources beyond capacity already planned were
13		identified in any of these scenarios. However, the results show 506MW and
14		539MW shortfalls in downward load-following capacity in the Trajectory and
15		Environmentally Constrained scenarios, respectively. No downward load-
16		following shortfalls were observed in the Cost and Time Constrained scenarios. No
17		regulation shortfalls were observed in any of the four priority scenarios. Slides 10
18		and 11 of Exhibit 1 provide additional details about these observations.
19		
20	Q.	Do you anticipate any resource needs resulting from the observed shortfalls in
21		downward load following capacity?
22	А.	No, not necessarily for these particular scenarios. Based on the magnitude and
23		frequency of the observed shortfalls, storage or curtailment opportunities should be
24		considered in lieu of additional capacity.
25		
26	Q.	Were any shortfalls or needs identified in the All Gas or Trajectory High Load
27		scenarios that the ISO ran?
28	А.	Yes. We observed 1400MW capacity need in the All Gas scenario and 4600MW
29		capacity need in the High Load Trajectory scenario to resolve shortfalls in upward
30		ancillary service and load following. No downward load following shortfall was

Page 44 of 50

1 observed in the All Gas. Downward load following shortfalls up to 856MW were 2 observed in the Trajectory High Load scenario. Slides 10 and 11 of Exhibit 1 3 contain additional details about these observations. 4 5 **Q**. Can you explain why shortfalls are observed in the All Gas scenario and 6 **Trajectory High Load scenarios?** 7 A. In the All Gas scenario, all new renewable resources were removed (except for 8 1750MW of customer side solar) while no additional resources were added from the 9 base scenario. Due to the removal of such capacity, the flexible fleet capacity is being used to meet the load and does not remain available to meet the load 10 11 following and regulation upward requirements. What this indicates is that qualified 12 capacity in excess of the planning reserve margin in the four priority scenarios 13 provides sufficient unloaded flexible capacity to meet the load following and 14 regulation needs while the renewable resource capacity is meeting the load. In the 15 All Gas scenario the planning reserve margin is significantly reduced while still 16 maintaining the required planning reserve margin. In the Trajectory High Load 17 scenario, the load was increased by 10% over Trajectory Base Load scenario. At these high load levels the flexible fleet capacity needs to produce energy to meet the 18 19 load during higher load periods. As a result, remaining flexible capacity is 20 insufficient to simultaneously meet the load following requirements. 21 22 Q. Can you conclude from the four priority scenarios that no needs above 23 planning reserve margin exist to meet renewable integration? 24 No. The four priority scenarios reflect scenarios with resource capacity in excess A. 25 of the required planning reserve margin (PRM) of 15%-17%. Table 7 and Figure 26 11, below, show the planning reserve margin of the different scenarios as calculated 27 by E3. As a result, the excess capacity above PRM provides sufficient flexible capacity to meet the simultaneous energy, operating reserve, regulation and load 28 29 following requirements of these four scenarios. However, we cannot conclude from 30 these results whether sufficient flexible capability would exist to meet the

Page 45 of 50

simultaneous energy, operating reserve, regulation and load following requirements
if the available generation capacity was not in excess of the 15-17% PRM. For
example, if the utilities contract for less import qualifying capacity, just meeting
their PRM of 117%, the ISO may need to dispatch the capacity that is currently
unloaded and providing flexibility services in these cases, and therefore may be
short the needed flexible capacity. The four priority scenarios were not analyzed
assuming the PRM would just be met but not exceeded.

8

Table 7: Planning Reserve Margin Calculated by E3

)	Planning Reserve Margin	51%	46%	46%	46%	39%	35%
		Trajectory -Base Load		Cost Constrained	Time Constrained	All Gas	Trajectory-High Load






Figure 11: Planning Reserve Margin

13

Page 46 of 50

1	Q.	Do the results of the Trajectory High Load scenario reflect a realistic bookend?
2	А.	Not necessarily. As stated in the scoping memo, while the Trajectory High Load
3		scenario may be more reflective of any combination of future uncertainties, such as
4		increased load growth or programmatic performance, the scenario also does not
5		account for the possible local capacity resources that may be needed due to retiring
6		OTC resources and therefore may reflect an overly conservative supply scenario.
7		Once the ISO's OTC studies are completed, it may be appropriate to consider
8		repowering or scenarios that consider local capacity resources to assess what if any
9		needs may exist in a higher load scenario.
10		
11	Q.	How did the total WECC-wide production cost compare among the scenarios?
12	A.	The total production cost of the four priority scenarios are all within 0.3% of each
13		other, with WECC wide production costs ranging from \$18.85 billion for
14		Environmentally Constrained scenario to \$18.89 billion for the Cost Constrained
15		scenario. The production costs to meet WECC load in the All Gas scenario were \$
16		20.79 billion. The production costs to meet WECC load in the Trajectory High
17		Load scenario were \$19.63 billion. This information can be found on Slide 14 of
18		Exhibit 1.
19		
20	Q.	How did the production costs to meet California load compare among the
21		scenarios?
22	А.	The total production costs to meet the California load of the four priority scenarios
23		were within 4% of each other. The Time Constrained scenario had the highest
24		costs to meet California load (\$7.45 billion), while the Environmentally Constrained
25		scenario had the lowest cost to meet California load (\$7.17 billion). The production
26		costs to meet California load in the All Gas scenario were \$8.37 billion. The
27		production costs to meet California load in the Trajectory High Load scenario were
28		\$8.07 billion. This information can be found on Slide 18 of Exhibit 1.
29		

Page 47 of 50

1	Q.	How did the total WECC-wide fuel usage compare among the scenarios?
2	А.	The total WECC fuel usage for the four priority scenarios ranged from 5.366 billion
3		MMBtu in the Time Constrained scenario to 5.375 billion MMBtu in the
4		Environmentally Constrained scenario. The total WECC fuel usage in the All Gas
5		scenario was 5.810billion MMBtu. The total WECC emission in the Trajectory
6		High Load scenario was 5.544billion MMBtu. This information can be found on
7		Slide 19 of Exhibit 1.
8		
9	Q.	How did the California fuel usage compare among the scenarios?
10	A.	The total California fuel usage for the four priority scenarios ranged from 1.326
11		billion MMBtu in the Environmentally Constrained scenario to 1.341 billion
12		MMBtu in the Time Constrained scenario. The total California fuel usage in the All
13		Gas scenario was 1.417 billion MMBtu. The total WECC emission in the
14		Trajectory High Load scenario was 1.437billion MMBtu. This information can be
15		found on Slide 20 of Exhibit 1.
16		
17	Q.	How did the total WECC-wide emissions compare among the scenarios?
18	А.	The total WECC emissions for the four priority scenarios ranged from 364,684
19		million metric tons at a cost of \$13.238 billion in the Time Constrained scenario to
20		366,059 million metric tons at a cost of \$13.287 billion in the Environmentally
21		Constrained scenario. The total WECC emission in the All Gas scenario was
22		398,089 million metric tons at a cost of \$14.450 billion. The total WECC emission
23		in the Trajectory High Load scenario was 377,070 at a cost of \$13.687 billion. This
24		information can be found on Slides 21 and 22 of Exhibit 1.
25		
26	Q.	How did the emissions attributable to meet California load compare among the
27		scenarios?
28	А.	The Environmentally Constrained scenario reflects the lowest emissions of 76,101
29		million metric tons while the Time Constrained scenario had the highest among the
30		four priority scenarios of 80,987 million metric tons. The Trajectory High Load

Page 48 of 50

1		scenario had 85,822 million metric tons attributable to meet California load. The
2		all gas scenario has a 92,299 million metric tons meet California load. This
3		information can be found on Slide 24 of Exhibit 1.
4		
5	Q.	How did the California net import compare between the scenarios?
6	A.	The maximum imports between the four priority scenarios had similar maximum
7		California net import of approximately 12,000MW. The Cost and Time
8		Constrained scenarios had the highest average net imports due the higher imports
9		renewable capacity. Slide 17 of Exhibit 1 provides a comparison of California
10		average net import for the different scenarios.
11		
12	Q.	Did the Step 2 results provide any insight into start-ups and capacity factors of
13		the fleet?
14	A.	A higher average number of annual starts on California gas turbines of
15		approximately 80-100 starts/year are observed versus 40-55 starts/year observed for
16		the WECC. A lower average number of starts on California combined cycle
17		resources of 40 starts/year versus 70-80 starts/year observed for the WECC. The
18		capacity factor of WECC coal resources is approximately 60% in the scenarios. The
19		capacity factor for combined cycle resources in California and WECC are both in
20		the range of 40%. The capacity factor for gas turbines in California are
21		approximately 6.4% versus 8% for WECC. Slides 25 and 26 of Exhibit 1 provide a
22		comparison of start-up and capacity factors for California and WECC for the
23		different scenarios.
24		
25	Q.	Were there any sensitivity runs performed assuming Helms could pump with 3
26		pumps year round?
27	A.	Yes. As I discussed earlier in my testimony, the ISO performed a sensitivity run on
28		the Trajectory Base Load scenario assuming Helms could pump with 3 pumps year
29		round. The total annual production costs to meet California load was reduced by
30		\$2.3 million when Helms was not restricted. However, additional scenarios and

Page 49 of 50

1		benefit considerations are needed to fully evaluate the incremental benefit of having
2		greater access to Helms pumping capabilities.
3		
4	Q.	How will these sensitivity results be used by the ISO?
5	A.	These results, plus additional simulations and benefit analyses, will be provided to
6		ISO transmission planning engineers for consideration in the 2011/2012 planning
7		cycle.
8		
9	V.	NEXT STEPS
10		
11	Q.	Will the ISO continue to work on the 33% integration study?
12	А.	Yes. The ISO recognizes that these 33% integration studies are based on a set of
13		planning assumptions that will continue to evolve. The ISO intends to run
14		additional scenarios and sensitivities that are relevant to the ISO's operational
15		responsibilities. For example, as I discussed above, the ISO believes it is
16		operationally relevant to consider a case with local capacity resources needed to
17		meet local reliability needs to offset the retirement of OTC resources, once the ISO
18		completes the OTC studies. In addition, the ISO expects to perform assessments of
19		the resource adequacy fleet to assess whether the capacity and characteristics of the
20		current resource adequacy fleet will be adequate to meet the changing flexibility
21		needs of the system. Importantly, this resource adequacy assessment will consider
22		only the generation under resource adequacy contract in order to capture the
23		potential reality that generation capacity not under a resource adequacy contract will
24		not be available due to lack of sufficient revenues. As the ISO completes these and
25		potentially other operational scenarios, the ISO will make the results available and
26		can provide updates in the next LTPP case.
27		
28	Q.	Does this conclude your testimony?
29	А.	Yes, it does.


Exhibit 1



n al an A an an

Exhibit 1– 2010 CPUC LTPP Docket No. R.10-05-006

July 1, 2011




Step 1 Operational requirement results

- Regulation and load following requirements determined 2010 CPUC-LTPP scenarios
- New load, wind and solar profiles were developed
- Updated load, wind and solar forecast errors were used to calculated requirements
- Refer to appendix for changes to profile and forecast error
- Load following requirement reduced from vintage cases due to reduced forecast errors
- Regulation requirements increased in some hours due to increase in 5 minute load forecast




Slide 2


Step 1: Hourly regulation capacity requirements, by scenario



- For purposes of comparison, the figures show the single highest hourly seasonal requirement from Step 1 for each season (using the 95th percentile)
- The actual cases use the maximum monthly requirement by hour for need determination and hourly value for production cost and emissions
- Discussion of sensitivity in Section 3




Step 1: Hourly load-following capacity requirements, by scenario



Notes:

- For purposes of comparison, the figures show the single highest hourly seasonal requirement from Step 1 for each season (using the 95th percentile)
- The actual cases use the maximum monthly requirement by hour for need determination and hourly value for production cost and emissions
- Discussion of sensitivity in Section 3



總統的於在於 Renewable portfolios for 2020: 2010 LTPP Scenarios

激激激发

Scenario	Region	Biomass/ biogas	Geothermal :	SmallHydro	Solar PV	Distributed Solar	Solar Thermal	Wind	Total
Trajectory	CREZ-North CA	3	0	0	900	0	0	1,205	2,108
	CREZ-South CA	30	667	0	2,344	0	3,069	3,830	9,940
	Out-of-State	34	154	16	340	0	400	4,149	5,093
	Non-CREZ	271	0	0	283	1,052	520	0	2,126
	Scenario Total	338	821	16	3,867	1,052	3,989	9,184	19,266
Environmentally	CREZ-North CA	25	0	0	1,700	0	0	375	2,100
Constrained	CREZ-South CA	158	240	0	565	0	922	4,051	5,935
	Out-of-State	222	270	132	340	0	400	1,454	2,818
	Non-CREZ	399	0	0	50	9,077	150	0	9,676
	Scenario Total	804	510	132	2,655	9,077	1,472	5,880	20,530
Cost Constrained	CREZ-North CA	0	22	0	900	0	0	378	1,300
	CREZ-South CA	60	776	0	599	0	1,129	4,569	7,133
	Out-of-State	202	202	14	340	0	400	5,639	6,798
	Non-CREZ	399	0	0	50	1,052	150	611	2,263
	Scenario Total	661	1,000	14	1,889	1,052	1,679	11,198	17,493
Time Constrained	CREZ-North CA	22	0	0	900	0	0	78	1,000
	CREZ-South CA	94	0	0	1,593	0	934	4,206	6,826
	Out-of-State	177	158	223	340	0	400	7,276	8,574
	Non-CREZ	268	0	0	50	2,322	150	611	3,402
	Scenario Total	560	158	223	2,883	2,322	1,484	12,171	19,802
High Load	CREZ-North CA	3	0	0	900	0	0	1,205	2,108
	CREZ-South CA	30	1,591	0	2,502	0	3,069	4,245	11,437
	Out-of-State	34	154	16	340	0	400	4,149	5,093
	Non-CREZ	271	0	0	283	1,052	520	0	2,126
	Scenario Total	338	1,745	16	4,024	1,052	3,989	9,599	20,763



ISO 33% RPS Study of Operational Requirements and Market Impacts Slide 5

Renewable portfolios for 2020: 2010 LTPP Scenarios

睯騘鵋踜聮ៈៈៈៈៈ

Capacity (MW)	pacity (MW) 33% Trajectory		33% Env Constrained		33% Cost Constrained		33% Time		33% Trajectroy Low		33% Trajectory High		20% Trajectory		2009 Vintage 33%	
		Out-of-		Out-of-		Out-of-		Out-of-		Out-of-		Out-of-		Out-of-		Out-of-
	In-State	State	In-State	State	In-State	State	In-State	State	In-State	State	In-State	State	In-State	State	In-State	State
Biogas	178	0	178	66	168	73	172	73	178	0	178	0	178	0	1409	
Biomass	126	34	404	156	291	129	212	103	126	34	126	34	126	34	1409	
Geothermal	667	154	240	270	797	202	0	158	617	154	1,591	154	113	154	2598	
Hydro	0	16	0	132	0	14	0	223	0	16	0	16	0	16	680	
Large Scale Solar PV	3,527	340	2,315	340	1,549	340	2,543	340	3,147	340	3,684	340	1,509	340	5432	534
Small Scale Solar PV	1,052	0	9,077	0	1,052	0	2,322	0	1,052	0	1,052	0	1,052	0	3432	234
Solar Thermal	3,589	400	1,072	400	1,279	400	1,084	400	1,790	400	3,589	400	1,034	400	6902	
Wind	5,034	4,149	4,426	1,454	5,559	5,639	4,895	7,276	4,006	4,149	5,450	4,149	3,877	1,454	11291	3302
Total	14,173	5,093	17,711	2,818	10,696	6,798	11,228	8,574	10,916	5,093	15,670	5,093	7 <i>,</i> 889	2,398	28312	




ISO 33% RPS Study of Operational Requirements and Market Impacts Slide 6

SB GT&S 0619820

()計 計)

医医尿管腔炎 Planning Reserve Margin for 2020 Portfolios: **2010 LTPP Scenarios**

谢能能能能的



Note: Planning reserve margin calculated by E3



Production simulation results in this section reflect certain assumptions

- Intra-hourly operational needs from Step 1 assume monthly maximum requirements for each hour
 - Regulation, load-following
- Additional resources are added by the model to resolve operational constraints (ramp, ancillary services); this process determines potential need.
- Renewable resources located outside California to serve California RPS will create costs that will be paid for by California load-serving entities – see Step 3 results completed by California IOUs




The analysis adds resources above the defined case resource level to resolve an observed operational violations.

- LTPP analysis did not require adding any generic units to meet PRM because CPUC scoping memo assumptions create a 2020 base dataset that has a significant amount of capacity above PRM
- Next slide shows operational requirement shortages (constraint violations)
- Results for production costs, fuel use and emissions by scenario assume that these resources are added to generation mix



ISO 33% RPS Study of Operational Requirements and Market Impacts Slide 9 Under CPUC Scoping Memo assumptions, there are some hours with load following down shortages.


905 909 700 805 805 806 309 900 900 900 900 800 900 900




Note: No generic capacity is added to meet load following down shortage. Other measures, such as generation curtailment should be able to address this issue



Generic resources are added to meet upward ancillary services and load following requirements in the two additional cases.



Note: There is no upward ancillary service and load following shortage under CPUC Scoping Memo assumptions



908 1955 1956 1958 1956 1956 1956 1956 1956 1956 1958 1958 1958 1958 1956

Discussion of results on additional resources

- No upward violations identified in the 2010 Trajectory, Environmental, Cost Constrained and Time Constrained scenarios due to combination of lower loads and reduced requirements
- Limited number of hours and magnitude of load following down violations warrant curtailment or other measures to resolve
- Results are sensitive to assumptions about load level, requirements based on forecast error, mix of resources, and maintenance schedules




ISO 33% RPS Study of Operational Requirements and Market Impacts Slide 12 Production costs and fuel consumption by scenario

- Production costs based primarily on generator heat rates and assumptions about fuel prices in 2020
- Trends in production costs related to fuel burn and variable O&M (VOM) costs are thus closely related
- Production costs have to be assigned to consuming regions by tracking imports and exports
- Costs associated with emission are tracked separately from fuel and VOM costs



ISO 33% RPS Study of Operational Requirements and Market Impacts Slide 13 WECC (including California) annual production costs (in 2020 dollars) by case



Notes: production cost includes generation cost and startup cost



Components for calculating California production costs

CA GENERATION COSTS

CA IMPORTS

- Dedicated Resources
 - Renewables
 - Firmed
 - Non-Firmed
 - Conventional Resources
 - i.e., Hoover, Palo Verde
- Undesignated (or nondedicated) Resources
 - Marginal resources in various





ISO 33% RPS Study of Operational Requirements and Market Impacts Slide 15

CA EXPORTS

- Undesignated (or nondedicated) Resources
 - Marginal resources within CA regions

Calculating total California production costs

+ CA Generation Costs

• Costs to operate CA units (fuel, VOM, start costs)

+ Cost of Imported Power (into CA)


- Dedicated Import Costs
- Undesignated (or non-dedicated) Import Costs
- Out of State renewables (zero production cost)

Cost of Exported Power (out of CA)

• Undesignated (or non-dedicated) Export Costs


= Total Production Cost of meeting CA load

Note: Dedicated vs. Non-dedicated may also be known as specified or non-specified



服服用器控制 California annual net import results by case

谢谢杨颜刻






ISO 33% RPS Study of Operational Requirements and Market Impacts Slide 17

SB GT&S 0619831

())計 ())

Annual production costs associated with California load (accounting for import/exports), by case




Note: Production cost associated with non-dedicated import is calculated based on the average cost (\$/MWh) of each of the regions the energy is imported from; for dedicated import it is based on the actual production cost of each of the dedicated resource and its energy flows into CA

California ISO 33% RPS Study of Operational Requirements and Market Impacts Slide 18 **燃烧的除**器 WECC (including California) annual fuel usage (MMBtu), by case

鬱鬱

褑隇鵽穖餟艕餯劔陱劔颰颰斄龗龗疄蠂銊躢蘷朣輫睙蜠鶔鶔甋輣鐀嵼噟勴濪蛼閠鐕か蛼譝ジ疄麘瞱鋖濄誻勫闣か蓙蘠蘠嬻瘷朣颹蘷쭨贎蘷櫽隓鵽鯼繌鱫鱫繌鱫鱫**鯼**鯼蘷蘷蘷蘷




MMBtu = million BTU for conventional/fossil resources




医医尿管炎炎 California annual in-state generation fuel usage by case


體體態影




MMBtu = million BTU for conventional/fossil resources




WECC (including California) annual emissions by case






()) 前


WECC (including California) annual emission costs by case






Calculation of emissions associated with California

- Production simulation modeling output includes GHG emissions (tons) per generator to capture WECC-wide emissions reductions, but:
 - The model solves production simulation for the WECC without considering contractual resources specifically dedicated to meet California load
 - Not all out of state (OOS) RPS energy dedicated to CA may "flow" into CA for every simulated hour as it could in actual operations (thus reducing emissions in CA)
- The emissions benefit of OOS RPS energy dedicated to California is counted towards meeting California load, the study uses an *ex post* emissions accounting method (next slide)



Emissions attributed to meet California load (accounting for Import/Exports), by scenario and emissions source




Note: Emissions associated with non-dedicated import is calculated based on the average emission rate (ton/GWh) of each of the regions the energy is imported from; for dedicated import it is based on the actual emission of each of the dedicated resource and its energy flows into CA


California ISO

ISO 33% RPS Study of Operational Requirements and Market Impacts Slide 24

WECC and California annual average capacity factors by case



WECC and California annual average number of startup by case



Comparison of WECC (including CA) and CA results

Case	Trajectory	Environment	Cost	Time	All-Gas	High-Load
1		Annual Aver	rage Capaci	ty Factor (%)		
WECC				• •		
CCGT	39.9	39.8	40.0	40.3	45.5	42.3
GT	7.7	8.1	8.2	7.8	8.7	7.7
ST	13.3	13.4	13.5	13.5	16.1	14.1
Coal	59.0	59.5	59.0	58.4	63.7	60.0
CA					•	
CCGT	41.3	40.4	40.7	41.7	46.1	45.5
GT	6.4	6.3	6.4	6.3	5.6	6.3
ST	8.9	8.7	9.2	9.1	9.1	9.5
Coal	N/A	N/A	N/A	N/A	N/A	N/A
		Number of	Start per U	nit per Year		
WECC					and the second se	-
CCGT	75.7	74.9	77.4	76.8	82.2	77.9
GT	54.7	55_6	49.3	49.0	53.8	68.1
ST	67.9	69.1	70.9	70.7	79.4	71.8
Coal	39.7	39.2	41.9	40.7	44.2	41.1
CA						
CCGT	43.9	42.3	42.6	42.8	44.9	44.0
GT	100.9	104.9	81,4	82.9	84.0	134_8
ST	37.0	34.2	37.1	38.4	45.5	40.4
Coal	N/A	N/A	N/A	N/A	N/A	N/A



ISO 33% RPS Study of Operational Requirements and Market Impacts Slide 27

線 館 🏥

APPENDIX: PRODUCTION SIMULATION MODEL CHANGES



Slide 28

SB_GT&S_0619842

Overview of Step 2 Database and Modeling

- To conduct the LTPP Step 2 analysis, an up-to-date PLEXOS database was required
- ISO used the 33% operational study PLEXOS database as a starting point
- Input data from this database were changed to align with the assumptions in the CPUC scoping memo
- Non-specified assumptions were updated by the ISO to reflect operational feasibility and to include the best publically available data
- To ensure the April 29th deadline was met, PLEXOS implemented several modeling enhancements to improve simulation efficiency





- Two sets of key inputs: CPUC specified assumptions and non-specified assumptions updated by the ISO
- Assumptions stated in the CPUC Scoping Memo
 - Load forecast that includes demand side reductions
 - Renewable resource build-out
 - Existing, planned and retiring generation
 - Maximum import capability to California
 - Gas price methodology for California
 - CO₂ price assumption
- Non-specified assumptions updated by the ISO
 - Allocation of reserve requirements between ISO and munis
 - Generator operating characteristics and profiles
 - Operational intertie limits
 - Loads, resources, transmission and fuel prices outside of California





CPUC SPECIFIED ASSUMPTIONS



Slide 31

SB_GT&S_0619845



- Nexant created a load profile that was consistent with the CPUC's forecasted load for the analysis of the four LTPP scenarios
- Load profile adjustment made to the CPUC specified demand side resources
 - Energy efficiency
 - Demand side CHP
 - Behind-the-meter PV modeled as supply
 - Non-event based demand response




Generation - CPUC Generation Dataset

- CPUC provided data on existing, planned and retiring generation facilities
- Existing resources specified by the CPUC were drawn from two resources:
 - 2011 Net Qualifying Capacity (NQC) as of August 2nd, 2010
 - ISO master generation list
- Additions and non-OTC retirements are drawn from the ISO OTC scenario analysis tool; other additions are resources with CPUC approved contracts that do not have AFC permits approved
 - Combined cycle resources in CPUC planned additions were modeled with generic unit operating characteristics taken from the MPR
- OTC retirements taken from the State Water Board adopted policy with several CPUC modifications



CPUC Supply Side CHP and DR Specifications

- Existing CHP and DR bundles in the 33% operational study PLEXOS database were scaled to match the incremental supply side CHP and DR goals in the CPUC scoping memo
- 761 MW of incremental supply side CHP was assumed to be online in 2020 with a heat rate of 8,893 Btu/kWh per the CPUC scoping memo
- 4,817 MW of incremental DR was modeled as supply in 2020 (including line losses)
 - Non-event based DR was included in the load profiles and not in the Step 2 database as supply side resource



Load and Resource Balance with CPUC assumptions

 The CPUC Scoping Memo assumptions estimate a 17,513 MW surplus above Planning Reserve Margin in 2020 in the ISO

Load and Resource Balance in the ISO using CPUC Resource Assumptions (MW)												
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020		
Load												
ISO Summer Peak Load	49,143	49,902	50,678	51,283	51,913	52,555	53,246	53,905	54,571	55,298		
Total Demand Side Reductions	(3,432)	(4,712)	(5 <i>,</i> 650)	(6,374)	(7,187)	(8,036)	(8,936)	(9,874)	(10,776)	(11,651)		
Net ISO Peak Summer Load	45,711	45,190	45,028	44,909	44,726	44,519	44,310	44,031	43,795	43,647		
Resources					a a a a a a a a a a a a a a a a a a a	An Distance			- Additional And And			
Existing Generation	52,435	52,435	52,435	52,435	52 <i>,</i> 435	52,435	52,435	52,435	52,435	52,435		
Retiring Generation	(1,260)	(1,425)	(1,425)	(2,434)	(4,694)	(5,646)	(10,378)՝	(11,329)	(12,280)	(14,357)		
Planned Additions (Thermal, RPS, CHP)	1,747	4,388	6,728	7,336	10,558	11,280	12,207	12,283	13,471	13,547		
Net Interchange (Imports- Exports)	16,955	16,955	16,955	16,955	16,955	16,955	16,955	16,955	16,955	16,955		
Summary					2.6.400.0000000	Sold in case of the second sec			*HAMMONOTH-4			
Total System Available Generation	69 <i>,</i> 877	72,353	74 <i>,</i> 693	74,292	75,254	75,024	71,219	70,344	70,581	68,580		
Total System Capacity Requirement (PRM)	53,482	52,872	52,683	52,544	52,329	52,087	51,843	51,516	51,240	51,067		
Surplus	16,395	19,480	22,010	21,748	22,924	22,936	19,376	18,827	19,340	17,513		



Slide 35

and and see our link she had see her link the link her link and

Updating Generation Data in 33% Operational Database

- The generation data in the 33% operational database were updated to reflect the specified existing, planned and retiring facilities in the CPUC scoping memo
- ISO also solicited feedback from the working group, stakeholders via ISO market notice and also all parties on the LTPP service list on generator operating characteristics which was incorporated into the Step 2 database
- ISO found some discrepancies in the CPUC generation assumptions which it has corrected in its Step 2 database and accounting:
 - Double-counting of the Ocotillo facility
 - Renewable resource capacity additions above what is chosen in the 33% RPS calculator
 - Double counting of several resources as both imports and resources





- CPUC scoping memo includes two separate facilities in its planned additions for Ocotillo (455 MW) and Sentinel (850 MW)
- Ocotillo is a subset of the Sentinel facility (units 1-5)
 - SCE signed a contract with Sentinel for an additional three units in 2008
- ISO Step 2 database only includes eight Sentinel units (850 MW) because Ocotillo (455 MW) is already accounted for in Sentinel's nameplate capacity



RPS Resources above 33%

- CPUC included 287 MW of RPS resources in its planned additions that are not included in the 33% RPS scenarios:
 - CalRENEW-1(A) (5 MW)
 - Copper Mountain Solar 1 PseudoTie-pilot (48 MW)
 - Vaca Dixon Solar Station (2 MW)
 - Blythe Solar 1 Project (21 MW)
 - Calabasas Gas to Energy Facility (14 MW)
 - Chino RT Solar Project (2 MW)
 - Chiquita Canyon Landfill (9 MW)
 - Rialto RT Solar (2 MW)
 - Santa Cruz Landfill G-T-E Facility (1 MW)
 - Sierra Solar Generating Station (9 MW)
 - Celerity I (15 MW)
 - Black Rock Geothermal (159 MW)
- If included, these resources will create RPS scenarios that are above 33% RPS
- These resources were not profiled in the Step 1 analysis
- ISO did not include these resources in the Step 2 database



Slide 38

Existing Generation/Imports Discrepancies

- The 2011 NQC list includes 2,626 MW of resources that are imports to the ISO
 - APEX_2_MIRDYN (505 MW)
 - MRCHNT_2_MELDYN (439 MW)
 - MSQUIT_5_SERDYN (1,182 MW)
 - SUTTER_2_PL1X3 (500 MW)
- The CPUC's original L&R tables counted the capacity of these resources twice:
 - 1. Directly, as specified resources with NQC capacity
 - 2. Indirectly, by assuming full transmission capability into the ISO
- For accounting purposes and to avoid double accounting, ISO has removed these resources from the available generation but maintains the assumption of full transmission capability into the ISO
- Modeled Coolwater 3 and 4 instead of assumed retired.



Load and Resource Balance After Assumption Modifications

 Accounting for all of these modifications, the load and resource balance has a surplus of 14,144 MW above PRM in 2020, compared to 17,513 MW above PRM using the CPUC assumptions

Load and Resou	urce Balanc	e in the l	SO using	CAISO Res	ource Mo	dification	s (MW)			
	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
Load										
Summer Peak Load	49,143	49,902	50,678	51,283	51,913	52,555	53,246	53,905	54,571	55,298
Total Demand Side Reductions	3,432	4,712	5,650	6,374	7,187	8,036	8,936	9,874	10,776	11,651
Net Peak Summer Load	45,711	45,190	45,028	44,909	44,726	44,519	44,310	44,031	43,795	43,647
Resources										
Existing Generation	49,809	49,809	49,809	49,809	49,809	49,809	49,809	49,809	49,809	49,809
Retiring Generation	(1,260)	(1,425)	(1,425)	(2,434)	(4,694)	(5,646)	(10,378)	(11,329)	(12,280)	(14,357)
Planned Additions (Thermal, RPS, CHP)	1,618	4,259	6,440	7,048	9,815	10,537	11,464	11,540	12,728	12,804
Net Interchange (Imports - Exports)	16,955	16,955	16,955	16,955	16,955	16,955	16,955	16,955	16,955	16,955
Summary										
Total System Available Generation	67,122	69,598	71,779	71,378	71,885	71,655	67,850	66,975	67,212	65,211
Total System Capacity Requirement (PRM)	53,482	52,872	52,683	52,544	52,329	52,087	51,843	51,516	51,240	51,067
Surplus Above PRM with CAISO Modifications	13,640	16,726	19,096	18,834	19,556	19,568	16,007	15,459	15,972	14,144
Surplus Above PRM with CPUC Assumptions	16,395	19,480	22,010	21,748	22,924	22,936	19,376	18,827	19,340	17,513
Difference in Surplus between CPUC and CAISO	2,755	2,755	2,914	2,914	3,369	3,369	3,369	3,369	3,369	3,369



MPR Gas Forecast Methodology

- CPUC Scoping Memo specifies that the LTPP proceeding use a gas forecast calculated using the same methodology as the Market Price Referent (MPR) using NYMEX data gathered from 7/26/2010 – 8/24/2010
 - MPR methodology provides a transparent framework to derive a forecast of natural gas prices at the utility burner-tip in California
 - In the near term (before 2023), the forecast is based on:
 - 1. NYMEX contract data for natural gas prices at Henry Hub and basis point differentials between HH and CA
 - 2. A municipal surcharge, calculated as a percentage of the commodity cost
 - 3. A gas transportation cost based on the tariffs paid by electric generators





2020 natural gas forecast for CA delivery points • (2010\$/MMBtu)

Zone	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Gas - PGE_Citygate	\$ 5.95	\$ 5.92	\$ 5.75	\$ 5.31	\$ 5.29	\$ 5.34	\$ 5.41	\$ 5.45	\$ 5.47	\$ 5.54	\$ 5.79	\$ 6.04
Gas - PGE_Citygate_BB	\$ 6.07	\$ 6.04	\$ 5.87	\$ 5.43	\$ 5.41	\$ 5.46	\$ 5.53	\$ 5.57	\$ 5.59	\$ 5.66	\$ 5.92	\$ 6.17
Gas - PGE_Citygate_LT	\$ 6.23	\$ 6.20	\$ 6.03	\$ 5.59	\$ 5.57	\$ 5.62	\$ 5.69	\$ 5.73	\$ 5.75	\$ 5.82	\$ 6.08	\$ 6.33
Gas - SoCal _Border	\$ 5.74	\$ 5.70	\$ 5.54	\$ 5.13	\$ 5.11	\$ 5.16	\$ 5.23	\$ 5.27	\$ 5.29	\$ 5.36	\$ 5.58	\$ 5.83
Gas - SoCal_Burnertip	\$ 6.18	\$ 6.15	\$ 5.98	\$ 5.57	\$ 5.54	\$ 5.60	\$ 5.67	\$ 5.71	\$ 5.72	\$ 5.80	\$ 6.02	\$ 6.28



Slide 42



 A \$36.30/short ton of CO₂ (2010\$) cost was used in the PLEXOS simulations per the CPUC scoping memo



Slide 43

SB_GT&S_0619857



NON-SPECIFIED ASSUMPTIONS UPDATED BY ISO



Slide 44

SB_GT&S_0619858

Allocation of Reserves Between ISO and Munis

- Step 1 analysis created statewide load following and regulation requirements
- Step 2 is an ISO-wide analysis that requires an allocator to split the load following and regulation requirements between the IOUs and Munis
- Allocator calculated using two parts:
 - 50% of allocator = ratio of peak load between the ISO (83%) and Munis (17%)
 - 50% of allocator = fraction of wind and solar resources delivered to California that are integrated by the ISO (94%) and Munis (6%)
- This results in the following allocation of the reserve requirements: 88.5% to the ISO and 11.5% to the Munis



Update of Generator Operating Characteristics

- ISO received feedback from 4 stakeholders on information in the 33% operational study PLEXOS database
 - Comprehensive list of changes came from SCE and included updated information on individual generator operating characteristics and SP15 hydro dispatch
 - Calpine submitted a new start profile for CCGTs
- CT planned additions and generic units were mapped to the operating characteristics of an LMS100 or LM6000 depending on plant size



Helms modeling

- PG&E updated the maximum capacity of the Helms reservoir to 184.5 GWh
- PG&E provided end of spring reservoir energy storage target and summer monthly energy usage schedules
- ISO consulted with PG&E to develop the appropriate pumping windows in 2020
 - availability in the summer months, Helms pumping was restricted to 1 pump between May and September
 - 3 pumps were assumed to be available for October through April
- Continued discussions with PG&E suggest that three pump capability in 2020 in non-summer months may not be possible; may warrant additional sensitivities

California ISO

Transmission Import Limits to CA

- ISO defined simultaneous import limits to CA
- ISO used a model developed by the ISO to estimate the Southern California Import Transmission (SCIT) limit based on
 - planned thermal additions
 - OTC retirements
 - renewable resources additions
 - neighboring transmission path flows into and around the SCIT area



Import Limits by Scenario and Time

Tranamiacian Limita (BANA/)	Summer	Summer	WinterPk	WinterOff
TransmissionLimits(MW)	Pk	Off Pk	winterek	Pk
TrajectoryCase				
S. Cal Import Limit to be used for study	12,726	10,290	11,331	8,405
Total California Import Limit	13,526	11,090	12,131	9,205
Environmental Case		13.0.0.0.0.0.0.0.0.0.0.0.0.0.0.0.0.0.0.0		
S. Cal Import Limit to be used for study	12,724	10,224	11,349	8,340
Total California Import Limit	13,524	11,024	12,149	9,140
Cost Case				
S. Cal Import Limit to be used for study	12,833	10,186	11,457	8,302
Total California Import Limit	13,633	10,986	12,257	9,102
Time Case		*****		
S. Cal Import Limit to be used for study	12,819	10,224	11,427	8,340
Total California Import Limit	13,619	11,024	12,227	9,140
All-Gas				
S. Cal Import Limit to be used for study	14,086	10,735	12,110	8,851
Total California Import Limit	14,886	11,535	12,910	9,651
High-Load				
S. Cal Import Limit to be used for study	12,610	10,237	11,270	8,352
Total California Import Limit	13,410	11,037	12,070	9,152



Slide 49

部級

Assumptions of Gas Forecast Outside of CA

- The MPR methodology provides a forecast of gas prices for generators inside of California
- In order to avoid skewing the relative competitive position of gas fired generators inside and outside of California, WECC-wide gas prices outside of California must be updated to reflect the same underlying commodity cost of gas embedded in the MPR forecast



Gas Forecast Outside of CA (cont'd)

- Created an MPR-style forecast for gas prices elsewhere in the WECC drawing upon available NYMEX contract data over the same trading period (7/26/10 – 8/24/10):
 - In addition to the California gas hubs (PG&E Citygate and Socal Border), forecast hub prices at Sumas, Permian, San Juan, and Rockies hubs using the NYMEX basis differentials
 - For each bubble (geographic area), add appropriate delivery charges (based on TEPPC delivery charges) to the appropriate hub price to determine the burnertip price
- Two specific changes were made to this methodology based on IOU feedback:
 - Arizona gas hub was moved from Permian to SoCal Border
 - Delivery charge was removed from Sumas hub to British Columbia



國國國際總統() Gas Forecast Outside of CA

酸酸酸酸

2020 natural gas forecast for delivery points outside of • California (2010\$/MMBtu)

Zone	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Gas - AECO_C	\$ 5.49	\$ 5.46	\$ 5.29	\$4.72	\$ 4.69	\$ 4.75	\$4.82	\$ 4.86	\$ 4.88	\$ 4.95	\$ 5.34	\$ 5.59
Gas - Arizona	\$ 6.06	\$ 6.02	\$ 5.85	\$ 5.42	\$ 5.39	\$ 5.45	\$ 5.52	\$ 5.57	\$ 5.58	\$ 5.66	\$ 5.89	\$ 6.16
Gas - Baja	\$ 5.74	\$ 5.70	\$ 5.54	\$ 5.13	\$ 5.11	\$ 5.16	\$ 5.23	\$ 5.27	\$ 5.29	\$ 5.36	\$ 5.58	\$ 5.83
Gas - Colorado	\$ 6.08	\$ 6.04	\$ 5.88	\$ 5.42	\$ 5.39	\$ 5.45	\$ 5.52	\$ 5.56	\$ 5.57	\$ 5.65	\$ 5.92	\$ 6.17
Gas - Idaho_Mont	\$6.00	\$ 5.97	\$ 5.81	\$ 5.23	\$ 5.21	\$ 5.26	\$ 5.33	\$ 5.37	\$ 5.39	\$ 5.46	\$ 5.85	\$ 6.10
Gas - Kern_River	\$ 5.74	\$ 5.70	\$ 5.54	\$ 5.13	\$ 5.11	\$ 5.16	\$ 5.23	\$ 5.27	\$ 5.29	\$ 5.36	\$ 5.58	\$ 5.83
Gas - Malin	\$5.98	\$ 5.95	\$ 5.79	\$ 5.10	\$ 5.07	\$ 5.13	\$ 5.20	\$ 5.24	\$ 5.26	\$ 5.33	\$ 5.83	\$ 6.08
Gas - Pacific_NW	\$ 6.11	\$ 6.08	\$ 5.91	\$ 4.98	\$ 4.95	\$ 5.01	\$ 5.08	\$ 5.12	\$ 5.14	\$ 5.21	\$ 5.96	\$ 6.21
Gas - Permian	\$ 5.58	\$ 5.54	\$ 5.38	\$ 5.01	\$ 4.99	\$ 5.04	\$ 5.11	\$ 5.15	\$ 5.17	\$ 5.24	\$ 5.42	\$ 5.67
Gas - Rocky_Mntn	\$ 5.49	\$ 5.46	\$ 5.29	\$ 4.72	\$ 4.69	\$ 4.75	\$4.82	\$ 4.86	\$ 4.88	\$ 4.95	\$ 5.34	\$ 5.59
Gas - San_Juan	\$ 5.52	\$ 5.499	\$ 5.3 <i>2</i> °	\$ 4.86	\$ 4.84	\$4.89 ⁹	\$ 4.96	\$ 5.00	\$ 5.02°	\$ 5.09	\$ 5.377	\$ 5.62°
Gas - Sierra_Pacific	\$6.12	\$ 6.08	\$ 5.92	\$ 5.48	\$ 5.46	\$ 5.51	\$ 5.58	\$ 5.62	\$ 5.64	\$ 5.71	\$ 5.96	\$ 6.21
Gas - Sumas	\$ 6.02	\$ 5.98	\$ 5.82	\$ 4.89	\$4.86	\$ 4.92	\$ 4.99	\$ 5.03	\$ 5.04	\$ 5.11	\$ 5.86	\$ 6.11
Gas - Utah	\$ 5.76	\$ 5.73	\$ 5.56	\$ 4.99	\$ 4.97	\$ 5.02	\$ 5.09	\$ 5.13	\$ 5.15	\$ 5.22	\$ 5.61	\$ 5.86
Gas - Wyoming	\$ 6.05	\$ 6.01	\$ 5.85	\$ 5.27	\$ 5.25	\$ 5.30	\$ 5.37	\$ 5.41	\$ 5.43	\$ 5.50	\$ 5.89	\$ 6.14





- PCO, a recent TEPPC database, was used to populate the PLEXOS database with loads, resources and transmission capacity for zones outside of California
- Embedded in this case were several coal plant retirements
- ISO incorporated several adjustments to this case:
 - Included several additional coal plant retirements that were announced but not included in PC0
 - Excluded the resources assumed to contribute to California's RPS portfolio that are located outside of California



Exclusion of RPS Resources from PCO

TEPPC's PCO case includes enough renewables to meet RPS goals in California and the rest of ٠ the WECC

- The portfolio for California is very similar to the Trajectory Case specified for the LTPP, which includes out-of-state renewables
- To develop consistent scenarios for LTPP, the RPS builds for CA in PCO must be adjusted ٠ according to the following framework:

		State	Resource	MW	GWh
		New Mexico	Biomass	39	231
		Idaho	Geothermal	27	198
	WECC-Wide RPS Resources in PC0	Nevada	Geothermal	76	561
MAXY SHIP MAY REPORT AN ADD DOT TO DEMAND REPORT OF DAMAGEN & SATTLE		Utah	Geothermal	120	885
	PC0 RPS Resources in CA	British Columbia	SmallHydro	90	442
		Oregon	Small Hydro	13	50
500004	PC0 OOS RPS Resources Attributed to CA	Nevada	Solar Thermal	285	933
	r co oos hi s hesources Attributed to eA	Arizona	Solar PV	39 27 76 120 90 13	737
		Nevada	Solar PV	23	41
+	CPUC RPS Portfolio (Traj/Env/Cost/Time)	Alberta	Wind	1,565	4,843
		Colorado	Wind	517	1,298
	RPS-Compliant LTPP Scenario	Montana	Wind	262	818
		Oregon	Wind	871	2,373
		Washington	Wind	1,252	3,004
		Wyoming	Wind	86	344
		Total		5,544	16,760

OOS resources to remove from PC0 Slide 54

Coal retirements by 2020

• PC0 includes the following coal plant retirements:

- AESO: Battle Units 3 & 4 and Wabamun
 Unit 4 (586 MW)
- NEVP: Reid Gardner Units 1-3 (330 MW)
- PSC: Arapahoe Units 3 & 4 and Cameo Units 1 & 2 (216 MW)
- Based on conversations with Xcel and announced retirements, ISO included the following retirements:

- Arapaho Unit 4 repowers as a natural gas combined cycle (109 MW)
- Cherokee Units 1-4 retire (722 MW); unit 4 repowers as a natural gas combined cycle (351 MW)
- Four Corners Units 1-3 retire (560 MW)
- Valmont Unit 5 retires (178 MW)





REFINEMENTS OF THE STATISTICAL MODEL OF OPERATIONAL REQUIREMENTS (STEP 1)



Slide 56

SB_GT&S_0619870

Step 1 inputs and analysis of the four scenarios results are available

- Aggregate minute and hourly profile data
- Load, wind and solar forecast error
- Monthly and daily regulation and load following requirements
- Data available at: http://www.caiso.com/23bb/23bbc01d7bd0.html



Refinements to load profiles

- Load peak demand and energy adjusted to conform to CPUC scoping memo based on 2009 CEC IEPR
- LTPP net load reduction of approximately 6,500 MW in 2020 relative to "vintage" 33% reference case due to demand side programs specified in the CPUC scoping memo
- Statewide peak load in CPUC Trajectory Case is 63,755 MW versus 70,180 MW in vintage 33% ISO Operational Study reference case



Refinements to load forecast error

and and the last the last the last and last last last the last dat the last last last may be last and last dat

- Updated load forecast error based on 2010 actual load and forecast data
- Hour ahead forecast data based on T-75 minutes in updated LTPP analysis versus T-2 hours in vintage case
- 5-minute data shows increased forecast error based on actual load data

	LTPP /	Analysis		Vintage Analysi				
Season	ADJUSTE D For PEAK (based on 2010	RT (T- 7.5min) STD 10% Improve 2020 (based on 2010 data)	НА	RT Autocorr	Season	HA STD 10% Improve 2020 (based on Vitage 2006	RT (T- 7.5min) STD 10% Improve 2020 (based on Vitage 2006 data)	
Spring	545.18	216.05	0.61	0.86	Spring	831.11	126	
Summer	636.03	288.03	0.7	0.92	Summer	1150.61	126	
Fall	539.69	277.38	0.65	0.9	Fall	835.11	126	
Winter	681.86	230.96	0.54	0.85	Winter	872.79	126	

Comparison of Load Forecast Errors



Refinements to wind profiles

- Wind sites were expanded to include quantity and locations consistent with CPUC scoping memo
- For new plants, wind plant production modeling based upon NREL 10 minute data production was expanded to include 21 distinct locations in California and 22 locations throughout the rest of WECC.



Refinements to wind forecasting errors

- Recalibrated wind forecast errors using profiled data
- Applied a *T-1hr* persistence method for estimating forecast errors

Comparison of Wind Forecast Errors (Std Dev)

Region	Case	Technology	MW	Persistent	Hour	Spring	Summer	Fall	Winter
CA	33%Base	Wind	9436	T-1	All	0.040	0.038	0.032	0.031
					Vintage Cases	0.050	0.045	0.044	0.041

Note: Actual wind forecast error based on existing PIRP resources is higher than forecast *T-1hr* based on profiles

PIRP Forecast Error								
Region	Tech	MW	Persistent	Hour	Spring	Summer	Fall	Winter
CA	Wind	1005	T-2	All	11.1%	10.8%	8.1%	6.0%
CA	Wind	1005	T-1	All	8.4%	7.1%	5.3%	3.9%
CA	Wind	1005	PIRP	All	10.5%	8.9%	8.4%	6.7%



Refinements to solar profiles


- Profiles for 2010 scenarios are developed based on satellite irradiation data¹ rather than rather than NREL land based measurement data used previously.
- Variability was introduced based on a plant footprint rather than a single point
- Better represents diversity of resources
- Expanded use of 1 minute irradiance data to use three locations:
 - Sacramento Municipal Utility District (SMUD) in Sacramento
 - Loyola Marymount University in Los Angeles, and
 - in Phoenix, AZ

¹The Solar Anywhere satellite solar irradiance data can be found at: https://www.solaranywhere.com/Public/About.aspx



Extended approach to profile small solar

- Extended method to profiling of small solar
- Define geographic boundaries of the 20 grids in Central, North, Mojave, and South area



- Choose each rectangular grid to represent an appropriate area. Each grid will have a different size rectangle
- Average the data on an hourly basis for each rectangle
- Follow similar process for developing solar profiles and adding 1-minute variability



Refinements to solar forecast errors

- Determined errors by analyzing 1-minute "clearness index" (CI) and irradiance data using *T-1 hr* persistence
- To address issues that arise using the *T-1 hr* persistence during early and later hours of the day, use 12-16 persistence to determine solar forecast error
- Results on next slide
 - CI persistence method for Hours 12-16 similar in outcome to "improved" errors
- Recommendations:
 - Since forecast errors are based on profiles and not actual production data, recommend calibrating the simulated to the actual forecast errors when more solar data is available
 - Continue to develop forecasting error for early and later hours of the day



Comparison of solar forecast error with persistence

Region	Case	Technology	MW	Persisten	Hour	0<=Cl<0.2	0.2<=Cl<0.5	0.5<=Cl<0.8	0.8<=Cl<=1
CA	33%Base	PV	3527	T-1	Hour12-16	0.035	0.069	0.056	0.023
CA	33%Base	ST	3589	T-1	Hour12-16	0.060	0.109	0.108	0.030
CA	33%Base	DG	1045	T-1	Hour12-16	0.022	0.047	0.039	0.018
CA	33%Base	CPV	1749	T-1	Hour12-16	0.016	0.033	0.031	0.016
		All			Vintage Cases	0.05	0.1	0.075	0.05

Comparison of Solar Forecast Errors



Slide 65

THE LINE OUR LINE AND LINE ONE THE THE THE AND THE AND THE AND THE LINE AND THE THE AND T

医胆碱 法保持法院 建长花 网络

SB_GT&S_0619879



IMPROVEMENTS TO SIMULATION EFFICIENCY



Slide 66

SB_GT&S_0619880

Modeling Improvements

- The model was modified to improve accuracy of modeling and efficiency of simulation while not compromising quality of results
- The major modifications implemented are:
 - Separation of spinning and non-spinning requirements
 - Generator ramp constraints for providing ancillary services and load following capacity
 - Simplified topology outside of California
 - Mixed integer optimization in California only
 - Tiered cost structure in generic resources in determining need for capacity



Separation of spinning and non-spinning requirements

- In the previous model, non-spinning includes spinning in both requirements and provision
- Spinning and non-spinning are separated in this model
 - The requirements for spinning and non-spinning are all 3% of load
 - The provision of non-spinning of a generator does not include its provision of spinning
- The separation is consistent with the ISO market definition and is needed to implement the ramp constraints as discussed below



Generator ramp constraints for providing ancillary services and load following capacity

- 60-minute constraint
 - The sum of intra-hour energy upward ramp, regulation-up, spinning, non-spinning, and load following up provisions is less than or equal to 60-minite upward ramp capability of the generator
 - The sum of intra-hour energy downward ramp, regulationdown, and load following down provisions is less than or equal to 60-minite downward ramp capability of the generator



Generator ramp constraints for providing ancillary services and load following capacity (cont.)

- 10-minute check constraint
 - The sum of upward AS and 50% of load following up provisions is less than or equal to 10-minite upward ramp capability
 - The sum of regulation-down and 50% of load following down provisions is less than or equal to 10-minite downward ramp capability



Generator ramp constraints for providing ancillary services and load following (cont.)

- 10-minute AS constraint
 - The sum of upward AS provisions is less than or equal to 10-minute upward ramp capability
 - Regulation -down provision is less than or equal to 10minute downward ramp capability
- 20-minute constraint
 - The sum of upward AS and load following up provisions is less than or equal to 10-minute upward ramp capability
 - The sum of regulation-down and load following down provisions is less than or equal to 10-minute downward ramp capability

California ISO

Simplified topology outside of California

- The topology was simplified by combining transmission areas (bubbles) outside CA according to the following rules:
 - The areas have no direct transmission connection to CA
 - The areas are combination by state or region (Pacific Northwest)
- There will be no transmission congestion within each of the combined areas



Mixed integer optimization in California only

- Model has mixed integer optimization in CA only
 - Mixed integer optimization applies to all CA generators and generators as dedicated import to CA only
 - These generators are subject to unit commitment decision in the optimization
 - Other generators outside CA are not subject to unit commitment decision
 - These generators are available for dispatch at any time (when they are not in outage)



Tiered cost structure in generic resources in determining need for capacity

- In the run to determine need for capacity, generic resources have high operation costs set up in a tiered structure such that:
 - The generic resources will be used only when they are absolutely needed to avoid violation of requirements
 - The use of generic resources will be in a progressive way (fully utilizing the capacity of one generic unit before starting to use the next one)
- The model using this method can determine the need for capacity in one simulation



Tiered cost structure in generic resources in determining need for capacity (cont.)

• The VOM cost and the cost to provide AS or load following of the generic resources are set up as

Tier 1 – \$10,000/MW	Tier 2 [_] \$15,000/MW
Tier 3 – \$20,000/MW	Tire 4 [_] \$25,000/MW

- In the run to determine the need for capacity startup costs of all generators are not considered for the method to work properly
- The run uses the monthly maximum regulation and load following requirements for each hour



ADDITIONAL CHANGES TO MODEL ASSUMPTIONS



Slide 76

SB_GT&S_0619890

Additional changes were implemented based on May 31, 2011 ALJ ruling

- Corrected the calendar year for load profile, renewable profiles, and Step 1 requirements
- Reset heat rate of El Segundo plant and the minimum capacity of the LMS100 and LM6000 units based on public available information
- Added CoolwtrS3 and CoolwtrS4 units according to ISO transmission planning assumptions
- Disallowed existing GT to provide off-line non-spinning, new GT is allowed
- Created a generic unit reflective of storage or curtailment to absorb load following down shortage



Additional changes were implemented based on May 31, 2011 ALJ ruling (cont.)

- Updated transmission wheeling rates as follows:
 - Using TEPPC PC0 Case non-zero rate for paths outside CA
 - Using vintage rates for paths in CA and for paths outside
 CA where PC0 Case has zero rates
- Separated BC and AESO and applied a \$48/MW wheeling rate (based on PC0 Case) to prevent large quantity of energy from flowing into AESO
- Switched the following dynamic resources to providing load following and ancillary services to meet the ISO requirements
 - APEX_2_MIRDYN (505 MW) MRCHNT_2_MELDYN (439 MW)
 - MSQUIT_5_SERDYN (1,182 MW) -SUTTER_2_PL1X3 (500 MW)




Additional changes were implemented based on May 31, 2011 ALJ ruling (cont.)

- Changed modeling of coal units with capacity greater than 300 MW to subject to commitment decision (integer variable)
- Updated SCIT and CA import limits based the revised SCIT model
- Revised generator outage rates to match monthly average outage (MW) with the ISO 2010 monthly minimum outage , no maintenance from Nov to Feb in Humboldt area



Outage profile used compared with actual outage profile





ISO 33% RPS Study of Operational Requirements and Market Impacts Slide 80

SB_GT&S_0619894