

From: Clanon, Paul
Sent: 9/8/2011 5:34:58 PM
To: Cherry, Brian K (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=BKC7)
Cc: Jacobson, Erik B (RegRel) (/O=PG&E/OU=Corporate/cn=Recipients/cn=EBJ1)
Bcc:
Subject: Re: Update; System Disturbance San Diego
Thx.

On Sep 8, 2011, at 5:33 PM, "Cherry, Brian K" <BKC7@pge.com> wrote:

We are fine here in PG&E's service territory. No outages.

From: Lemler, Gregg
Sent: Thursday, September 08, 2011 05:23 PM
To: Cherry, Brian K
Cc: Williams, Geisha
Subject: Fw: Update; System Disturbance San Diego

FYI. Gregg

From: [Redacted]
Sent: Thursday, September 08, 2011 04:35 PM
To: Trans-Sub Update
Subject: FW: Update; System Disturbance San Diego

At 1538 A loss of 500kV lines in the APS area created a disturbance resulting in over 4000MW of load lost in CAISO, IID, CFE. Restoration efforts are in affect Frequency went to 60.159. Frequency currently stable at 60.02.

PG&E System load; 17,079

[Redacted]

Senior Dispatcher
Electric System Dispatch Vacaville

[Redacted]

From: [Redacted]
Sent: Thursday, September 08, 2011 3:48 PM
To: Trans-Sub Update

Subject: System Disturbance San Diego

1539 CAISO reports San Diego Electrical system has blacked out. Cause unknown. PG&E system is stable. DCPD Units are stable.

System load 16865 MW

Redacted

Senior Dispatcher
Electric System Dispatch Vacaville

Redacted