

From: Clanon, Paul  
Sent: 9/8/2011 5:34:58 PM  
To: Cherry, Brian K (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=BKC7)  
Cc: Jacobson, Erik B (RegRel) (/O=PG&E/OU=Corporate/cn=Recipients/cn=EBJ1)  
Bcc:  
Subject: Re: Update; System Disturbance San Diego  
Thx.

On Sep 8, 2011, at 5:33 PM, "Cherry, Brian K" <[BKC7@pge.com](mailto:BKC7@pge.com)> wrote:

We are fine here in PG&E's service territory. No outages.

**From:** Lemler, Gregg  
**Sent:** Thursday, September 08, 2011 05:23 PM  
**To:** Cherry, Brian K  
**Cc:** Williams, Geisha  
**Subject:** Fw: Update; System Disturbance San Diego

FYI. Gregg

**From:** Armstrong, Dave (ET)  
**Sent:** Thursday, September 08, 2011 04:35 PM  
**To:** Trans-Sub Update  
**Subject:** FW: Update; System Disturbance San Diego

At 1538 A loss of 500kV lines in the APS area created a disturbance resulting in over 4000MW of load lost in CAISO, IID, CFE. Restoration efforts are in affect Frequency went to 60.159. Frequency currently stable at 60.02.

PG&E System load; 17,079

*David A Armstrong*  
**Senior Dispatcher**  
**Electric System Dispatch Vacaville**  
**707-449-6767**

---

**From:** Armstrong, Dave (ET)  
**Sent:** Thursday, September 08, 2011 3:48 PM  
**To:** Trans-Sub Update

**Subject:** System Disturbance San Diego

1539 CAISO reports San Diego Electrical system has blacked out. Cause unknown. PG&E system is stable. DCPD Units are stable.

System load 16865 MW

*David A Armstrong*  
**Senior Dispatcher**  
**Electric System Dispatch Vacaville**  
**707-449-6767**